

Attachment I
 NFVO Docket No. 14-CA-EO-01, HAR §11-60.1-15(a) Violations

Violation #	Violation Date	Stack #	Duration (min.)	Time Period	Description	Notes
1	3/6/2013	1&2	13	1345-1358	planned shutdown to repair scrubber pump leak caused VE in the range of 25%-35%	notification < 24 hr. prior to shutdown. Called 3/6/13, 12:09 p.m. 5-day letter due 3/13/13, received 3/15/13
2	7/26/2012	1&2	60	2000-2100	planned shutdown to repair scrubber pump leak (minimizing opacity by controlling boiler load)	notification < 24 hr. prior to shutdown. Called 7/26/12, 8:00 a.m.
3	10/26/2011	1&2	16	1648-1704	planned shutdown of scrubber pumps to repair damper hydraulic control (limit boiler load to control opacity)	notification < 24 hr. prior to shutdown. Called 10/27/11, 1756 (after shutdown occurred)
4	6/10/2011	1&2	570	0500-1430	planned shutdown to repair scrubber leak (limit boiler load to control opacity)	notification < 24 hrs. prior to shutdown. Called 6/9/11, 0530.
5	3/15/2011	1&2	60	0700-0800	planned shutdown to repair scrubber leak (limit boiler load to control opacity)	notification < 24 hr. prior to shutdown. Called 3/14/11, 1330
6	2/6/2011	1&2	555	0645-1600	planned shutdown to repair scrubber leak (limit boiler load to control opacity)	notification < 24 hr. prior to shutdown. Called 2/6/11, 0700 (after shutdown occurred)
7	11/11/2009	1&2	240	0345-0745	planned shutdown of scrubber to repair leak caused elevated VE	notification < 24 hr. prior to shutdown. Called 11/10/11, 0840