

**REQUEST FOR PUBLIC COMMENTS
ON DRAFT AIR PERMIT
REGULATING THE EMISSIONS OF AIR POLLUTANTS**

(Docket No. 16-CA-PA-07)

Pursuant to Hawaii Revised Statutes (HRS), Chapter 342B-13 and Hawaii Administrative Rules (HAR), Chapter 11-60.1, the Department of Health, State of Hawaii (DOH), is requesting public comments on a **DRAFT PERMIT AMENDMENT** presently under review for:

Covered Source Permit (CSP) No. 0097-01-C
Application for a Significant Modification No. 0097-11
Kauai Island Utility Cooperative
Port Allen Generating Station
Located At: 261 Akaula Street, Eleele, Kauai

The **DRAFT PERMIT AMENDMENT** is described as follows:

The proposed modification to CSP No. 0097-01-C allows specification used oil to be burned in the steam boiler, Unit S-1, without blending it with fuel oil no. 2, biodiesel, or a combination of fuel oil no. 2 and biodiesel. There is no increase in the total quantity of specification used oil that may be burned. The steam boiler is subject to the provisions of 40 CFR Part 63, Subpart JJJJJJ, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources. This will result in the following emission increases as shown in the table below.

Pollutant	Current Maximum Annual Emissions from Spec Oil Burning (tpy)	Post-Amendment Current Maximum Annual Emissions from Spec Oil Burning (tpy)	Emission Increase (tpy)	Significant Threshold (tpy)	Exceeds?
NO _x	9.6	19.6	10.0	40	no
SO ₂	35.5	35.5	0	40	no
CO	2.5	0.0	-2.5	100	no
VOC	0.1	0.1	0	40	no
PM ₁₀	4.0	8.7	4.8	15	no
PM _{2.5}	2.8	5.4	2.5	10	no
GHG	11,248	11,050	-199	75,000	no

The **ADMINISTRATIVE RECORD**, consisting of the **APPLICATION** and non-confidential supporting materials from the applicant, the permit review summary, and the **DRAFT PERMIT AMENDMENT**, is available for public inspection during regular office hours, Monday through Friday, 7:45 a.m. to 4:15 p.m., at the following locations:

Oahu:

- Clean Air Branch, Department of Health
919 Ala Moana Boulevard, Room 203, Honolulu, Oahu, 96814

Kauai:

- Kauai District Health Office, Department of Health
3040 Umi Street, Lihue, Kauai

All comments on the draft permit amendment and any request for a public hearing must be in writing, addressed to the Clean Air Branch at the above address and must be postmarked or received by May 19, 2016.

Any person may request a public hearing by submitting a written request that explains the party's interest and the reasons why a hearing is warranted. The DOH may hold a public hearing if a hearing would aid in DOH's decision. If a public hearing is warranted, a public notice for the hearing will be published at least thirty days in advance of the hearing.

Interested persons may obtain copies of the administrative record or parts thereof by paying **five (5) cents per page copying costs**. Please send written requests to the Clean Air Branch listed above or call Mr. Darin Lum at the Clean Air Branch at (808) 586-4200. Electronic copies of the draft permit amendment and permit review may be found online at <http://health.hawaii.gov/cab/public-notices/>.

Comments on the draft permit amendment should address, but need not be limited to, the permit conditions and the facility's compliance with federal and state air pollution laws, including: (1) the National and State Ambient Air Quality Standards; and (2) HRS, Chapter 342B and HAR, Chapter 11-60.1.

DOH will make a final decision on the permit amendment after considering all comments and will send notice of the final decision to each person who has submitted comments or requested such notice.

Virginia Pressler, M.D.
Director of Health