

## Chromium VI (Hexavalent Chromium) Test Results

Samples Collected from 2/22/2011 to 8/2/2011

Sample Location	Island	Sample Date	Total Chromium (ppb)	Hexavalent Chromium (ppb)	Sample Point ID
<b>Drinking Water Source*</b>					
Grammar School	Kauai	2/22/2011	7** (8/6/2008)	7.8	400-002
Anahola #A	Kauai	2/22/2011	6** (8/5/2008)	6.2	401-001
Hanapepe #4	Kauai	2/22/2011	9** (4/9/2008)	9.2	404-039
Waipao Valley Well	Kauai	2/22/2011	11** (4/9/2008)	8.1	406-002
Wainiha #1	Kauai	2/22/2011	10** (8/5/2008)	9.6	415-002
Olokele Shaft	Kauai	3/7/2011	6.0	5.6	417-002
Kahili Tunnel #1	Kauai	3/7/2011	1.2	1.3	421-012
Kealia Wells 1A & 2A	Kauai	3/7/2011	2.7	2.6	423-007
Kokee Noe Well	Kauai	3/7/2011	3.6	3.3	425-004
Princeville Well 2	Kauai	3/7/2011	1.8	1.8	428-002
Anahola Well	Kauai	3/7/2011	3.0	3.0	432-001
Kealia Wells 1A & 2A	Kauai	8/2/2011	2.6	2.2	423-007
Anahola Well	Kauai	8/2/2011	3.0	2.6	432-001
Princeville Wells 1 & 2	Kauai	8/2/2011	2.3	1.7	428-004
Kahili Tunnel #1	Kauai	8/2/2011	1.2	0.90	421-012
Kokee Noe Well	Kauai	8/2/2011	2.0	1.5	425-004
Olokele Shaft	Kauai	8/2/2011	6.1	5.5	417-002

\* All drinking water source samples are collected where the water enters the distribution system. The water from this sampling point can therefore be a mixture of all sources (e.g. groundwater wells or surface water) operating at the time of sampling.

\*\* Previously collected Total Chromium data. Sample dates for Total Chromium shown in parentheses.

The Hexavalent Chromium results for the State of Hawaii, ranging between ND and 9.6 ppb, are within the expected range of naturally occurring levels for Hawaii and are not indicative of industrial contamination.

[Click here for a link to the Department of Health's news release for more information.](#)

## Chromium VI (Hexavalent Chromium) Test Results

### PWS

No.	PWS Name	Water System Owner
400	DOW Lihue-Kapaa	Kauai Dept. of Water
401	DOW Anahola	Kauai Dept. of Water
404	DOW Hanapepe-Eleele	Kauai Dept. of Water
406	DOW Kekaha-Waimea	Kauai Dept. of Water
415	DOW Haena-Wainiha	Kauai Dept. of Water
417	Gay & Robinson	Gay & Robinson, Inc.
421	Koloa	Managed by Grove Farm Co., Inc.
423	Kealia	Kealia Water Co. Holdings, LLC
425	Kokee State Park	Dept. of Land & Natural Resources State Parks
428	Princeville	Princeville Utilities Co., Inc.
432	Anahola Farm Lots	Dept. of Hawaiian Home Lands
423	Kealia	Kealia Water Co. Holdings, LLC
432	Anahola Farm Lots	Dept. of Hawaiian Home Lands
428	Princeville	Princeville Utilities Co., Inc.
421	Koloa	Managed by Grove Farm Co., Inc.
425	Kokee State Park	Dept. of Land & Natural Resources State Parks
417	Gay & Robinson	Gay & Robinson, Inc.