

## ANALYTICAL REPORT

Eurofins Calscience LLC  
7440 Lincoln Way  
Garden Grove, CA 92841  
Tel: (714)895-5494

Laboratory Job ID: 570-78484-1

Client Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
T1&T2)

For:

Eurofins Eaton Analytical  
750 Royal Oaks Drive  
Monrovia, California 91016

Attn: Jaclyn Contreras



Authorized for release by:  
12/14/2021 3:40:23 PM

Xuan Dang, Project Manager I  
(714)895-5494  
[Xuan.Dang@eurofinset.com](mailto:Xuan.Dang@eurofinset.com)

### LINKS

Review your project  
results through  
**TotalAccess**

Have a Question?



Visit us at:

[www.eurofinsus.com/Env](http://www.eurofinsus.com/Env)

*The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.*

*This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.*

*Results relate only to the items tested and the sample(s) as received by the laboratory.*



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	2
Definitions/Glossary . . . . .	3
Case Narrative . . . . .	4
Detection Summary . . . . .	5
Client Sample Results . . . . .	6
Surrogate Summary . . . . .	8
QC Sample Results . . . . .	9
QC Association Summary . . . . .	11
Lab Chronicle . . . . .	12
Certification Summary . . . . .	13
Method Summary . . . . .	14
Sample Summary . . . . .	15
Chain of Custody . . . . .	16
Receipt Checklists . . . . .	19

# Definitions/Glossary

Client: Eurofins Eaton Analytical  
Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
T1&T2)

Job ID: 570-78484-1

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: Eurofins Eaton Analytical  
Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage T1&T2)

Job ID: 570-78484-1

---

**Job ID: 570-78484-1**

---

**Laboratory: Eurofins Calscience LLC**

---

**Narrative**

**Job Narrative  
570-78484-1**

**Comments**

No additional comments.

**Receipt**

The samples were received on 12/11/2021 10:30 AM. Unless otherwise noted below, the samples arrived in good condition, and where required, properly preserved and on ice. The temperature of the cooler at receipt was 3.6° C.

**GC Semi VOA**

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

**Organic Prep**

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.



# Detection Summary

Client: Eurofins Eaton Analytical  
Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
T1&T2)

Job ID: 570-78484-1

**Client Sample ID: Halawa Storage Tank 1 (S1)**

**Lab Sample ID: 570-78484-1**

No Detections.

**Client Sample ID: Halawa Storage Tank 2 (2)**

**Lab Sample ID: 570-78484-2**

No Detections.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

This Detection Summary does not include radiochemical test results.

Eurofins Calscience LLC

# Client Sample Results

Client: Eurofins Eaton Analytical  
 Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
 T1&T2)

Job ID: 570-78484-1

## Method: 8015B - Diesel Range Organics (DRO) (GC)

**Client Sample ID: Halawa Storage Tank 1 (S1)**

**Date Collected: 12/09/21 12:50**

**Date Received: 12/11/21 10:30**

**Lab Sample ID: 570-78484-1**

**Matrix: Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
C6 as C6	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C7 as C7	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C8 as C8	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C9-C10	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C11-C12	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C13-C14	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C15-C16	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C17-C18	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C19-C20	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C21-C22	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C23-C24	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C25-C28	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C29-C32	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C33-C36	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C37-C40	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C41-C44	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
C6-C44	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
Gasoline Range Organics (GRO)-C6-C10	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
Diesel Range Organics [C10-C28]	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1
Oil Range Organics (C28-C40)	ND		50	ug/L		12/13/21 09:56	12/13/21 18:09	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
<i>n</i> -Octacosane (Surr)	106		53 - 151	12/13/21 09:56	12/13/21 18:09	1

**Client Sample ID: Halawa Storage Tank 2 (2)**

**Date Collected: 12/09/21 13:10**

**Date Received: 12/11/21 10:30**

**Lab Sample ID: 570-78484-2**

**Matrix: Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
C6 as C6	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C7 as C7	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C8 as C8	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C9-C10	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C11-C12	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C13-C14	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C15-C16	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C17-C18	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C19-C20	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C21-C22	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C23-C24	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C25-C28	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C29-C32	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C33-C36	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C37-C40	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C41-C44	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
C6-C44	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
Gasoline Range Organics (GRO)-C6-C10	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
Diesel Range Organics [C10-C28]	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1

Eurofins Calscience LLC

# Client Sample Results

Client: Eurofins Eaton Analytical  
Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
T1&T2)

Job ID: 570-78484-1

## Method: 8015B - Diesel Range Organics (DRO) (GC) (Continued)

Client Sample ID: Halawa Storage Tank 2 (2)

Lab Sample ID: 570-78484-2

Date Collected: 12/09/21 13:10

Matrix: Water

Date Received: 12/11/21 10:30

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Oil Range Organics (C28-C40)	ND		51	ug/L		12/13/21 14:01	12/13/21 18:17	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
<i>n</i> -Octacosane (Surr)	83		53 - 151			12/13/21 14:01	12/13/21 18:17	1

# Surrogate Summary

Client: Eurofins Eaton Analytical  
Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
T1&T2)

Job ID: 570-78484-1

**Method: 8015B - Diesel Range Organics (DRO) (GC)**

**Matrix: Water**

**Prep Type: Total/NA**

## Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (53-151)
570-78484-1	Halawa Storage Tank 1 (S1)	106
570-78484-2	Halawa Storage Tank 2 (2)	83
LCS 570-200528/2-A	Lab Control Sample	107
LCS 570-200648/2-A	Lab Control Sample	97
LCSD 570-200528/3-A	Lab Control Sample Dup	99
LCSD 570-200648/3-A	Lab Control Sample Dup	89
MB 570-200528/1-A	Method Blank	119
MB 570-200648/1-A	Method Blank	95

### Surrogate Legend

OTCSN = n-Octacosane (Surr)



# QC Sample Results

Client: Eurofins Eaton Analytical  
 Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage T1&T2)

Job ID: 570-78484-1

## Method: 8015B - Diesel Range Organics (DRO) (GC)

**Lab Sample ID: MB 570-200528/1-A**  
**Matrix: Water**  
**Analysis Batch: 200572**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 200528**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
C6 as C6	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C7 as C7	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C8 as C8	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C9-C10	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C11-C12	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C13-C14	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C15-C16	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C17-C18	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C19-C20	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C21-C22	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C23-C24	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C25-C28	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C29-C32	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C33-C36	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C37-C40	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C41-C44	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
C6-C44	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
Gasoline Range Organics (GRO)-C6-C10	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
Diesel Range Organics [C10-C28]	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1
Oil Range Organics (C28-C40)	ND		50	ug/L		12/13/21 09:56	12/13/21 13:16	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
<i>n</i> -Octacosane (Surr)	119		53 - 151	12/13/21 09:56	12/13/21 13:16	1

**Lab Sample ID: LCS 570-200528/2-A**  
**Matrix: Water**  
**Analysis Batch: 200572**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 200528**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec. Limits
Diesel Range Organics [C10-C28]	4000	4380		ug/L		109	70 - 131

Surrogate	LCS %Recovery	LCS Qualifier	Limits
<i>n</i> -Octacosane (Surr)	107		53 - 151

**Lab Sample ID: LCSD 570-200528/3-A**  
**Matrix: Water**  
**Analysis Batch: 200572**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 200528**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec. Limits	RPD	RPD Limit
Diesel Range Organics [C10-C28]	4000	4131		ug/L		103	70 - 131	6	20

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
<i>n</i> -Octacosane (Surr)	99		53 - 151

# QC Sample Results

Client: Eurofins Eaton Analytical  
 Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage T1&T2)

Job ID: 570-78484-1

## Method: 8015B - Diesel Range Organics (DRO) (GC) (Continued)

**Lab Sample ID: MB 570-200648/1-A**  
**Matrix: Water**  
**Analysis Batch: 200606**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 200648**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
C6 as C6	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C7 as C7	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C8 as C8	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C9-C10	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C11-C12	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C13-C14	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C15-C16	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C17-C18	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C19-C20	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C21-C22	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C23-C24	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C25-C28	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C29-C32	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C33-C36	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C37-C40	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C41-C44	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
C6-C44	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
Gasoline Range Organics (GRO)-C6-C10	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
Diesel Range Organics [C10-C28]	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1
Oil Range Organics (C28-C40)	ND		50	ug/L		12/13/21 14:01	12/13/21 15:52	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
<i>n</i> -Octacosane (Surr)	95		53 - 151	12/13/21 14:01	12/13/21 15:52	1

**Lab Sample ID: LCS 570-200648/2-A**  
**Matrix: Water**  
**Analysis Batch: 200606**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 200648**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Diesel Range Organics [C10-C28]	4000	4235		ug/L		106	70 - 131

Surrogate	LCS %Recovery	LCS Qualifier	Limits
<i>n</i> -Octacosane (Surr)	97		53 - 151

**Lab Sample ID: LCSD 570-200648/3-A**  
**Matrix: Water**  
**Analysis Batch: 200606**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 200648**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	Limit
Diesel Range Organics [C10-C28]	4000	4385		ug/L		110	70 - 131	3	20

Surrogate	LCSD %Recovery	LCSD Qualifier	Limits
<i>n</i> -Octacosane (Surr)	89		53 - 151

# QC Association Summary

Client: Eurofins Eaton Analytical  
 Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
 T1&T2)

Job ID: 570-78484-1

## GC Semi VOA

### Prep Batch: 200528

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-78484-1	Halawa Storage Tank 1 (S1)	Total/NA	Water	3510C	
MB 570-200528/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-200528/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-200528/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	

### Analysis Batch: 200572

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-200528/1-A	Method Blank	Total/NA	Water	8015B	200528
LCS 570-200528/2-A	Lab Control Sample	Total/NA	Water	8015B	200528
LCSD 570-200528/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	200528

### Analysis Batch: 200600

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-78484-1	Halawa Storage Tank 1 (S1)	Total/NA	Water	8015B	200528

### Analysis Batch: 200606

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-78484-2	Halawa Storage Tank 2 (2)	Total/NA	Water	8015B	200648
MB 570-200648/1-A	Method Blank	Total/NA	Water	8015B	200648
LCS 570-200648/2-A	Lab Control Sample	Total/NA	Water	8015B	200648
LCSD 570-200648/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	200648

### Prep Batch: 200648

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
570-78484-2	Halawa Storage Tank 2 (2)	Total/NA	Water	3510C	
MB 570-200648/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-200648/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-200648/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	

# Lab Chronicle

Client: Eurofins Eaton Analytical  
 Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage T1&T2)

Job ID: 570-78484-1

## Client Sample ID: Halawa Storage Tank 1 (S1)

Lab Sample ID: 570-78484-1

Date Collected: 12/09/21 12:50

Matrix: Water

Date Received: 12/11/21 10:30

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	3510C			251.1 mL	2.5 mL	200528	12/13/21 09:56	UFLU	ECL 1
Total/NA	Analysis	8015B		1			200600	12/13/21 18:09	N5Y3	ECL 1
Instrument ID: GC50										

## Client Sample ID: Halawa Storage Tank 2 (2)

Lab Sample ID: 570-78484-2

Date Collected: 12/09/21 13:10

Matrix: Water

Date Received: 12/11/21 10:30

Prep Type	Batch Type	Batch Method	Run	Dil Factor	Initial Amount	Final Amount	Batch Number	Prepared or Analyzed	Analyst	Lab
Total/NA	Prep	3510C			245.8 mL	2.5 mL	200648	12/13/21 14:01	N5Y3	ECL 1
Total/NA	Analysis	8015B		1			200606	12/13/21 18:17	N5Y3	ECL 1
Instrument ID: GC93A										

**Laboratory References:**

ECL 1 = Eurofins Calscience LLC Lincoln, 7440 Lincoln Way, Garden Grove, CA 92841, TEL (714)895-5494

# Accreditation/Certification Summary

Client: Eurofins Eaton Analytical  
Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
T1&T2)

Job ID: 570-78484-1

## Laboratory: Eurofins Calscience LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
California	State	2944	09-30-22
Oregon	NELAP	CA300001	01-30-22

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

# Method Summary

Client: Eurofins Eaton Analytical  
Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
T1&T2)

Job ID: 570-78484-1

Method	Method Description	Protocol	Laboratory
8015B	Diesel Range Organics (DRO) (GC)	SW846	ECL 1
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	ECL 1

**Protocol References:**

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

**Laboratory References:**

ECL 1 = Eurofins Calscience LLC Lincoln, 7440 Lincoln Way, Garden Grove, CA 92841, TEL (714)895-5494

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

# Sample Summary

Client: Eurofins Eaton Analytical  
Project/Site: EEA - RED-HILL-INCIDENT(Halawa Storage  
T1&T2)

Job ID: 570-78484-1

---

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
570-78484-1	Halawa Storage Tank 1 (S1)	Water	12/09/21 12:50	12/11/21 10:30
570-78484-2	Halawa Storage Tank 2 (2)	Water	12/09/21 13:10	12/11/21 10:30

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15





ORIGIN ID: NAXA (808) 586-4258  
SEILA ARONI  
DEPARTMENT OF HEALTH/SDWB  
2385 WAINANO HOME RD.  
ULUAKUPU BLDG. 4  
PEARL CITY, HI 96782  
UNITED STATES US



SHIP DATE: 10DEC21  
ACTWGT: 12.00 LB  
CAD: 101971153/IN/NET4400  
DIMS: 16x12x14 IN  
BILL SENDER

TO **XUAN DANG**  
**EUROFINS CALSCIENCE**  
**7440 LINCOLN WAY**

**GARDEN GROVE CA 92641**  
REF  
(714) 895-5494  
INV  
PO


DEPT.

56DUJ3/E934/FE4A



J21222110180142

9 of 12  
MPS# **7754 6325 0882**  
0263  
Mstr# **7754 6324 7728**  
**W0 APVA**  
SATURDAY 12:00P  
PRIORITY OVERNIGHT  
0201  
92641  
CA-US SNA



570-78484 Waybill

After printing this label  
1 Use the 'Print' button on this page to print your label to your laser or inkjet printer  
2 Fold the printed page along the horizontal line  
3 Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned  
Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges along with the cancellation of your FedEx account number  
Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our Service Guide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15



# Login Sample Receipt Checklist

Client: Eurofins Eaton Analytical

Job Number: 570-78484-1

**Login Number: 78484**

**List Source: Eurofins Calscience LLC**

**List Number: 1**

**Creator: Ramos, Maribel**

Question	Answer	Comment
Radioactivity wasn't checked or is <math>\leq</math> background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <math><6\text{mm}</math> (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

