

Chow, Steven L CIV USN NAVFAC HAWAII PEARL (USA)

From: Chow, Steven L CIV NAVFAC HI, OPHC2
Sent: Friday, July 27, 2018 8:27 AM
To: 'James Liming'
Cc: Lisa Gomez; 'Ryan Yamauchi'; 'Hino, Francis'
Subject: QRVA Status/Prelim data

Jim,
I've gotten the following baseline thresholds from EV:

1. Small indefinite chronic release of 2,300 gallons per tank per year (or 6.3 gallons per tank per day).
2. Large sudden release of 120,000 gallons.

My understanding is that these thresholds would get us to an "unsafe drinking water" condition at our Red Hill shaft.

With the data/analysis that you have now, is there anything you can provide that we could use in our preparation for discussions with EPA/DOH (week of August 13, but we're preparing the data over the next two weeks)? Any data used would be preliminary and subject to your final report.

Thanks,
Steven