

DISCLAIMER: Sampling Plan will be updated/revised in coordination with Department of Health.

Ongoing/completed sampling efforts

New sampling requirements

¹ - Sampling requirements added 2 Jul 21

² - Sampling requirements added 19 Jul 21

23-Jul-21

SAMPLE TYPE	METHOD	LOCATIONS	FREQUENCY/DURATION	START DATE(S)	REPORTING
1 SOIL VAPOR SAMPLING					
Soil Vapor Concentrations	Photo-ionization Detector (PID)	Tanks 2-18, 20 - Include background reading at each tank	Daily, 7 days per week for 3 weeks until 9 Jun 21	- 10-12 May 21: Initial PID readings at Tanks 13-16 - 13 May 21: Include Tanks 13-18, 20 - 20 May 21: Include Tanks 2-12	- Excel spreadsheet - April monthly results
Soil Vapor Concentrations	Photo-ionization Detector (PID)	Tanks 11-18, 20 - Include background reading at each tank	Twice per week for 3 weeks (Monday, Thursday) ¹ 7 Jul 21: Additional 3 weeks ² 19 Jul 21: Additional 3 weeks	14 Jun 21 to 2 Jul 21 ¹ 6 Jul 21 to 23 Jul 21 ² 2 Aug 21 to 20 Aug 21	Excel spreadsheet
2 SUMMA CANISTER SAMPLING					
Summa Canister Samples	Method TO-15	Zone 7 sump, SV13S, SV16S, SV17S, SV18S, SV20S, SV20M	- One time - Additional targeted sampling if increased trends in PID readings are observed	- 10 May 21: tunnel air near the collection sump - 11 May 21: SV13S - 13 May 21: SV16S, SV17S, SV18S, SV20S - 14 May 21: SV20M	- Laboratory report with chromatograms - Expedited laboratory turnaround time (TAT) of 7 days
Summa Canister Samples	TO-15 & TO-3 w/ C5-C12	SV17S, SV18S, SV20M SVMP with highest PID readings (e.g., SV15S, SV17S, SV18S, SV20M) and most outer bound probe under the same tanks (SV15D, SV17D, SV18D, SV20D)	One time Once per month for 6 months	5 Jun 21 14 Jun 21 to 30 Nov 21	- Laboratory report with chromatograms - Expedited laboratory TAT (starts next business day after samples are received)
3 RHMW HEADSPACE MONITORING					
Headspace Monitoring	PID	RHMW01, RHMW01R, RHMW02, RHMW03, RHMW05 - 2 inches in well casing - Breathing zone	Daily, 7 days per week for 3 weeks until 9 Jun 21	- 12 May 21: Initial test at RHMW01R during GW sampling event - 13 May 21: Initial tests at RHMW01R, 02, 03 during GW sampling event - 15 May 21: Begin daily monitoring	Excel spreadsheet
Headspace Monitoring	PID	RHMW01R, RHMW02, RHMW03 - 2 inches in well casing - Breathing zone 23 Jun 21: Include RHMW01, RHMW05	Once per week for one month ¹ 7 Jul 21: Additional 3 weeks ² 19 Jul 21: Additional 3 weeks	14 Jun 21 to 9 Jul 21 ¹ 12 Jul 21 to 30 Jul 21 ² 2 Aug 21 to 20 Aug 21	Excel spreadsheet
4 FUEL PRODUCT GAUGING					
Fuel Product Gauging	Oil/water interface probe	RHMW01R, RHMW02, RHMW03 15 May 21: Include RHMW01 and RHMW05	Daily, 7 days per week for 3 weeks until 9 Jun 21	- 12 May 21: Initial test at RHMW01R during GW sampling event - 13 May 21: Initial tests at RHMW01R, 02, 03 during GW sampling event - 15 May 21: Begin daily monitoring	Excel spreadsheet
Fuel Product Gauging	Bailer	RHMW01R, RHMW02, RHMW03 23 Jun 21: Include RHMW01 (w/o bailer), RHMW05	Daily, 7 days per week Once per week for one month ¹ 7 Jul 21: Additional 3 weeks ² 19 Jul 21: Additional 3 weeks	2 Jun 21: begin bailer at 01R, 02, 03 3 Jun 21 to 9 Jun 21: 01R, 02, 03, 05 14 Jun 21 to 9 Jul 21: 01R, 02, 03 ¹ 12 Jul 21 to 30 Jul 21 ² 2 Aug 21 to 20 Aug 21	Excel spreadsheet, photos
5 GROUNDWATER SAMPLING					
Groundwater Sampling	TPH-g/d/o, BTEX, 1-methylnaphthalene, 2-methylnaphthalene, and naphthalene - Sample w/ bladder pump	RHMW01R, RHMW02, RHMW03	Every Monday, Wednesday, and Friday for 3 weeks until 11 Jun 21	- 12-13 May 21: 1st sample collection - 19-20 May 21: 2nd sample collection - 24 May : Initiate three times a week sampling	- Laboratory report with chromatograms - Expedited laboratory TAT
Groundwater Sampling	TPH-g/d/o, BTEX, 1-methylnaphthalene, 2-methylnaphthalene, and naphthalene - Sample w/ bailer, no purging prior to sampling; one weekly event with duplicate samples from bladder pump	RHMW01R, RHMW02, RHMW03	Monday, Wednesday, Friday until 11 Jun 21 Once per week for one month ¹ 7 Jul 21: Additional 3 weeks ² 19 Jul 21: Additional 3 weeks	2 Jun 21 to 11 Jul 21: begin bailer samples 14 Jun 21 to 9 Jul 21 ¹ 12 Jul 21 to 30 Jul 21 ² 2 Aug 21 to 20 Aug 21	- Laboratory report with chromatograms - Expedited laboratory TAT - DOH request to sample from uppermost portion of the water column without prior purging to ensure maximum possibility of identifying initial contaminant migration
6 DRINKING WATER SAMPLING					
Drinking Water Sampling	TPH-g/d/o, BTEX, 1-methylnaphthalene, 2-methylnaphthalene, and naphthalene	RHMW2254-01 - pre-chlorination from spigot	Once per week for one month ¹ 7 Jul 21: Additional 3 weeks ² 19 Jul 21: Additional 3 weeks	14 Jun 21 to 9 Jul 21 ¹ 12 Jul 21 to 30 Jul 21 ² 2 Aug 21 to 20 Aug 21	- Laboratory report with chromatograms - Expedited Laboratory TAT

AVERAGE SOIL VAPOR CONCENTRATION READINGS

DATE	SV02 S	SV02 M	SV02 D	SV03 S	SV03 M	SV03 D	SV04 S	SV04 M	SV04 D	SV05 S	SV05 M	SV05 D	SV06 S	SV06 M	SV07 S	SV07 M	SV07 D	SV08 S	SV08 M	SV08 D	SV09 S	SV09 M	SV09 D	SV10 S	SV10 M/D	SV11 S	SV11 M/D	SV12 S	SV12 M	SV12 D	SV13 S	SV13 M	SV13 D	SV14 S	SV14 M	SV14 D	SV15 S	SV15 M	SV15 D	SV16 S	SV16 M	SV16 D	SV17 S	SV17 M	SV17 D	SV18 S	SV18 D	SV20 S	SV20 M	SV20 D
4/22/2021	241	234	248	180	175	446	149	157	186	187	416	1170	3993	243	293	235	477	263	238	227	222	223	367	269	242	259	257	304	368	346	770	693	550	404	361	475	175	NC2	170	207	185	191	289	320	363	1009	1184	223	173	184

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

Notes:
* Air compressor used to clear obstruction prior to collecting sample
** "M/D" monitoring points were constructed to screen both middle & deep depth intervals along the respective underground storage tank.
NC - Not collected
NC1 - Not collected due to tank maintenance
NC2 - Not collected due to obstruction in vapor line

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.a. Soil Vapor Concentrations at Tanks 2-18 and 20

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

AVERAGE SOIL VAPOR CONCENTRATION READINGS (PPBV)

DATE	SV02 S	SV02 M	SV02 D	SV03 S	SV03 M	SV03 D	SV04 S	SV04 M	SV04 D	SV05 S	SV05 M	SV05 D	SV06 S	SV06 M	SV07 S	SV07 M	SV07 D	SV08 S	SV08 M	SV08 D	SV09 S	SV09 M	SV09 D	SV10 S	SV10M ^D	SV11 S	SV11M ^D	SV12 S	SV12 M	SV12 D	SV13 S	SV13 M	SV13 D	SV14 S	SV14 M	SV14 D	SV15 S	SV15 M	SV15 D	SV16 S	SV16 M	SV16 D	SV17 S	SV17 M	SV17 D	SV18 S	SV18 D	SV20 S	SV20 M	SV20 D		
5/10/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	252	347	201	0	0	0	432	NC2	184	219	142	109	NC3	NC3	NC3	NC3	NC3	NC3	NC3	NC3	NC3	
5/11/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	1,896	1,014	930	702	480	740	816	NC2	866	687	682	691	NC3	NC3	NC3	NC3	NC3	NC3	NC3	NC3	NC3	
5/12/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	0	0	0	0	0	0	0	NC2	0	0	0	0	0	NC3	NC3	NC3	NC3	NC3	NC3	NC3	NC3	NC3
5/13/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	1,623	1,202	1,024	1,164	813	1,401	546	NC2	363	336	266	183	57,667	49,333	4,787	120,000	121,333	9,837	232,667	14,433		
5/14/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	1,568	1,322	1,423	1,095	1,057	1,045	860	NC2	779	730	672	520	44,130	45,733	11,923	114,700	67,563	2,958	206,267	17,277		
5/15/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	961	973	1,013	687	612	634	720	NC2	365	655	431	272	33,670	26,477	13,337	122,000	41,970	0	23,460	7,203		
5/16/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	313	241	534	70	0	14	383	NC2	135	141	73	25	34,030	15,053	8,552	139,500	28,987	3,487	39,533	5,158		
5/17/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	2,180	1,153	1,000	601	797	803	813	NC2	315	327	148	237	30,280	13,807	8,750	118,667	19,067	6,866	50,070	3,618		
5/18/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	297	231	385	165	177	178	342	NC2	58	0	0	255	162,300	23,963	7,971	65,667	10,250	7,129	32,700	3,725		
5/19/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	480	445	443	524	379	424	445	NC2	152	242	138	237	136,333	92,333	6,363	146,667	15,833	8,796	32,900	7,321		
5/20/2021	87	77	85	199	191	252	239	132	108	339	1,103	1,002	4,776	310	414	166	491	196	203	238	137	271	173	177	24	171	127	304	236	200	199	446	481	246	430	237	239	NC2	42	63	8	55	96,333	29,967	7,251	105,067	18,667	5,536	24,333	5,285		
5/21/2021	197	97	792	94	177	170	128	46	132	580	776	691	5,021	416	408	322	7,201	253	275	298	413	370	318	236	214	348	382	530	320	232	1,123	557	721	258	242	326	409	NC2	164	244	97	153	NC1	NC1	NC1	118,167	25,133	6,469	34,563	5,417		
5/22/2021	512	425	466	513	428	419	2,108	532	644	688	1,199	620	5,238	864	2,428	633	3,915	602	660	753	603	665	778	646	579	613	559	1,178	642	619	937	847	1,066	845	806	718	1,030	NC2	792	788	636	588	30,340	14,330	5,622	66,800	5,611	5,137	16,000	7,003		
5/23/2021	229	160	115	125	141	158	102	121	163	220	729	540	3,647	449	513	254	1,461	255	303	317	205	317	288	234	1,237	215	161	456	247	277	442	356	401	187	NC4	291	613	NC2	132	153	111	78	158,533	51,787	4,558	94,500	8,164	5,404	46,210	4,544		
5/24/2021	236	237	186	219	214	227	172	204	217	239	775	595	4,906	418	467	331	2,210	417	425	491	494	465	491	462	468	497	598	963	529	507	599	651	887	669	NC4	682	1,457	NC2	623	653	570	559	75,900	48,033	4,935	86,267	10,160	4,575	21,000	3,773		
5/25/2021	279	250	265	218	236	267	179	213	296	456	806	693	3,869	529	554	290	2,248	285	281	285	410	403	462	450	456	502	572	779	532	508	694	684	1,083	882	NC4	734	1,450	NC2	392	411	341	234	25,367**	7,167**	6,501	25,000***	7,797	5,875	23,000***	6,074		
5/26/2021	309	226	253	376	315	343	201	239	384	317	688	2,601	3,557	589	650	309	1,474	461	549	692	386	320	393	524	368	609	564	1,960	676	595	809	708	1,184	565	NC4	1,262	1,559	NC2	337	392	164	135	144	32,800	16,667	4,892	88,767	14,107	4,637	18,633	6,488	
5/27/2021	170	143	201	435	173	177	80	107	125	349	929	336	4,270	521	1,134	226	749	285	296	465	335	363	294	285	196	351	381	568	351	488	247	327	1,062	62	536	107	1,044	NC2	0	1	0	0	33,700 ⁽²⁾	7,270	4,493	62,700 ⁽²⁾	13,687	4,113	18,030	4,948		
5/28/2021	368	215	288	579	357	370	402	408	454	459	1,112	878	4,917	427	1,135	431	874	637	548	613	634	585	606	419	489	503	458	942	556	402	831	803	947	419	563	495	1,567	NC2	452	400	318	266	10,890	6,616	6,377	53,633 ⁽²⁾	15,110	4,634	19,970	6,251		
5/29/2021	570	535	489	734	667	617	554	559	649	714	1,121	979	4,926	787	1,625	694	1,037	698	685	675	730	632	673	598	633	679	596	1,588	633	588	2,585	966	1,051	768	634	690	1,694	NC2	805	810	709	671	6,859	8,176	4,412	40,200 ⁽²⁾	8,374	5,605	12,033	7,123		
5/30/2021	413	777	289	544	462	591	549	606	591	705	1,139	1,183	3,555	1,017	1,426	881	1,011	835	760	786	834	768	802	673	549	749	665	1,066	729	506	NC1	NC1	NC1	631	634	625	1,126	NC2	602	511	452	393	43,513	7,440	5,527	127,733	18,743	1,937	24,267	2,187		
5/31/2021	0	0	0	0	0	0	0	0	0	0	53	187	5,365	60	438	137	85	0	30	7	0	0	0	0	0	0	0	0	0	0	1,002	832	1,428	0	0	0	0	NC2	0	0	0	0	138,367	9,660	4,752	60,500	9,767	3,212	13,333	3,672		
6/1/2021	155	56	148	126	116	220	189	70	254	215	563	436	3,357	274	438	170	378	310	262	267	172	247	222	152	191	172	146	202	263	198	NC1	NC1	NC1	233	177	227	811	NC2	117	165	86	78	NC1	NC1	NC1	25,933 ⁽²⁾	8,433 ⁽²⁾	3,550 ⁽²⁾	17,427	3,143		
6/2/2021	30	22	27	102	33	131	35	51	92	228	584	500	3,899	491	793	387	590	364	368	442	313	347	372	307	257	300	283	358	260	211	NC1	NC1	NC1	327	300	291	758	NC2	259	296	222	206	50,100	8,938	6,222	96,267	13,847	3,928	14,877	4,307		
6/3/2021	517	312	377	484	468	619	488	539	555	639	1034	773	4,563	718	933	540	914	610	519	698	703	570	515	486	480	606	477	606	339	456	1,017	1,324	1,069	610	408	496	800	NC2	538	482	396	363	16,340	5,654	4,870	46,967 ⁽²⁾	13,273	4,846	13,883	5,383		
6/4/2021	371	273	253	307	316	348	329	317	363	391	787	782	4,676	814	762	458	749	607	601	674	822	878	1,065	720	506	698	666	667	547	586	1,518	1,518	1,545	788	593	696	875	NC2	663	627	577	528	19,203	6,901	8,926	45,200 ⁽²⁾	19,040 ⁽²⁾	3,776	4,974	3,697		
6/5/2021	0	0	0	0	0	0	0	0	0	0	0	0	4,195	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	215	125	169	0	0	0	0	NC2	0	0	0	0	94,000 ⁽²⁾	18,203	4,858	38,367 ⁽²⁾	12,617	3,416	3,769	2,943		
6/6/2021	209	62	124	173	138	219	212	136	213	321	704	380	3,526	515	392	227	500	269	256	264	249	210	231	158	150	181	159	243	149	152	611	634	776	220	208	272	382	NC2	306	314	200	226	181,733	11,070	5,481	25,053	12,617	3,293	3,036	2,474		
6/7/2021	143	44	50	171	124	217	213	288	288	384																																										

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

⁴ - ppmv PID experienced unanticipated malfunction as indicated by a failed calibration check. PID result based on a second ppbv PID suggests the value is between 50 ppm - 150 ppm.

NC5 - Not collected - not required by the DOH Transition Plan.

DATE	Tank 2	Tank 3	Tank 4	Tank 5	Tank 6	Tank 7	Tank 8	Tank
------	--------	--------	--------	--------	--------	--------	--------	------

5/10/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	6,900	4,300	8,200	10,300	41,000	70,000	71,000	
5/11/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	5,455	5,037	5,068	6,308	NC	NC	
5/12/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	11,000	8,369	130	610	NC	NC	NC	
5/13/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	36,550	30,120	2,617	1,239	39,740	38,730	11,900	
5/14/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	32,630	12,640	4,288	4,266	38,500	17,000	17,230	
5/15/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	11,310	3,975	3,015	3,160	31,300	23,310	51,300	
5/16/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	10,180	3,628	3,930	4,295	39,960	21,270	33,510	
5/17/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	32,190	2,571	2,694	1,172	29,000	15,000	7,500	
5/18/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	13,500	1,930	496	2,487	10,360	9,023	7,568	
5/19/2021	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	6,620	1,237	631	634	5,300	9,000	6,000	
5/20/2021	1,301	1,270	1,219	1,150	1,089	1,101	1,297	1,079	1,008	1,067	1,255	2,438	1,261	613	348	10,700	7,800	7,700	
5/21/2021	1,323	1,168	1,051	1,154	1,606	1,578	1,364	2,303	1,352	1,404	1,317	1,968	1,053	650	598	NC1	15,200	6,200	
5/22/2021	3,317	3,228	3,251	3,464	3,316	3,422	3,520	3,592	3,872	3,787	3,799	5,004	4,601	3,907	4,050	13,100	17,100	16,000	
5/23/2021	1,097	1,069	1,004	1,020	1,040	1,049	1,021	932	1,003	921	1,009	3,610	469	465	348	11,600	10,800	8,100	
5/24/2021	1,135	1,015	1,048	1,082	1,028	1,187	1,563	1,758	1,888	2,459	2,733	2,872	2,943	2,134	1,986	8,065	8,054	6,841	
5/25/2021	970	1,054	957	945	845	1,099	946	926	1,541	1,875	2,022	2,894	2,458	2,085	530	13,000	16,000	>20,000	
5/26/2021	1,817	2,036	3,608	6,460	7,201	6,820	4,902	8,302	NC	6,814	5,951	22,840	11,400	1,911	494	8,000	25,300	10,600	
5/27/2021	3,605	2,652	3,725	7,278	7,426	4,895	4,637	4,281	5,403	4,575	5,784	8,932	400	187	229	6,000 ²	11,200 ²	7,900 ²	
5/28/2021	2,975	2,803	3,070	3,241	3,184	4,520	8,374	6,249	4,396	4,544	4,558	2,902	3,333	2,391	2,609	15,890	23,340	14,230	
5/29/2021	3,229	3,348	3,484	3,503	3,228	3,124	3,488	3,545	3,879	3,878	4,303	9,914	3,225	3,394	3,721	9,000	10,200	10,100	
5/30/2021	980	1,257	1,418	1,873	2,025	2,168	2,139	2,314	2,385	2,295	2,014	NC1	1,723	1,502	1,586	9,018	9,613	1,301	
5/31/2021	898	640	1,524	1,716	1,238	1,836	954	736	626	560	645	9,503	253	0	0	5,679	5,321	2,885	
6/1/2021	730	691	752	767	751	805	786	NC	NC	715	912	NC1	708	307	454	NC1	6,300	5,000	
6/2/2021	846	667	653	918	1,805	1,306	1,379	1,406	1,391	1,522	1,510	NC1	877	1,018	920	10,470	10,690	11,210	
6/3/2021	2,240	2,232	2,234	2,445	2,511	2,321	2,713	2,714	2,781	3,056	3,356	2,746	3,502	2,378	2,279	15,000	21,500	12,500	
6/4/2021	1,131	1,105	1,120	1,024	1,813	1,479	2,683	4,737	3,876	3,216	3,600	7,549	3,907	2,360	2,257	13,500	15,900	14,500	
								21,000											
6/5/2021	337	394	313	276	343	346	381	304	333	303	602	5,633	256	0	0	4,867	5,370	4,535	
6/6/2021	618	641	693	694	750	822	756	689	779	712	875	4,412	676	391	487	5,400	4,500	4,759	
6/7/2021	763	1,046	1,327	1,736	1,805	1,847	1,940	1,752	1,974	2,034	2,610	3,703	3,031	2,092	2,740	8,700	5,000	5,000	
6/8/2021	645	721	1,070	1,239	1,715	1,298	1,545	1,576	1,514	1,760	2,030	2,586	1,329	1,577	1,641	13,330	9,593	15,420	
6/9/2021	844	850	1,017	805	967	973	939	845	966	900	1,042	4,147	906	422	450	7,981	8,282	6,985	
6/14/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	554	440	915	740	240	304	3,890	3,994	2,505
6/18/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	2,122	2,373	12,000	3,534	1,624	1,920	19,800	26,500	17,200
6/21/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	2,363	2,611	43,170	2,424	1,151	1,076	14,820	10,300	11,680
6/24/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,023	781	8,634	1,157	115	118	4,173	5,980	5,954
6/28/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,749	2,023	8,180	3,448	1,496	1,497	9,900 ²	11,500 ²	10,300 ²
7/1/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	511	540	11,410	1,560	456	514	237,400 ³	42,110	3,373
7/6/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	917	933	4,084	1,611	0	0	4,492	3,270	3,268
7/8/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	666	474	2,130	1,352	23	34	2,988	6,500	4,212
7/12/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	20,500	33,080	347,000	71,240	648	725	5,842	3,718	7,853
7/15/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	389	440	826	903	128	25	3,520	3,568	2,020
7/19/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	314	327	939	927	43	402	3,175	5,834	4,280
7/22/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	640	413	2,815	540	0	230	3,454	3,286	3,112
8/2/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,451	1,456	1,823	1,187	1,149	1,231	17,310	4,083	16,220
8/5/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	34	0	1,830	132	0	4	1,854	2,309	2,121
8/9/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	291	355	3,410	355	580	355	1,288	2,756	2,303
8/12/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	0	0	0	0	0	0	637	1,275	1,873
8/16/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	409	329	504	466	408	410	1,417	1,856	1,415
8/19/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	147	199	1,395	1,332	95	122	1,050	2,785	7,313
8/23/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	694	683	1,651	315	160	218	3,885	2,436	1,603
8/26/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	0	0	0	706	47	45	1,518	2,123	4,210
8/30/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,242	1,065	1,232	679	1,280	1,401	10,920	3,687	8,234
9/2/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	422	435	461	499	504	500	996	1,361	1,988
9/7/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	198	100	242	96	80	443	8,913	6,560	11,090
9/9/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	148	124	150	201	93	69	3,185	3,820	2,621
9/13/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	186	222	221	230	172	242	6,878	6,415	8,658
9/16/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,901	225	325	676	303	352	6,562	6,710	4,414
9/20/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	94	42	89	163	17	25	4,348	3,739	5,896
9/23/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	193	343	269	206	135	186	2,381	3,199	3,134
9/27/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	87	104	186	160	115	152	3,057	3,356	2,448
9/30/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	452	436	719	445	595	612	5,018	4,811	3,327

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.a. Soil Vapor Concentrations at Tanks 2-18 and 20

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

10/4/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	227	183	761	337	137	148	2,213	4,020	1,293
10/7/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	460	493	282	190	101	148	7,830	6,561	7,453
10/12/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	136	172	752	498	127	144	7,191	6,690	2,816
10/14/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	468	495	1,016	807	911	2,342	4,638	3,947	8,821
10/18/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	112	147	67	664	77	80	1,221	1,262	905
10/21/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	98	66	111	303	532	811	4,196	NC1	5,894
10/21/2021	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	155,000 ⁽⁴⁾	-	18,100 ⁽⁴⁾
10/25/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	2,983	3,252	106,800	3,500	480	396	5,064	4,420	4,256
10/28/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,290	1,312	1,667	938	1,108	977	3,750	1,563	2,987
11/1/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	962	707	751	NC1	642	720	9,873	4,378	8,193
11/4/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	275	313	550	478	372	532	3,256	4,514	8,630
11/8/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	275	215	204	702	674	627	5,320	5,413	4,934
11/11/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,270	1,274	1,294	1,382	1,011	1,085	4,181	5,172	3,412
11/15/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	433	325	373	359	249	280	6,657	7,805	1,634
11/18/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	945	820	839	885	951	1,310	4,879	6,062	2,523
11/22/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,132	1,049	1,093	842	957	1,056	6,538	6,013	5,956
11/24/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	1,160	1,165	1,151	1,081	1,293	1,258	4,185	4,525	1,352
11/29/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	606	644	551	402	300	252	5,833	5,889	2,054
12/2/2021	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	NC5	270	306	835	802	1,387	1,392	3,689	4,631	1,341

Notes:
¹ - "M/D" monitoring points were constructed to screen both middle & deep depth intervals along the respective underground storage tank.
² - Soil vapor concentration measured using a ppmv PID.
³ - Epoxy coatings being applied in the area near Tank 17. Epoxy coating contain volatile organic compounds which can be detected by the monitoring equipment used to collect SVM samples.
⁴ - Solvent odor from work occurring in the area near Tank 18 caused elevated background PID readings.
* Air compressor used to clear obstruction prior to collecting sample
** - Estimated value - Calibration check observed an approximately 40% low bias reading.
*** - Estimated value - Inadvertent early termination of PID reading.

NC - Not collected
NC1 - Not collected due to tank maintenance
NC2 - Not collected due to obstruction in vapor line
NC3 - Not collected - monitoring vault potentially compromised by relaese. Replacing tubing and cleaning valves. Sampling to begin 14 May
NC4 - Not collected due to a broken valve/fitting. A replacement valve is being pursued.
NC5 - Not collected - not required by the DOH Transition Plan.,
Soil vapor concentration readings are reported in parts per billion by volume (ppbv).

	RHMW01						RHMW01R						RHMW02						RHMW03						RHMW05						
DATE	TIME	AMBIENT (ppmv)	HEADSPACE (ppmv)	DTW (ft btoc)	PRODUCT? (Yes/No)	THICKNESS (ft)	TIME	AMBIENT (ppmv)	HEADSPACE (ppmv)	DTW (ft btoc)	PRODUCT? (Yes/No)	THICKNESS (ft)	TIME	AMBIENT (ppmv)	HEADSPACE (ppmv)	DTW (ft btoc)	PRODUCT? (Yes/No)	THICKNESS (ft)	TIME	AMBIENT (ppmv)	HEADSPACE (ppmv)	DTW (ft btoc)	PRODUCT? (Yes/No)	THICKNESS (ft)	TIME	AMBIENT (ppmv)	HEADSPACE (ppmv)	DTW (ft btoc)	PRODUCT? (Yes/No)	THICKNESS (ft)	
5/12/2021	NC1	NC1	NC1	NC1	NC1	NC1	1553	2.2	0.1	83.69	No	NA	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1
5/13/2021	NC1	NC1	NC1	NC1	NC1	NC1	1150	1.3	0.3	83.85	No	NA	1000	1.1	0.1	86.77	No	NA	1030	0.8	0.1	103.02	No	NA	NC1	NC1	NC1	NC1	NC1	NC1	NC1
-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
5/15/2021	1111	5.158	3.902	83.97	No	NA	1103	5.158	0.378	83.76	No	NA	1123	4.833	0.594	86.66	No	NA	1128	3.985	0.413	102.88	No	NA	1048	5.094	0.345	83.38	No	NA	
5/16/2021	1105	4.463	3.508	83.87	No	NA	1110	4.463	0	83.63	No	NA	1123	4.054	0	86.57	No	NA	1143	3.548	0.036	102.79	No	NA	1049	4.753	0	83.24	No	NA	
5/17/2021	1310	5.415	5.100	83.96	No	NA	1304	5.170	0	83.73	No	NA	1328	7.511	0.174	86.62	No	NA	1336	3.314	0.280	102.83	No	NA	1318	5.601	0.140	83.33	No	NA	
5/18/2021	1307	2.53	2.15	83.95	No	NA	1304	2.53	0	83.74	No	NA	1315	5.056	0	86.66	No	NA	1324	0.965	0	102.87	No	NA	1256	2.174	0	83.39	No	NA	
5/19/2021	0856	2.482	2.165	83.99	No	NA	0859	2.482	0.200	83.78	No	NA	0907	1.926	0.270	86.68	No	NA	0917	1.149	0.105	102.94	No	NA	0848	2.556	0.260	83.48	No	NA	
5/19/2021	NC1	NC1	NC1	NC1	NC1	NC1	1400	0.3	0.0	83.74	No	NA	1600	0.1	0.0	86.67	No	NA	1620	0.1	0.0	102.91	No	NA	NC1	NC1	NC1	NC1	NC1	NC1	NC1
5/20/2021	0939	1.476	1.290	84.00	No	NA	0942	1.476	0.204	NM	NA	NA	0947	1.040	0.180	NM	NA	NA	1128	0.811	0.068	NM	NA	NA	0931	1.622	0.130	83.42	No	NA	
5/20/2021	NC1	NC1	NC1	NC1	NC1	NC1	1130	1.7	0.2	83.81	No	NA	1015	0.7	0.0	86.74	No	NA	1210	1.1	0.0	102.93	No	NA	NC1	NC1	NC1	NC1	NC1	NC1	NC1
5/21/2021	0724	1.562	1.378	84.03	No	NA	0722	1.562	NM	NM	NA	NA	1056	1.339	0.202	86.74	No	NA	1048	0.689	0.181	102.95	No	NA	0717	1.456	0.080	83.44	No	NA	
5/21/2021	NC1	NC1	NC1	NC1	NC1	NC1	1500	0.2	0.4	83.81	No	NA	1540	0.1	0.1	86.72	No	NA	1622	0.1	0	102.94	No	NA	NC1	NC1	NC1	NC1	NC1	NC1	NC1
5/22/2021	0745	3.440	3.202	84.05	No	NA	0750	3.440	0.227	83.84	No	NA	0945	3.386	0.590	86.73	No	NA	1246	4.060	0.507	102.97	No	NA	0734	3.525	0.152	83.44	No	NA	
5/23/2021	0626	1.322	1.188	83.96	No	NA	0630	1.322	0.295	83.75	No	NA	0737	0.948	0.063	86.66	No	NA	0943	0.595	0.113	102.86	No	NA	0620	1.419	0.146	83.36	No	NA	
5/24/2021	0800	1.333	1.171	83.89	No	NA	0804	1.333	0	83.66	No	NA	0905	1.076	0.140	86.59	No	NA	1129	2.228	0.370	102.87	No	NA	0752	1.395	0	83.27	No	NA	
5/24/2021	NC1	NC1	NC1	NC1	NC1	NC1	1100	0.1	0.0	83.73	No	NA	1245	0.3	0.1	86.68	No	NA	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1
5/25/2021	0842	1.023	0.829	83.96	No	NA	0844	1.023	0.096	83.74	No	NA	1001	0.945	16.19 (see note)	86.65	No	NA	1153	2.09	0.552	102.88	No	NA	0835	1.074	0.113	83.36	No	NA	
5/25/2021	-	-	-	-	-	-	-	-	-	-	-	-	1251	1.291	0.295	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/25/2021	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	NC1	1440	0.0	0.0	102.85	No	NA	NC1	NC1	NC1	NC1	NC1	NC1	NC1
5/26/2021	0724	1.898	1.697	83.95	No	NA	0832	1.0	0.1	83.77	No	NA	1038	3.2	0.3	86.70	No	NA	1400	0.1	0.0	102.93	No	NA	0717	1.983	0.055	83.34	No	NA	
5/27/2021	1008	3.978	2.650	84.03	No	NA	1013	3.978	0	83.79	No	NA	1125	5.484	14.43 (see note)	86.71	No	NA	1324	0.400	0	102.93	No	NA	1002	5.871	0	83.43	No	NA	
5/27/2021	-	-	-	-	-	-	-	-	-	-	-	-	1125	-	0.156	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5/28/2021	0912	3.146	2.117	84.03	No	NA	0830	0.6	0.0	83.83	No	NA	1100	2.5	0.3	86.73	No	NA	1405	0.4	0.0	102.95	No	NA	0907	3.167	0	83.42	No	NA	
5/29/2021	0747	3.188	2.736	84.01	No	NA	0747	3.188	0.590	83.78	No	NA	0924	2.890	0.640	86.69	No	NA	1142	2.451	0.746	102.93	No	NA	0738	2.992	0.056	83.42	No	NA	
5/30/2021	0646	1.143	1.029	84.02	No	NA	0647	1.143	0.064	83.81	No	NA	0745	1.930	0.335	86.72	No	NA	0954	1.372	0.881	102.98	No	NA	0638	1.205	0	83.42	No	NA	
5/31/2021	1103	1.006	0.668	84.02	No	NA	0805	0.0	0.0	83.82	No	NA	0939	0.0	0.0	86.74	No	NA	1119	0.1	0.0	102.96	No	NA	1058	0.955	0.0	83.42	No	NA	
6/1/2021	0641	0.850	0.605	84.02	No	NA	0639	0.850	0.200	83.81	No	NA	0738	0.776	0.800	86.77	No	NA	0943	0.428	0.212	102.97	No	NA	0629	1.003	0	83.44	No	NA	
6/2/2021	0608	1.008	0.580	84	No	NA	0833	0.2	0.1	83.84	No	NA	1017	0.3	0.1	86.79	No	NA	1154	0.2	0.0	103.04	No	NA	0602	1.05	0	83.4	No	NA	
6/3/2021	0839	2.507	1.855	84.04	No	NA	0837	2.507	0.925	83.83	No	NA	0939	2.434	0.897	86.74	No	NA	1136	2.784	1.295	102.83	No	NA	0819	2.369	0.092	83.45	No	NA	
6/4/2021	0854	1.202	0.831	83.98	No	NA	0930	0.1	0.2	83.82	No	NA	1050	0.7	0.2	86.73	No	NA	1157	0.6	0.2	103.17	No	NA	0842	1.155	0.184	83.39	No	NA	
6/5/2021	1309	0.633	0.277	83.89	No	NA	1310	0.633	0	83.67	No	NA	1415	0.292	0	86.60	No	NA	1601	0	0	102.95	No	NA	1253	0.723	0	83.25	No	NA	
6/6/2021	0718	0.686	0.574	83.97	No	NA	0723	0.686	0.193	83.77	No	NA	0837	0.582	0.237 (see note)	86.66	No	NA	1050	0.466	0.233	102.84	No	NA	0703	0.836	0	83.36	No	NA	
6/7/2021	0805	0.677	0.497	84.00	No	NA	0804	0.0	0.0	83.72	No	NA	0918	0.2	0.4	86.68	No	NA	1020	0.2	0.0	103.00	No	NA	0753	0.743	0	83.37	No	NA	
6/8/2021	0742	0.814	0.709	83.96	No	NA	0750	0.814	0.285	83.78	No	NA	0855	1.321	0.464	86.69	No	NA	1117	1.818	7.300	102.85	No	NA	0731	0.950	0	83.36	No	NA	
6/9/2021	0814	0.889	0.737	84.03	No	NA	0945	0.1	0.2	83.81	No	NA	1044	0.1	0.0	86.71	No	NA	1131	0.0	0.0	102.99	No	NA	0801	1.042	0	83.41	No	NA	
6/11/2021	NC1	NC1	NC1	NC1	NC1	NC1	0800	0.0	0.2	83.82	No	NA	0900	0.2	0.0	86.74	No	NA	0955	0.0	0.0	102.97	No	NA	NC1	NC1	NC1	NC1	NC1	NC1	NC1
6/17/2021	NC2	NC2	NC2	NC2	NC2	NC2	0945	0.0	0.0	83.93	No	NA	1045	0.0	0.2	86.84	No	NA	1206	0.0	0.0	103.07	No	NA	NC2	NC2	NC2	NC2	NC2	NC2	NC2
6/24/2021	NC2	NC2	NC2	NC2	NC2	NC2	1000	0.2	0.1	83.84	No	NA	1100	0.0	0.0	86.76	No	NA	1200	0.3	5.1	102.98	No	NA	NC2	NC2	NC2	NC2	NC2	NC2	NC2
6/28/2021	0926	1.694	1.483	84.08	No																										

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.c. Monitoring Wells: RHMW01, RHMW01R, RHMW02, RHMW03, and RHMW05 - Headspace and Fuel Product Gauging
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

	RHMW01						RHMW01R						RHMW02						RHMW03						RHMW05					
DATE	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS
		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)
8/5/2021	0710	0.11 (see note)	0.038 (see note)	NC3	NC3	NC3	0955	0.0	0.0	84.03	No	NA	1100	0.0	0.3	86.93	No	NA	1203	0.0	0.6	103.16	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
8/9/2021	0735	0.315	0.318	NC3	NC3	NC3	0727	0.315	0.115	83.95	No	NA	0740	0.256	1.276 (see note)	86.48	No	NA	0806	0.198	0.054	103.90	No	NA	0714	0.278	0	83.58	No	NA
8/12/2021	NC2	NC2	NC2	NC2	NC2	NC2	0933	0.0	0.0	84.07	No	NA	1035	0.0	0.8	86.96	No	NA	1142	0.0	0.1	103.17	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
8/16/2021	1139	0.418	0.386	NC3	NC3	NC3	1142	0.419	0.423	84.11	No	NA	1222	0.321	0.214 (see note)	86.98	No	NA	1210	0.338	0	103.22	No	NA	1127	0.407	0	83.77	No	NA
8/19/2021	NC2	NC2	NC2	NC2	NC2	NC2	0950	0.1	0.2	84.02	No	NA	1120	0.2	0.3	86.95	No	NA	1220	0.1	0.1	103.18	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
8/23/2021	1515	0.795	0.746	NC3	NC3	NC3	1520	0.800	0	83.90	No	NA	1540	0.773	22.640	86.83	No	NA	1612	0.834	0.113	103.04	No	NA	1450	0.799	0	83.51	No	NA
8/26/2021	NC2	NC2	NC2	NC2	NC2	NC2	0950	0.0	0.0	84.01	No	NA	1117	0.0	0.2	86.88	No	NA	1225	0.0	2.0	103.11	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
8/30/2021	1051	1.032	0.93	NC3	NC3	NC3	1054	1.027	0.500	83.99	No	NA	1104	1.062	0.362 (see note)	86.91	No	NA	1112	1.156	0.215	103.11	No	NA	1044	0.976	0	83.56	No	NA
9/1/2021	NC2	NC2	NC2	NC2	NC2	NC2	0930	0.0	1.4	84.09	No	NA	1042	0.0	0.2	86.97	No	NA	1145	0.0	0.2	103.17	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
9/7/2021	1210	0.135	0.107	NC3	NC3	NC3	1201	0.131	0 (see note)	84.00	No	NA	1222	0.061	0.137 (see note)	86.93	No	NA	1238	0.02	0.245	103.24	No	NA	1150	0.106	0	83.64	No	NA
9/8/2021	NC2	NC2	NC2	NC2	NC2	NC2	0935	0.0	0.1	84.09	No	NA	1125	0.0	0.4	86.97	No	NA	1305	0.0	0.0	103.10	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
9/13/2021	1058	0.195	0.181	NC3	NC3	NC3	1055	0.187	0	83.91	No	NA	1116	0.137	1.03 (see note)	86.84	No	NA	1129	0.108	0.157	103.07	No	NA	1040	0.152	0	83.52	No	NA
9/15/2021	NC2	NC2	NC2	NC2	NC2	NC2	1005	0.1	0.1	84.03	No	NA	1300	0.1	1.2	86.89	No	NA	1357	0.1	0.1	103.16	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
9/20/2021	NC	NC	NC	NC3	NC3	NC3	0857	0.412	0	83.99	No	NA	0908	0.061	1.241	86.95	No	NA	1002	0.030	0.049	103.3	No	NA	0850	0.135	0	83.63	No	NA
9/22/2021	NC2	NC2	NC2	NC2	NC2	NC2	0952	0.1	0.1	83.98	No	NA	1125	0.1	0.4	86.88	No	NA	1240	0.0	0.0	103.12	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
9/23/2021	0938	0.267	0.207	NC3	NC3	NC3	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC	NC
9/27/2021	0802	0.120	0.125	NC3	NC3	NC3	0801	0.120	0 (see note)	84.07	No	NA	0810	0.068	0.868 (see note)	87.01	No	NA	0820	0.057	0.157	103.17	No	NA	0747	0.105	0	83.64	No	NA
9/29/2021	NC2	NC2	NC2	NC2	NC2	NC2	0952	0.0	0.0	84.11	No	NA	1100	0.0	0.3	86.94	No	NA	1140	0.0	0.0	103.14	No	NA	NC2	NC2	NC2	NC2	NC2	NC2
10/4/2021	1524	0.956	0.952	NC3	NC3	NC3	1520	0.997	0	83.93	No	NA	1530	0.459	0	86.89	No	NA	1552	0.060	0	103.12	No	NA	1510	1.231	0	83.52	No	NA
10/6/2021	NC2	NC2	NC2	NC2	NC2	NC2	1000	0.0	0.1	84.06	No	NA	1110	0.1	1.9	86.98	No	NA	1245	0.0	0.1	103.18	No	NA	0850	0.0	0.0	83.68	No	NA
10/12/2021	1211	0.139	0.129	NC3	NC3	NC3	1219	0.140	0.093	84.11	No	NA	1228	0.078	0	87.03	No	NA	1330	0.142	0.042	103.19	No	NA	1206	0.125	0	83.74	No	NA
10/13/2021	NC2	NC2	NC2	NC2	NC2	NC2	1030	0.1	0.2	84.09	No	NA	1140	0.1	1.2	87.04	No	NA	1240	0.2	0.1	103.22	No	NA	0905	0.1	0.1	83.71	No	NA
10/20/2021	1028	0.0	0.0	84.37	No	NA	1059	0.0	0.1	84.14	No	NA	1220	0.0	0.0	87.04	No	NA	1348	0.0	0.0	103.22	No	NA	0857	0.0	0.0	83.78	No	NA
10/27/2021	0935	0.1	0.1	84.42	No	NA	0933	0.1	0.1	84.19	No	NA	1027	0.5	3.1	87.09	No	NA	1118	0.1	0.1	103.28	No	NA	0830	0.1	0.0	83.84	No	NA
11/3/2021	1020	0.0	0.0	NC3	NC3	NC3	1030	0.1	0.2	84.19	No	NA	1127	0.1	0.0	87.04	No	NA	1235	0.0	0.1	103.23	No	NA	0923	0.0	0.0	83.80	No	NA
11/10/2021	1140	0.0	0.1	NC3	NC3	NC3	1143	0.0	0.0	84.16	No	NA	1338	0.0	0.0	87.04	No	NA	1517	0.0	0.0	103.28	No	NA	0950	0.0	0.0	83.79	No	NA
11/17/2021	1135	0.0	0.0	NC3	NC3	NC3	1138	0.0	0.1	84.16	No	NA	1323	0.0	0.0	87.04	No	NA	1505	0.0	0.0	103.29	No	NA	1018	0.1	0.0	83.77	No	NA
11/24/2021	1005	0.0	0.0	NC3	NC3	NC3	1003	0.0	0.0	84.29	No	NA	1108	0.0	0.0	87.15	No	NA	1210	0.0	0.0	103.37	No	NA	0855	0.0	0.0	83.93	No	NA
12/1/2021	1040	0.2	0.2	NC3	NC3	NC3	1035	0.2	0.0	83.83	No	NA	1202	0.0	0.0	86.75	No	NA	1312	0.0	0.0	103.02	No	NA	NC4	NC4	NC4	NC4	NC4	NC4

DTW = Depth-to-water
ft = feet
ft btoc = feet below top of casing
NA = Not applicable
NM = No measurement taken, due to equipment installed in well.
ppmv = parts-per-million, volume
NC - Not collected
NC1 - Not collected due to headspace and fuel product gauging occurring only where groundwater sampling was being conducted.
NC2 - Not collected - monitoring well not being sampled for groundwater in the DOH Transition Plan.
NC3 - Fuel product gauging not conducted at RHMW01 per email correspondence from DOH on 7/27/2021
NC4 - Monitoring well being sampled for the November 20 event and reported separately

Notes:
5/25/2021: Initial headspace reading at RHMW02 was unusually high. No signs of fuel product (sheen or odor) were observed during fuel product gauging. Returned to verify headspace reading and it was significantly lower, as shown in the second set of results.
5/27/2021: Initial headspace reading at RHMW02 was ~14.43 ppmv, but dropped to 0.156 ppmv. No fuel product measured.
6/6/2021: Immediate headspace reading was 3.316 ppmv, but dropped quickly to value recorded.
7/12/2021 Strong background chemical odor related to contractor work at Tank 13.
7/26/2021: Initial headspace reading was ~11.33 ppmv, but dropped quickly to 0.483 ppmv. No fuel product measured.

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.c. Monitoring Wells: RHMW01, RHMW01R, RHMW02, RHMW03, and RHMW05 - Headspace and Fuel Product Gauging
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

RHMW01							RHMW01R						RHMW02						RHMW03						RHMW05					
DATE	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS
		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)		(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)

8/5/2021: Headspace and breathing zone PID readings taken at RHMW01 due to inadvertently being excluded on 8/2/2021.
8/9/2021: Initial headspace reading was ~22.35 ppm, but dropped quickly to value recorded.
8/16/2021: Initial headspace reading was 7.621 ppm, but dropped quickly to value recorded.
8/30/2021: Initial headspace reading was 5.032 ppm, but dropped to value recorded.
9/7/2021: Initial headspace reading at RHMW01R was 0.910 ppm, but dropped to value recorded. Initial headspace reading at RHMW02 was 4.521 ppm, but dropped to value recorded.
9/13/2021: Initial headspace reading at RHMW01R was ~14.1 ppm, but dropped to value recorded.
9/27/2021: Initial headspace reading at RHMW01R was 0.600 ppm, but dropped to value recorded. Initial headspace reading at RHMW02 was 5.806 ppm, with strong sulfur odor, but dropped to value recorded.

Red Hill Bulk Fuel Storage Facility

Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021

Additional Sampling: Headspace and Fuel Product Gauging

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

Additional Sampling 09/29/2021-10/04/2021

Well Name	Date	TIME	AMBIENT	HEADSPACE	DTW	PRODUCT?	THICKNESS
			(ppmv)	(ppmv)	(ft btoc)	(Yes/No)	(ft)
RHMW05	9/29/2021	8:50	0.0	0.0	83.66	No	NA
RHMW19	9/30/2021	9:05	0.0	0.0	427.30	No	NA
RHMW10	9/30/2021	11:17	0.0	0.0	478.33	No	NA
RHMW09	9/30/2021	12:50	0.0	0.0	378.32	No	NA
RHMW08	9/30/2021	14:35	0.0	0.0	293.14	No	NA
RHMW04	10/1/2021	8:25	0.0	9.0 ⁽¹⁾	294.59	No	NA
RHMW06	10/1/2021	10:00	0.0	0.0	241.76	No	NA
RHMW16	10/1/2021	11:25	0.0	0.0	202.46	No	NA
OWDFMW01	10/1/2021	12:38	0.0	0.0	120.70	No	NA
RHMW12A	10/4/2021	9:04	0.0	0.1	221.41	No	NA

Notes:

DTW = Depth-to-water

ft = feet

ft btoc = feet below top of casing

NA = Not applicable

ppmv = parts-per-million, volume

¹ - Ants around RHMW04. Team sprayed isopropyl alcohol in order to get ants off lid. Reading was high due to residual alcohol.

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #							96179	96188	96179	96179	96188	96179
		Sample ID							ERH1363	ERH1365	ERH1367	ERH1362	ERH1364	ERH1366
		Collected							5/12/2021	5/13/2021	5/13/2021	5/12/2021	5/13/2021	5/13/2021
		Sampling Method ^{3, 4}							Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow
Final results provided (validation completed)		Sample Type							Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank
		Location							RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03
			RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)							
Analyte	Screening Criteria	SSRBL						Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.4	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95.0	<18.0	ug/L	<18.0 U	100.0	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350.0	1500.0	2900.0	150.0	380.0	ug/L	180.0 J	1600.0 J	200.0 J	–	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67.0	260.0	690.0	<25.0	<300.0	ug/L	<300.0 U	360.0 J	<300.0 U	–	–
TPH-o	500	–	<40.0	<300.0	<300.0	330.0	<300.0	310.0	ug/L	<300.0 U	240.0 J	220.0 J	–	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	–	–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52.0	<0.025	<0.10	ug/L	<0.10 U	33	<0.10 U	–	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51.0	<0.025	<0.10	ug/L	<0.10 U	24	<0.10 U	–	–
Naphthalene	17	–	<0.10	0.19	32.0	98.0	<0.025	<0.10	ug/L	<0.10 U	59	<0.10 U	–	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility

Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021

2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #								96269	96282	96282	96269	96282	96282
		Sample ID								ERH1370	ERH1372	ERH1374	ERH1369	ERH1371	ERH1373
		Collected								5/19/2021	5/20/2021	5/20/2021	5/19/2021	5/20/2021	5/20/2021
		Sampling Method ^{3, 4}								Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow
Final results provided (validation completed)		Sample Type								Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank
		Location								RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	—	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	—	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	—	<0.30	<0.30	<0.30	0.4	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	—	<18.0	<18.0	<18.0	95.0	<18.0	<18.0	ug/L	<18.0 U	37.0	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350.0	1500.0	2900.0	150.0	380.0	ug/L	210.0 J	1700.0	170.0 J	—	—	—
TPH-d w/ Silica Gel Cleanup ¹	—	—	<300.0	67.0	260.0	690.0	<25.0	<300.0	ug/L	<300.0 U	340.0	<300.0 U	—	—	—
TPH-o	500	—	<40.0	<300.0	<300.0	330.0	<300.0	310.0	ug/L	<300.0 U	250.0 J	210.0 J	—	—	—
TPH-o w/ Silica Gel Cleanup ¹	—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	—	—	—
1-Methylnaphthalene	10	—	<0.025	<0.10	8.7	52.0	<0.025	<0.10	ug/L	<0.10 U	21	<0.10 U	—	—	—
2-Methylnaphthalene	10	—	<0.025	<0.10	7.2	51.0	<0.025	<0.10	ug/L	<0.10 U	9.5	<0.10 U	—	—	—
Naphthalene	17	—	<0.10	0.19	32.0	98.0	<0.025	<0.10	ug/L	<0.10 U	52	<0.10 U	—	—	—

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #							96320	96320	96343	96320	96320	96343	96363	96363	96363	96363	96363	96363	96410	96410	96410	96410	96410	96410	
		Sample ID							ERH1376	ERH1378	ERH1380	ERH1375	ERH1377	ERH1379	ERH1382	ERH1384	ERH1386	ERH1381	ERH1383	ERH1385	ERH1388	ERH1390	ERH1392	ERH1387	ERH1389	ERH1391	
		Collected							5/24/2021	5/24/2021	5/25/2021	5/24/2021	5/24/2021	5/25/2021	5/26/2021	5/26/2021	5/26/2021	5/26/2021	5/26/2021	5/26/2021	5/28/2021	5/28/2021	5/28/2021	5/28/2021	5/28/2021	5/28/2021	
		Sampling Method ^{3, 4}							Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow
Final results provided (validation completed)		Sample Type							Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	
		Location							RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Result Q	
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.4	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
TPH-g	300	–	<18.0	<18.0	<18.0	95.0	<18.0	<18.0	ug/L	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 UJ	<18.0 UJ	<18.0 UJ	<18.0 UJ	<18.0 UJ	<18.0 UJ	<18.0 U	80.0	<18.0 U	<18.0 U	<18.0 U	<18.0 U	
TPH-d	400	4500	<300.0	350.0	1500.0	2900.0	150.0	380.0	ug/L	310.0 J	1500.0	160.0 J	–	–	–	210.0 J	1600	<300.0 U	–	–	–	180.0 J	1400.0 J	180.0 J	–	–	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67.0	260.0	690.0	<25.0	<300.0	ug/L	<300.0 U	360.0	<300.0 U	–	–	–	<300.0 U	380.0	–	–	–	<300.0 UJ	210.0 J	<300.0 UJ	–	–	–	
TPH-o	500	–	<40.0	<300.0	<300.0	330.0	<300.0	310.0	ug/L	<300.0 U	170.0 J	<300.0 U	–	–	–	<300.0 U	<300.0 U	<300.0 U	–	–	–	<300.0 UJ	190.0 J	180.0 J	–	–	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	–	–	–	<300.0 U	<300.0 U	–	–	–	<300.0 UJ	<300.0 UJ	<300.0 UJ	–	–	–	
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52.0	<0.025	<0.10	ug/L	<0.10 U	22.0	<0.10 U	–	–	–	<0.10 U	19	<0.10 U	–	–	–	<0.10 U	17	<0.10 U	–	–	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51.0	<0.025	<0.10	ug/L	<0.10 U	11.0 J	<0.10 U	–	–	–	<0.10 U	11	<0.10 U	–	–	–	<0.10 U	7.0	<0.10 U	–	–	–
Naphthalene	17	–	<0.10	0.19	32.0	98.0	<0.025	<0.10	ug/L	<0.10 U	47.0	<0.10 U	–	–	–	<0.10 U	39	<0.10 U	–	–	–	<0.10 U	35	<0.10 U	–	–	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"-" - not applicable

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #						96410	96410	96410	96410	96410	96410	96438	96438	96438	96438	96438	96438	96438	96463	96463	96463	96463	96463	96463
		Sample ID						ERH1394	ERH1396	ERH1398	ERH1393	ERH1395	ERH1397	ERH1400	ERH1402	ERH1404	ERH1399	ERH1401	ERH1403	ERH1406	ERH1408	ERH1410	ERH1405	ERH1407	ERH1409	
		Collected						5/31/2021	5/31/2021	5/31/2021	5/31/2021	5/31/2021	5/31/2021	6/2/2021	6/2/2021	6/2/2021	6/2/2021	6/2/2021	6/2/2021	6/4/2021	6/4/2021	6/4/2021	6/4/2021	6/4/2021	6/4/2021	
		Sampling Method ^{3, 4}						Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Low-Flow	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer
Final results provided (validation completed)		Sample Type						Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	
		Location						RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.4	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
TPH-g	300	–	<18.0	<18.0	<18.0	95.0	<18.0	<18.0	ug/L	<18.0 U	81.0	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	38.0	<18.0 U	<18.0 U	<18.0 U	<18.0 U	27.0	<18.0 U	<18.0 U	<18.0 U	
TPH-d	400	4500	<300.0	350.0	1500.0	2900.0	150.0	380.0	ug/L	200.0 J	1300.0	180.0 J	–	–	–	270.0 J	2000.0	260.0 J	–	–	–	270.0 J	1500.0	330.0	–	
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67.0	260.0	690.0	<25.0	<300.0	ug/L	<300.0 U	330.0	<300.0 U	–	–	–	<300.0 U	290 J	<300.0 U	–	–	–	<300.0 U	390.0	<300.0 U	–	
TPH-o	500	–	<40.0	<300.0	<300.0	330.0	<300.0	310.0	ug/L	<300.0 U	180.0 J	180.0 J	–	–	–	160 J	300 J	330	–	–	–	200.0 J	370.0	580.0 ²	–	
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	–	–	–	<300.0 U	<300.0 U	<300.0 U	–	–	–	<300.0 U	<300.0 U	<300.0 U	–	
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52.0	<0.025	<0.10	ug/L	<0.10 U	14	<0.10 U	–	–	–	<0.10 U	20	<0.10 U	–	–	–	<0.10 U	12	<0.10 UJ	–	
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51.0	<0.025	<0.10	ug/L	<0.10 U	7.0	<0.10 U	–	–	–	<0.10 U	12	<0.10 U	–	–	–	<0.10 U	2.8	<0.10 UJ	–	
Naphthalene	17	–	<0.10	0.19	32.0	98.0	<0.025	<0.10	ug/L	<0.10 U	29	<0.10 U	–	–	–	<0.10 U	42	<0.10 U	–	–	–	<0.10 U	26	<0.10 UJ	–	

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"-" - not applicable

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #						96472	96472	96472	96472	96472	96472	96524	96524	96524	96524	96524	96524	96548	96548	96548	96548	96548	96548
		Sample ID						ERH1412	ERH1414	ERH1416	ERH1411	ERH1413	ERH1415	ERH1418	ERH1420	ERH1422	ER1417	ERH1419	ERH1421	ERH1424	ERH1428	ERH1426	ERH1423	ERH1427	ERH1425
		Collected						6/7/2021	6/7/2021	6/7/2021	6/7/2021	6/7/2021	6/7/2021	6/9/2021	6/9/2021	6/9/2021	6/9/2021	6/9/2021	6/9/2021	6/11/2021	6/11/2021	6/11/2021	6/11/2021	6/11/2021	6/11/2021
		Sampling Method ^{3, 4}						Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer
Final results provided (validation completed)		Sample Type						Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank
		Location						RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Results Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 UJ	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 UJ	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 UJ	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.4	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 UJ	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95.0	<18.0	<18.0	ug/L	<18.0 U	33.0	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	60.0	<18.0 UJ	<18.0 U	<18.0 U	<18.0 U	<18.0 U	47.0	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350.0	1500.0	2900.0	150.0	380.0	ug/L	220.0 J	1900.0	430.0	–	–	–	230.0 J	1900.0	370.0	–	–	–	210.0 J	2100.0	260.0 J	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67.0	260.0	690.0	<25.0	<300.0	ug/L	<300.0 U	400.0	<300.0 U	–	–	–	<300.0 U	<300.0 U	<300.0 U	–	–	–	<300.0 U	250.0 J	<300.0 U	–
TPH-o	500	–	<40.0	<300.0	<300.0	330.0	<300.0	310.0	ug/L	320.0	320.0	840.0 ²	–	–	–	190.0 J	240.0 J	550.0 ²	–	–	–	<300.0 U	410.0	370.0	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	350.0	–	–	–	<300.0 U	<300.0 U	200.0 J	–	–	–	<300.0 U	<300.0 U	<300.0 U	–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52.0	<0.025	<0.10	ug/L	<0.10 U	19	<0.10 UJ	–	–	–	<0.10 UJ	12 J	<0.10 UJ	–	–	–	<0.10 U	14	<0.10 U	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51.0	<0.025	<0.10	ug/L	<0.10 U	14	<0.10 UJ	–	–	–	<0.10 UJ	7.2 J	<0.10 UJ	–	–	–	<0.10 U	6.0	<0.10 U	–
Naphthalene	17	–	<0.10	0.19	32.0	98.0	<0.025	<0.10	ug/L	<0.10 U	43	<0.10 UJ	–	–	–	<0.10 UJ	24 J	<0.10 UJ	–	–	–	<0.10 U	26	<0.10 U	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"-" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event			SDG #						96623	96623	96623	96623	96623	96623	
			Sample ID						ERH1440	ERH1442	ERH1444	ERH1439	ERH1441	ERH1443	
			Collected						6/17/2021	6/17/2021	6/17/2021	6/17/2021	6/17/2021	6/17/2021	
			Sampling Method ^{3, 4}						Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	
Final results provided (validation completed)			Sample Type						Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	
			Location						RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.4	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95.0	<18.0	<18.0	ug/L	<18.0 U	23.0	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350.0	1500.0	2900.0	150.0	380.0	ug/L	240.0 J	2000.0	220.0 J	–	–	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67.0	260.0	690.0	<25.0	<300.0	ug/L	<300.0 U	740.0	<300.0 U	–	–	–
TPH-o	500	–	<40.0	<300.0	<300.0	330.0	<300.0	310.0	ug/L	170.0 J	350.0	330.0	–	–	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	150.0 J	160.0 J	200.0 J	–	–	–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52.0	<0.025	<0.10	ug/L	0.43	19	<0.10 U	–	–	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51.0	<0.025	<0.10	ug/L	<0.10 U	8.3	<0.10 U	–	–	–
Naphthalene	17	–	<0.10	0.19	32.0	98.0	<0.025	<0.10	ug/L	<0.10 U	33	<0.10 U	–	–	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility

Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021

2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #							96682	96682	96682	96682	96682	96682	
		Sample ID							ERH1448	ERH1450	ERH1452	ERH1447	ERH1449	ERH1451	
		Collected							6/24/2021	6/24/2021	6/24/2021	6/24/2021	6/24/2021	6/24/2021	
		Sampling Method ^{3, 4}							Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	
Final results provided (validation completed)		Sample Type							Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	
		Location							RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	
			RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)								
Analyte	Screening Criteria	SSRBL							Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	52	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	160 J	1400	150 J	–	–	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L	150 J+	470	<300.0 U	–	–	–
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	<300.0 U	<300.0 U	170 J	–	–	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	–	–	–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	<0.10 U	24	<0.10 U	–	–	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10 U	17	<0.10 U	–	–	–
Naphthalene	17	–	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	54	<0.10 U	–	–	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

J+ - estimated value, high bias

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event	SDG #		96682	96682	96682	96682
	Sample ID		ERH1448	ERH1450	ERH1452	ERH1454
	Collected		6/24/2021	6/24/2021	6/24/2021	6/24/2021
	Sampling Method ^{1, 2}		Bailer	Bailer	Bailer	—
Final results provided (validation completed)	Sample Type		Primary	Primary	Primary	Primary
	Location		RHMW01R	RHMW02	RHMW03	RHSF
SVOC - Cindy Complete	Screening Criteria	Units	Result Q	Result Q	Result Q	Result Q
1,2,4-Trichlorobenzene	70	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
1,2-Dichlorobenzene	10	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
1,3-Dichlorobenzene	5.0	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
1,4-Dichlorobenzene	5.0	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
1,4-Dioxane	0.46	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U
1-Methylnaphthalene	10	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2,4,5-Trichlorophenol	17	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2,4,6-Trichlorophenol	7.1	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2,4-Dichlorophenol	0.3	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2,4-Dimethylphenol	400	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2,4-Dinitrophenol	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2,4-Dinitrotoluene	0.25	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2,6-Dinitrotoluene	0.052	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2-Chloronaphthalene	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2-Chlorophenol	0.18	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2-Methylnaphthalene	10	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2-Methylphenol	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2-Nitroaniline	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
2-Nitrophenol	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
3,3'-Dichlorobenzidine	0.17	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
3-Nitroaniline	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
3/4-Methylphenol	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
4,6-Dinitro-2-Methylphenol	-	ug/L	<5.00 U	<5.00 U	<5.00 U	5.2 J
4-Bromophenyl Phenyl Ether	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
4-Chloro-3-Methylphenol	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
4-Chloroaniline	0.39	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
4-Chlorophenyl Phenyl Ether	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
4-Nitroaniline	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
4-Nitrophenol	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Acenaphthene	20	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Acenaphthylene	236	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Anthracene	0.18	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Benz (a) Anthracene	0.029	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Benzo (a) Pyrene	0.20	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Benzo (b) Fluoranthene	0.22	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Benzo (g,h,i) Perylene	0.13	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Benzo (k) Fluoranthene	0.40	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Benzyl Alcohol	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Bis (2-chlorethoxy) Methane	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Bis (2-chloroethyl) Ether	0.014	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Bis (2-ethylhexyl) Phthalate	6.0	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Bis(2-chloro-1-methylethyl)ethe	0.37	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Butyl Benzyl Phthalate	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Carbazole	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Chrysene	1.0	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event	SDG #		96682	96682	96682	96682
	Sample ID		ERH1448	ERH1450	ERH1452	ERH1454
	Collected		6/24/2021	6/24/2021	6/24/2021	6/24/2021
	Sampling Method ^{1, 2}		Bailer	Bailer	Bailer	—
Final results provided (validation completed)	Sample Type		Primary	Primary	Primary	Primary
	Location		RHMW01R	RHMW02	RHMW03	RHSF
SVOC - Cindy Complete	Screening Criteria	Units	Result Q	Result Q	Result Q	Result Q
Di-n-butyl Phthalate	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Di-n-octyl Phthalate	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Dibenz (a,h) Anthracene	0.022	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Dibenzofuran	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Diethyl Phthalate	980	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Dimethyl Phthalate	3200	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Diphenylamine	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Fluoranthene	13	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Fluorene	236	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Hexachlorobenzene	0.00030	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Hexachlorobutadiene	0.20	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Hexachlorocyclopentadiene	-	ug/L	<20.00 UJ	<20.00 UJ	<20.00 UJ	<20.00 UJ
Hexachloroethane	0.40	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Indeno (1,2,3-cd) Pyrene	0.095	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Isophorone	82	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
N-nitrosodi-n-propylamine	-	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Naphthalene	17	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Nitrobenzene	0.14	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Pentachlorophenol	1.0	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Phenanthrene	214	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Phenol	300	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U
Pyrene	68	ug/L	<5.00 U	<5.00 U	<5.00 U	<5.00 U

Notes:

Screening criteria based on DOH Tier 1 EALs, Table D-1b Groundwater Action Levels, where groundwater is a current or potential drinking water resource, and surface water body is not located within 150m of release site (DOH 2017).

¹ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

² - Bailer method – sample without purging and from the top of the water column.

J - estimated value

B - blank method contamination

U - nondetect value

ID - identification

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #							96701	96701	96714	96714	96714	96714	96701	96714	96714	
		Sample ID							ERH1456	ERH1529	ERH1530	ERH1458	ERH1531	ERH1460	ERH1455	ERH1457	ERH1459	
		Collected							6/30/2021	6/30/2021	6/30/2021	6/30/2021	6/30/2021	6/30/2021	6/30/2021	6/30/2021	6/30/2021	
		Sampling Method ^{3, 4}							Low-Flow	Bailer	Low-Flow	Bailer	Low-Flow	Bailer	–	–	–	
Final results provided (validation completed)		Sample Type							Primary	Primary	Primary	Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	
		Location							RHMW01R	RHMW01R	RHMW02	RHMW02	RHMW03	RHMW03	RHMW01R	RHMW02	RHMW03	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	<18.0 U	170	130	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	200 J	270 J	1800	1800	160 J	220 J	–	–	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0 U	<300.0 U	520	570	<300.0 U	<300.0 U	–	–	–
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	<300.0 U	210 J	210 J	320	200 J	350	–	–	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	<300.0 U	<300.0 U	150 J	–	–	–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	<0.10 U	0.22	13	20	<0.10 U	<0.10 U	–	–	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10 U	<0.10 U	11	10	<0.10 U	<0.10 U	–	–	–
Naphthalene	17	–	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	<0.10 U	26	32	<0.10 U	<0.10 U	–	–	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"–" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event			SDG #						96778	96778	96778	96778	96778			
			Sample ID						ERH1464	ERH1466	ERH1468	ERH1463	ERH1465			
			Collected						7/8/2021	7/8/2021	7/8/2021	7/8/2021	7/8/2021			
			Sampling Method ^{3, 4}						Bailer	Bailer	Bailer	Bailer	Bailer			
Final results provided (validation pending)			Sample Type						Primary	Primary	Primary	Trip Blank	Trip Blank			
			Final results provided (validation completed)			Location						RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02, RHMW03
	Screening Criteria	SSRBL				RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q
Benzene			5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene			30	—	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene			40	—	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)			20	—	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g			300	—	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d			400	4500	<300.0	350	1500	2900	150	380	ug/L	pending *	pending *	310 J	—	—
TPH-d w/ Silica Gel Cleanup ¹			—	—	<300.0	67	260	690	<25.0	<300.0	ug/L	pending *	pending *	<300.0 U	—	—
TPH-o			500	—	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	pending *	pending *	660 ²	—	—
TPH-o w/ Silica Gel Cleanup ¹			—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	—	—
1-Methylnaphthalene			10	—	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	0.28	19	<0.10 U	—	—
2-Methylnaphthalene			10	—	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10 U	6.9	<0.10 U	—	—
Naphthalene			17	—	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	37	<0.10 U	—	—

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

* Discrepancies noted in the final report are being corrected

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #							96846	96846	96846	96846	96846	96846	
		Sample ID							ERH1533	ERH1535	ERH1537	ERH1532	ERH1534	ERH1536	
		Collected							7/15/2021	7/15/2021	7/15/2021	7/15/2021	7/15/2021	7/15/2021	
		Sampling Method ^{3, 4}							Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	
Final results provided (validation pending)		Sample Type							Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	
		Location							RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	260 J	2700	250 J	–	–	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0 U	660	<300.0 U	–	–	–
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	180 J	530 ²	610 ²	–	–	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	–	–	–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	0.23	19	<0.10 U	–	–	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10 U	11	<0.10 U	–	–	–
Naphthalene	17	–	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	38	<0.10 U	–	–	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #							97004	97004	97004	97004	97004	97004	
		Sample ID							ERH1549	ERH1551	ERH1553	ERH1548	ERH1550	ERH1552	
		Collected							7/29/2021	7/29/2021	7/29/2021	7/29/2021	7/29/2021	7/29/2021	
		Sampling Method ^{3, 4}							Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	
Final results provided (validation completed)		Sample Type							Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	
		Location							RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	—	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	—	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	—	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	—	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	59	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	260 J	2400	260 J	—	—	—
TPH-d w/ Silica Gel Cleanup ¹	—	—	<300.0	67	260	690	<25.0	<300.0	ug/L	160 J	530	<300.0 U	—	—	—
TPH-o	500	—	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	200 J	440	490	—	—	—
TPH-o w/ Silica Gel Cleanup ¹	—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	230 J	250 J	250 J	—	—	—
1-Methylnaphthalene	10	—	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	0.30	28	<0.10 U	—	—	—
2-Methylnaphthalene	10	—	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	0.17 J	26	<0.10 U	—	—	—
Naphthalene	17	—	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	60	<0.10 U	—	—	—

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event			SDG #		97057		97057		97057		97057		97057		97057	
			Sample ID		ERH1576		ERH1578		ERH1580		ERH1575		ERH1577		ERH1579	
			Collected		8/5/2021		8/5/2021		8/5/2021		8/5/2021		8/5/2021		8/5/2021	
			Sampling Method ^{3, 4}		Bailer		Bailer		Bailer		Bailer		Bailer		Bailer	
Final results provided (validation pending)			Sample Type		Primary		Primary		Primary		Trip Blank		Trip Blank		Trip Blank	
Final results provided (validation completed)			Location		RHMW01R		RHMW02		RHMW03		RHMW01R		RHMW02		RHMW03	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	—	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	0.30 J	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	—	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	—	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	—	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	92	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	230 J	2900	430	—	—	—	—
TPH-d w/ Silica Gel Cleanup ¹	—	—	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0 U	680	<300.0 U	—	—	—	—
TPH-o	500	—	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	180 J	380	710 ²	—	—	—	—
TPH-o w/ Silica Gel Cleanup ¹	—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	240 J	—	—	—	—
1-Methylnaphthalene	10	—	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	0.20	35	<0.10 U	—	—	—	—
2-Methylnaphthalene	10	—	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10 U	29	<0.10 U	—	—	—	—
Naphthalene	17	—	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	62	<0.10 U	—	—	—	—

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event			SDG #						97159	97159	97159	97159	97159	97159	
			Sample ID						ERH1584	ERH1586	ERH1588	ERH1583	ERH1585	ERH1587	
			Collected						8/12/2021	8/12/2021	8/12/2021	8/12/2021	8/12/2021	8/12/2021	
			Sampling Method ^{3, 4}						Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	
Final results provided (validation pending)			Sample Type						Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	
Final results provided (validation completed)			Location						RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	—	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	—	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	—	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	—	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	200 J	3000	350	—	—	—
TPH-d w/ Silica Gel Cleanup ¹	—	—	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0 U	690	<300.0 U	—	—	—
TPH-o	500	—	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	160 J	480	790 ²	—	—	—
TPH-o w/ Silica Gel Cleanup ¹	—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	260 J	—	—	—
1-Methylnaphthalene	10	—	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	0.088 J	32	<0.10 U	—	—	—
2-Methylnaphthalene	10	—	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10 U	26	<0.10 U	—	—	—
Naphthalene	17	—	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	67	<0.10 U	—	—	—

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event			SDG #							97221	97221	97221	97221	97221	97221
			Sample ID							ERH1592	ERH1594	ERH1596	ERH1591	ERH1593	ERH1595
			Collected							8/19/2021	8/19/2021	8/19/2021	8/19/2021	8/19/2021	8/19/2021
			Sampling Method ^{3, 4}							Bailer	Bailer	Bailer	Bailer	Bailer	Bailer
Final results provided (validation pending)			Sample Type							Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank
Final results provided (validation completed)			Location							RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03
				RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)							
Analyte	Screening Criteria	SSRBL							Units	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	85	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	230 J	3300	270 J	–	–	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0 U	340	<300.0 U	–	–	–
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	310 J	470	520 ²	–	–	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	190 J	<300.0 U	190 J	–	–	–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	pending	53	<0.10 U	–	–	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	pending	49	<0.10 U	–	–	–
Naphthalene	17	–	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	110	<0.10 U	–	–	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility

Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021

2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #								97307	97307	97307	97307	97307	97307	97307
		Sample ID								ERH1617	ERH1624	ERH1619	ERH1621	ERH1616	ERH1618	ERH1620
		Collected								8/26/2021	8/26/2021	8/26/2021	8/26/2021	8/26/2021	8/26/2021	8/26/2021
		Sampling Method ^{3, 4}								Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer
Final results provided (validation pending)		Sample Type								Primary	Field Duplicate	Primary	Primary	Trip Blank	Trip Blank	Trip Blank
Final results provided (validation completed)		Location								RHMW01R	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	320	270 J	2800	410	–	–	–
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0 U	<300.0 U	620	<300.0 U	–	–	–
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	220 J	300 J	370	860	–	–	–
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0 U	<300.0 U	<300.0 U	550	–	–	–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	<0.10 U	<0.10 U	21	<0.10 U	–	–	–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10 U	<0.10 U	18	<0.10 U	–	–	–
Naphthalene	17	–	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	<0.10 U	42	<0.10 U	–	–	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event			SDG #						97378	97378	97378	97378	97378	97378	97378		
			Sample ID						ERH1640	ERH1647	ERH1642	ERH1644	ERH1639	ERH1641	ERH1643		
			Collected						9/1/2021	9/1/2021	9/1/2021	9/1/2021	9/1/2021	9/1/2021	9/1/2021		
			Sampling Method ^{3, 4}						Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer		
Final results provided (validation pending)			Sample Type						Primary	Field Duplicate	Primary	Primary	Trip Blank	Trip Blank	Trip Blank		
			Location						RHMW01R	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03		
				RHMW01 2018-2021 Historical Ranges (min/max)	RHMW02 2018-2021 Historical Ranges (min/max)	RHMW03 2018-2021 Historical Ranges (min/max)											
Analyte	Screening Criteria	SSRBL					Units	Result	Q	Result	Q	Result	Q	Results	Q	Result	Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30	U	<0.30	U	<0.30	U	<0.30	U
Ethylbenzene	30	—	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50	U	<0.50	U	<0.50	U	<0.50	U
Toluene	40	—	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30	U	<0.30	U	<0.30	U	<0.30	U
Xylenes (Total)	20	—	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30	U	<0.30	U	<0.30	U	<0.30	U
TPH-g	300	—	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0	U	<18.0	U	<18.0	U	<18.0	U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	240	J	250	J	3600	260	J	
TPH-d w/ Silica Gel Cleanup ¹	—	—	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0	U	<300.0	U	1400	<300.0	U	
TPH-o	500	—	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	160	J	220	J	560 ²	520 ²		
TPH-o w/ Silica Gel Cleanup ¹	—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0	U	<300.0	U	180	J	190	J
1-Methylnaphthalene	10	—	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	0.28		0.25		31	<0.10	U	
2-Methylnaphthalene	10	—	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	0.085	J	0.064	J	29	<0.10	U	
Naphthalene	17	—	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10	U	<0.10	U	67	<0.10	U	

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility

Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021

2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling

DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #								97541	97541	97541	97541	97541	97541	97541
		Sample ID								ERH1662	ERH1669	ERH1664	ERH1666	ERH1661	ERH1663	ERH1665
		Collected								9/15/2021	9/15/2021	9/15/2021	9/15/2021	9/15/2021	9/15/2021	9/15/2021
		Sampling Method 1,2								Bailer	Bailer	Bailer	Bailer	—	—	—
Final results provided (validation pending)		Sample Type								Primary	Field Duplicate	Primary	Primary	Trip Blank	Trip Blank	Trip Blank
		Location								RHMW01R	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03
			RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)									
Analyte	Screening Criteria	SSRBL							Units	Result Q	Result Q	Result Q	Result Q	Results Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	—	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	—	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	—	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	—	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0 U	<18.0 U	46	<18.0 U	<18.0 U	23	<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	240 J	280 J	2600	350	—	—	—
TPH-d w/ Silica Gel Cleanup ¹	—	—	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0 U	<300.0 U	1100	<300.0 U	—	—	—
TPH-o	500	—	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	210 BJ	310 BJ	470 B	700 B	—	—	—
TPH-o w/ Silica Gel Cleanup ¹	—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	150 BJ	250 BJ	160 BJ	440 B	—	—	—
1-Methylnaphthalene	10	—	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	0.19 J	0.21	33	<0.10 U	—	—	—
2-Methylnaphthalene	10	—	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10 U	<0.10 U	33	<0.10 U	—	—	—
Naphthalene	17	—	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10 U	<0.10 U	70	<0.10 U	—	—	—

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

B - the analyte was found in the method blank, as well as in the sample

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event			SDG #						97642	97642	97642	97642	97642	97642	97642			
			Sample ID						ERH1671	ERH1678	ERH1673	ERH1675	ERH1670	ERH1672	ERH1674			
			Collected						9/22/2021	9/22/2021	9/22/2021	9/22/2021	9/22/2021	9/22/2021	9/22/2021			
			Sampling Method ^{3, 4}						Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer			
Final results provided (validation pending)			Sample Type						Primary	Field Duplicate	Primary	Primary	Trip Blank	Trip Blank	Trip Blank			
			Location						RHMW01R	RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03			
				RHMW01 2018-2021 Historical Ranges (min/max)	RHMW02 2018-2021 Historical Ranges (min/max)	RHMW03 2018-2021 Historical Ranges (min/max)												
Analyte	Screening Criteria	SSRBL						Units	Result	Q	Result	Q	Result	Q	Result	Q		
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30	U	<0.30	U	<0.30	U	<0.30	U	
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L	<0.50	U	<0.50	U	0.27	J	<0.50	U	
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L	<0.30	U	<0.30	U	<0.30	U	<0.30	U	
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L	<0.30	U	<0.30	U	<0.30	U	<0.30	U	
TPH-g	300	–	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L	<18.0	U	<18.0	U	55	<18.0	U	<18.0	U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	270	J	220	J	3300	360			
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L	<300.0	U	<300.0	U	670	<300.0	U		
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	170	BJ	200	BJ	470	B	530	B	
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<300.0	UB	180	BJ	250	BJ	200	BJ	
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L	<0.10	U	0.10	J	25	<0.10	U		
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L	<0.10	U	<0.10	U	23	<0.10	U		
Naphthalene	17	–	<0.10	0.19	32	98	<0.025	<0.10	ug/L	<0.10	U	<0.10	U	49	<0.10	U		

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen

⁴ - Bailer method – sample without purging and from the top of the water column

J - estimated value

U - nondetect value

B - the analyte was found in the method blank, as well as in the sample

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #		97741		97741		97741		97741		97717		97741	
		Sample ID		ERH1753		ERH1754		ERH1755		ERH1756		ERH1757		ERH1760	
		Collected		9/29/2021		9/29/2021		9/29/2021		9/29/2021		9/29/2021		9/29/2021	
		Sampling Method ^{3, 4}		Bailer		Bailer		Bailer		Bailer		Low-Flow		–	
Preliminary results provided (final results pending)		Sample Type		Primary		Primary		Primary		Primary		Primary		Trip Blank	
Final results provided (validation pending)		Location		RHMW01R		RHMW02		RHMW03		RHMW05		RHMW2254-01		RHMW01R, 02, 03, 05	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L					<0.30 U	
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L					<0.50 U	
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L					<0.30 U	
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L					<0.30 U	
TPH-g	300	–	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L					<18.0 U	
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L					<300.0 U	
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L					<300.0 U	
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L					180 BJ	
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L					160 BJ	
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L					<0.10 U	
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L					<0.10 U	
Naphthalene	17	–	<0.10	0.19	32	98	<0.025	<0.10	ug/L					<0.10 U	
Total Organic Carbon	–	–	450	970	3000	4400	1290	1800	ug/L					<350 U	

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

B - the analyte was found in the method blank, as well as in the sample

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"–" - not applicable

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
2.c. Monitoring Wells: RHMW01R, RHMW02, RHMW03 - Groundwater Sampling
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #							97850	97850	97850	97850	97833	97850	97850	97850	97850	97833
		Sample ID							ERH1803	ERH1806	ERH1809	ERH1812	ERH1815	ERH1802	ERH1805	ERH1808	ERH1811	ERH1814
		Collected							10/13/2021	10/13/2021	10/13/2021	10/13/2021	10/13/2021	10/13/2021	10/13/2021	10/13/2021	10/13/2021	10/13/2021
		Sampling Method 1,2							Bailer	Bailer	Bailer	Bailer	Low-Flow	–	–	–	–	–
		Sample Type							Primary	Primary	Primary	Primary	Primary	Trip Blank	Trip Blank	Trip Blank	Trip Blank	Trip Blank
		Location							RHMW01R	RHMW02	RHMW03	RHMW05	RHMW2254-01	RHMW01R	RHMW02	RHMW03	RHMW05	RHMW2254-01
Preliminary results provided (final results pending)		Final results provided (validation pending)																
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q
Benzene	5	750	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L					<0.30 U				<0.30 U
Ethylbenzene	30	–	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	ug/L					<0.50 U				<0.50 U
Toluene	40	–	<0.30	<0.30	<0.30	<0.30	<0.30	<0.30	ug/L					<0.30 U				<0.30 U
Xylenes (Total)	20	–	<0.30	<0.30	<0.30	0.37	<0.30	<0.30	ug/L					<0.30 U				<0.30 U
TPH-g	300	–	<18.0	<18.0	<18.0	95	<18.0	<18.0	ug/L					<18.0 U				<18.0 U
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L					<300.0 U				–
TPH-d w/ Silica Gel Cleanup	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L					<300.0 U				–
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L					<300.0 U				–
TPH-o w/ Silica Gel Cleanup	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L					<300.0 U				–
1-Methylnaphthalene	10	–	<0.025	<0.10	8.7	52	<0.025	<0.10	ug/L					<0.10 U				–
2-Methylnaphthalene	10	–	<0.025	<0.10	7.2	51	<0.025	<0.10	ug/L					<0.10 U				–
Naphthalene	17	–	<0.10	0.19	32	98	<0.025	<0.10	ug/L					<0.10 U				–
Total Organic Carbon	–	–	450	970	3000	4400	1290	1800	ug/L					17600				–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.
- Bailer method – sample without purging and from the top of the water column.

J - estimated value
U - nondetect value
ID - identification
TPH-g - total petroleum hydrocarbons gasoline
TPH-d - total petroleum hydrocarbons diesel (JP-5)
TPH-o - total petroleum hydrocarbons oil/grease
"- " - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Drinking Water Sampling - RHMW2254-01 Pre-Chlorination
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Drinking Water Sampling Event		SDG #		96439	96439	96537	96537	96623	96623	96682	96682
		Sample ID		ERH1430	ERH1429	ERH1432	ERH1431	ERH1446	ERH1445	ERH1454	ERH1453
		Collected		6/3/2021	6/3/2021	6/10/2021	6/10/2021	6/17/2021	6/17/2021	6/24/2021	6/24/2021
Final results provided (validation completed)		Sample Type		Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank
		Location		RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF
Analyte	Screening Criteria	SSRBL	Units	Result Q	Results Q	Result Q	Results Q	Result Q	Results Q	Result Q	Results Q
Benzene	5	750	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	—	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	—	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	—	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	—	ug/L	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	ug/L	<300.0 U	—	<300.0 U	—	<300.0 U	—	<300.0 U	—
TPH-d w/ Silica Gel Cleanup	—	—	ug/L	<300.0 U	—	—	—	<300.0 U	—	<300.0 U	—
TPH-o	500	—	ug/L	<300.0 U	—	<300.0 U	—	<300.0 U	—	<300.0 U	—
TPH-o w/ Silica Gel Cleanup	—	—	ug/L	<300.0 U	—	—	—	<300.0 U	—	<300.0 U	—
1-Methylnaphthalene	10	—	ug/L	<0.10 U	—	<0.10 UJ	—	<0.10 U	—	<0.10 U	—
2-Methylnaphthalene	10	—	ug/L	<0.10 U	—	<0.10 UJ	—	<0.10 U	—	<0.10 U	—
Naphthalene	17	—	ug/L	<0.10 U	—	<0.10 UJ	—	<0.10 U	—	<0.10 U	—

Notes:
 J - estimated value
 U - nondetect value
 ID - identification
 TPH-g - total petroleum hydrocarbons gasoline
 TPH-d - total petroleum hydrocarbons diesel (JP-5)
 TPH-o - total petroleum hydrocarbons oil/grease
 "—" - not applicable
 RHSF - Drinking water samples collected from an operating pump, each equipped with a tap or spigot for sampling.

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Drinking Water Sampling - RHMW2254-01 Pre-Chlorination
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Drinking Water Sampling Event		SDG #		96714	96714	96778	96778	96846	96846	96919	96919	97004	97004
		Sample ID		ERH1462	ERH1461	ERH1470	ERH1469	ERH1539	ERH1538	ERH1547	ERH1546	ERH1555	ERH1554
		Collected		7/1/2021	7/1/2021	7/8/2021	7/8/2021	7/15/2021	7/15/2021	7/22/2021	7/22/2021	7/29/2021	7/29/2021
Final results provided (validation pending)		Sample Type		Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank
Final results provided (validation completed)		Location		RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF
Analyte	Screening Criteria	SSRBL	Units	Result Q	Results Q	Result Q	Results Q	Result Q	Results Q	Result Q	Results Q	Result Q	Results Q
Benzene	5	750	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U			<0.30 U	<0.30 U
Ethylbenzene	30	–	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U			<0.50 U	<0.50 U
Toluene	40	–	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U			<0.30 U	<0.30 U
Xylenes (Total)	20	–	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U			<0.30 U	<0.30 U
TPH-g	300	–	ug/L	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U			<18.0 U	<18.0 U
TPH-d	400	4500	ug/L	<300.0 U	–	<300.0 U	–	<300.0 U	–			<300.0 U	–
TPH-d w/ Silica Gel Cleanup	–	–	ug/L	<300.0 U	–	<300.0 U	–	<300.0 U	–			<300.0 U	–
TPH-o	500	–	ug/L	<300.0 U	–	370	–	480	–			230 J	–
TPH-o w/ Silica Gel Cleanup	–	–	ug/L	<300.0 U	–	<300.0 U	–	<300.0 U	–			200 J	–
1-Methylnaphthalene	10	–	ug/L	<0.10 U	–	<0.10 U	–	<0.10 U *	–			<0.10 U	–
2-Methylnaphthalene	10	–	ug/L	<0.10 U	–	<0.10 U	–	<0.10 U *	–			<0.10 U	–
Naphthalene	17	–	ug/L	<0.10 U	–	<0.10 U	–	<0.10 U *	–			<0.10 U	–

Notes:
 J - estimated value
 U - nondetect value
 ID - identification
 TPH-g - total petroleum hydrocarbons gasoline
 TPH-d - total petroleum hydrocarbons diesel (JP-5)
 TPH-o - total petroleum hydrocarbons oil/grease
 "–" - not applicable
 RHSF - Drinking water samples collected from an operating pump, each equipped with a tap or spigot for sampling.

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Drinking Water Sampling - RHMW2254-01 Pre-Chlorination
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event				SDG #		97057	97057	97159	97159	97221	97221	97307	97307
				Sample ID		ERH1582	ERH1581	ERH1590	ERH1589	ERH1598	ERH1597	ERH1623	ERH1622
				Collected		8/5/2021	8/5/2021	8/12/2021	8/12/2021	8/19/2021	8/19/2021	8/26/2021	8/26/2021
Final results provided (validation pending)				Sample Type		Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank
				Location		RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF
Analyte		Screening Criteria	SSRBL	Units	Result Q	Results Q	Result Q	Results Q	Result Q	Results Q	Result Q	Results Q	
Benzene		5	750	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
Ethylbenzene		30	–	ug/L	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	
Toluene		40	–	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
Xylenes (Total)		20	–	ug/L	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	
TPH-g		300	–	ug/L	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	
TPH-d		400	4500	ug/L	<300.0 U	–	<300.0 U	–	<300.0 U	–	<300.0 U	–	
TPH-d w/ Silica Gel Cleanup ¹		–	–	ug/L	<300.0 U	–	<300.0 U	–	<300.0 U	–	<300.0 U	–	
TPH-o		500	–	ug/L	540 ²	–	480	–	320	–	530 ²	–	
TPH-o w/ Silica Gel Cleanup ¹		–	–	ug/L	<300.0 U	–	<300.0	–	<300.0 U	–	<300.0 U	–	
1-Methylnaphthalene		10	–	ug/L	<0.10 U	–	<0.10 U	–	<0.10 U	–	<0.10 U	–	
2-Methylnaphthalene		10	–	ug/L	<0.10 U	–	<0.10 U	–	<0.10 U	–	<0.10 U	–	
Naphthalene		17	–	ug/L	<0.10 U	–	<0.10 U	–	<0.10 U	–	<0.10 U	–	

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

J - estimated value

U - nondetect value

ID - identification

TPH-g - total petroleum hydrocarbons gasoline

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

RHSF - Drinking water samples collected from an operating pump, each equipped with a tap or spigot for sampling.

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Drinking Water Sampling - RHMW2254-01 Pre-Chlorination
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #		97378	97378	97466	97466	97541	97541	97642	97642	97717	97717	97717
		Sample ID		ERH1646	ERH1645	ERH1659	ERH1658	ERH1668	ERH1667	ERH1677	ERH1676	ERH1758	ERH1759	ERH1761
		Collected		9/1/2021	9/1/2021	9/8/2021	9/8/2021	9/15/2021	9/15/2021	9/22/2021	9/22/2021	9/29/2021	9/29/2021	9/29/2021
Final results provided (validation pending)		Sample Type		Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank	Primary	Trip Blank	Primary	Field Duplicate	Trip Blank
Final results provided (validation completed)		Location		RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF	RHSF, RHMW2254-01
Analyte	Screening Criteria	SSRBL	Units	Result Q	Results Q	Result Q	Results Q	Results Q	Results Q	Results Q	Results Q	Results Q	Results Q	Results Q
Benzene	5	750	ug/L	<0.30 U	<0.30 U			<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Ethylbenzene	30	—	ug/L	<0.50 U	<0.50 U			<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U	<0.50 U
Toluene	40	—	ug/L	<0.30 U	<0.30 U			<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
Xylenes (Total)	20	—	ug/L	<0.30 U	<0.30 U			<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U	<0.30 U
TPH-g	300	—	ug/L	<0.18 U	<0.18 U			<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U	<18.0 U
TPH-d	400	4500	ug/L	<300.0 U	—			<300.0 U	—	<300.0 U	—	<300.0 U	<300.0 U	—
TPH-d w/ Silica Gel Cleanup	—	—	ug/L	<300.0	—			<300.0 U	—	<300.0 U	—	<300.0 U	<300.0 U	—
TPH-o	500	—	ug/L	480	—			270 BJ	—	490 B	—	170 BJ	170 BJ	—
TPH-o w/ Silica Gel Cleanup	—	—	ug/L	170 J	—			370 B	—	280 BJ	—	160 BJ	<300.0 U	—
1-Methylnaphthalene	10	—	ug/L	<0.10 U	—			<0.10 U	—	<0.10 U	—	<0.10 U	<0.10 U	—
2-Methylnaphthalene	10	—	ug/L	<0.10 U	—			<0.10 U	—	<0.10 U	—	<0.10 U	<0.10 U	—
Naphthalene	17	—	ug/L	<0.10 U	—			<0.10 U	—	<0.10 U	—	<0.10 U	<0.10 U	—
Total Organic Carbon	—	—	ug/L	—	—			—	—	—	—	<350 U	—	—

Notes:
 J - estimated value
 U - nondetect value
 B - the analyte was found in the method blank, as well as in the sample
 ID - identification
 TPH-g - total petroleum hydrocarbons gasoline
 TPH-d - total petroleum hydrocarbons diesel (JP-5)
 TPH-o - total petroleum hydrocarbons oil/grease
 "—" - not applicable
 RHSF - Drinking water samples collected from an operating pump, each equipped with a tap or spigot for sampling.

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Drinking Water Sampling - RHMW2254-01 Pre-Chlorination
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #		97783	97783	97783	97833	97833	97833				
		Sample ID		ERH1798	ERH1800	ERH1797	ERH1818	ERH1820	ERH1817				
		Collected		10/6/2021	10/6/2021	10/6/2021	10/13/2021	10/13/2021	10/13/2021				
Final results provided (validation pending)		Sample Type		Primary	Field Duplicate	Trip Blank	Primary	Field Duplicate	Trip Blank				
Final results provided (validation completed)		Location		RHSF	RHSF	RHSF	RHSF	RHSF	RHSF				
Analyte	Screening Criteria	SSRBL	Units	Result Q	Result Q	Results Q	Result Q	Result Q	Results Q				
Benzene	5	750	ug/L				<0.30 U	<0.30 U	<0.30 U				
Ethylbenzene	30	—	ug/L				<0.50 U	<0.50 U	<0.50 U				
Toluene	40	—	ug/L				<0.30 U	<0.30 U	<0.30 U				
Xylenes (Total)	20	—	ug/L				<0.30 U	<0.30 U	<0.30 U				
TPH-g	300	—	ug/L				<18.0 U	<18.0 U	<18.0 U				
TPH-d	400	4500	ug/L				<300.0 U	<300.0 U	—				
TPH-d w/ Silica Gel Cleanup	—	—	ug/L				<300.0 U	<300.0 U	—				
TPH-o	500	—	ug/L				<300.0 U	<300.0 U	—				
TPH-o w/ Silica Gel Cleanup	—	—	ug/L				<300.0 U	<300.0 U	—				
1-Methylnaphthalene	10	—	ug/L				<0.10 U	<0.10 U	—				
2-Methylnaphthalene	10	—	ug/L				<0.10 U	<0.10 U	—				
Naphthalene	17	—	ug/L				<0.10 U	<0.10 U	—				
Total Organic Carbon	—	—	ug/L				17300	—	—				

Notes:
 J - estimated value
 U - nondetect value
 B - the analyte was found in the method blank, as well as in the sample
 ID - identification
 TPH-g - total petroleum hydrocarbons gasoline
 TPH-d - total petroleum hydrocarbons diesel (JP-5)
 TPH-o - total petroleum hydrocarbons oil/grease
 "—" - not applicable
 RHSF - Drinking water samples collected from an operating pump, each equipped with a tap or spigot for sampling.

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Additional Sampling: Drinking Water
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #		B21092272	B21092273	B21092273	B21092370	B21092370	B21100022	B21100022	B21092660	B21100147	B21100147	B21100126
		Sample ID		ERH1677	ERH1745	ERH1746	ERH1747	ERH1748	ERH1749	ERH1750	ERH1751	ERH1758	ERH1759	ERH1775
		Collected		9/22/2021	9/23/2021	9/23/2021	9/24/2021	9/25/2021	9/26/2021	9/27/2021	9/28/2021	9/29/2021	9/29/2021	9/30/2021
Final results provided (validation pending)		Sample Type		Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary	Duplicate	Primary
Final results provided (validation completed)		Location		RHSF pre-chlorination	RHSF pre-chlorination	RHSF post-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination
Analyte	Screening Criteria	SSRBL	Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q
TPH-d	400	4500	ug/L	<150 U	<140 U	<150 U	<140 U	<150 U	<140 U	<140 U	<140 U	<140 U	<140 U	<140 U
TPH-d w/ Silica Gel Cleanup	—	—	ug/L	—	—	<120 U	—	—	<110 U	<110 U	—	—	—	—
TPH-o	500	—	ug/L	<150 U	<140 U	<150 U	<140 U	<150 U	<140 U	<140 U	<140 U	<140 U	<140 U	<140 U
TPH-o w/ Silica Gel Cleanup	—	—	ug/L	—	—	<150 U	—	—	<140 U	<140 U	—	—	—	—

Notes:
 U - nondetect value
 ID - identification
 TPH-d - total petroleum hydrocarbons diesel (JP-5)
 TPH-o - total petroleum hydrocarbons oil/grease
 "—" - not applicable
 RHSF - Drinking water samples collected from an operating pump, each equipped with a tap or spigot for sampling.

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
Additional Sampling: Drinking Water
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #	B21100171	B21100756	B21100824	B21100827	B21100828	B21100828	B21100806	B21100806	B21101306	B21101306	B21101919	B21101919
		Sample ID	ERH1776	ERH1777	ERH1778	ERH1779	ERH1780	ERH1781	ERH1799	ERH1801	ERH1819	ERH1821	ERH1840	ERH1842
		Collected	10/1/2021	10/2/2021	10/3/2021	10/4/2021	10/5/2021	10/5/2021	10/6/2021	10/6/2021	10/13/2021	10/13/2021	10/20/2021	10/20/2021
Final results provided (validation pending)		Sample Type	Primary	Primary	Primary	Primary	Primary	Field Duplicate	Primary	Field Duplicate	Primary	Field Duplicate	Primary	Field Duplicate
Final results provided (validation completed)		Location	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination	RHSF pre-chlorination
Analyte	Screening Criteria	SSRBL	Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q
TPH-d	400	4500	ug/L	<140 U	<140 U	<140 U	<140 U	<140 U	<140 U	<140 U	<140 U	<140	<150	<150 U
TPH-d w/ Silica Gel Cleanup	-	-	ug/L	-	-	-	-	-	-	-	-	-	-	-
TPH-o	500	-	ug/L	<140 U	<140 U	<140 U	<140 U	100 J	<140 U	<140 U	<140 U	<140	<150	<150 U
TPH-o w/ Silica Gel Cleanup	-	-	ug/L	-	-	-	-	-	-	-	-	-	-	-

Notes:
U - nondetect value
ID - identification
TPH-d - total petroleum hydrocarbons diesel (JP-5)
TPH-o - total petroleum hydrocarbons oil/grease
"-"- not applicable
RHSF - Drinking water samples collected from an operating pump, each equipped with a tap or spigot for sampling.

Red Hill Bulk Fuel Storage Facility
Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
Additional Sampling: Groundwater - In-tunnel Wells
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #							B21092272	B21092272	B21092272	B21100125	B21100125	B21100125	B21100125	B21100147	
		Sample ID							ERH1671	ERH1673	ERH1675	ERH1753	ERH1754	ERH1755	ERH1756	ERH1757	
		Collected							9/22/2021	9/22/2021	9/22/2021	9/29/2021	9/29/2021	9/29/2021	9/29/2021	9/29/2021	
		Sampling Method ^{3, 4}							Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Low-Flow	
Preliminary results provided (final results pending)		Sample Type							Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary	
Final results provided (validation pending)		Location							RHMW01R	RHMW02	RHMW03	RHMW01R	RHMW02	RHMW03	RHMW05	RHMW2254-01	
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	260 J	2700	160 J	390	2400	220 J	50 J	<140 U
TPH-d w/ Silica Gel Cleanup ¹	—	—	<300.0	67	260	690	<25.0	<300.0	ug/L	51 J	510	<130 U	80 J	580	<120 U	<120 U	-
TPH-o	500	—	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	220 J	380	320	140 J	380	720 ²	<150 U	<140 U
TPH-o w/ Silica Gel Cleanup ¹	—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<140 U	<160 U	<160 U	<150 U	<140 U	<150 U	<150 U	-

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value
U - nondetect value
ID - identification
TPH-d - total petroleum hydrocarbons diesel (JP-5)
TPH-o - total petroleum hydrocarbons oil/grease
"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Additional Sampling: Groundwater - Exterior Wells
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event			SDG #		B21100166_977 48	B21100166_977 48	B21100166_977 48	B21100166_977 48	B21100166_977 48	B21100166_977 48	B21100166_977 48	B21100827	B21100827	B21100834_977 69	B21100834	B21100834	
			Sample ID		ERH1762	ERH1763	ERH1764	ERH1765	ERH1766	ERH1768	ERH1769	ERH1770	ERH1767	ERH1772	ERH1771	ERH1773	ERH1774
			Collected		10/1/2021	10/1/2021	9/30/2021	9/30/2021	9/30/2021	10/1/2021	9/30/2021	10/1/2021	10/4/2021	10/4/2021	10/5/2021	10/5/2021	10/5/2021
			Sampling Method ^{3,4}		Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Bailer	Westbay-packers	Westbay-packers
Preliminary results provided (final results pending)			Sample Type		Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary	Field Duplicate	Primary	Field Blank	Equipment Blank	
Final results provided (validation pending)			Location		RHMW04	RHMW06	RHMW08	RHMW09	RHMW10	RHMW16	RHMW19	OWDFMW01	RHMW12A	RHMW12A	RHMW14-03	RHMW14-03	RHMW14-03
Analyte	Screening Criteria																
		SSRBL	Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q
TPH-d	400	4500	ug/L	47 J	<150 U	<150 U	<140 U	<140 U	73 J	82 J	420	220 J	230 J	<150 U	<140 U	<140 U	
TPH-d w/ Silica Gel Cleanup [†]	—	—	ug/L	<120 U	<120 U	<120 U	<120 U	<120 U	<120 U	<120 U	<110 U	< 110 U	< 110 U	—	—	—	
TPH-o	500	—	ug/L	170 J	150 J	<150 U	<140 U	140 J	320	380	240	170 J	160 J	<150 U	<140 U	<140 U	
TPH-o w/ Silica Gel Cleanup [†]	—	—	ug/L	<150 U	<150 U	<150 U	<140 U	<140 U	<140 U	<150 U	<140 U	<140 U	<140 U	—	—	—	
Total Organic Carbon	—	—	ug/L	2,100	430 J	420 J	220 J	720 J	210 J	580 J	1800	5300	—	200 J	—	—	

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method -- sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method -- sample without purging and from the top of the water column.

J - estimated value
 U - nondetect value
 ID - identification
 TPH-d - total petroleum hydrocarbons diesel (JP-5)
 TPH-o - total petroleum hydrocarbons oil/grease
 "—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Additional Sampling: Groundwater - In-tunnel Wells
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event				SDG #						B21100806	B21100806	B21100806	B21100806	B21100806	B21101306	B21101306	B21101306	B21101306	B21101306
				Sample ID						ERH1784	ERH1787	ERH1790	ERH1793	ERH1796	ERH1804	ERH1807	ERH1810	ERH1813	ERH1816
				Collected						10/6/2021	10/6/2021	10/6/2021	10/6/2021	10/6/2021	10/13/2021	10/13/2021	10/13/2021	10/13/2021	10/13/2021
				Sampling Method ^{3,4}						Bailer	Bailer	Bailer	Bailer	Low-Flow	Bailer	Bailer	Bailer	Bailer	Low-Flow
Preliminary results provided (final results pending)				Sample Type						Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary
Final results provided (validation pending)				Location						RHMW01R	RHMW02	RHMW03	RHMW05	RHMW2254-01	RHMW01R	RHMW02	RHMW03	RHMW05	RHMW2254-01
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	490	3100	180 J	56 J	<140 U	420	3500	120 J	59 J	<140 U
TPH-d w/ Silica Gel Cleanup ¹	–	–	<300.0	67	260	690	<25.0	<300.0	ug/L	120 J	750	<140 U	<140 U	<140 U	<120 U	580	<120 U	<120 U	–
TPH-o	500	–	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	180 J	380	570 ²	87 J	170 J	190 J	430	330	110 J	<140 U
TPH-o w/ Silica Gel Cleanup ¹	–	–	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<140 U	<140 U	<140 U	<140 U	<140 U	<150 U	<140 U	<150 U	<150 U	–

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

ID - identification

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable

Red Hill Bulk Fuel Storage Facility
 Notice of Interest 20210507-0852 JP-5 spill that occurred on 6 May 2021
 Additional Sampling: Groundwater - In-tunnel Wells
DISCLAIMER: Preliminary Data: Undergoing Validation - Subject to Change.

2021 NOI Emergency Groundwater Sampling Event		SDG #								B21101919	B21101919	B21101919	B21101919	B21101919	B2110057	B2110057	B2110057	B2110057	B2110057
		Sample ID								ERH1834	ERH1828	ERH1831	ERH1825	ERH1837	ERH1845	ERH1848	ERH1851	ERH1854	ERH1857
		Collected								10/20/2021	10/20/2021	10/20/2021	10/20/2021	10/20/2021	10/27/2021	10/27/2021	10/27/2021	10/27/2021	10/26/2021
		Sampling Method ^{3,4}								Bailer	Bailer	Bailer	Bailer	Low-Flow	Bailer	Bailer	Bailer	Bailer	Low-Flow
Preliminary results provided (final results pending)		Sample Type								Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary	Primary
Final results provided (validation pending)		Location								RHMW01R	RHMW02	RHMW03	RHMW05	RHMW2254-01	RHMW01R	RHMW02	RHMW03	RHMW05	RHMW2254-01
Analyte	Screening Criteria	SSRBL	RHMW01 2018-2021 Historical Ranges (min/max)		RHMW02 2018-2021 Historical Ranges (min/max)		RHMW03 2018-2021 Historical Ranges (min/max)		Units	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q	Result Q
TPH-d	400	4500	<300.0	350	1500	2900	150	380	ug/L	670	3000	150 J	91 J	<140 U					
TPH-d w/ Silica Gel Cleanup ¹	—	—	<300.0	67	260	690	<25.0	<300.0	ug/L	140 J	790	<110 U	<110 U	—					
TPH-o	500	—	<40.0	<300.0	<300.0	330	<300.0	310	ug/L	250 J	300	280 J	pending	<140 U					
TPH-o w/ Silica Gel Cleanup ¹	—	—	<40.0	<300.0	<40.0	<300.0	<40.0	<300.0	ug/L	<140 U	<140 U	<140 U	<140 U	—					

Notes:

¹ - Silica Gel Cleanup is an EPA approved methodology (SW-846 Method 3630C) that separates fuel related compounds from non-fuel related or naturally-occurring compounds from the sample. When these non-fuel related compounds are reported in the sample results, the reported value is skewed high.

² - After the application of Silica Gel Cleanup, TPH-o levels are below the screening criteria (EAL). TPH-o detects heavy oils and greases. JP-5 is not a heavy oil or grease. DOH does not have a screening criteria (EAL) for silica gel cleanup.

³ - Low-flow method – sample with bladder pump, after purging and from approximately mid-screen.

⁴ - Bailer method – sample without purging and from the top of the water column.

J - estimated value

U - nondetect value

ID - identification

TPH-d - total petroleum hydrocarbons diesel (JP-5)

TPH-o - total petroleum hydrocarbons oil/grease

"—" - not applicable