

Exhibit D12

Tank	April 24, 2017 ¹		September 2021 ² (estimated)		Last Inspection Date ³	Estimated Years Since Last Inspection
	Start	Finish	Start	Finish		
1	empty		empty		NA	NA
2	3/7/2024	10/14/2026	2028	2031	2008	13
3	2/4/2019	9/10/2021	2026	2028	1983	38
4	5/12/2016	1/3/2020	2022	2025	1983	38
5	8/1/2016	6/22/2018	2017	2020	2020	1
6	3/7/2024	10/14/2026	2031	2033	2006	15
7	6/30/2022	2/5/2025	2030	2032	1998	23
8	10/22/2020	5/31/2023	2028	2030	1998	23
9	10/22/2020	5/31/2023	2028	2030	1995	26
10	6/30/2022	2/5/2025	2030	2032	1998	23
11	2/14/2019	9/22/2021	2025	2027	1981	40
12	2/14/2019	9/22/2021	2025	2027	1995	26
13	5/12/2016	9/26/2018	2017	2022	1995	22
14	5/12/2016	6/20/2018	2017	2023	1982	35
15	6/30/2022	2/5/2025	2023	2026	2005	16
16	6/30/2022	10/14/2026	2026	2028	2006	15
17	5/12/2016	9/27/2018	2017	2021	2012	5
18	5/12/2016	1/15/2020	2020	2024	1960	60
19	empty		empty		NA	NA
20	11/13/2025	6/21/2028	2032	2035	2008	13
empty, under maintenance						
Tanks that have not been inspected for over 20 years and are currently active						

¹ Naval Facilities Engineering Command, *Red Hill Facility, Tank Inspection, Repair, and Maintenance Procedure Decision Document*, dated April 24, 2017 (pg 19-6)

² Navy Region Hawaii, *Supplement to Red Hill Bulk Fuel Storage Facility Administrative Order on Consent Tank Upgrade Alternatives and Release Detection Decision Document*, August 2021 (pg 84)

³ Naval Facilities Engineering Command, *Red Hill Facility, Tank Inspection, Repair, and Maintenance Report*, October 11, 2016 (pg 19-8)