

Non-Validated GW PFAS Summary Prelim_Not in EDMS

1/4/2023

					AF-HDMW225303-WGN01B-2212W2	AF-RHMW02-WGN01LF-2212W2	AF-RHMW03-WGN01LF-2212W2	AF-RHMW17-WGN01LF-2212W1						
					22L0083-01	22L0083-03	22L0083-02	22L0057-03						
					12-Dec	12-Dec	12-Dec	7-Dec						
Method	Analyte	Cas Rn	Tapwater RSL	DOH EALs	Units	Result	Qualifier	Result	Qualifier	Result	Qualifier	Result	Qualifier	
EPA 1633	11CL-PF3OUDS	763051-92-9	—	—	ng/L	4.1	U	0.34	U	0.35	U	0.34	U	
	3:3FTCA	113507-82-7	—	—	ng/L	8.2	U	0.68	U	0.7	U	0.69	U	
	4:2FTS	757124-72-4	—	—	ng/L	8.2	U	0.68	U	0.7	U	0.69	U	
	5:3FTCA	914637-49-3	—	—	ng/L	8.2	U	0.68	U	0.7	U	0.69	IR2, U	
	6:2FTS	27619-97-2	—	—	ng/L	7.1	J	2.1		5.2		13		
	7:3FTCA	812-70-4	—	—	ng/L	8.2	U	0.68	U	0.7	U	0.69	U	
	8:2FTS	39108-34-4	—	—	ng/L	8.2	U	0.68	U	0.7	U	0.69	U	
	9CL-PF3ONS	756426-58-1	—	—	ng/L	4.1	U	0.34	U	0.35	U	0.34	U	
	ADONA	919005-14-4	—	—	ng/L	4.1	U	0.34	U	0.35	U	0.34	U	
	HFPO-DA	13252-13-6		6	160	ng/L	4.1	U	0.34	U	0.35	U	0.34	U
	NEtFOSA	4151-50-2	—	—	ng/L	8.2	U	0.68	U	0.7	U	0.69	U	
	NEtFOSAA	2991-50-6	—	—	ng/L	2	U	0.17	U	0.17	U	0.17	U	
	NEtFOSE	1691-99-2	—	—	ng/L	12	U	1	U	1	U	1	U	
	NFDHA	151772-58-6	—	—	ng/L	4.1	U	0.34	U	0.35	U	0.34	U	
	NMeFOSA	31506-32-8	—	—	ng/L	8.2	U	0.68	U	0.7	U	0.69	U	
	NMeFOSAA	2355-31-9	—	—	ng/L	2	U	0.17	U	0.17	U	0.17	U	
	NMeFOSE	24448-09-7	—	—	ng/L	12	U	1	U	1	U	1	U	
	PFBA	375-22-4	—		7600	ng/L	8.2	U	0.68	U	2.8		4.6	
	PFBS	375-73-5		601	600	ng/L	2	U	0.17	U	0.17	U	0.19	J
	PFDA	335-76-2	—		4	ng/L	2	U	0.17	U	0.16	J	0.17	U
	PFDOA	307-55-1	—		13	ng/L	2	U	0.17	U	0.17	U	0.17	U
	PFDOS	79780-39-5	—	—		ng/L	2	U	0.17	U	0.17	U	0.17	U
	PFDS	335-77-3	—		20	ng/L	2	U	0.17	U	0.17	U	0.17	U
	PFEESA	113507-82-7	—	—		ng/L	4.1	U	0.34	U	0.35	U	0.34	U
	PFHPA	375-85-9	—		40	ng/L	2	U	0.16	IR1, J	0.87		0.98	
	PFHPS	375-92-8	—		20	ng/L	2	U	0.17	U	0.17	U	0.17	U
	PFHXA	307-24-4	—		4000	ng/L	2	U	0.21	J	1.5		2.9	
	PFHXS	355-46-4		39	19	ng/L	0.65	J	0.17	U	0.067	J	0.053	MI5, J
	PFMBA	863090-89-5	—	—		ng/L	4.1	U	0.34	U	0.35	U	0.34	U
	PFMPA	377-73-1	—	—		ng/L	4.1	U	0.34	U	0.35	U	0.34	U
	PFNA	375-95-1		6	4	ng/L	2	U	0.17	U	0.17	J	0.17	U
	PFNS	68259-12-1	—	—		ng/L	2	U	0.17	U	0.17	U	0.17	U
	PFOA	335-67-1		6	40	ng/L	1.7	J	0.17	U	0.3	J	0.23	J
	PFOS	1763-23-1		4	40	ng/L	0.66	J	0.18	J	0.13	IR2, J	0.096	MI5, J
	PFOSA	754-91-6	—		24	ng/L	2	U	0.17	U	0.17	U	0.72	
	PFPEA	2706-90-3	—		800	ng/L	4.1	U	0.48	J	3.8		7.6	
	PFPEES	630402-22-1	—	—		ng/L	2	U	0.17	U	0.17	U	0.17	U
	PFTEDA	376-06-7	—		130	ng/L	2	U	0.17	U	0.17	U	0.17	U
	PFTRDA	72629-94-8	—		13	ng/L	3.1	U	0.26	U	0.26	U	0.26	U
	PFUnA	2058-94-8	—		10	ng/L	2	U	0.17	U	0.15	IR2, J	0.17	U

Non-Validated GW PFAS Summary Prelim_Not in EDMS

1/4/2023

					AF-HDMW225303-WGN01LF-2212W3	AF-RHMW10-WGN01LF-2212W3	AF-RHMW12A-WGFD01LF-2212W3	AF-RHMW12A-WGN01LF-2212W3						
					22L0148-01	22L0148-02	22L0160-02	22L0160-01						
					20-Dec	20-Dec	21-Dec	21-Dec						
Method	Analyte	Cas Rn	Tapwater RSL	DOH EALs	Units	Result	Qualifier	Result	Qualifier	Result	Qualifier	Result	Qualifier	
EPA 1633	11CL-PF3OUDS	763051-92-9	—	—	ng/L	0.4	U	0.37	U	0.41	U	0.38	U	
	3:3FTCA	113507-82-7	—	—	ng/L	0.8	U	0.75	U	0.81	U	0.76	U	
	4:2FTS	757124-72-4	—	—	ng/L	0.8	U	0.75	U	0.81	U	0.76	U	
	5:3FTCA	914637-49-3	—	—	ng/L	0.8	U	0.75	U	0.81	U	0.76	U	
	6:2FTS	27619-97-2	—	—	ng/L	0.8	U	0.75	U	0.51	J	2.3		
	7:3FTCA	812-70-4	—	—	ng/L	0.8	U	0.75	U	0.81	U	0.76	U	
	8:2FTS	39108-34-4	—	—	ng/L	0.8	U	0.75	U	0.81	U	0.76	U	
	9CL-PF3ONS	756426-58-1	—	—	ng/L	0.4	U	0.37	U	0.41	U	0.38	U	
	ADONA	919005-14-4	—	—	ng/L	0.4	U	0.37	U	0.41	U	0.38	U	
	HFPO-DA	13252-13-6		6	160	ng/L	0.4	U	0.37	U	0.41	U	0.38	U
	NEtFOSA	4151-50-2	—	—	ng/L	0.8	U	0.75	U	0.81	U	0.76	U	
	NEtFOSAA	2991-50-6	—	—	ng/L	0.2	U	0.19	U	0.2	U	0.19	U	
	NEtFOSE	1691-99-2	—	—	ng/L	1.2	U	1.1	U	1.2	U	1.1	U	
	NFDHA	151772-58-6	—	—	ng/L	0.4	U	0.37	U	0.41	U	0.38	U	
	NMeFOSA	31506-32-8	—	—	ng/L	0.8	U	0.75	U	0.81	U	0.76	U	
	NMeFOSAA	2355-31-9	—	—	ng/L	0.2	U	0.19	U	0.2	U	0.19	U	
	NMeFOSE	24448-09-7	—	—	ng/L	1.2	U	1.1	U	1.2	U	1.1	U	
	PFBA	375-22-4	—		7600	ng/L	0.8	U	0.53	J	2.5	2.7		
	PFBS	375-73-5		601	600	ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFDA	335-76-2	—		4	ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFDOA	307-55-1	—		13	ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFDOS	79780-39-5	—	—		ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFDS	335-77-3	—		20	ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFEESA	113507-82-7	—	—		ng/L	0.4	U	0.37	U	0.41	U	0.38	U
	PFHPA	375-85-9	—		40	ng/L	0.2	U	0.19	U	0.25	J	0.29	J
	PFHPS	375-92-8	—		20	ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFHXA	307-24-4	—		4000	ng/L	0.2	U	0.19	U	1.4	1.3		
	PFHXS	355-46-4		39	19	ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFMBA	863090-89-5	—	—		ng/L	0.4	U	0.37	U	0.41	U	0.38	U
	PFMPA	377-73-1	—	—		ng/L	0.4	U	0.37	U	0.41	U	0.38	U
	PFNA	375-95-1		6	4	ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFNS	68259-12-1	—	—		ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFOA	335-67-1		6	40	ng/L	0.2	U	0.19	IR2, U	0.2	U	0.19	U
	PFOS	1763-23-1		4	40	ng/L	0.2	IR2, U	0.19	IR2, U	0.089	J	0.065	J
	PFOSA	754-91-6	—		24	ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFPEA	2706-90-3	—		800	ng/L	0.4	U	0.13	J	5	5		
	PFPESE	630402-22-1	—	—		ng/L	0.2	U	0.19	U	0.2	U	0.19	U
	PFTEA	376-06-7	—		130	ng/L	0.2	U	0.19	U	0.2	IR2, U	0.19	U
	PFTRDA	72629-94-8	—		13	ng/L	0.3	U	0.28	U	0.31	U	0.28	U
	PFUnA	2058-94-8	—		10	ng/L	0.2	U	0.19	U	0.2	U	0.19	U

Non-Validated GW PFAS Summary Prelim_Not in EDMS

1/4/2023

							AF-RHMW16-WGN01LF-2212W3
							22L0160-03
							21-Dec
Method	Analyte	Cas Rn	Tapwater RSL	DOH EALs	Units	Result	Qualifier
EPA 1633	11CL-PF3OUDS	763051-92-9	—	—	ng/L	0.37	U
	3:3FTCA	113507-82-7	—	—	ng/L	0.75	U
	4:2FTS	757124-72-4	—	—	ng/L	0.75	U
	5:3FTCA	914637-49-3	—	—	ng/L	0.75	U
	6:2FTS	27619-97-2	—	—	ng/L	0.75	U
	7:3FTCA	812-70-4	—	—	ng/L	0.75	U
	8:2FTS	39108-34-4	—	—	ng/L	0.75	U
	9CL-PF3ONS	756426-58-1	—	—	ng/L	0.37	U
	ADONA	919005-14-4	—	—	ng/L	0.37	U
	HFPO-DA	13252-13-6		6 160	ng/L	0.37	U
	NEtFOSA	4151-50-2	—	—	ng/L	0.75	U
	NEtFOSAA	2991-50-6	—	—	ng/L	0.19	U
	NEtFOSE	1691-99-2	—	—	ng/L	1.1	U
	NFDHA	151772-58-6	—	—	ng/L	0.37	U
	NMeFOSA	31506-32-8	—	—	ng/L	0.75	U
	NMeFOSAA	2355-31-9	—	—	ng/L	0.19	U
	NMeFOSE	24448-09-7	—	—	ng/L	1.1	U
	PFBA	375-22-4	—		7600 ng/L	0.75	U
	PFBS	375-73-5		601	600 ng/L	0.19	U
	PFDA	335-76-2	—		4 ng/L	0.19	U
	PFDOA	307-55-1	—		13 ng/L	0.19	U
	PFDOS	79780-39-5	—	—	ng/L	0.19	U
	PFDS	335-77-3	—		20 ng/L	0.19	U
	PFEESA	113507-82-7	—	—	ng/L	0.37	U
	PFHPA	375-85-9	—		40 ng/L	0.19	U
	PFHPS	375-92-8	—		20 ng/L	0.19	U
	PFHXA	307-24-4	—		4000 ng/L	0.19	U
	PFHXS	355-46-4		39	19 ng/L	0.19	U
	PFMBA	863090-89-5	—	—	ng/L	0.37	U
	PFMPA	377-73-1	—	—	ng/L	0.37	U
	PFNA	375-95-1		6	4 ng/L	0.19	U
	PFNS	68259-12-1	—	—	ng/L	0.19	U
	PFOA	335-67-1		6	40 ng/L	0.19	U
	PFOS	1763-23-1		4	40 ng/L	0.19	U
	PFOSA	754-91-6	—		24 ng/L	0.19	U
	PFPEA	2706-90-3	—		800 ng/L	0.37	U
	PFPEs	630402-22-1	—	—	ng/L	0.19	U
	PFTEDA	376-06-7	—		130 ng/L	0.19	U
	PFTRDA	72629-94-8	—		13 ng/L	0.28	U
	PFUnA	2058-94-8	—		10 ng/L	0.19	U