



CONTRACT REPORT
CR-NAVFAC-EXWC-SH-FY22268
AUGUST 2022

FIRE SUPPRESSION ASSESSMENT REPORT

FUEL TRANSFER INFRASTRUCTURE
ASSESSMENT
Red Hill Bulk Fuel Storage Facility, Hawaii
(RHL)

Austin Brookenbrough and Associates, LLC

(b) (6)
[Redacted]

[Redacted] August 2022



This page is intentionally left blank.



REPORT DOCUMENTATION PAGE

1. REPORT DATE 08/29/2022	2. REPORT TYPE Contract Report	3. DATES COVERED	
		START DATE 3/21/2022	END DATE 4/1/2022

4. TITLE AND SUBTITLE

Fire Suppression Assessment Report Red Hill Bulk Fuel Storage Facility

5a. CONTRACT NUMBER N39430-20-D-2242	5b. GRANT NUMBER	5c. PROGRAM ELEMENT NUMBER
--	-------------------------	-----------------------------------

5d. PROJECT NUMBER 22-022	5e. TASK NUMBER N3943022F4333	5f. WORK UNIT NUMBER 1719610
-------------------------------------	---	--

6. AUTHOR(S)

Austin Brockenbrough and Associates, LLC

7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES)

Austin Brockenbrough & Associates, LLC
1011 Boulder Springs Drive, Suite 200
Richmond, Virginia 23225

8. PERFORMING ORGANIZATION REPORT NUMBER

9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) NAVFAC EXWC 1000 23rd Avenue Port Hueneme, CA 93043	10. SPONSOR/MONITOR'S ACRONYM(S) NAVFAC EXWC	11. SPONSOR/MONITOR'S REPORT NUMBER(S) CR-NAVFAC-EXWC-SH-22268
---	--	--

12. DISTRIBUTION/AVAILABILITY STATEMENT
[REDACTED] August 2022

13. SUPPLEMENTARY NOTES

14. ABSTRACT

On November 21, 2021, a fuel spill occurred from AFFF containment drainage piping in the Red Hill Tunnel complex. At the time it was reported this leak occurred from the fire protection system. As a result of this a Statement of Work for Architecture / Engineering (Austin Brockenbrough and Associates) services was instigated to perform an assessment at the Red Hill Bulk Fuel Storage Facility at Joint Base Pearl Harbor Hickam. This work included a comprehensive assessment of the fire protection systems installed in the Red Hill Tunnel.

15. SUBJECT TERMS

Red Hill Fire Suppression System Assessment Bulk Fuel Storage Facility

16. SECURITY CLASSIFICATION OF:

a. REPORT U	b. ABSTRACT U	c. THIS PAGE U	17. LIMITATION OF ABSTRACT SAR	18. NUMBER OF PAGES 273
-----------------------	-------------------------	--------------------------	--	-----------------------------------

19a. NAME OF RESPONSIBLE PERSON

(b) (6)

19b. PHONE NUMBER (include area code)

(b) (6)

This page is intentionally left blank.





FIRE SUPPRESSION ASSESSMENT REPORT

FINAL SUBMITTAL

FUEL TRANSFER INFRASTRUCTURE ASSESSMENT Red Hill Bulk Fuel Storage Facility, Hawaii

Delivery Order No. N3943022F4333
A/E Contract No. N39430-20-D-2242

Submitted to:
NAVFAC EXWC
1000 23rd Avenue,
Port Hueneme, CA 93043-4370

August 28, 2022

Submitted by:


JENSEN HUGHES
4445 Corporation Lane
Virginia Beach, VA, 23455
Phone: 757-213-6856
www.jensenhughes.com
1AJW22016

TABLE OF CONTENTS

Executive Summary	4
Part 1 – Site Assessment and Engineering Evaluation	5
1. Red Hill Site Layout	5
2. Fire Protection Systems Summary	7
A. Class I Standpipe System	7
B. Preaction AFFF/Water Sprinkler System	7
C. Wet-Pipe Sprinkler System	8
D. Water Supply System	8
E. Fire Department Connections	9
F. Fire Pump	9
G. Fire Alarm and Mass Notification System	9
a. Digital Control System	13
b. Smoke Ventilation	14
H. AFFF Retention System	14
I. Ventilation and Smoke Control	15
3. Fire Protection Survey Results	16
A. Condition of Fire Protection Systems and Comparison of Design Versus Installed Conditions	16
a. Standpipe System	16
b. Preaction AFFF/Water Sprinkler System	16
c. Wet Pipe Sprinkler System	17
d. Site Water Supply	17
e. Fire Department Connections	17
f. Fire Pump System	17
g. Fire Alarm and Mass Notification System	18
h. AFFF Retention System	19
B. Fire Protection Systems Recommendations of 2010 Audit Report	20
4. Summary of Fire Protection and Retention System Performance	22
A. May 6, 2021, Fuel Release Incident	22
B. November 21, 2021, Fuel Release Incident	23
5. Maintenance Records Review	24
A. Standpipe System	24
B. Preaction AFFF/Water Sprinkler System	25
C. Nitrogen Generation System	29
D. Wet Pipe Sprinkler System	31
E. Site Water Supply	37
F. Fire Department Connections	39
G. Fire Pump System	40
H. Fire Alarm and Mass Notification System	55
I. AFFF Retention System	92
J. Maintenance Records Summary of Findings	92
Part 2 – Summary of Findings	93
1. Fire Protection Systems	93
2. Retention System	94
3. Fire Protection System Maintenance	94



Part 3 – Recommended Betterments 95
Appendices Table of Contents 96



ACRONYMS

AFFF	Aqueous Film Forming Foam
API	American Petroleum Institute
AUTO	Automatic
DCS	Digital Control System
EXWC	Engineering and Expeditionary Warfare Center
FAMN	Fire Alarm Mass Notification
FA/MIN	Fire Alarm / Mass Notification
FLC	Fleet Logistics Center
FY	Fiscal Year
GPM	Gallons per Minute
IR	Infra-Red
ITM	Inspection, Testing and Maintenance
JP-5	Jet Fuel
Local Operating Console	LOC
NAVFAC	Naval Facilities Engineering Systems Command
NFPA	National Fire Protection Association
RHT	Red Hill Tank
RDC	Regional Dispatch Center
SCBA	Self-Contained Breathing Apparatus
UFC	Unified Facilities Criteria
UGPH	Underground Pump House
UL	Underwriters Laboratory
UT	Upper Tunnel

EXECUTIVE SUMMARY

On November 21, 2021, a fuel spill occurred from AFFF containment drainage piping in the Red Hill Tunnel complex. At the time it was reported this leak occurred from the fire protection system. As a result of this a Statement of Work for Architecture/Engineering services was instigated to perform an assessment at the Red Hill Bulk Fuel Storage Facility at Joint Base Pearl Harbor Hickam. This work included a comprehensive assessment of the fire protection systems installed in the Red Hill Tunnel.

A site assessment of the fire protection systems at Red Hill Bulk Fuel Storage Facility (Red Hill) was undertaken by Jensen Hughes from 21 March – 1 April 2022. The purpose of the assessment was to perform a comprehensive review of each Fire Protection System, documenting the current condition and comparing the installed conditions with the design conditions, to investigate how the active fire protection systems including the retention line and retention tank performed during the events of May 6 and November 21, 2021 and to examine the Inspection, testing and maintenance that has been performed on the fire protection systems and compare it with the requirements of UFC 3-601-02.

The assessment of the fire protection systems revealed that the overall condition of the fire protection systems was very good with most of this equipment having been constructed as part of project FY 15 MILCON P-1551 Upgrade Fire Suppression and Ventilation Systems Red Hill Bulk Fuel Storage Facility, completed in 2018. Several recommendations were made to correct code deficiencies. The apparent unreliability of the Kingfisher Fire Alarm Radio Transmitter was the most critical of these recommendations.

A review of the events of May 6th and November 21, 2021, revealed that fuel was lifted by sump pumps into the AFFF containment piping because of a large spill on May 6th. This action was not intended by the sequence of operations of this system – changes made to the sequence during construction required this system to be interlocked with the fire alarm system – which was not reported to have been operated on May 6th. A manual should be developed that documents the complete sequence of operation of these systems and these systems should be recommissioned to confirm their sequence of operations.

After this assessment was begun the Navy announced that they intend to return the Red Hill Bulk Fuel Storage Facility to operation so that it can be decommissioned as a fuel storage facility. As a result of this recommendations for significant design changes for the AFFF containment drainage system and changes to the fire protection Inspection, Testing and Maintenance program do not appear to be warranted. Similarly, recommendations for betterments for the system are only necessary if the facility is to remain as a fuel storage facility.

PART 1 – SITE ASSESSMENT AND ENGINEERING EVALUATION

A site assessment of the fire protection systems at Red Hill Bulk Fuel Storage Facility (Red Hill) was undertaken by Jensen Hughes from 21 March – 1 April 2022. The purpose of the assessment was to:

1. Perform a comprehensive review of each Fire Protection System, documenting the current condition of the fire protection systems including:
 - a. A general description and summary of each system reviewed.
 - b. Confirmation that the active fire protection systems were installed as designed in project FY 15 P-1551 – Upgrade Fire Suppression and Ventilation Systems, highlighting any variance of installation over designed conditions.
2. Summary of system performance May 6th and Nov 21.
3. Confirm the fire protection systems satisfy the recommendations of the 2010 Audit Report – Department of the Navy Red Hill and Upper Tank Farm Fuel Storage Facilities.
4. Identify pathways for fuel to get into the containment system.
5. Maintenance records review including a maintenance summary of each system versus requirements of UFC 3-601-02.

1. RED HILL SITE LAYOUT

The Red Hill Bulk Fuel Storage facility consists of a series of 20 – 300,000BBL (12.6M gal) underground fuel storage tanks. The 20 fuel tanks are located as 10 pairs of tanks with access tunnels located near the top and bottom of the tanks running between the pairs. The Upper Access Tunnel can be accessed directly via (b) (3) (A) entrances – (b) (3) (A). There are two elevators connecting the Upper and Lower Access Tunnel areas. (b) (3) (A) connects the Upper Access Tunnel to the Lower Access Tunnel, with a stop approximately midway between the Upper and Lower Access Tunnels, at the end of the (b) (3) (A) access tunnel. (b) (3) (A) connects just the Upper and Lower Access Tunnels. The Upper Access Tunnel is provided to access the top of the storage tanks and runs from Tanks 19 and 20 to (b) (3) (A). The Lower Access Tunnel is longer than the Upper Tunnel, it continues beyond Tanks 1 and 2 down the hillside eventually coming to a junction at the water pumping station, where the Harbor Access Tunnel splits off. The Lower Access Tunnel continues from the split to (b) (3) (A). While (b) (3) (A) serves as a discharge point from the Lower Access Tunnel, the Harbor Access Tunnel continues (b) (3) (A) to the Underground Pumphouse and (b) (3) (A) at Pearl Harbor. The Harbor Access Tunnel can also be accessed from (b) (3) (A) via the (b) (3) (A) Tunnel.

An isometric of the tank and tunnel layout can be found on the following page.

2. FIRE PROTECTION SYSTEMS SUMMARY

The fire protection systems installed at Red Hill include the following:

A. Class I Standpipe System

A looped 8-inch sprinkler/standpipe main boosted by the fire pump serves all fire protection systems within the tunnel. These systems include standpipes for Upper and Lower Tunnel, preaction sprinkler for Lower Tunnel and various wet pipe sprinkler systems for Upper Tunnel, elevator shafts and gauger station areas. This 8” loop includes three main legs: 1) An exterior leg routed outside the tunnel from the fire pump house to (b) (3) (A) 2) An interior leg from (b) (3) (A) up (b) (3) (A) shaft, through the Upper Tunnel to (b) (3) (A) and, 3) An interior leg from (b) (3) (A) down (b) (3) (A) shaft through the Lower Tunnel to (b) (3) (A). The fire pump ties to this loop with an 8-inch line from the fire pump house near (b) (3) (A). Fire department inlet connections are provided outside the tunnel connecting to the 8” loop at (b) (3) (A). The standpipe system includes valves and outlets with automatic pressure regulating valves that are UL listed for fire department use. The standpipe outlets are placed at each tank junction and spaced at 200-foot increments designed for 500 gpm hose stream in the Upper Tunnel and 200-foot increments design for 1,000 gpm hose stream in the Lower Tunnel. These design flows comply with NFPA 14 requirements. The standpipe system is provided in the Upper Tunnel from tanks 1 through 20 (not including (b) (3) (A)), and in the Lower Tunnel from the new oil tight door up to the end of the Lower Tunnel at tanks 19 & 20. The standpipe system is supported by an electric fire pump to boost the pressure in the Upper Tunnel to comply with NFPA 14 to provide 100 psi at the outlet of the hydraulically most remote 2 1/2 in. (65 mm) hose connection.

B. Preaction AFFF/Water Sprinkler System

Due to the hazards of (b) (3) (A) fuel lines with fittings, joints, valves, and other appurtenances that transfer fuel from the underground fuel tanks to/from the Pearl Harbor fuel pump house, the Lower Tunnel in the area of the tank farm was defined as an inside liquid storage area per NFPA. NFPA 30 requires inside liquid storage areas to be protected by a foam-water sprinkler system with 15-minute foam capacity. A preaction Aqueous Film Forming Foam (AFFF)/water sprinkler system, satisfying NFPA 16 guidelines, is provided for the Lower Tunnel area serving tanks 1-20. The system is designed for a density of 0.16 gpm per square foot over an area of approximately 10,000 square feet (one compartment) in accordance with NFPA 16. There are 5 preaction systems feed from the 8” sprinkler/standpipe main located in the Lower Tunnel. The preaction valves in each AFFF/water sprinkler riser are Viking flow control valves that regulate the water pressure downstream of the flow control valve.

Per NFPA 16 items such as storage tanks and proportioners for foam concentrates, pumps for water and foam concentrates, and control valves for water, foam concentrates, and foam solution, need to be located as near as possible to the hazard or hazards they protect but not be exposed to a hazard that

could impair the system. To satisfy this requirement, the five AFFF/water pre-action riser assemblies are provided within a 1-hour enclosure.

A triple IR flame detection system is provided to activate the preaction AFFF/water systems.

C. Wet-Pipe Sprinkler System

As there are no fuel lines in the Upper Tunnel, this area is not considered as hazardous as the Lower Tunnel. Therefore wet-pipe sprinkler systems, meeting NFPA 13 guidelines, are installed to protect the Upper Tunnel. Two risers are provided Upper Tunnel #1 (UT#1) and Upper Tunnel #2 (UT#2). UT#2 also supplies water for (b) (3) (A) machine rooms and lobbies as required by UFC 3-600-01 for electric traction elevators. These sprinkler systems include all pipe, fittings, valves, sprinklers, and appurtenances necessary to support these systems. Adequate pressures are achieved without the aid of the fire pump. However, the fire pump was connected to the sprinkler systems to augment any pressure shortages due to larger than design fire areas being activated. The wet-pipe sprinkler systems are sized for a density of 0.4 gpm per square foot over an area of 2,500 square feet following Extra Hazard 2 (EH2) design requirements. An additional 500 gpm will also be available for use by exterior fire hydrants or standpipe system.

A wet pipe sprinkler system is also provided for the transformer room, gauger room, and electrical room in the Lower Tunnel. The riser for this system is in the Lower Tunnel fed from the 8” sprinkler/standpipe main.

D. Water Supply System

All fire suppression systems provided require water supply to function. When designed UFC 3-600-01 stated that where onsite storage is a sole source water supply that the tank or tanks must be divided to ensure that more than 50% of the required storage is always available. To this end, a new 250,000-gallon water storage tank was constructed for the exclusive use by the fire protection systems of the Red Hill Bulk Fuel Storage Facility. The new tank was connected on the suction side of the fire pumps along with an existing 250,000-gallon water tank which ensures that the 50% of the storage capacity is available with one tank out of service. UFC 3-600-1 requires distribution mains to be looped to always provide 50% flow during a main break. A water line that runs along the upper access road supplies water to hydrants located at (b) (3) (A). This line also ties-in to the interior water line system the feeds all fire suppression systems and forms a fire protection main loop. The water tanks are supplied with water primarily from the booster pumps tied to the water supply at Pearl Harbor. There is an additional line from a Board of Water Supply (BWS) system which serves as a secondary source should the main source become unavailable.

E. Fire Department Connections

NFPA 13 and NFPA 16 require two 2 1/2 in. NH internal threaded swivel fittings. NFPA 14 requires fire department connect to be sized per standpipe system demand with one 2 1/2 in. inlet for every 250 gpm of design flow. NFPA 14 requires 1,000 gpm flow rate calculation for standpipe system in a sprinklered building. Six 2-1/2" fire department inlet connections are installed at (b) (3) (A) NFPA 16 requires evaluation of fire department connection to avoid over pressurizing system components, imbalance of proportioning equipment, dilution of proportioned foam solution, and pressure and flows exceeding the foam system design. Each fire department connection should have signs indicating the following:

1. Per NFPA 16 to indicate "THIS CONNECTION FEEDS A FOAM-WATER SPRINKLER SYSTEM. DO NOT PUMP AT PRESSURES EXCEEDING [insert design pressure] UNTIL FOAM LIQUID SUPPLY IS EXHAUSTED. IF INCIDENT IS CONTROLLED BY FOAM BLANKET, DO NOT DESTROY FOAM BLANKET BY EXCESSIVE APPLICATION OF WATER, and
2. Per NFPA 13 and NFPA 14 to indicate "AUTOSPKR AND STANDPIPE".

F. Fire Pump

The AFFF/water preaction and wet-pipe sprinkler systems are provided adequate water and pressure to operate correctly without the aid of a fire pump. However, per NFPA 14, a minimum operating pressure of 100 psi is required at the most remote standpipe hose connection. The system alone would not be capable of delivering the required 100 psi to the most remote standpipe hose connection throughout the Upper and Lower Tunnels, therefore an electric fire pump is provided to increase the pressure to 100 psi at all outlets. A second fire pump is provided as a backup but remains "OFF" until an operator manually turns the fire pump "ON". Though technically only required for the Upper Tunnel portion of the standpipe system, boosted pressure is also available for use by all suppression systems to augment pressures as deemed necessary by the fire department.

G. Fire Alarm and Mass Notification System

The fire alarm and mass notification system was installed as part of the project to upgrade all fire suppression systems and the ventilation systems, Project FY15-P-1551. The fire alarm and mass notification (FAMN) system is a network of panels to allow command and control functions on a limited basis from multiple locations in the tunnel complex. The system uses Gamewell/FCI equipment (manufactured by Honeywell) to monitor and control fire alarm devices located throughout the Facility and interconnected/integrated with various auxiliary systems throughout the tunnel facility. Depending on the location within the Facility, the peripheral devices include manual fire alarm boxes, smoke and heat detection, duct-mounted smoke detection, and both addressable monitor and control modules to interface with various auxiliary system functions. Auxiliary systems monitored include:

- Fire sprinkler control valves and water flow switches
- Fire pump controllers

- Underground Pump House (UGPH) existing AFFF and FM-200 Releasing Panel (alarm, AFFF discharge, and trouble)
- Fire Suppression Water Tank Levels
- Aqueous Film Forming Foam (AFFF) fire suppression effluent retention tank levels
- Select Exhaust Fans for operation
- Compartmentalization and Oil-tight doors (local manual request for closure)

Auxiliary systems receiving an input from the FAMN system include:

- Release AFFF fire suppression systems in Lower Tunnel Tank Farm
- Activate AFFF pumps in the Fire Pump House
- Manual ON/OFF control of select exhaust fans associated with compartments in Lower Tunnel
- Activation (closure) of fire/smoke dampers
- Compartment roll-up and man door release
- Oil-tight door release and scissor-lift activation
- Elevator recall and shunt trip operation
- Elevator lobby door release

The FAMN system will also provide audible and visual notification throughout the tunnel facility utilizing speakers for both automatic and live voice message, and strobes.

The Lower Tunnel area is classified as a hazardous Class I Division 2 electrical environment, with the exception of the Gauger's Office, Gauger's Station Electrical Room, and the Office and Control Room areas of the UGPH. Devices located in the Lower Tunnel, outside of these specific rooms/areas are listed for installation and use in explosive environments.

The FAMN system is also connected to control and annunciation equipment using a dedicated fiber optic network. This equipment consists of graphic workstations with video display units (VDU), located in the UGPH Control Room, Gauger Office, each ADIT (tunnel entrance - total of six), and in Building 1757, a remote building outside the Tunnel Facility located at Pearl Harbor. The VDUs at the ADITs are enclosed in what appears to be temperature-regulated, weatherproof cabinets with a clear panel front. The network of graphic workstations provides the fire department with remote access and control of the FAMN system and ventilation systems from these same locations.

The FAMN system is monitored by the Base Fire Department using two Kingfisher Company, Inc. wireless communicators; one located at (b) (3) (A) covering the UGPH, (b) (3) (A) and the Harbor Tunnel systems, and one at (b) (3) (A) covering ADITs (b) (3) (A). Upper and Lower Tunnels, and the Fire Pump House. Connection of the FAMN system speakers to the base-wide mass notification system (Federal Signal Ultravoice) is provided by an Ultravoice Remote Interface (UVRI) cabinet located at the entrance to ADIT 1.

The equipment provided can vary by location in the tunnel complex, depending on the operating environment, auxiliary systems present, and the need for command-and-control functions, either on a limited or global basis. The following is a summary of the equipment by location.

UGPH/ADIT 1 – The Control Room in the UGPH is the location of the system “headend” equipment with all inputs annunciating here, and provisions for making live voice announcements, as well as controlling fans, smoke dampers, and releasing compartment doors associated with the tunnels. The fire alarm detection system installed prior to the project in 2015, which uses a Cheetah brand fire alarm control unit and also controls the existing FM-200 fire suppression system, was not replaced in 2015. It was retained, and remains operational, strictly for activation of the FM-200 system and to control the various fans in the UGPH during a fire emergency. It monitors a combination of heat detection and infra-red (IR) flame detection throughout the UGPH but has no associated notification appliances. The new fire alarm/mass notification system was installed with its own heat detection and IR flame detection in parallel with that of the existing system, along with manual fire alarm boxes (pull stations). It provides the live and automatic voice messages for the UGPH, along with visual notification using strobes throughout the building. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

Harbor Tunnel – The main tunnel from the UGPH to the fuel tanks contains explosion-proof equipment consisting of pull stations, heat detectors, speakers, and strobes. There are also equipment cabinets in explosion-proof enclosures containing amplifiers, power supplies, etc. every few hundred feet to support the devices in the tunnel. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

(b) (3) (A) Connection Tunnel – This is the entrance from COMPACFLT headquarters and connects with the Harbor Tunnel near the UGPH. It contains weatherproof equipment consisting of pull stations, heat detectors, speakers, and strobes. There are also equipment cabinets in weatherproof enclosures containing amplifiers, power supplies, etc. to support the devices in the tunnel. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

(b) (3) (A) Connection Tunnel – This is an entrance at Red Hill and connects with the Harbor Tunnel nearest to the Tank Farm. It contains weatherproof equipment consisting of pull stations, heat detectors, speakers, and strobes. In addition, this is one of two locations where the FAMN system interfaces with the Digital Control System (DCS) panel DDC-9, which serves as an interface between the FAMN system and other systems in the tunnel (e.g., fire resistance-rated compartment door status, sump, and sump pump status, AFFF and groundwater retention system level, etc.) and their status. There are also equipment cabinets in weatherproof enclosures containing amplifiers, power supplies, etc. to support the devices in the tunnel. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

(b) (3) (A) Connection Tunnel – This is an entrance at Red Hill to the Upper Tunnel of the Tank Farm at Tanks 1 and 2. It contains weatherproof equipment consisting of pull stations, heat detectors, speakers, and strobes. There are also equipment cabinets in weatherproof enclosures containing amplifiers,

power supplies, etc. to support the devices in the tunnel. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

(b) (3) (A) Connection Tunnel – This is an entrance at Red Hill at the Upper Tunnel and connects to the Tank Farm between Tanks 15 and 16. It contains weatherproof equipment consisting of pull stations, heat detectors, speakers, and strobes. It also provides access to the Lower Tunnel and **(b) (3) (A)** Connection Tunnel using one of two elevators. In addition, there is a remote command panel equipped with: a network annunciator; a remote microphone; as well as fan, smoke damper, door, and speaker control switches. There are also equipment cabinets in weatherproof enclosures containing amplifiers, power supplies, etc. to support the devices in the tunnel. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

(b) (3) (A) Connection Tunnel – This is an entrance at Red Hill which accesses the **(b) (3) (A)** Elevator at a level between the Upper Tunnel and Lower Tunnel. It contains weatherproof equipment consisting of pull stations, heat detectors, speakers, and strobes. It also provides access to the Upper and Lower Tunnels using the **(b) (3) (A)** Elevator. In addition, there is a remote command panel equipped with: a network annunciator; a remote microphone; as well as fan, smoke damper, door, and speaker control switches. There are also equipment cabinets in weatherproof enclosures containing amplifiers, power supplies, etc. to support the devices in the tunnel. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

Lower Tunnel Tank Farm – This level is located at the bottom of the storage tanks and contains the pipes which transport the fuel to/from the UGPH. The Lower Tunnel contains explosion-proof equipment consisting of pull stations, heat detectors, duct-mounted smoke detectors for smoke damper control, IR flame detectors, speakers, and strobes. The IR flame detectors are used as part of the AFFF fire suppression deluge system present in this part of the tunnel complex. The FAMN system also monitors the door position of the compartment doors (man doors and roll-down doors). There are also equipment cabinets in explosion-proof enclosures containing amplifiers, power supplies, etc. every few hundred feet to support the devices in the tunnel. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

Gauger Office – This office area is in the Lower Tunnel between Tanks 15 and 17, next to the passenger elevator from the Upper Tunnel. It is separated from the Lower Tunnel hazardous environment by fire and smoke resistance-rated construction which allows the use of non-explosion-proof equipment inside its area. This area has a remote command panel equipped with a network annunciator; a remote microphone; as well as fan, smoke damper, door, and speaker control switches. It also has one of the fire alarm control panels which monitors the IR flame detectors in the Lower Tunnel of the Tank Farm and houses the panel which activates the AFFF fire suppression systems in this same area. In addition, this is the second location where the FAMN system interfaces with the Digital Control System (DCS) panel DDC-1.

Upper Tunnel Tank Farm - This level is located near the top of the storage tanks, with ships ladders at the tanks providing access to the very top of the tanks. It contains weatherproof equipment consisting of pull stations, heat detectors, duct-mounted smoke detectors for smoke damper control, speakers, and strobes. While the shafts surrounding the ships ladders to the top of the tanks contain explosion-proof heat detectors, speakers, and strobes. The Upper Tunnel itself also has equipment cabinets in weatherproof enclosures containing amplifiers, power supplies, etc. every few hundred feet to support the devices in the tunnel. Power for the equipment is derived from an emergency power electrical panel in the immediate vicinity of the panel equipment.

Fire Pump Building – This building is located just below (b) (3) (A) It has a remote command panel equipped with a network annunciator; a remote microphone; as well as fan, smoke damper, door, and speaker control switches. The building houses: two fire pumps; the AFFF storage tank, two AFFF pumps, and an emergency generator. It is protected by standard pull stations, speakers, and strobes. The FAMN system also monitors the building wet fire sprinkler system, as well as the fire and AFFF pumps.

a. **Digital Control System**

The Digital Control System (DCS) consists of networked digital controller panels used to monitor and, in some cases control, systems associated with compartmentalization and remediation during a fuel fire or fuel leak in the Lower Tunnel Tank Farm. The DCS is not part of the fire alarm system, but the two systems communicate with each other. This network is used to monitor various systems associated with the removal and containment of the effluent from the activation of the AFFF fire suppression systems during a fuel leak or fire. The DCS monitors:

- Level of effluent in sump pits (float switch and high level).
- Associated sump pumps (four at each compartment door) for running, overheating, and water infiltration.
- High-level condition in retention tank.
- High-level condition in secondary containment area.
- Oil-tight door “close” request pushbutton and door position (open/close), scissor lift motion and position.
- Fire water tank water level (high/low).
- Groundwater level at compartment doors.
- Groundwater collection pumps running.
- Emergency generator fuel tank level and leak detectors (Fire Pump Building).

In turn, the DCS controls, provides local control of, or provides an output contact for:

- Sump pumps at compartment and oil-tight doors (hand/off/auto).
- Activation of audible and visual alarms indicating scissor lift and door activation at oil-tight door.
- Oil-tight door position and activation of local pushbutton associated with closing door manually.
- FAMN system monitoring of status for sump pumps and groundwater collection pumps running, sump high level, retention tank and secondary containment levels, pushbutton request to close oil-tight door, and fire water tank levels.

b. Smoke Ventilation

The Tunnel Complex has many supply and exhaust fans present throughout to maintain a tenable and safe environment. Command and control of the fans and dampers appears to be possible from a graphic control panel outside the entrance to (b) (3) (A) according to notes on the panel, not all fans in the complex are yet connected to it. The FAMIN system has a limited role in the ventilation of smoke during or after a fire in the tunnels. It controls (b) (3) (A) fans (b) (3) (A) (b) (3) (A)) in the Upper and Lower Tunnels in the Tank Farm area. It also controls the fire/smoke dampers in this area as well. The existing Cheetah fire alarm and releasing panel in the UGPH Control Room controls the fans located in the UGPH. The graphic fan control panels provided as part of the P-1551 project appear to indicate there are a total of (b) (3) (A) fans.

H. AFFF Retention System

The foam/water discharged from the AFFF/water preaction systems is collected by transverse trenches at each fire/smoke compartment in the Lower Tunnel. These fire/smoke separations segregate every four tanks into a separate compartment. The foam/water and any fuel from a fuel leak/discharge that sheet flows into these trenches is collected and routed to a sump pit, one for each 4-tank compartment area, these sumps are located near the downhill fire/smoke compartment separation. There are 4 large sump pumps in each sump pit (3 primary and 1 backup pumps) and these lift the effluent into a 14-inch AFFF retention line. This retention line is connected to a 153,000-gallon AFFF retention tank located outside of Adit 3. The tank is sized to accommodate a 20-minute discharge of the Lower Tunnel fire extinguishing system, plus an additional (b) (3) (A) fuel that could leak from the fuel system in the Lower Tunnel. The sump pumps are activated automatically on level controls and announce a supervisory alarm when operated. During construction changes were made to the sequence of operations of this system to require the fire alarm system to be in alarm before the sump pumps operate.

A separate smaller ground water collection pump is also located in the sump pits to collect and pump any incidental ground water seepage in the tunnel into the main slop tank sump pump pit located below tanks 1 and 2. This system is provided to prevent unintended operation of the main AFFF retention pumps. The ground water collection pumps are interlocked to shut down when the fire alarm system is activated.

The main AFFF retention sump pumps, and the ground water sump pumps are also interlocked to shut down if the new oil tight door is closed. This is done via the DCS, which monitors the closed position of the oil tight door via a door switch and is also interfaced with the sump pumps to shut them down. The new oil tight door is closed upon activation of the high groundwater float switch at the oil tight door, or activation of a manual push button at the oil tight door. During construction the sequence of operations was changed to remove closing on the oil tight doors upon receiving a signal from the fire alarm system.

The main AFFF retention tank is designed as an API 650 steel fuel storage tank as it may collect fuel from a fuel leak. The AFFF retention tank is provided with a containment berm to comply with environmental regulations for spill control.

I. Ventilation and Smoke Control

This facility currently has an operating ventilation system including several ventilation fans that are utilized to control the concentration of fugitive emissions of fuel fumes to below 25% of the lower explosive limit. It is desirable that these fans be able to exhaust smoke during or after a fire to be controlled by the fire department as they deem necessary. Currently, the fans are sized to control the smoke in most locations allowing occupants to egress prior to being overcome by smoke. The existing fans are tolerant of the heat of the smoke generated more than 3 feet from the fans. Fire closer than this will consume the fans and render them inoperable. The fans, however, are not explosion proof. The FY15 P-1551 project replaced mechanical/electrical motors of the fans to make them explosion proof in the Lower Tunnel, like the fire alarm system outlined above. Additional upgrades to the existing ventilation system for enhanced smoke control were not provided as part of the project. Similarly, the provision of self-contained breathing apparatus (SCBA) was not provided as part of the project.

3. FIRE PROTECTION SURVEY RESULTS

A. Condition of Fire Protection Systems and Comparison of Design Versus Installed Conditions

Over the 12-day period from March 21 to April 1, 2022, each of the fire protection systems was surveyed by a team of Jensen Hughes fire protection engineers. Surveys were conducted to compare the systems as installed to the as-built shop drawings provided from the FY 15 P-1551 project. Drawings of the survey results are contained in Appendices A through H.

a. Standpipe System

Site survey notes for the standpipe system can be found in Appendix A. Generally, the drawings provided as as-built drawings from the FY15 P-1551 did not appear to have been updated to reflect as-built conditions. This included how supply sprinkler piping was being routed and a few instances where the standpipe hose valve connections were installed in a different location.

The standpipe system itself was observed to be in very good overall condition. The hose valves are provided with pressure-regulating devices but were not provided with a valved outlet for a pressure gauge to be connected. A valved outlet should be provided for each location with a pressure-regulating device so a pressure gauge can be attached to verify the required pressure is being provided.

b. Preaction AFFF/Water Sprinkler System

Site survey notes for the preaction AFFF/water system can be found in Appendix B. Generally, the drawings provided as as-built drawings from the FY15 P-1551 did not appear to have been updated to reflect as-built conditions. There were many locations where additional sprinklers and/or additional branch lines had been provided and these are noted in the site survey notes. The location of seismic braces in many instances also did not match locations shown on the drawings. The backgrounds on which the drawings were prepared also seemed to have frequent inconsistencies with the observed field conditions.

The preaction AFFF/water sprinkler system itself was observed to be in very good overall condition. Significant external pipe degradation was observed in the riser for Preaction System 3 due to the constant dripping of ground water seepage into the riser closet and onto the piping. A ceiling should be constructed in this room, like the metal ceiling constructed in other areas of the Lower Tunnel, to stop water dripping in this room. Once water no longer dripping into this riser room the degraded riser piping should be replaced.

Site survey notes for the AFFF storage and pumping system can be found in Appendix D. The AFFF storage and pumping system, located in the fire pumphouse building, were also visually inspected, and appeared to be in very good overall condition. The foam pumps themselves were tagged out of service, this appeared to be due to a leak in the underground piping between the fire pumphouse and (b) (3) (A) where the foam concentrate piping enters the tunnel system. The system installation matched what was indicated on the as-built drawings provided.

The nitrogen generating system for the preaction system was observed to be in very good overall condition. The system as installed matched the as-built drawings provided.

c. Wet Pipe Sprinkler System

Site survey notes for the wet-pipe sprinkler system can be found in Appendix A. Generally, the drawings provided as as-built drawings from the FY15 P-1551 did not appear to have been updated to reflect as-built conditions. This included the routing of sprinkler piping, location of bulkheads/doors, and the number of branch lines installed in the access tunnels to the storage tanks.

The wet-pipe sprinkler system itself was observed to be in very good overall condition. Significant external pipe degradation was observed at various locations in the Upper and Lower Tunnels. There is sprinkler piping missing hangers on branch line, temporary ventilation ductwork obstructing sprinklers, sprinkler risers, and being supported by the sprinkler piping resulting in external loading not accounted for when designing hangers to support the sprinkler piping.

The “as-built” drawings should be redlined and incorporated into a new drawing to account for all field changes made during installation. Additionally, hangers need to be installed on unsupported piping and the temporary ventilation ductwork needs to be relocated.

d. Site Water Supply

The site water supply system installation matched what was indicated on the as-built drawings provided and was observed to be in very good overall condition.

e. Fire Department Connections

Site survey notes for the fire department connections can be found in Appendix A. The system installation matched what was indicated on the as-built drawings provided and was observed to be in very good overall condition.

The fire department connections were not provided with signs indicating the system they served, and the operating pressures required. The signs should be provided at each fire department connection are as follows:

1. Per NFPA 16 to indicate “THIS CONNECTION FEEDS A FOAM-WATER SPRINKLER SYSTEM. DO NOT PUMP AT PRESSURES EXCEEDING [insert design pressure] UNTIL FOAM LIQUID SUPPLY IS EXHAUSTED. IF INCIDENT IS CONTROLLED BY FOAM BLANKET, DO NOT DESTROY FOAM BLANKET BY EXCESSIVE APPLICATION OF WATER”, and
2. Per NFPA 13 and NFPA 14 to indicate “AUTOSPKR AND STANDPIPE”.

f. Fire Pump System

Site survey notes for the fire pump system can be found in Appendix C. The system installation matched what was indicated on the as-built drawings provided and was observed to be in very good overall condition.

g. Fire Alarm and Mass Notification System

Site survey notes for the fire alarm and mass notification system can be found in Appendix E. The upgrade of the fire alarm system was included as part of project FY15 P-1551 in direct response to findings and recommendations found in and audit conducted by Naval Audit Services and titled Department of the Navy Red Hill and Upper Tank Farm Fuel Storage Facilities (N2010-0049, dated 16 August 2010). Specifically, the audit referenced recommendations from a 1998 assessment which identified a need for emergency voice/alarm communication system in the RH facility to alert occupants of a fire or other emergency (Finding 3 Safety Measures). Based on our observations as to the extent to which the new system offers one-way voice communication to all areas of the Red Hill Bulk Fuel Storage Facility, it would appear the 1998 recommendation and 2010 audit comment has been addressed by the installation of this system. The overall physical condition of the system panels and devices appeared to be “good”, with no signs of damage. However, there were code deficient conditions associated with device placement, spacing/coverage, or obstruction.

In general, the as-built shop drawings provided (Revision 6, dated 23 January 2018) do not accurately reflect the installed device locations. For initiating devices (e.g., pull stations, heat detection, addressable monitor modules, etc.), approximately 5% - 10% of device locations were inaccurate. Most of the spacing of these installed devices appeared to maintain code compliance. However, it is estimated over 85% of the notification appliances were inaccurately located on the as-built drawings. Most of these devices still maintained compliance with required spacing, but a significant number of visual notification devices were over-spaced creating code deficient conditions. These devices are spaced beyond the maximum distance allowed by NFPA 72 of 100 feet. This occurs at several intervals, where a device will be spaced 110 – 120 feet from the previous device, and then 70 – 80 feet to the next device. There did not appear to be any field conditions which would contribute to the extended spacing. Spacing of these devices should be corrected so they are within the code required spacing. All devices in the entire length of tunnel from the Underground Pumphouse to the Harbor Tunnel intersection of Adit 2 were not accurately located on the as-built drawings. There are also numerous label errors, mostly of single, isolated devices, that should be corrected.

In addition, all of the explosion-proof strobes located in the Tank Farm portion of the Lower Tunnel are obstructed and violate NFPA 72. The code requires strobes to be visible by direct concentrated viewing (i.e., you have to be able to see the actual strobe lens from all parts of the corridor) in order to use corridor spacing of minimum 15cd strobes mounted up to 100 feet apart. The strobes in this section of the tunnel are mounted with the bottom of the strobe lens well above the adjacent pipe stand structure and pipes. Personnel on the actual walking portion of the tunnel will not be able to see the strobes at all.

There were also inaccuracies associated with equipment shown on the as built drawings not being installed, or installed in a different orientation (i.e., mounting on wall instead of ceiling, or vice-versa). Many of these examples involved duct-mounted smoke detection at smoke dampers, usually where installation of this type of device was not possible. However, there was no documentation indicating

the required detection was exempted nor was spot detection provided at the damper. Some of this may be attributable to the fact the drawings provided and reviewed would not necessarily reflect changes associated with Revisions R and S (dated 21 June 2018) of the design drawings, some of which affected systems monitored by the fire alarm and mass notification system.

h. AFFF Retention System

Ideally a foam retention system should operate by gravity flow such that discharged AFFF effluent and fuel may be collected via gravity thereby eliminating any moving parts. Unfortunately, it was determined during design that it was not possible for this system to operate under gravity. It would be ideal if drainage from the Adit 3 end of the tunnel into the retention tank could occur under gravity, however doing this would require finding a site for the tank where the top of the tank was below 98' elevation. Without significant additional excavation this would also require piping from the tunnel, which during a retention event would contain AFFF, to be located underground. There are numerous areas in the system where low points are provided and effluent collects at these points. The first low points are the 5 sump pits provided at each fire/smoke wall. Effluent drains to these pits and is lifted by sump pumps into the AFFF retention piping. The second collection of low points are those low points created when the retention line changes elevation in the tunnel to pass over doorways and other obstructions. Each of these changes in elevation creates a local localized low point which is eventually overcome by the overall grade of the tunnel and slope of the retention pipe. Low point drains were observed at these locations which permit the pipe to be drained at each of these individual low points. The third and final low point is created by the elevation of the retention tank, the drain line into the retention tank, and each of the 5 sumps. The bottom of the retention tank itself is noted as being at an elevation of 119', while the low point in the tunnels themselves at Adit 3 is 98'. During construction it was noted (RFI-0069) that all the tunnel retention piping to the point below the fire door between tanks 3-4 and tanks 5-6 is at or below the 119' elevation making the entire volume of the retention piping below this door a low point (~between 30,000 and 40,000 gals). As constructed the entry point in to the retention tank is at the top of the tank itself making the top of the tank the height that must be overcome for effluent to flow under gravity into the retention tank – the effect of this is to make even more of the retention line a low point, such that it is likely more than 40,000 gal of effluent would have to enter the retention line before any of it would flow into the tank. Any discharge from the tanks would have to fill the entire length of the retention line to Adit 3 to an elevation equal with the elevation of the top of tank entry before effluent could flow into the retention tank. For spills less than 40,000 gals no effluent will reach the retention tank, rather these spills will be held in the numerous low points throughout the system. An overall survey of elevations along the retention line, which was performed during the site survey, could be further developed, and used to evaluate where effluent is likely retained based on the location of effluent entering the retention system. A small sump and manually activated sump pump were provided at the low point of Adit 3 to be able to pump from the low point to a valved header at Adit 3 to allow fluid in the low point to be pumped to a tanker truck for disposal.

The AFFF retention system as finally installed did not match the as-built drawings. The retention system was constructed of HDPE pipe for the entire system. After installation changes were made to the retention system which are not reflected on the as-built drawings. These changes included:

1. Steel pipe and valves were installed for the system from the sump to the main 14-inch retention line.
2. The main 14-inch retention line was changed to steel pipe for approximately 100 ft from a point after the penetration of the fire/smoke wall to a point upstream of the sump piping inlet.
3. Spring operated control valves with a fusible link are in the piping upstream of the sump pumps and upstream of the pipe type junction.

These changes were not documented as part of the as-built drawings, and it is not clear that any acceptance testing of this altered system along with the already accepted fire alarm systems was undertaken.

There are numerous improvements that could be recommended to improve the operation of the retention system. However, at this stage with the established goal of ultimately taking the fuel storage tanks out of service within the next 2-3 years any recommendations for significant alterations to the retention system do not appear to be warranted.

B. Fire Protection Systems Recommendations of 2010 Audit Report

The 2010 Department of the Navy Red Hill and Upper Tank Farm Fuel Storage Facilities Audit report contained a list of 13 identified safety hazards. At the time of the report 7 of these hazards were identified as having been corrected, 2 were identified as outstanding but with funding having been secured for mitigation, and preventative maintenance was identified as ongoing. This left three remaining hazards that were identified in the Audit report. The report recommendations identified these items, as indicated below, and recommended they be prioritized as critical:

1. Install an automatic fixed fire suppression system at the lower tank storage area. NAVFAC Pacific engineers have recommended the installation of an Aqueous Film Forming Foam (AFFF) Deluge system.
2. Install an emergency voice/alarm communication system at Red Hill.
3. Upgrade the existing fire protection water main in the upper and lower tunnels at Red Hill.

Each of these Audit report recommendations was addressed by construction project FY15 MILCON P-1551 Fire Protection, which included the installation of:

1. Five (5) foam water preaction systems in the Lower Tunnel. As part of this system a new fire pump system was also provided that boosts the water supply pressure from the water storage tanks to the Red Hill Fire Protection Systems.



2. An emergency voice fire alarm and mass notification system from Adit 1 throughout the entire Red Hill Bulk Fuel Storage Facility.
3. An 8” looped fire protection main and standpipe & hose system throughout the Upper and Lower Tunnel areas.
4. A second water supply tank adjacent to the existing water supply tank to supply the Red Hill Fire Protection Systems.

The addition of these systems satisfies the outstanding fire protection/life safety recommendations of the 2010 Audit Report.



4. SUMMARY OF FIRE PROTECTION AND RETENTION SYSTEM PERFORMANCE

A. May 6, 2021, Fuel Release Incident

A significant discharge of fuel occurred from a rupture of a fuel line in the Lower Access Tunnel at Tanks 18 and 20 at approximately 1812 hours on May 6, 2021. The root cause of the incident was the incorrect sequence of opening of fuel valves while fuel was being taken from Tank 12, with collateral damage and leaks occurring in the area around Tanks 18 and 20. This leaked fuel, once in the Lower Access Tunnel, flowed in the direction of the sump pits associated with Door C-1 at Gaugers office (south of Tanks 17/18), and potentially Door 5 (south of Tanks 13/14), respectively.

Ultimately most of this fuel discharge was collected by the retention system, however due to the significant number of low points and the relative elevation of the line into the retention tank at [REDACTED] compared with the tanks themselves, none of this fuel drained to the retention tank. As evidenced by the later discovery of fuel in the retention line however, it is unequivocal that fuel was lifted by the sump pumps into the retention line but there was no record of operation of the sump pumps on the day of the incident. Anecdotal reports from the day indicate that the fire alarm system in the tunnel was not in alarm during this incident. Sequence of operation changes made during construction of project P-1551 were supposed to interface the sump pumps with the fire alarm system such that they would not operate without a fire alarm. As evidenced by fuel being found in the containment system piping, it appears the installed sequence of operations does not match what is presented in the as-built drawings.

The fire alarm/mass notification (FA/MN) system does not, and is not required to, detect a fuel leak. It only detects conditions that could occur because of a fuel leak - ignition (flame detection) and fire (heat detection). Even with the manual pull stations provided, the normal procedure would not necessarily include activation during a fuel leak without ignition, or threat of ignition.

The indirect mechanisms in place to automatically notify and annunciate on the FA/MN system included the following auxiliary system interfaces:

- Fuel sump pump running at Door C-1; if sufficient fuel were to accumulate and cause the fuel levels to activate the individual float switches provided to engage the associated pumps.
- Fuel Sump pump running at Door 5; if sufficient fuel was able to travel this distance and cause the fuel levels to activate the individual float switches provided to engage the associated pumps.

The fuel sump pump float switches and pump running status are monitored by the Digital Control System (DCS). The DCS is the indirect mechanism that provides status inputs to the FA/MN for the following conditions:

- Sump “X” High Level Float Switch (1 for each sump), note that the high sump level float switch is located higher than all sump pump float switches in each sump pit.
- Sump Pump SP-Door-“X”-C1, 1 to 5 Pump Running (1 for each of the 5 pumps in each of the sumps)

Given the amount of fuel believed to be released, and reported observations made by personnel present during the leak, the sump pumps at Door C-1, at a minimum, accumulated enough fuel to activate the float switch and start the fuel sump pumps running in that door's associated sump pit.

The interface of the FA/MN system and the DCS occurs in two locations: at DCS cabinet DDC-9, near the (b) (6) (A) entry point; and at DDC-1 in the Lower Tunnel Gaugers Office. The FA/MN system uses addressable monitor modules to monitor the DCS outputs. At a minimum, the reporting addresses associated with Door C-1 would be (b) (3) (A). If any of the pumps activate, its corresponding address should appear as an input in the FA/MN history log.

Based on our analysis of the provided system history log, there were no inputs from these nodes (panels), much less these specific addresses, on the day of the leak event. It is not known as to why the fuel sump pump running status did not announce on the FA/MN system. The history log did not indicate any impairment of these associated panels on the day of the event. However, the fire protection ITM program indicates multiple occasions of a period of years where the Kingfisher failed to transmit signals to the Regional Dispatch Center.

B. November 21, 2021, Fuel Release Incident

A further fuel discharge occurred on November 21, 2021. This discharge was as a direct result of the May 6 incident. On this day a low point drain on the 14-inch retention line was hit by a vehicle (or something being carried on a vehicle) and broken. Fuel from the May 6 incident that remained in the retention line was then released to the Lower Tunnel. This occurred in the Lower Tunnel below the oil tight door. The only drainage in this area of the tunnel is directly to the groundwater aquifer.

The fuel from the retention line on November 21st appears to have been fuel that remained in the retention line from the May 6th incident. Due to system design all low points need to be checked, not finding fuel in the retention tank, or at the lowest point in the system is no guarantee that fuel is not in the system because it will be retained at the first low point below where fuel enters the system, until this low point is overcome and then it will accumulate at the next low point down the line. Due to the low slope and large diameter of the retention line this can mean significant pockets of fuel are retained at low points in the middle of the system.

5. MAINTENANCE RECORDS REVIEW

UFC 3-601-02 7 October 2021 contains maintenance requirements for fire protection systems. It should be noted that this UFC was updated after the project and the current fire protection maintenance contract. Items that are new to this edition of the UFC are shown shaded in these tables. The requirements for each system type are contained in sections A through I, there are no fire protection testing requirements for the AFFF retention system.

A. Standpipe System

Hose outlets and FDCs inspection, test and maintenance is conducted with the wet pipe sprinkler system. See Section C – Wet Pipe Sprinklers for more information.

B. Preaction AFFF/Water Sprinkler System

Lower Tunnel Preaction Maintenance Summary (Systems 1-5)

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
Semi-Annually	Foam concentrate		Inspect for quality and evidence of sludge or deterioration		
			Verify adequate supply		
Annually	Control valves (sealed, locked, or electrically supervised)		Verify proper valve position	Yes	06/20/2021 (RHT Lower Tunnel DS1 - June 20, 2021) 06/20/2021 (RHT Lower Tunnel DS2 - June 20, 2021), 06/20/2021 (FLC AFFF ZONE 5 PA_DS 6.20.21) 06/20/2021 (FLC AFFF ZONE 4 PA_DS 6.20.21), 06/20/2021 (FLC AFFF ZONE 3 PA_DS 6.20.21)
			Waterflow alarm devices	Operate alarm test valve to verify initiation and receipt of alarm	
	Pre-action valve and trim		Verify alarm test valve alignment and tamper switch (if sealed or electrically supervised)		
			Inspect the exterior of valves, gauges, trim alignment	Yes	06/20/2021 (RHT Lower Tunnel DS1 - June 20, 2021) 06/20/2021 (RHT Lower Tunnel DS2 - June 20, 2021), 06/20/2021 (FLC AFFF ZONE 5 PA_DS 6.20.21), 06/20/2021 (FLC AFFF ZONE 4 PA_DS 6.20.21), 06/20/2021 (FLC AFFF ZONE 3 PA_DS 6.20.21)
		Verify valve pressure and legibility of the hydraulic nameplate			
	Main drain		Conduct a main drain test to verify supply (valve position)	Yes	6/20/2021 (static only) (RHT Lower Tunnel DS1 - June 20, 2021)

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
			Document static and residual pressure readings on a 3-inch by 5-inch tag and secure it to the system pressure gauge	Yes	06/20/2021 (static only) (RHT Lower Tunnel DS2 - June 20, 2021), 06/20/2021 (static only) (FLC AFFF ZONE 5 PA_DS 6.20.21), 06/20/2021 (static only) (FLC AFFF ZONE 4 PA_DS 6.20.21), 06/20/2021 (static only) (FLC AFFF ZONE 3 PA_DS 6.20.21)
			Compare results with results from previous main drain tests and original acceptance test		
			Verify that the results are within acceptable limits or identify corrective measures		
	Fire department connection		Verify accessibility and condition		06/20/2021 (RHT Lower Tunnel DS1 - June 20, 2021) 06/20/2021 (RHT Lower Tunnel DS2 - June 20, 2021), 06/20/2021 (FLC AFFF ZONE 5 PA_DS 6.20.21), 06/20/2021 (FLC AFFF ZONE 4 PA_DS 6.20.21), 06/20/2021 (FLC AFFF ZONE 3 PA_DS 6.20.21)
			If caps are removed or missing, check for obstructions		
			Verify system check valve is not leaking		
			Verify gaskets are present		
			Lubricate if swivels do not rotate smoothly		
			Verify proper operation of ball drip drain prior to the cold season		
2 Years	Control Valves		Operate valve through entire travel to verify function	Yes	06/20/2021 (RHT Lower Tunnel DS1 - June 20, 2021) 06/20/2021

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date		
			Lubricate valves and stems to ensure operability	Yes	(RHT Lower Tunnel DS2 - June 20, 2021), 06/20/2021 (FLC AFFF ZONE 5 PA_DS 6.20.21), 06/20/2021 (FLC AFFF ZONE 4 PA_DS 6.20.21), 06/20/2021 (FLC AFFF ZONE 3 PA_DS 6.20.21)		
			Verify that valve supervisory switches detect a change in valve position	Yes			
	Pre-action valve		Trip to verify proper operation				
			Verify function of manual actuators (if provided)				
			Inspect internal condition and clean valve seat before resetting				
	Low point drains		Drain all low points after pre-action valve trip test				
	Air supply (if present)		Test the automatic air pressure maintenance device				
			Test the high/low air supply alarms				
	5 Years	Strainers		Clean and inspect the interior to verify condition			The system is not old enough to have required this testing.
	10 Years	Gauges		Calibrate or replace gauges			
10 Years and every 10 years thereafter	Dry Sprinklers		Replace all sprinkler or test a sample of sprinklers to verify response characteristics *				
20 Years and every 10 years thereafter	Fast response sprinklers and extra high temperature sprinklers		Replace all sprinkler or test a sample of sprinklers to verify response characteristics*				
50 Years and every 10 years thereafter	Standard sprinklers		Replace all sprinkler or test sample closed-head sprinklers to verify response characteristics *				

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
Following system modification or repair	Main drain (following maintenance or repair action requiring the water supply to be shut off)		Conduct main drain test to verify supply (valve position)		
			Compare results with result from previous main drain tests and original acceptance test		
			Verify that the results are within acceptable limits or identify corrective measures		
			Document static and residual pressure readings on a 3-inch by 5-inch tag and secure it to the system pressure gauge		

* A representative sample of sprinklers for testing must consist of one (1) percent of the sprinklers installed of the same type, with a minimum of four (4) sprinklers sampled. Submit sprinklers to a recognized testing laboratory (NRTL) for these tests.

C. Nitrogen Generation System

These ITM items should be part of the preaction systems ITM (however these requirements are new to the October 2021 edition of UFC 3-601-02 and are shown shaded).

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
Monthly	Generation System		Verify generation system is free of physical damage.		
			Verify proper valve positions		
			Verify generation system is in normal operating condition.		
			Verify the power wiring to the generation system is free of physical damage.		
Annually	Filter Elements		Replace the activated carbon and coalescing filter elements.		
	Intake Filters		Clean the air compressor intake filter elements, replace intake filters if necessary.		
	Strainer Screens		Clean air tank blow-down strainer screens.		
	System Concentration		Verify the generation system is maintaining a nitrogen composition of 98% in the system served. Verify nitrogen composition at remote test locations.		
2 Years	System Operation		Verify generation system operates on the proper pressure drop and ceases operation at the proper set point.		
			Verify generation system does not overheat or present any unusual noise or vibration during operation.		

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
			. Verify the means of anchoring the generation system to the structure is secure, tight, and free of physical damage.		
	Safety Relief Valves		Manually test safety relief valves.		
5 Years	Leakage Test		Inspect system served by generation system for leaks by conducting a pressure loss test.	The system is not old enough to have required this testing.	
	System Performance		Verify generation system restores normal gas pressure and concentration in the system served within the required timeframe.		

D. Wet Pipe Sprinkler System

Wet Pipe Maintenance Summary - Upper Tunnel WS #1

Frequency	Component	Task	Record of Completion	Date
Annually	Control valves (sealed, locked, or electrically supervised)	Verify proper valve position	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Waterflow alarm devices	Verify initiation and receipt of alarm (alternate use of alarm test line and inspectors test connection annually)	Yes
	Verify operation of exterior water flow alarm (if present)		N/A	N/A
	Verify alarm test valve alignment and tamper switch (if sealed or electrically supervised)		Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
	Alarm valve and trim	Visually check the exterior of valves, gauges, trim alignment	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Verify valve pressure and legibility of the hydraulic nameplate	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
	Main drain	Conduct a main drain test to verify supply (valve position)	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Document static and residual pressure readings on a 3-inch by 5-inch tag and secure it to the system pressure gauge	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Compare results with results from previous main drain tests and original acceptance test	No	-
		Verify that the results are within acceptable limits or identify corrective measures	No	-
	Fire department connection	Verify accessibility and condition	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		If caps are removed or missing, check for obstructions	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel

Frequency	Component	Task	Record of Completion	Date
		Verify system check valve is not leaking	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Verify gaskets are present	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Lubricate if swivels do not rotate smoothly	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Verify proper operation of ball drip drain prior to the cold season	N/A	N/A
2 Years	Control Valves	Operate valve through entire travel to verify function	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Lubricate valves and stems to ensure operability	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
		Verify that valve supervisory switches detect a change in valve position	Yes	04/26/2019RHT Upper Tunnel 06/25/2021RHT Upper Tunnel
5 Years	Alarm Valve	Clean and inspect the interior to verify condition	The facility is not old enough nor have system modifications or repairs been made to have required this testing.	
	Strainers	Inspect internally and clean to good condition		
	Automatic Air Release	Confirm proper operation		
10 Years	Gauges	Calibrate or replace gauges		
20 Years	Fast response sprinklers and extra high temperature sprinklers	Replace all sprinklers		
50 Years and every 20 years thereafter	Standard sprinklers	Replace all sprinkler or test sample closed-head sprinklers to verify response characteristics *		
Following system modification or repair	Main drain (following maintenance or repair action)	Conduct main drain test to verify supply (valve position) Compare results with result from previous main drain tests and original acceptance test		

Frequency	Component	Task	Record of Completion	Date
	requiring the water supply to be shut off)	Verify that the results are within acceptable limits or identify corrective measures Document static and residual pressure readings on a 3-inch by 5-inch tag and secure it to the system pressure gauge		

* A representative sample of sprinklers for testing must consist of one (1) percent of the sprinklers installed of the same type, with a minimum of four (4) sprinklers sampled. Submit sprinklers to a recognized testing laboratory (NRTL) for these tests.

Wet Pipe Maintenance Summary - Upper Tunnel WS #2

Frequency	Component	Task	Record of Completion	Date	
Annually	Control valves (sealed, locked, or electrically supervised)	Verify proper valve position	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel	
	Waterflow alarm devices	Verify initiation and receipt of alarm (alternate use of alarm test line and inspectors test connection annually)	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel	
		Verify operation of exterior water flow alarm (if present)	N/A	N/A	
		Verify alarm test valve alignment and tamper switch (if sealed or electrically supervised)	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel	
	Alarm valve and trim	Visually check the exterior of valves, gauges, trim alignment	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel	
		Verify valve pressure and legibility of the hydraulic nameplate	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel	
	Main drain	Conduct a main drain test to verify supply (valve position)	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel	
		Document static and residual pressure readings on a 3-inch by 5-inch tag and secure it to the system pressure gauge	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel	
		Compare results with results from previous main drain tests and original acceptance test	No	-	
		Verify that the results are within acceptable limits or identify corrective measures	No	-	
			Verify accessibility and condition	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel

Frequency	Component	Task	Record of Completion	Date
	Fire department connection	If caps are removed or missing, check for obstructions	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel
		Verify system check valve is not leaking	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel
		Verify gaskets are present	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel
		Lubricate if swivels do not rotate smoothly	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel
		Verify proper operation of ball drip drain prior to the cold season	N/A	N/A
2 Years	Control Valves	Operate valve through entire travel to verify function	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel
		Lubricate valves and stems to ensure operability	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel
		Verify that valve supervisory switches detect a change in valve position	Yes	04/26/2019 RHT Upper Tunnel 06/25/2021 RHT Upper Tunnel
5 Years	Alarm Valve	Clean and inspect the interior to verify condition	The facility is not old enough nor have system modifications or repairs been made to have required this testing.	
	Strainers	Inspect internally and clean to good condition		
	Automatic Air Release	Confirm proper operation		
10 Years	Gauges	Calibrate or replace gauges		
20 Years	Fast response sprinklers and extra high temperature sprinklers	Replace all sprinklers		
50 Years and every 20 years thereafter	Standard sprinklers	Replace all sprinkler or test sample closed-head sprinklers to verify response characteristics *		

Frequency	Component	Task	Record of Completion	Date
Following system modification or repair	Main drain (following maintenance or repair action requiring the water supply to be shut off)	Conduct main drain test to verify supply (valve position)		
		Compare results with result from previous main drain tests and original acceptance test		
		Verify that the results are within acceptable limits or identify corrective measures		
		Document static and residual pressure readings on a 3-inch by 5-inch tag and secure it to the system pressure gauge		

* A representative sample of sprinklers for testing must consist of one (1) percent of the sprinklers installed of the same type, with a minimum of four (4) sprinklers sampled. Submit sprinklers to a recognized testing laboratory (NRTL) for these tests.

E. Site Water Supply

Frequency	Component	Task	Record of Completion	Date
Annually	Control valves (sealed, locked, or electrically supervised)	Verify proper valve position		
	Water Level (with remote electric supervision of water level)	Verify proper water level in tank.		
	Tank	Inspect exterior for condition, damage, corrosion, and accessibility		
	Cathodic Protection	Inspect to ensure proper operation		
2 Years	Control Valves	Operate valve through entire travel to verify function		
		Lubricate valves and stems to ensure operability		
		Verify that valve supervisory switches detect a change in valve position		
	Water Level Alarms and Level Indicators	Test water level alarms to verify operability and set points.		
	Automatic Fill Valve	Actuate valve automatically by lowering the water level in the tank		
		Measure refill rate and record data.		
Tank Vent	Inspect and clean tank vents.			
3 Years	Tank (without cathodic protection)	Conduct internal tank inspection to determine condition and amount of corrosion.		
5 Years	Tanks (with cathodic protection)	Conduct internal tank inspection to determine condition and amount of corrosion.	The facility is not old enough nor have system modifications or repairs been made to have required this testing.	
	Pressure Gauges	Calibrate or replace gauges		
	Check Valves	Inspect interior of valves.		
	Level Indicator Test	Calibrate level indicator		

Frequency	Component	Task	Record of Completion	Date
	Automatic Fill Valve	Perform internal inspection of automatic fill valve.		



F. Fire Department Connections

Hose outlets and FDCs inspection, test and maintenance is conducted with the wet pipe sprinkler system. See Section C – Wet Pipe Sprinklers for more information



G. Fire Pump System

Fire Pump 1

Frequency	Component	Task	Record of Completion	Date	Issues
Monthly	Pump House	Inspect for proper condition, ventilation, and heating	Yes	08/20/2019 10/29/2019	05/06/2020 Pump started smoking 06/02/2020 Churn not performed
	Pressure Gauges	Check reading and verify gauge operability	Yes	11/21/2019	10/21/2020 Churn not performed
				12/04/2019	11/10/2020 Churn not performed
	Controllers	Inspect electric connections	Yes	01/09/2020	12/07/2020 Churn not performed
		Operate manual and automatic starting methods	Yes	02/07/2020 03/20/2020	01/05/2021 Churn not performed 02/09/2021 Churn not performed
		Verify that automatic controllers are in the automatic (AUTO) setting	Yes	04/20/2020 05/06/2020 06/02/2020	03/31/2021 Relief valves not operated Churn not performed
	Pumps	Start and churn to verify operability. (Where equipment permits, allow water to flow back to the source.) [Operate electric pumps for 10 minutes.]	Yes	08/10/2020	05/18/2021 Churn not performed
				09/11/2020	06/22/2021 Churn not performed
				10/21/2020	07/02/2021
				11/10/2020	Melted packing clogging drain
12/07/2020		Reducer is showing heavy signs of corrosion			
Verify operation of relief valves	Yes	01/05/2021	Noticeable vibrations and shavings after running.		
		02/09/2021	Brushing needs replacement		
		03/31/2021	Churn not performed		
		05/18/2021	08/05/2021 Churn not performed		
		06/22/2021	01/10/2022		
		07/02/2021	Vibrations coming from pump on startup, unable to run for 10 minutes		
		08/05/2021			
09/08/2021					
11/03/2021					
12/01/2021					
01/10/2022					
				RHT Fire Pump 1	

Frequency	Component	Task	Record of Completion	Date	Issues
	Pump House	Check packing leakage for proper water lubrication			
		Verify proper drainage			
	Controllers	Resolve all trouble indications			
	Control valves	Verify proper valve position	Yes	08/20/2019 10/29/2019 11/21/2019 12/04/2019 01/09/2020 02/07/2020 03/20/2020 04/20/2020 05/06/2020 06/02/2020 08/10/2020 09/11/2020 10/21/2020 11/10/2020 12/07/2020 01/05/2021 02/09/2021 03/31/2021 05/18/2021 06/22/2021 07/02/2021 08/05/2021 09/08/2021 11/03/2021 12/01/2021 01/10/2022	

Frequency	Component	Task	Record of Completion	Date	Issues
				RHT Fire Pump 1	
Annually	Control Valves	Operate valve through entire travel to verify function	Yes	06/22/2021	
2 Years	Control Valves Pumps	Lubricate valves and stems to ensure operability	Yes	06/22/2021	
		Verify that valve supervisory switches detect a change in valve position			
		Check coupling alignment to ensure that the shaft is aligned			06/22/2021 Not performed
	Pumps Relief valves	Check pump shaft end play			06/22/2021 Not performed
		Lubricate bearings	Yes	06/22/2021	
	Calibrate valves			06/22/2021 Not performed	
Emergency power supply	Test to verify availability and capacity for pump motor	Yes	06/22/2021		
5 Years	Pump	Conduct flow test to verify pump output. Test may be through a flow meter returning the water to a storage reservoir or through the test header. Recirculation of water to the suction piping is not permitted. In a multi-pump installation, each pump may be tested separately at not less than 100 percent design capacity for 30 minutes.			Facility is not old enough to have required this testing.

Fire Pump 2

Frequency	Component	Task	Record of Completion	Date	Issues
Monthly	Pump House	Inspect for proper condition, ventilation, and heating	Yes	08/20/2019 11/21/2019	01/09/2020 Pump smoking from bearings, further investigation needed, pump should not be run anymore, until issue is resolved. 02/07/2020 Churn not performed, Did not operate pump due to smoking issue, possible air leak in suction line or pump packing failure. 04/20/2020 Pump still smoking, after troubleshooting identified packing is overheating and not allowing water to cool the pump shaft. Recommend packing replacement. 05/06/2020 Pump still smoking, after troubleshooting identified packing is overheating and not allowing water to cool the pump shaft. Recommend packing replacement. 07/02/2020 28. Upon arrival placed system on test, & isolated Fire Pump #2. After previously reassembling packing & recharging system we turned Fire pump on & ran for the full 10 mins. Both Pumps need to be opened up, cleaned, & repacked so we can adjust packing to proper drip rate, & make adjustments as we run pump. After repacking recommend running weekly. 09/11/2020 Churn not performed 10/21/2020 Churn not performed 11/10/2020 Churn not performed
	Pressure Gauges	Check reading and verify gauge operability	Yes	12/04/2019 01/09/2020	
	Controllers	Inspect electric connections	Yes	02/07/2020	
		Operate manual and automatic starting methods	Yes	04/20/2020 05/06/2020	
		Verify that automatic controllers are in the automatic (AUTO) setting	Yes	07/02/2020 08/10/2020 09/11/2020	
	Pumps	Start and churn to verify operability. (Where equipment permits, allow water to flow back to the source.) [Operate electric pumps for 10 minutes.]	Yes	10/21/2020 11/10/2020 12/07/2020 01/05/2021	
			Yes	02/09/2021 03/31/2021	
		Verify operation of relief valves	Yes	05/18/2021 07/02/2021 08/05/2021 09/08/2021 11/03/2021 12/01/2021 01/10/2022	

Frequency	Component	Task	Record of Completion	Date	Issues
					12/07/2020 Churn not performed 01/05/2021 Churn not performed 02/09/2021 Churn not performed 03/31/2021 1. 1/2" x 1/4" reducer for sensing line gauge above FP by 8" check valve has pin hole leak needs to be replaced. 2. 2 Bolts for 8" check valve (Tyco CV-1) have rusted & need to be replaced. 05/18/2021 Churn not performed 07/02/2021 Churn not performed 08/05/2021 Churn not performed 2 bolts on check valve face plate need replacement due to heavy corrosion 09/08/2021 2 bolts on check valve face plate need replacement 11/03/2021 2 bolts on 8" check valve have rusted and need to be replaced 12/01/2021 Churn not performed 01/10/2022 Pump began smoking after 5 minutes Churn not performed
	Pump House	Check packing leakage for proper water lubrication			
		Verify proper drainage			
	Controllers	Resolve all trouble indications			
	Control valves	Verify proper valve position	Yes	08/20/2019 10/29/2019 11/21/2019 12/04/2019 01/09/2020 02/07/2020 03/20/2020	

Frequency	Component	Task	Record of Completion	Date	Issues
				04/20/2020 05/06/2020 06/02/2020 08/10/2020 09/11/2020 10/21/2020 11/10/2020 12/07/2020 01/05/2021 02/09/2021 03/31/2021 05/18/2021 07/02/2021 08/05/2021 09/08/2021 11/03/2021 12/01/2021 01/10/2022	
Annually	Control Valves	Operate valve through entire travel to verify function			No record of annual or 2-year test ever having been performed for this pump.
2 Years	Control Valves Pumps	Lubricate valves and stems to ensure operability			
		Verify that valve supervisory switches detect a change in valve position			
		Check coupling alignment to ensure that the shaft is aligned			
	Pumps Relief valves	Check pump shaft end play			
		Lubricate bearings			
		Calibrate valves			

Frequency	Component	Task	Record of Completion	Date	Issues
	Emergency power supply	Test to verify availability and capacity for pump motor			
5 Years	Pump	Conduct flow test to verify pump output. Test may be through a flow meter returning the water to a storage reservoir or through the test header. Recirculation of water to the suction piping is not permitted. In a multi-pump installation, each pump may be tested separately at not less than 100 percent design capacity for 30 minutes.			Facility is not old enough to have required this testing.

Foam Fire Pump 1

Frequency	Component	Task	Record of Completion	Date	Issues
Monthly	Pump House	Inspect for proper condition, ventilation, and heating	Yes	08/20/2019 11/21/2019	09/11/2020 Pump off due to underground leak 11/10/2020 Pump off due to underground leak
	Pressure Gauges	Check reading and verify gauge operability	Yes	12/04/2019 01/09/2020	12/07/2020 Pump off due to underground leak 01/05/2021 Pump off due to underground leak
	Controllers	Inspect electric connections	Yes	02/07/2020	02/09/2021 Pump off due to underground leak
		Verify that automatic controllers are in the automatic (AUTO) setting	Yes	03/20/2020 04/20/2020	03/31/2021 Pump off due to underground leak 05/18/2021 Pump off due to underground leak
		Operate manual and automatic starting methods		05/06/2020 07/02/2020	06/22/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak
	Pumps	Start and churn to verify operability. (Where equipment permits, allow water to flow back to the source.) [Operate electric pumps for 10 minutes.] Verify operation of relief valves		08/10/2020 09/11/2020 11/10/2020 12/07/2020	07/02/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak
				01/05/2021 02/09/2021	
				03/31/2021	
	Controllers Batteries	Resolve all trouble indications	Yes	05/18/2021 06/22/2021 07/02/2021 08/05/2021 09/08/2021 11/03/2021 12/01/2021 01/10/2022	08/05/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak 11/03/2021 Slight leak under pump recommend replacing seal. Pump off due to underground leak 12/01/2021 Slight leak under pump recommend replacing seal. Pump off due to underground leak 01/10/2022 Slight leak under pump recommend replacing seal. Pump off due to underground leak

Frequency	Component	Task	Record of Completion	Date	Issues
		Verify proper valve position	Yes	08/20/2019 11/21/2019 12/04/2019 01/09/2020 02/07/2020 03/20/2020 04/20/2020 05/06/2020 07/02/2020 08/10/2020 09/11/2020 11/10/2020 12/07/2020 01/05/2021 02/09/2021 03/31/2021 05/18/2021 06/22/2021 07/02/2021 08/05/2021 09/08/2021 11/03/2021 12/01/2021 01/10/2022	09/11/2020 Pump off due to underground leak 11/10/2020 Pump off due to underground leak 12/07/2020 Pump off due to underground leak 01/05/2021 Pump off due to underground leak 02/09/2021 Pump off due to underground leak 03/31/2021 Pump off due to underground leak 05/18/2021 Pump off due to underground leak 06/22/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak 07/02/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak 08/05/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak 09/08/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak 11/03/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak 12/01/2021 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak 01/10/2022 AFFF solution seeping out of the 1" discharge line from jockey pump. 1" check valve may need replacement. AFFF is leaking from the pump, seals may need replacement that is rated for AFFF or equivalent Pump off due to underground leak 11/03/2021 Slight leak under pump recommend replacing seal. Pump off due to underground leak 12/01/2021 Slight leak under pump recommend replacing seal. Pump off due to underground leak 01/10/2022 Slight leak under pump recommend replacing seal. Pump off due to underground leak

Frequency	Component	Task	Record of Completion	Date	Issues
	Control valves	Operate valve through entire travel to verify function	Yes	06/22/2021	
	Control Valves	Lubricate valves and stems to ensure operability			06/22/2021 Not performed
Semi-Annually	Foam proportioning system/foam pumps	Test pump to ensure operability.			
		Inspect proportioning system for proper valve alignment and system condition			
		Flush pumps after operation			
Annually	Control valves	Verify that valve supervisory switches detect a change in valve position			
2 Years	Control Valves Pumps	Check coupling alignment to ensure that the shaft is aligned			06/22/2021 Not performed
		Check pump shaft end play			06/22/2021 Not performed
		Lubricate bearings	Yes	06/22/2021	
	Pumps Relief valves Emergency power supply	Calibrate valves			06/22/2021 Not performed
		Test to verify availability and capacity for pump motor			06/22/2021 Not performed
5 Years	Pump	Conduct flow test to verify pump output. Test may be through a flow meter returning the water to a storage reservoir or through the test header. Recirculation of water to the suction piping is not permitted. In a multi-pump installation, each pump may be			Facility is not old enough to have required this testing.



Frequency	Component	Task	Record of Completion	Date	Issues
		tested separately at not less than 100 percent design capacity for 30 minutes.			



Foam Fire Pump 2

Frequency	Component	Task	Record of Completion	Date	Issues
Monthly	Pump House	Inspect for proper condition, ventilation, and heating	Yes	08/20/2019 11/21/2019	09/11/2020 Pump off due to underground leak 10/21/2020 Pump off due to underground leak
	Pressure Gauges	Check reading and verify gauge operability	Yes	12/04/2019 01/09/2020	11/10/2020 Pump off due to underground leak 12/07/2020 Pump off due to underground leak
	Controllers	Inspect electric connections	Yes	02/07/2020	01/05/2021 Pump off due to underground leak
		Verify that automatic controllers are in the automatic (AUTO) setting	Yes	03/20/2020 04/20/2020	02/09/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak
		Operate manual and automatic starting methods		05/06/2020 07/02/2020	03/31/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak
	Pumps	Start and churn to verify operability. (Where equipment permits, allow water to flow back to the source.) [Operate electric pumps for 10 minutes.]	Yes	08/10/2020	05/18/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak
				09/11/2020	02/09/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak
		10/21/2020		03/31/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak	
		11/10/2020		06/22/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak	
		12/07/2020		07/02/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak	
01/05/2021		08/05/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak			
02/09/2021		09/08/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak			
03/31/2021	11/03/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak				
05/18/2021	12/01/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution or equivalent. Pump off due to underground leak				
06/22/2021	01/10/2022 AFFF buildup under pump. Left out of service				

Frequency	Component	Task	Record of Completion	Date	Issues
					06/22/02021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution or equivalent. Left out of service 08/05/2021 Slight AFFF leak found below pump, recommend replacing seal for one rated for corrosive liquids. Left out of service 09/08/2021 Slight AFFF leak found below pump, recommend replacing seal for corrosive Liquids. Pump off due to underground leak 11/03/2021 Slight leak under pump recommend replacing seal. Pump off due to underground leak 12/01/2021 Slight leak under pump recommend replacing seal. Pump off due to underground leak 01/10/2022 Slight leak under pump recommend replacing seal. Pump off due to underground leak
	Controllers	Resolve all trouble indications			
Semi-Annually	Foam proportioning system/foam pumps	Test pump to ensure operability.			
		Inspect proportioning system for proper valve alignment and system condition			
		Flush pumps after operation			
Annually	Control valves	Verify proper valve position	Yes	08/20/2019 11/21/2019 12/04/2019 01/09/2020 02/07/2020 03/20/2020 04/20/2020 05/06/2020 07/02/2020 08/10/2020	09/11/2020 Pump off due to underground leak 10/21/2020 Pump off due to underground leak 11/10/2020 Pump off due to underground leak 12/07/2020 Pump off due to underground leak 01/05/2021 Pump off due to underground leak 02/09/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak

Frequency	Component	Task	Record of Completion	Date	Issues
				09/11/2020 10/21/2020 11/10/2020 12/07/2020 01/05/2021 02/09/2021 03/31/2021 05/18/2021 06/22/2021 07/02/2021 08/05/2021 09/08/2021 11/03/2021 12/01/2021 01/10/2022	03/31/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak 05/18/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak 02/09/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak 03/31/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak 05/18/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution. Pump off due to underground leak 06/22/2021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution or equivalent. Pump off due to underground leak 07/02/2021 AFFF buildup under pump. Left out of service 06/22/02021 AFFF build up found under pump, recommend replacing seal in pump rated for AFFF solution or equivalent. Left out of service 08/05/2021 Slight AFFF leak found below pump, recommend replacing seal for one rated for corrosive liquids. Left out of service 09/08/2021 Slight AFFF leak found below pump, recommend replacing seal for corrosive Liquids. Pump off due to underground leak 11/03/2021 Slight leak under pump recommend replacing seal. Pump off due to underground leak

Frequency	Component	Task	Record of Completion	Date	Issues
					12/01/2021 Slight leak under pump recommend replacing seal. Pump off due to underground leak 01/10/2022 Slight leak under pump recommend replacing seal. Pump off due to underground leak
2 Years	Control Valves	Operate valve through entire travel to verify function	Yes	06/22/2021	
		Lubricate valves and stems to ensure operability			06/22/2021 Not performed
		Verify that valve supervisory switches detect a change in valve position			
	Pumps	Check coupling alignment to ensure that the shaft is aligned			06/22/2021 Not performed
		Check pump shaft end play			06/22/2021 Not performed
		Lubricate bearings	Yes	06/22/2021	
	Relief valves	Calibrate valves			06/22/2021 Not performed
Emergency power supply	Test to verify availability and capacity for pump motor			06/22/2021 Not performed	
5 Years	Pump	Conduct flow test to verify pump output. Test may be through a flow meter returning the water to a storage reservoir or through the test header. Recirculation of water to the suction piping is not permitted. In a multi-pump installation, each pump may be tested separately at not less than 100 percent design capacity for 30 minutes.			Facility is not old enough to have required this testing.

H. Fire Alarm and Mass Notification System

Mass Notification ITM items should be part of this summary (however these requirements are new to the October 2021 edition of UFC 3-601-02 and are shown shaded).

FLC Adit 1 Fire Alarm MNS Maintenance Summary

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
Annually	Control Panel and Annunciator Equipment (monitored)		Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs, one of each type) and operation of notification appliances and auxiliary functions (outputs, one of each type).	Yes	12/20/2019 (FLC [redacted] Node 1 FA 19120), 12/27/2019 (FLC [redacted] and Node 6 19120), 09/29/2020 (FLC [redacted] Node 6 20122), 11/15/2021 (FLC [redacted] Node 6 FA - Nov 15, 2021), 11/17/2021 (FLC [redacted] Node 2), 11/17/2021 (FLC [redacted] Node 1 FA),
			Verify that all lamps and LEDs are illuminated.	Yes	12/20/2019 (FLC [redacted] ode 1 FA 19120), 12/27/2019 (FLC [redacted] and Node 6 19120), 09/29/2020 (FLC [redacted] ode 6 20122), 11/15/2021 (FLC [redacted] ode 6 FA - Nov 15, 2021), 11/17/2021 (FLC [redacted] ode 2 FA), 11/17/2021 (FLC [redacted] ode 1 FA),
			Load test backup batteries using a meter (when provided)	Yes	12/20/2019 (FLC [redacted] ode 1 FA 19120), 12/27/2019 (FLC [redacted] and Node 6 19120), 09/29/2020 (FLC [redacted] ode 6 20122), Batteries for Node 6 failed the load test. 11/15/2021 (FLC [redacted] ode 6 FA - Nov 15, 2021), Batteries for Node 6 failed the load test. 11/17/2021 (FLC [redacted] ode 2 FA), 11/17/2021 (FLC [redacted] ode 1 FA),
			Verify condition of power supplies and batteries.	Yes	12/20/2019 (FLC [redacted] ode 1 FA 19120), 12/27/2019 (FLC [redacted] and Node 6 19120), 09/29/2020 (FLC [redacted] ode 6 20122),

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date	(b) (3) (A)
					11/15/2021 (FLC 11/17/2021 (FLC 11/17/2021 (FLC	ode 6 FA - Nov 15, 2021), ode 2 FA), ode 1 FA),
			Resolve any trouble indications			
	Remote Power Supplies and Notification Appliance Circuit Power Extenders		Verify that all lamps and LEDs are illuminated.	Yes	12/20/2019 (FLC 12/27/2019 (FLC 09/29/2020 (FLC 11/17/2021 (FLC 11/17/2021 (FLC	ode 1 FA 19120), and Node 6 19120), ode 6 20122), ode 2 FA), ode 1 FA),
			Load test backup batteries using a meter (when provided)	Yes	12/20/2019 (FLC 12/27/2019 (FLC 09/29/2020 (FLC 11/17/2021 (FLC 11/17/2021 (FLC Batteries Node 1 Batteries in pow CHG120 RPS N1	ode 1 FA 19120 0 & PM-9 failed the load test. and Node 6 19120), 20122), ode 2 FA), ode 1 FA), y N8 UGPH, CAB1B RPS 3, fisher IRAC-2 failed.
			Verify condition of power supplies and batteries.	Yes	12/20/2019 (FLC 12/27/2019 (FLC 09/29/2020 (FLC 11/17/2021 (FLC 11/17/2021 (FLC	ode 1 FA 19120), and Node 6 19120), ode 6 20122), ode 2 FA), ode 1 FA),
	Initiating devices	Manual Fire Alarm Stations	Verify station is accessible (visual)	Yes	12/20/2019 (FLC 12/27/2019 (FLC 11/17/2021 (FLC 11/17/2021 (FLC	ode 1 FA 19120), and Node 6 19120), ode 2 FA), ode 1 FA),
		Radiant Energy-Sensing Detectors (Optical Detectors)	If used for releasing service, inhibit releasing function	Yes	12/27/2019 (FLC 09/29/2020 (FLC 11/15/2021 (FLC	and Node 6 19120), ode 6 20122), ode 6 FA - Nov 15, 2021),
			Test to verify alarm initiation and receipt	Yes	12/27/2019 (FLC 09/29/2020 (FLC	and Node 6 19120), ode 6 20122),

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
					11/15/2021 (FLC [REDACTED] Node 6 FA - Nov 15, 2021),
			Verify that no facility changes affect performance	Yes	12/27/2019 (FLC [REDACTED] and Node 6 19120), 09/29/2020 (FLC [REDACTED] Node 6 20122), 11/15/2021 (FLC [REDACTED] Node 6 FA - Nov 15, 2021),
			Verify alignment of the positioning markings at all adjustment locations	No	
			If used for releasing service, configure system for automatic operation	Yes	12/27/2019 (FLC [REDACTED] and Node 6 19120), 09/29/2020 (FLC [REDACTED] Node 6 20122), 11/15/2021 (FLC [REDACTED] Node 6 FA - Nov 15, 2021),
			If used for releasing service, restore to releasing service	Yes	12/27/2019 (FLC [REDACTED] and Node 6 19120), 09/29/2020 (FLC [REDACTED] Node 6 20122), 11/15/2021 (FLC [REDACTED] Node 6 FA - Nov 15, 2021),
		Smoke Detectors (Single-station)	Test with manufacturer-approved smoke simulant to verify smoke entry and alarm initiation and receipt.	Yes	12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] and Node 6 19120), 11/17/2021 (FLC [REDACTED] Node 2 FA), 11/17/2021 (FLC [REDACTED] Node 1 FA),
			Verify that no facility changes affects performance.		12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] and Node 6 19120), 11/17/2021 (FLC [REDACTED] Node 2 FA), 11/17/2021 (FLC [REDACTED] Node 1 FA),
		Supervisory Devices	Test to verify initiation and receipt of supervisory alarm	Yes	12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] and Node 6 19120),
	Notification Appliances and Voice Communication (telephone, speakers,		Test to verify operability	Yes	12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] and Node 6 19120), 11/17/2021 (FLC [REDACTED] Node 1 FA), A/Vs not tested.

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	horns, and strobe lights)				
	Radio Alarm Transmitters and Receivers		Test to verify operability		12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] and Node 6 19120), 09/29/2020 (FLC [REDACTED] Node 6 20122), 11/15/2021 (FLC [REDACTED] Node 6 FA - Nov 15, 2021), 11/17/2021 (FLC [REDACTED] Node 2 FA), Kingfisher transmitter not sending signals to RDC.
	Fire Alarm Control Panel with Integrated Mass Notification (FMCP)		Test to verify proper receipt of signals (inputs) from Local Operating Consoles (LOCs) and the Installation's site-wide system and operation of notification appliances and auxiliary functions (outputs).		
	LOCs		Verify station is accessible (visual).		
	Text Message Signs		Test to verify operability		
2 Years	Initiating Devices	Manual Fire Alarm Stations	Operate to verify alarm receipt	Yes	12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] 2 and Node 6 19120), 11/17/2021 (FLC [REDACTED] Node 2 FA) 11/17/2021 (FLC [REDACTED] Node 1 FA),
Heat Detectors (restorable)		Test with a heat source to verify alarm initiating and receipt	Yes	12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] 2 and Node 6 19120), 11/17/2021 (FLC [REDACTED] Node 2 FA), 11/17/2021 (FLC [REDACTED] Node 1 FA),	
		Verify that no facility changes affect performance	Yes	12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] 2 and Node 6 19120), 11/17/2021 (FLC [REDACTED] Node 2 FA),	

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
					11/17/2021 (FLC [REDACTED] Node 1 FA),
		Smoke Detectors	Test with manufacturer-approved smoke simulat to verify smoke entry and alarm initiation and receipt	Yes	12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] and Node 6 19120), 11/17/2021 (FLC [REDACTED] Node 2 FA), 11/17/2021 (FLC [REDACTED] Node 1 FA),
			Verify that no facility changes affect performance	Yes	12/20/2019 (FLC [REDACTED] Node 1 FA 19120), 12/27/2019 (FLC [REDACTED] and Node 6 19120), 11/17/2021 (FLC [REDACTED] Node 2 FA), 11/17/2021 (FLC [REDACTED] Node 1 FA),
		Supervisory Devices	Test to verify initiation and receipt of supervisory alarm	Yes	12/27/2019 (FLC [REDACTED] and Node 6 19120),
	FMCP and LOCs		Operate microphone to verify proper operation		
			Operate all pre-recorded message activation switches to verify proper operation.		
			Operate all notification zone selection switches, if provided, to verify proper operation.		
5 Years	Smoke Detectors		Test detector sensitivity to ensure that the detector has remained within its listed and marked sensitivity range (or 4 percent obscuration light gray smoke, if not marked)		Facility is not old enough to have required this testing.

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
10 Years	Initiating devices	Carbon Monoxide Detectors	Replace detectors		
		Radiant Energy-Sensing Detectors (Optical Detectors)	Verify manufacturer's service life for detection elements. UV detection element's normal service life is 10 years; others vary by manufacturer		
			Replace detectors which have exceeded manufacturer's recommended service life for detection elements.		
20 Years	Initiating devices	Smoke Detectors	Replace detectors		
		Air Sampling Smoke Detectors	Replace detection element		
	Control Panel and Annunciator Equipment (monitored)		Verify manufacturer's service life for control elements		
			Verify manufacturer has continued technical and parts support for the specific model		
			Replace control equipment that has exceeded manufacturer's recommended service life limits or if the manufacturer has ceased to provide technical and parts support		

FLC Adit 2 Fire Alarm MNS Maintenance Summary

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date	(b) (3) (A)
Annually	Control Panel and Annunciator Equipment (monitored)		Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs, one of each type) and operation of notification appliances and auxiliary functions (outputs, one of each type).	Yes	05/13/2019 (FL Node11), 01/09/2020 (FL Node11 19120), 11/30/2020 (FL Node11 20122 - November 30, 2020), 02/11/2022 (FL Node 11 FA)	
			Verify that all lamps and LEDs are illuminated.	Yes	05/13/2019 (FL Node11), 01/09/2020 (FL Node11 19120), 11/30/2020 (FL Node11 20122 - November 30, 2020), 02/11/2022 (FL Node 11 FA),	
			Load test backup batteries using a meter (when provided)	Yes	05/13/2019 (FL Node11), 01/09/2020 (FL Node11 19120), 11/30/2020 (FL Node11 20122 - November 30, 2020),	
			Verify condition of power supplies and batteries.	Yes	05/13/2019 (FL Node11), 01/09/2020 (FL Node11 19120), 11/30/2020 (FL Node11 20122 - November 30, 2020)	
			Resolve any trouble indications			
	Remote Power Supplies and Notification Appliance		Verify that all lamps and LEDs are illuminated.	Yes	05/13/2019 (FL Node11), 01/09/2020 (FL Node11 19120), 11/30/2020 (FL Node11 20122 - November 30, 2020), 02/11/2022 (FL Node 11 FA),	

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date	(b) (3) (A)
	Circuit Power Extenders		Load test backup batteries using a meter (when provided)	Yes	05/13/2019 (FLC [redacted] Node11), 01/09/2020 (FLC [redacted] Node11 19120), 11/30/2020 (FLC [redacted] Node11 20122 - November 30, 2020),	
			Verify condition of power supplies and batteries.	Yes	05/13/2019 (FLC [redacted] Node11), 01/09/2020 (FLC [redacted] Node11 19120), 11/30/2020 (FLC [redacted] Node11 20122 - November 30, 2020),	
	Initiating devices	Manual Fire Alarm Stations	Verify station is accessible (visual)	Yes	05/13/2019 (FLC [redacted] Node11), 01/09/2020 (FLC [redacted] Node11 19120), 11/30/2020 (FLC [redacted] Node11 20122 - November 30, 2020), 02/11/2022 (FLC [redacted] Node 11 FA),	
	Notification Appliances and Voice Communication (telephone, speakers, horns, and strobe lights)		Test to verify operability	Yes	05/13/2019 (FLC [redacted] Node11), 01/09/2020 (FLC [redacted] Node11 19120), 11/30/2020 (FLC [redacted] Node11 20122 - November 30, 2020),	
	Radio Alarm Transmitters and Receivers		Test to verify operability		05/13/2019 (FLC [redacted] Node11), 01/09/2020 (FLC [redacted] Node11 19120), 11/30/2020 (FLC [redacted] Node11 20122 - November 30, 2020), Kingfisher transmitter not sending signals to RDC.	
	Fire Alarm Control Panel with Integrated Mass		Test to verify proper receipt of signals (inputs) from Local Operating Consoles (LOCs) and the Installation's site-wide			

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Notification (FMCP)		system and operation of notification appliances and auxiliary functions (outputs).		
	LOCs		Verify station is accessible (visual).		
	Text Message Signs		Test to verify operability		
2 Years	Initiating Devices	Manual Fire Alarm Stations	Operate to verify alarm receipt	Yes	05/13/2019 (FLC Node11), 01/09/2020 (FLC Node11 19120), 11/30/2020 (FLC Node11 20122 - November 30, 2020), 02/11/2022 (FLC Node 11 FA),
		Heat Detectors (restorable)	Test with a heat source to verify alarm initiating and receipt	Yes	05/13/2019 (FLC Node11), 01/09/2020 (FLC Node11 19120), 11/30/2020 (FLC Node11 20122 - November 30, 2020), 02/11/2022 (FLC Node 11 FA),
			Verify that no facility changes affect performance	Yes	05/13/2019 (FLC Node11), 01/09/2020 (FLC Node11 19120), 11/30/2020 (FLC Node11 20122 - November 30, 2020), 02/11/2022 (FLC Node 11 FA)
	FMCP and LOCs		Operate microphone to verify proper operation		
			Operate all pre-recorded message activation switches to verify proper operation.		
			Operate all notification zone selection switches, if		

(b) (3) (A)

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
			provided, to verify proper operation.		
5 Years	Smoke Detectors		Test detector sensitivity to ensure that the detector has remained within its listed and marked sensitivity range (or 4 percent obscuration light gray smoke, if not marked)		Facility is not old enough to have required this testing.
10 Years	Initiating devices	Radiant Energy-Sensing Detectors (Optical Detectors)	Verify manufacturer's service life for detection elements. UV detection element's normal service life is 10 years; others vary by manufacturer		
		Radiant Energy-Sensing Detectors (Optical Detectors)	Replace detectors which have exceeded manufacturer's recommended service life for detection elements.		
		Smoke Detectors	Replace detectors		
20 Years	Initiating devices		Verify manufacturer's service life for control elements		
	Control Panel and Annunciator Equipment (monitored)		Verify manufacturer has continued technical and parts support for the specific model		
			Replace control equipment that has exceeded manufacturer's		

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
			recommended service life limits or if the manufacturer has ceased to provide technical and parts support		

FLC Adit 3 Fire Alarm MNS Maintenance Summary

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date	(b) (3) (A)
Annually	Control Panel and Annunciator Equipment (monitored)		Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs, one of each type) and operation of notification appliances and auxiliary functions (outputs, one of each type).	Yes	05/24/2019 (FLC Node 33 and Node 37), 03/27/2020 (FLC Node 33 and Node 37 19120), 04/30/2021 (FLC Node 33 and Node 37 20122)	
			Verify that all lamps and LEDs are illuminated.	Yes	05/24/2019 (FLC Node 33 and Node 37), 03/27/2020 (FLC Node 33 and Node 37 19120), 04/30/2021 (FLC Node 33 and Node 37 20122)	
			Load test backup batteries using a meter (when provided)	Yes	05/24/2019 (FLC Node 33 and Node 37), 03/27/2020 (FLC Node 33 and Node 37 19120), 04/30/2021 (FLC Node 33 and Node 37 20122)	
			Verify condition of power supplies and batteries.	Yes	05/24/2019 (FLC Node 33 and Node 37), 03/27/2020 (FLC Node 33 and Node 37 19120), 04/30/2021 (FLC Node 33 and Node 37 20122)	
			Resolve any trouble indications			
	Remote Power Supplies and Notification Appliance Circuit Power Extenders		Verify that all lamps and LEDs are illuminated.	Yes	05/24/2019 (FLC Node 33 and Node 37), 03/27/2020 (FLC Node 33 and Node 37 19120), 04/30/2021 (FLC Node 33 and Node 37 20122)	
			Load test backup batteries using a meter (when provided)	Yes	05/24/2019 (FLC Node 33 and Node 37), 03/27/2020 (FLC Node 33 and Node 37 19120), 04/30/2021 (FLC Node 33 and Node 37 20122)	
			Verify condition of power supplies and batteries.	Yes	05/24/2019 (FLC Node 33 and Node 37), 03/27/2020 (FLC Node 33 and Node 37 19120), 04/30/2021 (FLC Node 33 and Node 37 20122)	

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Initiating devices	Manual Fire Alarm Stations	Verify station is accessible (visual)	Yes	05/24/2019 (FLC [REDACTED] Node 33 and Node 37), 03/27/2020 (FLC [REDACTED] Node 33 and Node 37 19120), 04/30/2021 (FLC [REDACTED] Node 33 and Node 37 20122),
	Notification Appliances and Voice Communication (telephone, speakers, horns, and strobe lights)		Test to verify operability	Yes	05/24/2019 (FLC [REDACTED] Node 33 and Node 37), 03/27/2020 (FLC [REDACTED] Node 33 and Node 37 19120), 04/30/2021 (FLC [REDACTED] Node 33 and Node 37 20122)
	Radio Alarm Transmitters and Receivers		Test to verify operability	Yes	05/24/2019 (FLC [REDACTED] Node 33 and Node 37), 03/27/2020 (FLC [REDACTED] Node 33 and Node 37 19120), Kingfisher transmitters and not transmit signals to RDC. 04/30/2021 (FLC [REDACTED] Node 33 and Node 37 20122)
	Fire Alarm Control Panel with Integrated Mass Notification (FMCP)		Test to verify proper receipt of signals (inputs) from Local Operating Consoles (LOCs) and the Installation's site-wide system and operation of notification appliances and auxiliary functions (outputs).		
	LOCs		Verify station is accessible (visual).		
	Text Message Signs		Test to verify operability		
2 Years	Initiating Devices	Manual Fire Alarm Stations	Operate to verify alarm receipt	Yes	05/24/2019 (FLC [REDACTED] Node 33 and Node 37), 03/27/2020 (FLC [REDACTED] Node 33 and Node 37 19120), 04/30/2021 (FLC [REDACTED] Node 33 and Node 37 20122)

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
		Heat Detectors (restorable)	Test with a heat source to verify alarm initiating and receipt	Yes	05/24/2019 (FLC [REDACTED] Node 33 and Node 37), FHD N37L2M53 d [REDACTED] activate. 03/27/2020 (FLC [REDACTED] Node 33 and Node 37 19120), 04/30/2021 (FLC [REDACTED] Node 33 and Node 37 20122)
			Verify that no facility changes affect performance	Yes	05/24/2019 (FLC [REDACTED] Node 33 and Node 37), 03/27/2020 (FLC [REDACTED] Node 33 and Node 37 19120), 04/30/2021 (FLC [REDACTED] Node 33 and Node 37 20122)
		Supervisory Devices	Test to verify initiation and receipt of supervisory alarm	Yes	05/24/2019 (FLC [REDACTED] Node 33 and Node 37), 03/27/2020 (FLC [REDACTED] Node 33 and Node 37 19120), 04/30/2021 (FLC [REDACTED] Node 33 and Node 37 20122)
	FMCP and LOCs		Operate microphone to verify proper operation		
			Operate all pre-recorded message activation switches to verify proper operation.		
			Operate all notification zone selection switches, if provided, to verify proper operation.		
5 Years	Smoke Detectors		Test detector sensitivity to ensure that the detector has remained within its listed and marked sensitivity range (or 4 percent obscuration light gray smoke, if not marked)		Facility is not old enough to have required this testing.
	Initiating Devices	Radiant Energy-Sensing Detectors	Verify manufacturer's service life for detection elements. UV detection element's normal service		

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
		(Optical Detectors)	life is 10 years; others vary by manufacturer		
			Replace detectors which have exceeded manufacturer's recommended service life for detection elements.		
20 Years	Initiating devices	Smoke Detectors	Replace detectors		
	Control Panel and Annunciator Equipment (monitored)		Verify manufacturer's service life for control elements		
			Verify manufacturer has continued technical and parts support for the specific model		
			Replace control equipment that has exceeded manufacturer's recommended service life limits or if the manufacturer has ceased to provide technical and parts support		

FLC Adit 6 fire Alarm MNS Maintenance Summary

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date	(b) (3) (A)
Annually	Control Panel and Annunciator Equipment (monitored)		Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs, one of each type) and operation of notification appliances and auxiliary functions (outputs, one of each type).	Yes	11/05/2019 (FLC 10/30/2020 (FLC 11/30/2020 (FLC	Node 53 19120), Node 53 20122), Node 53 FA - Nove 19, 2021)
			Verify that all lamps and LEDs are illuminated.	Yes	11/05/2019 (FLC 10/30/2020 (FLC 11/19/2021 (FLC	Node 53 53 19120), Node 53 20122), Node 53 FA - Nove 19, 2021)
			Load test backup batteries using a meter (when provided)	Yes	11/05/2019 (FLC 10/30/2020 (FLC 11/19/2021 (FLC Batteries for Gam Batteries for Nod	Node 53 19120), FACP failed the load test. Node 53 20122), Node 53 FA - Nove 19, 2021) ACP failed the load test
			Verify condition of power supplies and batteries.	Yes	11/05/2019 (FLC 10/30/2020 (FLC 11/19/2021 (FLC	Node 53 19120), Node 53 20122), Node 53 FA - Nove 19, 2021)
			Resolve any trouble indications			
			Remote Power Supplies and Notification Appliance Circuit Power Extenders		Verify that all lamps and LEDs are illuminated.	Yes
Load test backup batteries using a meter (when provided)	Yes	11/05/2019 (FLC 10/30/2020 (FLC 11/19/2021 (FLC			Node 53 19120), Node 53 20122), Node 53 FA - Nove 19, 2021)	
Verify condition of power supplies and batteries.	Yes	11/05/2019 (FLC 10/30/2020 (FLC 11/19/2021 (FLC			Node 53 19120), Node 53 20122), Node 53 FA - Nove 19, 2021)	

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Initiating devices	Manual Fire Alarm Stations	Verify station is accessible (visual)	Yes	11/05/2019 (FLC Node 53 19120), 10/30/2020 (FLC Node 53 20122), 11/19/2021 (FLC Node 53 FA - Nove 19, 2021)
	Notification Appliances and Voice Communication (telephone, speakers, horns, and strobe lights)		Test to verify operability	Yes	11/05/2019 (FLC Node 53 19120), 10/30/2020 (FLC Node 53 20122),
	Radio Alarm Transmitters and Receivers		Test to verify operability	Yes	11/05/2019 (FLC Node 53 19120), Radio transmitter transmit signals to RDC. 10/30/2020 (FLC Node 53 20122), Radio transmitter transmit signals to RDC. 11/30/2020 (FLC Node 53 FA - Nove 19, 2021)
	Fire Alarm Control Panel with Integrated Mass Notification (FMCP)		Test to verify proper receipt of signals (inputs) from Local Operating Consoles (LOCs) and the Installation's site-wide system and operation of notification appliances and auxiliary functions (outputs).		
	LOCs		Verify station is accessible (visual).		
	Text Message Signs		Test to verify operability		

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
2 Years	Initiating Devices	Manual Fire Alarm Stations	Operate to verify alarm receipt	Yes	11/05/2019 (FLC [REDACTED] Node 53 19120), 10/30/2020 (FLC [REDACTED] Node 53 20122), 11/19/2021 (FLC [REDACTED] Node 53 FA - Nove 19, 2021)
		Heat Detectors (restorable)	Test with a heat source to verify alarm initiating and receipt	Yes	11/05/2019 (FLC [REDACTED] Node 53 19120), 10/30/2020 (FLC [REDACTED] Node 53 20122), 11/19/2021 (FLC [REDACTED] Node 53 FA - Nove 19, 2021) FHD N53L1M41 c activate.
			Verify that no facility changes affect performance	Yes	11/05/2019 (FLC [REDACTED] Node 53 19120), 10/30/2020 (FLC [REDACTED] Node 53 20122), 11/19/2021 (FLC [REDACTED] Node 53 FA - Nove 19, 2021)
		Supervisory Devices	Test to verify initiation and receipt of supervisory alarm	Yes	11/05/2019 (FLC [REDACTED] Node 53 19120), 10/30/2020 (FLC [REDACTED] Node 53 20122),
	FMCP and LOCs		Operate microphone to verify proper operation		
			Operate all pre-recorded message activation switches to verify proper operation.		
			Operate all notification zone selection switches, if provided, to verify proper operation.		
5 Years	Smoke Detectors		Test detector sensitivity to ensure that the detector has remained within its listed and marked sensitivity range (or 4 percent obscuration light gray smoke, if not marked)		Facility is not old enough to have required this testing.

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
		Radiant Energy-Sensing Detectors (Optical Detectors)	Verify manufacturer's service life for detection elements. UV detection element's normal service life is 10 years; others vary by manufacturer		
			Replace detectors which have exceeded manufacturer's recommended service life for detection elements.		
20 Years	Initiating devices	Smoke Detectors	Replace detectors		
	Control Panel and Annunciator Equipment (monitored)		Verify manufacturer's service life for control elements		
			Verify manufacturer has continued technical and parts support for the specific model		
			Replace control equipment that has exceeded manufacturer's recommended service life limits or if the manufacturer has ceased to provide technical and parts support		

FLC Harbor Tunnel Fire Alarm MNS Maintenance Summary

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
Annually	Control Panel and Annunciator Equipment (monitored)		Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs, one of each type) and operation of notification appliances and auxiliary functions (outputs, one of each type).	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
			Verify that all lamps and LEDs are illuminated.	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
			Load test backup batteries using a meter (when provided)	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122),
			Verify condition of power supplies and batteries.	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
		Resolve any trouble indications			
	Remote Power Supplies and Notification		Verify that all lamps and LEDs are illuminated.	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122),

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Appliance Circuit Power Extenders				02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
			Load test backup batteries using a meter (when provided)	Yes	03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), Batteries failed equipment Cabinet #22. 02/16/2022 (FLC Harbor Tunnel Node 31 FA), Batteries leaking acid equipment cabinet #40. Batteries not tested cabinet #38.
			Verify condition of power supplies and batteries.	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
	Initiating devices	Manual Fire Alarm Stations	Verify station is accessible (visual)	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
	Notification Appliances and Voice Communication (telephone, speakers, horns, and strobe lights)		Test to verify operability	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), Two MPS with incorrect printed label noted. 02/16/2022 (FLC Harbor Tunnel Node 31 FA), A/V devices not tested.

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Radio Alarm Transmitters and Receivers		Test to verify operability		02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), Kingfisher transmitter did not transmit signals to RDC. 02/16/2022 (FLC Harbor Tunnel Node 31 FA), Kingfisher transmitter did not transmit signals to RDC.
	Fire Alarm Control Panel with Integrated Mass Notification (FMCP)		Test to verify proper receipt of signals (inputs) from Local Operating Consoles (LOCs) and the Installation’s site-wide system and operation of notification appliances and auxiliary functions (outputs).		
	LOCs		Verify station is accessible (visual).		
	Text Message Signs		Test to verify operability		
2 Years	Initiating Devices	Manual Fire Alarm Stations	Operate to verify alarm receipt	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
		Heat Detectors (restorable)	Test with a heat source to verify alarm initiating and receipt	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122),

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
					02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
			Verify that no facility changes affect performance	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
		Supervisory Devices	Test to verify initiation and receipt of supervisory alarm	Yes	02/11/2020 (FLC Node 21 Harbor Tunnel 19120), 03/02/2020 (FLC Node 31 Harbor Tunnel 19120), 01/29/2021 (FLC Node 21 Harbor Tunnel 20122), 02/04/2021 (FLC Node 31 Harbor Tunnel 20122), 02/15/2022 (FLC Harbor Tunnel Node 21 FA), 02/16/2022 (FLC Harbor Tunnel Node 31 FA),
	FMCP and LOCs		Operate microphone to verify proper operation		
			Operate all pre-recorded message activation switches to verify proper operation.		
			Operate all notification zone selection switches, if provided, to verify proper operation.		
5 Years	Smoke Detectors		Test detector sensitivity to ensure that the detector has remained within its listed and marked sensitivity range (or 4 percent obscuration light gray smoke, if not marked)		Facility is not old enough to have required this testing.

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
10 Years	Initiating devices	Radiant Energy-Sensing Detectors (Optical Detectors)	Verify manufacturer's service life for detection elements. UV detection element's normal service life is 10 years; others vary by manufacturer		
			Replace detectors which have exceeded manufacturer's recommended service life for detection elements.		
20 Years	Initiating devices	Smoke Detectors	Replace detectors		
	Control Panel and Annunciator Equipment (monitored)		Verify manufacturer's service life for control elements		
			Verify manufacturer has continued technical and parts support for the specific model		
			Replace control equipment that has exceeded manufacturer's recommended service life limits or if the manufacturer has ceased to provide technical and parts support		

FLC Lower Tunnel (Gauger Station) Fire Alarm MNS Maintenance Summary

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
Annually	Control Panel and Annunciator Equipment (monitored)		Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs, one of each type) and operation of notification appliances and auxiliary functions (outputs, one of each type).	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
			Verify that all lamps and LEDs are illuminated.	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
			Load test backup batteries using a meter (when provided)	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
			Verify condition of power supplies and batteries.	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
			Resolve any trouble indications		
	Remote Power Supplies and Notification Appliance Circuit Power Extenders		Verify that all lamps and LEDs are illuminated.	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
			Load test backup batteries using a meter (when provided)	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120), Batteries in cabinets #58, #61, #65, #68, #69, #71 & #72 failed.
			Verify condition of power supplies and batteries.	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
	Initiating devices	Manual Fire Alarm Stations	Verify station is accessible (visual)	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
		Radiant Energy-Sensing Detectors	If used for releasing service, inhibit releasing function		03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
		(Optical Detectors)	Test to verify alarm initiation and receipt		03/14/2019 (FA report Lower Tunnel), UV/IR detector N23L2M99 did not activate. 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120), UV/IR detector N23L2M99 did not activate
	Verify that no facility changes affect performance			03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),	
	Verify alignment of the positioning markings at all adjustment locations				
	If used for releasing service, configure system for automatic operation				
	If used for releasing service, restore to releasing service				
	Notification Appliances and Voice Communication (telephone, speakers, horns, and strobe lights)		Test to verify operability	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120), Speaker Circuit with 6 speakers from cabinet \$59 did not activate.
	Radio Alarm Transmitters and Receivers		Test to verify operability	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120), Kingfisher transmitter did not transmit signal to RDC.
	Fire Alarm Control Panel with Integrated		Test to verify proper receipt of signals (inputs) from Local Operating Consoles (LOCs) and the		

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Mass Notification (FMCP)		Installation’s site-wide system and operation of notification appliances and auxiliary functions (outputs).		
	LOCs		Verify station is accessible (visual).		
	Text Message Signs		Test to verify operability		
2 Years	Initiating Devices	Manual Fire Alarm Stations	Operate to verify alarm receipt	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
		Heat Detectors (restorable)	Test with a heat source to verify alarm initiating and receipt		03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120), FHD N44L2M132 and N44L2M133 did not activate.
			Verify that no facility changes affect performance		03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
		Smoke Detectors (Single-station)	Test with manufacturer-approved smoke simulat to verify smoke entry and alarm initiation and receipt.		03/14/2019 (FA report Lower Tunnel), FSD elevator 72 did not activate 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120), FSD elevator 72 did not activate
			Verify that no facility changes affects performance.		03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),
	Supervisory Devices	Test to verify initiation and receipt of supervisory alarm	Yes	03/14/2019 (FA report Lower Tunnel), 04/02/2020 (FLC Lower Tunnel N44 and Node 23 19120),	
	FMCP and LOCs		Operate microphone to verify proper operation		
		Operate all pre-recorded message activation			

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
			switches to verify proper operation.		
			Operate all notification zone selection switches, if provided, to verify proper operation.		
5 Years	Smoke Detectors		Test detector sensitivity to ensure that the detector has remained within its listed and marked sensitivity range (or 4 percent obscuration light gray smoke, if not marked)		Facility is not old enough to have required this testing.
10 Years	Initiating devices	Radiant Energy-Sensing Detectors (Optical Detectors)	Verify manufacturer's service life for detection elements. UV detection element's normal service life is 10 years; others vary by manufacturer		
			Replace detectors which have exceeded manufacturer's recommended service life for detection elements.		
20 Years	Initiating devices	Smoke Detectors	Replace detectors		
		Air Sampling Smoke Detectors	Replace detection element		
	Control Panel and Annunciator		Verify manufacturer's service life for control elements		

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Equipment (monitored)		Verify manufacturer has continued technical and parts support for the specific model		
			Replace control equipment that has exceeded manufacturer's recommended service life limits or if the manufacturer has ceased to provide technical and parts support		

FLC Upper Pumphouse Fire Alarm MNS Maintenance Summary

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
Annually	Control Panel and Annunciator Equipment (monitored)		Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs, one of each type) and operation of notification appliances and auxiliary functions (outputs, one of each type).	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
			Verify that all lamps and LEDs are illuminated.	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
			Load test backup batteries using a meter (when provided)	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
			Verify condition of power supplies and batteries.	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), Batteries for Gamewell FACP failed. 10/29/2020 (FLC Upper Pump House N50 20122),
			Resolve any trouble indications		
	Remote Power Supplies and Notification Appliance Circuit Power Extenders		Verify that all lamps and LEDs are illuminated.	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
			Load test backup batteries using a meter (when provided)	Yes	04/03/2019 (FLC Upper Pump House N50), Batteries Equipment Cab #111 replaced. 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
			Verify condition of power supplies and batteries.	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
	Initiating devices	Manual Fire Alarm Stations	Verify station is accessible (visual)	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
	Notification Appliances and		Test to verify operability	Yes	04/03/2019 (FLC Upper Pump House N50),

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Voice Communication (telephone, speakers, horns, and strobe lights)				10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
	Radio Alarm Transmitters and Receivers		Test to verify operability	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), Kingfisher transmitter did not transmit signals to RDC. 10/29/2020 (FLC Upper Pump House N50 20122),
	Fire Alarm Control Panel with Integrated Mass Notification (FMCP)		Test to verify proper receipt of signals (inputs) from Local Operating Consoles (LOCs) and the Installation's site-wide system and operation of notification appliances and auxiliary functions (outputs).		
	LOCs		Verify station is accessible (visual).		
	Text Message Signs		Test to verify operability		
2 Years	Initiating Devices	Manual Fire Alarm Stations	Operate to verify alarm receipt	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
		Smoke Detectors	Test with manufacturer-approved smoke simulant to verify smoke entry and alarm initiation and receipt	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
			Verify that no facility changes affect performance	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
		Supervisory Devices	Test to verify initiation and receipt of supervisory alarm	Yes	04/03/2019 (FLC Upper Pump House N50), 10/19/2019 (FLC Upper Pump House N50 19120), 10/29/2020 (FLC Upper Pump House N50 20122),
	FMCP and LOCs		Operate microphone to verify proper operation		
			Operate all pre-recorded message activation switches to verify proper operation.		
			Operate all notification zone selection switches, if provided, to verify proper operation.		
5 Years	Smoke Detectors		Test detector sensitivity to ensure that the detector has remained within its listed and marked sensitivity range (or 4 percent obscuration light gray smoke, if not marked)		Facility is not old enough to have required this testing.
10 Years	Initiating devices	Radiant Energy-Sensing Detectors (Optical Detectors)	Verify manufacturer's service life for detection elements. UV detection element's normal service life is 10 years; others vary by manufacturer		
			Replace detectors which have exceeded manufacturer's recommended service life for detection elements.		
20 Years	Initiating devices	Smoke Detectors	Replace detectors		

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Control Panel and Annunciator Equipment (monitored)		Verify manufacturer's service life for control elements		
			Verify manufacturer has continued technical and parts support for the specific model		
			Replace control equipment that has exceeded manufacturer's recommended service life limits or if the manufacturer has ceased to provide technical and parts support		

FLC Upper Tunnel Fire Alarm MNS Maintenance Summary

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
Annually	Control Panel and Annunciator Equipment (monitored)		Test to verify proper receipt of alarm, supervisory, and trouble signals (inputs, one of each type) and operation of notification appliances and auxiliary functions (outputs, one of each type).	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
			Verify that all lamps and LEDs are illuminated.	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
			Load test backup batteries using a meter (when provided)	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), Batteries failed load test Cabinet #101 & #104. 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122), Batteries failed load test Cabinet #101 & #104.
			Verify condition of power supplies and batteries.	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
			Resolve any trouble indications		
	Remote Power Supplies and Notification Appliance Circuit Power Extenders		Verify that all lamps and LEDs are illuminated.	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
			Load test backup batteries using a meter (when provided)	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
			Verify condition of power supplies and batteries.	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
	Initiating devices	Manual Fire Alarm Stations	Verify station is accessible (visual)	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
	Notification Appliances and Voice		Test to verify operability	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
	Communication (telephone, speakers, horns, and strobe lights)				
	Radio Alarm Transmitters and Receivers		Test to verify operability	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), Kingfisher transmitter did not transmit signals to RDC. 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122), Kingfisher transmitter did not transmit signals to RDC.
	Fire Alarm Control Panel with Integrated Mass Notification (FMCP)		Test to verify proper receipt of signals (inputs) from Local Operating Consoles (LOCs) and the Installation’s site-wide system and operation of notification appliances and auxiliary functions (outputs).		
	LOCs		Verify station is accessible (visual).		
	Text Message Signs		Test to verify operability		
2 Years	Initiating Devices	Manual Fire Alarm Stations	Operate to verify alarm receipt	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
		Heat Detectors (restorable)	Test with a heat source to verify alarm initiating and receipt	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), Heat Detector N60L1M66 did not activate. 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122), Heat Detectors N5L1M54, N5L1M64 & N5L1M84 did not activate.

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
			Verify that no facility changes affect performance	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
		Supervisory Devices	Test to verify initiation and receipt of supervisory alarm	Yes	06/08/2020 (FLC Upper Tunnel N5 and Node 60 19120), 06/11/2021 (FLC Upper Tunnel N5 and Node 60 20122),
	FMCP and LOCs		Operate microphone to verify proper operation		
			Operate all pre-recorded message activation switches to verify proper operation.		
			Operate all notification zone selection switches, if provided, to verify proper operation.		
5 Years	Smoke Detectors		Test detector sensitivity to ensure that the detector has remained within its listed and marked sensitivity range (or 4 percent obscuration light gray smoke, if not marked)		Facility is not old enough to have required this testing.
		Radiant Energy-Sensing Detectors (Optical Detectors)	Verify manufacturer's service life for detection elements. UV detection element's normal service life is 10 years; others vary by manufacturer		
			Replace detectors which have exceeded		

Frequency	Component	Sub-component (if applicable)	Task	Record of Completion	Date
			manufacturer's recommended service life for detection elements.		
20 Years	Initiating devices	Smoke Detectors	Replace detectors		
	Control Panel and Annunciator Equipment (monitored)		Verify manufacturer's service life for control elements		
			Verify manufacturer has continued technical and parts support for the specific model		
			Replace control equipment that has exceeded manufacturer's recommended service life limits or if the manufacturer has ceased to provide technical and parts support		

I. AFFF Retention System

There are no UFC 3-601-02 Fire Protection System Inspection, Testing and Maintenance requirements for the retention system.

J. Maintenance Records Summary of Findings

The review of the maintenance records highlighted the following issues:

1. For most systems annual inspections are not being performed annually, typically these inspections are happening on a 2-year cycle.
2. Items identified in an annual report as requiring repair were often re-identified in a follow-on annual report (typically performed ~2 years later)— meaning that repairs were not made for more than 2-years.
3. The Kingfisher Radio transmitter was identified on 11 annual test reports as not transmitting to the Regional Dispatch Center. These incidents occurred on tests occurring over the period 10/19/2019 through 02/16/2022 – with 2 incidents in late 2019, 5 incidents in 2020, 2 incidents in 2021 and 2 incidents in early 2022. During this same period there were 11 fire alarm tests on other days in which signals were reported as being received at the RDC – 2 tests in late 2019, 5 tests during 2020, and 4 tests in 2021. Based on these results there appears to be only a 50% success rate in transmitting signals to the RDC.
4. The testing documentation and tests being performed are based on NFPA 72 requirements, rather than on the requirements of UFC 3-601-02.
5. To date no testing of Mass Notification specific panels has been incorporated into the testing program. This is a new requirement of the October 2021 edition of UFC 3-601-02.

PART 2 – SUMMARY OF FINDINGS

1. FIRE PROTECTION SYSTEMS

Findings/recommendations for fire protection system repairs are as follows:

1. The hose valves are provided with pressure-regulating devices but were not provided with a valved outlet for a pressure gauge to be connected. A valved outlet should be provided for each location with a pressure-regulating device so a pressure gauge can be attached to verify the required pressure is being provided.
2. Significant external pipe degradation was observed in the riser for Preaction System 3 due to the constant dripping of ground water seepage into the riser closet and onto the piping. A ceiling should be constructed in this room, like the metal ceiling constructed in other areas of the Lower Tunnel, to stop water dripping in this room and the degraded riser piping should be replaced.
3. The fire department connections were not provided with signs indicating the system they served, and the operating pressures required. An appropriate sign should be provided at each fire department connection.
4. A significant number of fire alarm visual notification devices were over-spaced creating code deficient conditions. These devices are spaced beyond the maximum distance allowed by NFPA 72 of 100 feet. This occurs at several intervals, where a device will be spaced 110 – 120 feet from the previous device, and then 70 – 80 feet to the next device. There did not appear to be any field conditions which would contribute to the extended spacing. Spacing of these devices should be corrected so they are within the code required spacing.
5. There are also numerous fire alarm system device label errors, mostly of single, isolated devices, that should be corrected.
6. All the explosion-proof fire alarm strobes located in the Tank Farm portion of the Lower Tunnel are obstructed and violate NFPA 72. The code requires strobes to be visible by direct concentrated viewing (i.e., you must be able to see the actual strobe lens from all parts of the corridor) to use corridor spacing of minimum 15cd strobes mounted up to 100 feet apart. The strobes in this section of the tunnel are mounted with the bottom of the strobe lens well above the adjacent pipe stand structure and pipes. Personnel on the actual walking portion of the tunnel do not have a direct line of sight to the strobes. The location of these devices should be corrected to allow viewing by tunnel users.
7. The fire alarm Kingfisher Radio transmitter appears to be non-functional an inordinate amount of the time. Further investigation is required to determine why the Kingfisher transmitter is not

continuously communicating with the Regional dispatch center. Design improvements/repairs are required to ensure continuity of fire alarm signal transmission.

8. The sequence of operations of the fire protection and AFFF retention system is complex and there is no operations manual that clearly illustrates the interrelation between these two systems. An operations manual should be developed so that tunnel operators understand the operation of the systems. To ensure the correct sequence of operations of these systems the fire protection and AFFF retention systems should be recommissioned to confirm these systems are operating per the requirements of the final sequence of operations.

If the facility were to be maintained in operational condition for continued fuel operations, then the following additional items would be recommended:

1. In numerous specific instances the as-built drawings do not accurately represent the installed conditions. The as-built drawings across all disciplines should be updated to match actual installed conditions.
2. There were also inaccuracies associated with equipment shown on the as built drawings not being installed, or installed in a different orientation (i.e., mounting on wall instead of ceiling, or vice-versa). Many of these examples involved duct-mounted smoke detection at smoke dampers, usually where installation of this type of device was not possible. However, there was no documentation indicating the required detection was exempted nor was spot detection provided at the damper. Some of this may be attributable to the fact the drawings provided and reviewed would not necessarily reflect changes associated with Revisions R and S (dated 21 June 2018) of the design drawings, some of which affected systems monitored by the fire alarm and mass notification system. The as-built drawings be updated to match installed conditions.

2. RETENTION SYSTEM

There are numerous improvements that could be recommended to the operation of the retention system. However, at this stage with the established goal of ultimately taking the fuel storage tanks out of service within the next 2-3 years any recommendations for significant alterations to the retention system do not appear to be warranted. Confirmation of the correct sequence of operation of the system, as recommended in item 8 above, should be performed.

3. FIRE PROTECTION SYSTEM MAINTENANCE

1. A complete overhaul of the fire protection system maintenance program to align it with UFC 3-601-02 requirements and better oversight to confirm timely ITM is being provided could be recommended. However, at this stage with the established goal of ultimately taking the fuel storage tanks out of service within the next 2-3 years any recommendations for significant alterations to the fire protection ITM program does not appear warranted.

PART 3 – RECOMMENDED BETTERMENTS

If the facility was to remain as an operational fuel storage facility our recommendations for betterments are as follows:

1. Upgrades the AFFF retention system to permit the collection of effluent in the area outside (b) (3) (A) under gravity flow should be made.
3. Establish a standalone ITM program for Red Hill. Due to the critical nature of this facility this program should be funded and directly overseen by the Red Hill Facility managers independent of any other ITM programs on the base.

The Scope of work listed achieving faster response by fire detection/protection systems as a potential betterment. However, this would not appear to be warranted. The flame detection system installed is reasonable quick with an adequate false activation rejection rate. There appears to be no significant benefit, or obvious candidate, for a faster detection and fire protection activation.



APPENDICES TABLE OF CONTENTS

Appendix A. Site Survey Notes Class I Standpipe, Wet pipe Sprinkler, Fire Department Connections Systems.....	97
Appendix B. Site Survey Notes Preaction Foam/Water Sprinkler System.....	136
Appendix C. Site Survey Notes Fire Pump System.....	151
Appendix D. Site Survey Notes Foam Pump System.....	157
Appendix E. Site Survey Notes Fire Alarm/MNS System.....	161





**APPENDIX A. SITE SURVEY NOTES CLASS I STANDPIPE, WET PIPE
SPRINKLER, FIRE DEPARTMENT CONNECTIONS SYSTEM**



FIRE PROTECTION GENERAL NOTES

1. INSTALLATION SHALL CONFORM TO NFPA 13 2013 .
2. ALL MATERIALS INSTALLED SHALL BE NEW, UL LISTED AND/ OR F.M. "APPROVED" FOR FIRE PROTECTION USE.
3. SWAY BRACING TO BE PER NFPA 13, 2013 EDITION.
 - LATERAL BRACING MAY BE OMITTED FROM PIPES INDIVIDUALLY SUPPORTED BY ROOFS LESS THEN 6" LONG.
 - THE DISTANCE BETWEEN THE LAST BRACE AND THE END OF THE PIPE SHALL NOT EXCEED 6'-0" ON A FEED OR CROSS MAIN SHALL BE PROVIDED WITH A LATERAL BRACE.
 - LATERAL BRACES MAY ACT AS LONGITUDINAL BRACES ONLY WHEN INSTALLED WITHIN 2'-0" OF THE PIPE BEING BRACED
- LONGITUDINALLY
 - THE FOUR WAY BRACE SHALL BE ATTACHED ABOVE THE FLEXIBLE CONNECTION REQUIRED FOR THE RISER, AND TO THE WALL STRUCTURE.
 - THE END SPRINKLER ON A BRANCH LINE SHALL BE RESTRAINED AGAINST EXCESSIVE MOVEMENT BY USE OF A WRAP AROUND U-HOOK OR OTHER APPROVED MEANS.
 - ALL BRACES ARE CALCULATED. SEE CALCULATION AND DETAIL SHEET FP-4.
- 3b. THE SYSTEM IS OVER 100 PSI AND MUST HAVE THE LAST HANGER ON THE END OF BRANCHLINES SUPPLYING PENDENT SPRINKLERS AT DROPPED CEILINGS INSTALLED WITHIN 12" OF THE END OF THE LINE PER 9.2.3.4.4.
4. ALL SPRINKLER SYSTEM CONTROL VALVES SHALL BE PROVIDED WITH TAMPER SWITCHES. ALL SYSTEMS SHALL BE EQUIPPED WITH A FLOW SWITCH. ALL TAMPERS AND FLOW SWITCHES SHALL BE MONITORED BY AN OFF-SITE PROPRIETARY STATION, U.L. LISTED AND/ OR F.M. APPROVED AND INSTALLED BY OTHERS.
5. ALL GROOVED COUPLINGS INSTALLED SHALL BE RIGID TYPE. (U.N.O.)
6. THE USE OF GROOVED FITTINGS WILL BE LIMITED TO PIPES HAVING A NOMINAL DIAMETERS OF 1 1/2" INCHES OR LARGER.
7. COUPLINGS AND FITTINGS MAY BE CAST IRON, MALLEABLE IRON OR DUCTILE IRON.
8. GENERAL CONTRACTOR SHALL MAKE PIPING ABOVE SUSPENDED CEILINGS ACCESSIBLE FOR VISUAL INSPECTION AS A CONDITION OF FINAL APPROVAL.
9. ALL NEW ABOVEGROUND PIPING WILL BE BLK SCH 40 EXCEPT FOR FOAM CONCENTRATE PIPING THAT SHALL BE STAINLESS STEEL AND PVC DRAIN LINES.
10. ALL NEW SYSTEMS SHALL BE HYDROSTATICALLY TESTED AT 200 PSI OR 50 PSI IN EXCESS OF THE MAXIMUM PRESSURE, WHEN THE MAXIMUM PRESSURE TO BE MAINTAINED IN EXCESS OF 150 PSI.
11. FLEXIBLE COUPLINGS TO BE INSTALLED WITHIN 12" OF EITHER SIDE OF MASONRY OR CONCRETE WALLS. FLEXIBLE COUPLINGS TO BE INSTALLED WITHIN 12" ABOVE AND WITHIN 24" BELOW FLOORS, A FLEXIBLE COUPLING TO BE INSTALLED ON RISERS MORE THAN 3' & LESS THAN 7". IN RISERS MORE THAN 7', FLEXIBLE COUPLINGS TO BE INSTALLED WITHIN 24" OF THE TOP AND BOTTOM OF THE RISER.
12. SPRINKLER HEADS IN CEILING TILES ARE NOT REQUIRED TO BE CENTER OF TILE.
13. SPRINKLER HEADS TO BE AT LEAST 6" FROM CEILING GRID.
14. ALL PIPING PENETRATIONS IN FIRE RATED WALLS/FLOORS OTHER THAN MASONRY/CONCRETE SHALL BE SIZED AS FOLLOWS:
 - NOMINALLY 2" LARGER THAN PIPE FOR 1" TO 3" NOMINAL PIPE DIAMETERS.
 - FOR PIPING 4" AND LARGER, THE HOLE DIAMETER IS TO BE 4" LARGER THAN NOMINAL PIPE DIAMETER.
- NO CLEARANCE IS REQUIRED FOR NON-FIRE RATED WALLS/FLOORS OTHER THAN MASONRY/CONCRETE.
15. ALL PREACTION SYSTEM MAIN PIPING TO BE SLOPED AS THE NATURAL SLOPE OF THE TUNNELS ALLOW. LINE PIPING TO BE SLOPED PER NFPA-13.

FIRE PROTECTION DESIGN CRITERIA

THE FIRE PROTECTION SYSTEM SHALL BE HYDRAULICALLY DESIGNED AND INSTALLED IN ACCORDANCE WITH THE FOLLOWING CRITERIA:

UPPER TUNNEL (TANKS COMPARTMENT)
 DESIGN DENSITY: 0.4 GPM/SF [NFPA 13: EXTRA HAZARD GROUP 2]
 DESIGN AREA: 2,500 SF (UPPER TUNNEL UP TO ADIT 5 DOOR AND ADIT 4 DOOR.)
 HOSE STREAM: 500 GPM DURATION: 90 MINUTES

THE ZONES TO BE COVERED ARE SHOWN ON THE LAYOUTS.

UPPER TUNNEL STANDPIPE
 FLOW DEMAND: 1000 GPM
 PRESSURE: MIN 100 PSI AT NOZZLE
 DURATION: 90 MINUTES

LOWER TUNNEL (TANKS COMPARTMENTS)
 DESIGN DENSITY: 0.16 GPM/SF [NFPA 16, SINGLE INTERLOCK ELECTRIC RELEASE PRE-ACTION SYSTEM, 3% AFF MIF-F 24385 PREACTION AFF SYSTEMS ARE ACTUATED BY CROSSE-ZONE TRIPLE IR DETECTION]
 DESIGN AREA: COMPARTMENT AREA (APPROXIMATELY 10,000 SF)
 HOSE STREAM: 1000 GPM



LOWER TUNNEL (GAUGER OFFICE AND ELECTRICAL ROOM)
 DESIGN DENSITY: 0.2 GPM/SF [NFPA 13 : ORDINARY HAZARD GROUP 2]
 DESIGN AREA: 1,500 SF
 HOSE STREAM: 250 GPM
 DURATION: 60 MINUTES
 THE ZONE TO BE COVERED IS SHOWN ON THE LAYOUT

LOWER TUNNEL STANDPIPE
 FLOW DEMAND: 1000 GPM
 PRESSURE: MIN 100 PSI AT VALVE
 DURATION: 60 MINUTES


FIRE PUMP BUILDING (ELECTRICAL ROOM, FIRE PUMP ROOM, AND AFF PUMP ROOM, GENERATOR ROOM)
 DESIGN DENSITY: 0.2 GPM/SF [NFPA 13 : ORDINARY HAZARD GROUP 2]
 DESIGN AREA: 1,500 SF
 HOSE STREAM: 250 GPM
 DURATION: 60 MINUTES

CONTRACT DEVIATIONS & COORDINATION


- 1) THE CONTRACT DOCUMENTS SHOW 2 JOCKEY PUMPS. NFPA REQUIRES ONLY ONE. TOTAL FIRE SYSTEMS, INC. WILL SUPPLY AND PROVIDE THE SECOND JOCKEY PUMP / CONTROLLER AS A SPARE AND NOT INSTALL IT AS SHOWN. THEY WILL BE LEFT IN THE LOCATION AS DIRECTED.
- 2) WE HAVE DELETED THE INDIVIDUAL PRV'S FOR THE RV'S AND SPRINKLER RISER'S AND INSTALLING A MASTER PRV WITH BACKUP FOR BOTH THE LOWER AND UPPER TUNNEL. NFPA REQUIRES TESTING OF THESE DEVICES BOTH AT THE PROJECT COMPLETION AND ANNUALLY. THERE ARE NO PROVISIONS FOR THEIR TESTING SHOWN AND OR CALLED FOR. THE DESIGN USING MASTER PRV'S WILL REDUCE THE FUTURE MAINTENANCE AND WILL IMPROVE THE SYSTEM OVERALL.
- 3) DELETION OF THE FDC AND ITS PIPING AS SHOWN FOR THE AFF FOAM SYSTEMS. NFPA PROHIBITS THE FDC TO BE SUPPLIED ABOVE THE SHUT OFF ON MULTIPLE RISER SYSTEMS AS SHOWN. FURTHER THE FDC'S SUPPLYING THE 8" SUPPLY HAVE AN FDC SHOWN AT ADIT'S 3, 4, 5, & 6 AS REQUIRED BY NFPA BELOW THE CONTROL VALVE.
- 4) REDESIGN OF THE FIRE PUMP ROOM DUE TO THE PIPING BEING RUN OVERHEAD HAS RESULTED IN CHANGES TO THE FLOOR DRAIN, ALLOWABLE LIGHT FIXTURE LOCATIONS, POWER HOOKUP LOCATIONS, AND WATER SERVICE ENTRY LOCATION AND CONFIGURATION. OTHER TRADES WILL NEED TO MODIFY THEIR SCOPE OF WORK TO ACCOMMODATE THIS RECONFIGURATION.
- 5) EXTERIOR BACKFLOW PREVENTORS (IN SITE CONTRACTOR'S SCOPE) HAVE BEEN ELIMINATED AND ARE NOT INCLUDED IN OUR HYDRAULIC CALCULATIONS ON THE DISCHARGE SIDE OF THE PUMP. ONE BACKFLOW IN THE LINE FROM THE TANK TO THE FIRE PUMP HAS BEEN ACCOUNTED FOR BY REDUCING THE AVAILABLE WATER FROM THE CALCULATED WATER FLOW TEST BY 12 PSI REFLECTED IN THE SUBSEQUENT CALCULATIONS FOR UPPER AND LOWER TUNNELS.




HANGER DETAIL - TOP BEAM CLAMP
 N.T.S.
 USE ONLY WHERE HANGING TO EXISTING I-BEAM STRUCTURE WITH TUNNEL.




HANGER DETAIL - UP TO 4" PIPE
 N.T.S.
 TYP. FOR BRANCH-LINES AND SMALL MAINS




HANGER DETAIL - UP TO 6"-8" PIPE
 N.T.S.
 TYP. FOR 6" AND 8" MAINS (6" AND 12" BIM BUT WITH NFPA RED'D ATR)



HANGER DETAIL #52 - SIDE SAMMY
 N.T.S.
 TYP. FOR BRANCH-LINES UNDER RAUK CATCH CEILING AREAS




HANGER DETAIL #51 - BOTTOM SAMMY
 N.T.S.
 ALTERNATE FOR BRANCH-LINES UNDER RAUK CATCH CEILING AREAS



PIPE STAND DETAIL
 N.T.S.

AS BUILT

10-10-17	10-10-17	10-10-17	10-10-17	10-10-17	10-10-17	10-10-17	10-10-17	10-10-17	10-10-17
CRETEFIELD PROJECT, INC. 884 KAWANOA STREET KAWAHAU, HAWAII 96765 TEL: 808-885-0900 FAX: 808-885-2000									
PROJECT NO.: SHEET NO.: DATE:									
REVISIONS: NO. DATE DESCRIPTION									
SUBMITTED BY: DATE: CHECKED BY: DATE:									
DESIGNER: DATE: APPROVED BY: DATE:									
CONTRACTOR:									
GENERAL CONTRACTOR:									
SPECIALTY CONTRACTOR:									
DESIGNATED BY THE OWNER:									
NAVFAC HAWAII									
JOINT BASE PEARL HARBOR HONOLULU (RED HILL) FT 16 P-1561 (DESC-1561), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY									
FIRE PROTECTION GENERAL NOTES									
SHEET NO.: 1206/13									
NAVFAC DEDMO NO.:									
F-001									




PUMP HOUSE OVERHEAD FIRE SPRINKLER SYSTEM

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORKING TRACES AS NECESSARY TO AVOID CONFLICTS AND TO PROVIDE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES


10-14-17	AS BUILT	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17																													
1	FINAL CHECKING FOR DESIGN REVISIONS	2	ADD - 1500 IN THE OVERHEAD PUMP BUILDING	3	REV - ADDS 250 GPM HOSE ALLOWANCE TO THE	4	REV - ADDS 250 GPM HOSE ALLOWANCE TO THE	5	REV - ADDS 250 GPM HOSE ALLOWANCE TO THE	6	REV - ADDS 250 GPM HOSE ALLOWANCE TO THE																												
<p>UNIVERSITY PROJECT, INC. 808 SHANNON STREET IDEALHILL, INDIANAPOLIS 46240 TEL: (317) 955-0500 FAX: (317) 955-0501</p>																																							
<p>CONTRACT NO. 1326143</p>																																							
<p>CONTRACTOR'S NAME: NAVAFAC HAWAII</p>																																							
<p>CLIENT: JOINT BASE PEARL HARBOR HONOLULU (RED HILL), HONOLULU, HAWAII</p>																																							
<p>PROJECT: PY18 P-1851 (DESC-1851), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY</p>																																							
<p>DESCRIPTION: FIRE PROTECTION OVERHEAD SPRINKLER PLAN NEW FIRE PUMP BUILDING</p>																																							
<p>AS BUILT</p>																																							
<p>SPRINKLER HEAD LEGEND:</p> <table border="1"> <thead> <tr> <th>SYMBOL</th> <th>QNTY</th> <th>COMPONENT</th> <th>HEAD</th> <th>GLASS</th> <th>TEMP</th> <th>QUANTITY</th> </tr> </thead> <tbody> <tr> <td>⊙</td> <td>VEB2</td> <td>1/2"</td> <td>6.6</td> <td>BRASS</td> <td>ROSE</td> <td>138°</td> <td>34</td> </tr> <tr> <td colspan="7" style="text-align: right;">TOTAL SPRINKLERS THIS LEVEL</td> </tr> <tr> <td colspan="7" style="text-align: right;">34</td> </tr> </tbody> </table>											SYMBOL	QNTY	COMPONENT	HEAD	GLASS	TEMP	QUANTITY	⊙	VEB2	1/2"	6.6	BRASS	ROSE	138°	34	TOTAL SPRINKLERS THIS LEVEL							34						
SYMBOL	QNTY	COMPONENT	HEAD	GLASS	TEMP	QUANTITY																																	
⊙	VEB2	1/2"	6.6	BRASS	ROSE	138°	34																																
TOTAL SPRINKLERS THIS LEVEL																																							
34																																							
<p>FB101A</p>																																							



PARTIAL FIRE PROTECTION NEW PLAN - AREA 79 - LOWER LEVEL (b) (3) (A)

PARTIAL FIRE PROTECTION NEW PLAN - AREA 79 - LOWER LEVEL (b) (3) (A)

PARTIAL FIRE PROTECTION NEW PLAN - AREA 78 - LOWER LEVEL (b) (3) (A)



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	SH	ORIFIC. RATIO	HEAD PRESS.	PLATE NUMBER	TEMP.	Q. AMT.
STANDARD RESP. SPRINKLER	⊙	1/2	6.8	300 PSI	N/A	170°	8
STANDARD RESP. SPRINKLER	⊙	1/2	6.8	300 PSI	N/A	200°	136
STANDARD RESP. SPRINKLER ON LINES	⊙	1/2	6.8	300 PSI	N/A	200°	429
STANDARD RESP. SPRINKLER - PLATE	⊙	1/2	6.8	300 PSI	SPC. CHG.	170°	4
STANDARD RESP. HORIZONTAL SIDEWALL	△	1/2	6.8	300 PSI	NONE	170°	2

TOTAL SPRINKLERS THIS LEVEL: 417

REVISIONS

NO.	DATE	BY	DESCRIPTION
1	10-20-17
2	10-20-17
3	10-20-17
4	10-20-17
5	10-20-17
6	10-20-17
7	10-20-17
8	10-20-17
9	10-20-17
10	10-20-17

NAVFAC HAWAII

NAVFAC HAWAII ENGINEERING COMMAND

NAVFAC HAWAII

NAVFAC HAWAII (RED HILL)

NAVFAC HAWAII (RED HILL) UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS; RED HILL FUEL STORAGE FACILITY

PARTIAL FIRE PROTECTION NEW PLAN - AREA 78 & 79 - LOWER LEVEL (ADT 3)

PROJECT NO. 1306143

CONTRACT NO. 1306143

DATE: 10/20/17

SCALE: 1/8" = 1' 0"


FT128

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG ALL TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

SEE SHEET FT128 FOR CONTINUATION



PARTIAL FIRE PROTECTION NEW PLAN - AREA 77 - LOWER LEVEL

SCALE 1/8" = 1' 0"

LATERAL BRACE CONFIGURATION 100-0221

(b) (3) (A)

STA. 124+81
OLD ED. STA. 124+20 @ 122+83



PARTIAL FIRE PROTECTION NEW PLAN - AREA 55 - LOWER LEVEL

SCALE 1/8" = 1' 0"

(b) (3) (A)

(b) (3) (A)

STA. 127+00

STA. 128+00


(b) (3) (A)

(b) (3) (A)

(b) (3) (A)


LATERAL BRACING AT SUPPORT 191 CONFIGURATION 100-0222 & 0223

LATERAL BRACING AT SUPPORT 189 CONFIGURATION 100-0222 & 0223



PARTIAL FIRE PROTECTION NEW PLAN - AREA 56 - LOWER LEVEL

SCALE 1/8" = 1' 0"



KEY PLAN


AS BUILT

SCALE: 1/8" = 1' 0"

PIPE INLET HEAD DESIGNATION	SYMBOL	DN	DEPTH (M)	HEAD (M)	FLARE (M)	TRUNK	ORIGIN
STANDARD RESP. SPRINKLER	⊙	150	1.0	0.4	BRASS	NOVA	170F
STANDARD RESP. SPRINKLER	⊙	150	1.0	0.4	BRASS	NOVA	200F
STANDARD RESP. SPRINKLER ON LIFE G.	⊙	150	1.0	0.4	BRASS	NOVA	200F
STANDARD RESP. PENDENT W/PLATE	⊙	150	1.0	0.4	BRASS	2PC CHN	170F
STANDARD HORIZONTAL DOWNWALL	◁	125	1.0	0.4	BRASS	NOVA	170F

TOTAL SPRINKLERS THIS LEVEL: 417

NO.	DATE	DESCRIPTION	BY	CHK.
1	10-14-17	ISSUED FOR PERMITS
2	10-14-17	FINAL REVIEW FOR PERMITS
3	10-14-17	REV - ISSUED FOR PERMITS
4	10-14-17	REV - ISSUED FOR PERMITS
5	10-14-17	REV - ISSUED FOR PERMITS



NAVIFAC HAWAII
 NAVAL FACILITIES ENGINEERING COMMAND
 1001 W. WILSON DRIVE
 DANIEL HANAU
 JOINT BASE PEARL HARBOR HICKAM (RED HILL)
 FY15 P-155 (DESC: 1551) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN -
 AREAS 77, 55 & 56 - LOWER LEVEL

REVISIONS:





NO.	DATE	DESCRIPTION	BY	CHK.
1	10-14-17	ISSUED FOR PERMITS
2	10-14-17	FINAL REVIEW FOR PERMITS
3	10-14-17	REV - ISSUED FOR PERMITS
4	10-14-17	REV - ISSUED FOR PERMITS
5	10-14-17	REV - ISSUED FOR PERMITS

PROJECT NO.: 1306143
 CENTER CONTR. NO.: 449
 DRAWING NO.: 417
 TOTAL SPRINKLERS THIS LEVEL: 417

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

DATE: 10-14-17

SEE SHEET FT129 FOR CONTINUATION



AS BUILT

SCALE: 1/8" = 1' 0"

PIPE NUMBER	SYMBOL	DN	WALL THICKNESS	HEAD	FLANGE	TRUNK	ORIGIN
STANDARD RESP. PIPE	○	1/2	0.4	BRASS	N/A	170F	3
STANDARD RESP. PIPE	○	1/2	0.4	BRASS	N/A	200F	3
STANDARD RESP. PIPE	○	1/2	0.4	BRASS	N/A	200F	3
STANDARD RESP. PIPE	○	1/2	0.4	BRASS	N/A	170F	3
STANDARD RESP. PIPE	○	1/2	0.4	BRASS	N/A	170F	3
STANDARD RESP. PIPE	○	1/2	0.4	BRASS	N/A	170F	3
STANDARD RESP. PIPE	○	1/2	0.4	BRASS	N/A	170F	3
STANDARD RESP. PIPE	○	1/2	0.4	BRASS	N/A	170F	3

NO. 1-17	NO. 2-17	NO. 3-17	NO. 4-17	NO. 5-17	NO. 6-17	NO. 7-17	NO. 8-17	NO. 9-17	NO. 10-17

1. CHECK THE 2D DRAWING SET BEFORE SETTING UP OR UNDER WAY CONSTRUCTION.

CPT
 CIVIL ENGINEERING, INC.
 1814 HANAWALE STREET
 HONOLULU, HAWAII 96813
 TEL: (808) 953-2200
 FAX: (808) 953-2202

DESIGN: []
 CHECKED: []
 APPROVED: []

PROJECT: []
 SHEET: []

REVISIONS:

NO.	DESCRIPTION	DATE

SCALE: 1/8" = 1' 0"

TOTAL SPANNERS THIS LEVEL: 417


FT130

DATE: 10/17/2017


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES


1 2 3 4 5




PARTIAL FIRE PROTECTION NEW PLAN - AREA 59 - LOWER LEVEL
SCALE 1/8" = 1' 0"



PARTIAL FIRE PROTECTION NEW PLAN - AREA 60 - LOWER LEVEL
SCALE 1/8" = 1' 0"



PARTIAL FIRE PROTECTION NEW PLAN - AREA 61 - LOWER LEVEL
SCALE 1/8" = 1' 0"



KEY PLAN

AS BUILT



SPRINGER HEAD SYMBOL	SYMBOL	SH	DEPTH	LENGTH	HEAD	FLARE	TRAMP	ON AXIS
STANDARD RESP SPRING	⊙	VIS 100	1/2	8.4	BRASS	NOA	170"	3
STANDARD RESP SPRING	⊙	VIS 100	1/2	8.4	BRASS	NOA	264"	3
STANDARD RESP SPRING ON LIFE G	⊙	VIS 100	1/2	8.4	BRASS	NOA	264"	4
STANDARD RESP PENDANT W/PLATE	⊙	VIS 100	1/2	8.4	BRASS	JPC CHN	170"	4
STANDARD HORIZONTAL SIDEWALL	◁	170311	1/2	8.4	BRASS	NONE	170"	2

TOTAL SPRINGERS THIS LEVEL: 417

NO. 1-17	NO. 2-17	NO. 3-17	NO. 4-17	NO. 5-17	NO. 6-17	NO. 7-17	NO. 8-17	NO. 9-17	NO. 10-17	NO. 11-17	NO. 12-17	NO. 13-17	NO. 14-17	NO. 15-17	NO. 16-17	NO. 17-17	NO. 18-17	NO. 19-17	NO. 20-17	

NAVIFAC

CPI

ENGINEERING COMPANY

NAVFAC HAWAII

JOINT BASE PEARL AND HERMES (RED HILL)

FY15 P-155 (DESC: 1551) UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

PARTIAL FIRE PROTECTION NEW PLAN - AREAS 59, 60 & 61 - LOWER LEVEL

REVISIONS

NO.	DATE	DESCRIPTION	BY	CHKD
1	01/11/17	ISSUED FOR CONSTRUCTION

PROJECT NO. 1306143

CONTR. CONTR. NO.

NAVFAC DRAWING NO.

FT131

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D

C

B

A


D

C

B

A

SEE SHEET FT131 FOR CONTINUATION




PARTIAL FIRE PROTECTION NEW PLAN - AREA 62 - LOWER LEVEL

SCALE 1/8" = 1' 0"




SEE SHEET FT133 FOR CONTINUATION



PARTIAL FIRE PROTECTION NEW PLAN - AREA 63 - LOWER LEVEL

SCALE 1/8" = 1' 0"



KEY PLAN

AS BUILT

SCALE 1/8" = 1' 0"

SPRINGER HEAD SYMBOL	SYMBOL	SIZE	ORIFICE	LENGTH	HEAD	FLAME	TRAMP	ORIFICE
STANDARD RESP SPRINGER	○	1/2	0.4	BRASS	N/A	170"	2	
STANDARD RESP SPRINGER	○	1/2	0.4	BRASS	N/A	200"	2	
STANDARD RESP SPRINGER ON LIFE G	○	1/2	0.4	BRASS	N/A	200"	4	
STANDARD RESP SPRINGER W/ LATE	○	1/2	0.4	BRASS	JPC CHN	170"	4	
STANDARD RESP HORIZONTAL DOWNWALL	◁	1/2	0.4	BRASS	NONE	170"	2	

TOTAL SPRINGERS THIS LEVEL: 417

NO. 1-17	NO. 2-17	NO. 3-17	NO. 4-17	NO. 5-17	NO. 6-17	NO. 7-17	NO. 8-17	NO. 9-17	NO. 10-17	NO. 11-17	NO. 12-17	NO. 13-17	NO. 14-17	NO. 15-17	NO. 16-17	NO. 17-17	NO. 18-17	NO. 19-17	NO. 20-17
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20

1. CHECK THE 200 DRAWING SET BEFORE BY ME OR UNDER MY SUPERVISION.

CPI

CENTIFEL PACIFIC, INC.
1814 HANAWALE STREET
HONOLULU, HAWAII 96813

TEL: (808) 953-2800
FAX: (808) 953-2800

DES: [] DIM: [] DATE: []

FOR ISSUED BY: []

FOR CHECKED BY: []

FOR APPROVED BY: []

DESCRIPTION: []

SCALE: []

PROJECT: []

SHEET NUMBER: []

PROJECT NUMBER: []

REVISIONS: []

NAVFAC HAWAII
NAVAL FACILITIES ENGINEERING COMMAND
REPORT OF THE NAVY
JOINT BASE PEARL HARBOR HICKAM (RED HILL)
OAHU, HAWAII
FY15 P-155 (DESC: 1551) UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FIRE PROTECTION NEW PLAN -
AREAS 62 & 63 - LOWER LEVEL

PROJECT NO.: 1306143
CENTER CONTR. NO.: []
NAVFAC DRAWING NO.: []

FT132





DATE: 10/27/2015

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

SEE SHEET FT132 FOR CONTINUATION

1 2 3 4 5



AS BUILT



TYPE	SYMBOL	SH	DEPTH	LENGTH	HEAD	FLARE	TRAMP	ON AXIS
STANDARD RESP. SPRINKLER	(Symbol)	1/2	8.4	BRASS	NOA	170F	3	
STANDARD RESP. SPRINKLER	(Symbol)	1/2	8.4	BRASS	NOA	250F	136	
STANDARD RESP. SPRINKLER ON LIFE G	(Symbol)	1/2	8.4	BRASS	NOA	250F	409	
STANDARD RESP. PENDANT W/PA LITE	(Symbol)	1/2	8.4	BRASS	ZPC CHN	170F	1	
STANDARD NONRECHARG. DOWNWAL	(Symbol)	1/2	8.4	BRASS	NONE	170F	2	

NO. 14-17	NO. 15-17	NO. 16-17	NO. 17-17	NO. 18-17	NO. 19-17	NO. 20-17	NO. 21-17	NO. 22-17	NO. 23-17	NO. 24-17
1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1
1	1	1	1	1	1	1	1	1	1	1


NAVAFAC
 CIVIL FACILITIES ENGINEERING COMMAND
 HONOLULU, HAWAII
 JONATHAN PEARL HARBOR HICKAM (RED HILL)
 FY15 P-155 (DESC. 1551) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN -
 AREAS 62 & 63 - LOWER LEVEL
 FT133

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.
 IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES
 TOTAL SPRINKERS THIS LEVEL: 417

1 2 3 4 5


66

6



1
FD100 FT134
SCALE 1/8" = 1' 0"

PARTIAL FIRE PROTECTION NEW PLAN - AREA 66 - LOWER LEVEL



AS BUILT

PIPE RISER HEAD SYMBOL	SYMBOL	SH	CONC/GRANITE	HEAD TYPE	FLARE TYPE	TANK	ORIGIN
STANDARD RISE UPFRIGHT	⊙	V15100	1/2	6.4	BRASS	N/A	170F
STANDARD RISE UPFRIGHT	⊙	V15100	1/2	6.4	BRASS	N/A	264F
STANDARD RISE UPFRIGHT ON URV G	⊙	V15100	1/2	6.4	BRASS	N/A	264F
STANDARD RISE UPFRIGHT W/FLARE	⊙	V15100	1/2	6.4	BRASS	JPC CHN	170F
STANDARD HORIZONTAL SIDEWALL	◁	T19311	1/2	6.4	BRASS	NONE	170F

REV	DATE	BY	CHKD	APP'D	DESC

NAVIFAC

CPT

CITYFIELD PACIFIC, INC.
184 HANAWALE STREET
HONOLULU, HAWAII 96813

TEL: (808) 953-2800
FAX: (808) 953-2700

DESIGN	DATE
FOR SUBMITTED WORK	

REVISIONS OF THE WORK

NAVIFAC HAWAII

LOCAL, HONOLULU, HAWAII

JOINT BASE PEARL HARBOR HICKAM (RED HILL)
FY15 P-155 (DESC: 1551) UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FIRE PROTECTION NEW PLAN -
AREA 66 - LOWER LEVEL

REVISION NO. 1306143
CENTER CONTR. NO.
NAVIFAC DRAWING NO.
TOTAL SPANNERS THIS LEVEL: 417


FT134

DRAWING MADE BY: JEFF 2015

1 2 3 4 5

THE DESIGNER SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES




PARTIAL FIRE PROTECTION NEW PLAN - AREA 67 - LOWER LEVEL



FD100 FT134 SCALE 1/8" = 1' 0"

SCALE 1/8" = 1' 0"



AS BUILT

SYMBOL	IN	DRIVE	GAUGE	FRAM	PLATE	TEMP	QTY/AM	STAND
○	1/2	S.A.	BRASS	N/A	175°	8	STANDARD RESP UPRIGHT	13208-13
○	1/2	S.A.	BRASS	N/A	284°	136	STANDARD RESP UPRIGHT	13208-13
○	1/2	S.A.	BRASS	N/A	284°	449	STANDARD RESP UPRIGHT ON SPONGE	13208-13
○	1/2	S.A.	BRASS	SFC CHR	175°	8	STANDARD RESP ENGINE W/ PLATE	13208-13
△	1/2	S.A.	BRASS	NONE	175°	2	STANDARD RESP HORN SIGNAL	13208-13

TOTAL SPR HEADS THIS LEVEL: 417

NO. 1	DATE	BY	CHKD
NO. 2	DATE	BY	CHKD
NO. 3	DATE	BY	CHKD
NO. 4	DATE	BY	CHKD
NO. 5	DATE	BY	CHKD
NO. 6	DATE	BY	CHKD
NO. 7	DATE	BY	CHKD
NO. 8	DATE	BY	CHKD
NO. 9	DATE	BY	CHKD
NO. 10	DATE	BY	CHKD
NO. 11	DATE	BY	CHKD
NO. 12	DATE	BY	CHKD
NO. 13	DATE	BY	CHKD
NO. 14	DATE	BY	CHKD
NO. 15	DATE	BY	CHKD
NO. 16	DATE	BY	CHKD
NO. 17	DATE	BY	CHKD
NO. 18	DATE	BY	CHKD
NO. 19	DATE	BY	CHKD
NO. 20	DATE	BY	CHKD

NAVAFAC HAWAII
 CIVIL ENGINEERING
 1000 S. WILSON AVENUE, SUITE 100
 HONOLULU, HAWAII 96819
 TEL: (808) 955-0900
 FAX: (808) 955-2000


PROJECT: JOINT BASE PEARL HARBOR HICOM (RED HILL) OAHU, HAWAII
 FT16 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN - AREA 67 - LOWER LEVEL

PROJECT NO.: FT135



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORK SHALL BE INSTALLED AS NECESSARY TO AVOID CONFLICTS AND TO BE INSTALLED WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

REVISIONS: 10/22/05



PARTIAL FIRE PROTECTION NEW PLAN - AREA 68 - LOWER LEVEL
SCALE 1/8" = 1' 0"



AS BUILT

SPRINKLER HEAD LEGEND:		SYMBOL	IN	ORIFICE	ACTOR	FRAG	GLASS	TEMP	CEILING	HEAD
STANDARD RESP UPFRIGHT		⊙	1/2	S.A.	BRASS	N/A	N/A	179°	5	
STANDARD RESP UPRIGHT		⊙	1/2	S.A.	BRASS	N/A	N/A	284°	136	
STANDARD RESP UPRIGHT CN SPRIG		⊙	1/2	S.A.	BRASS	N/A	N/A	284°	44P	
STAND RESP ENDING W/ PLATE		⊙	1/2	S.A.	BRASS	SFC CHN	179°	5		
STAND RESP HORN SIGNAL SIDEWALL		⊙	1/2	S.A.	BRASS	NONE	179°	5		

TOTAL SPR HEADS THIS LEVEL: 417

NO. 10-18-17	NO. 10-17-17	NO. 10-16-17	NO. 10-15-17	NO. 10-14-17
NO. 10-13-17	NO. 10-12-17	NO. 10-11-17	NO. 10-10-17	NO. 10-09-17
NO. 10-08-17	NO. 10-07-17	NO. 10-06-17	NO. 10-05-17	NO. 10-04-17
NO. 10-03-17	NO. 10-02-17	NO. 10-01-17	NO. 10-00-17	NO. 09-29-17

1. VERIFY THAT THIS DRAWING HAS BEEN APPROVED BY THE USER OF EACH OF THESE DRAWINGS.
 CREDITED PROJECT, INC.
 200 W. KALANIOU STREET
 HONOLULU, HAWAII 96819
 TEL: (808) 955-0908
 FAX: (808) 955-2501
 E-MAIL: INFO@CREDITED.COM
 WWW.CREDITED.COM

SUBMITTED BY: HCL PLO/DR: [] DATE PRODUCTION: [] SERVICE MANAGER: [] CHECKED BY: [] DATE CHECKED: []	PROJECT: [] SHEET NO.: FT136
--	----------------------------------

LEAD ENGINEER: []
 PROJECT MANAGER: []
 DESIGNER: []
 CHECKER: []
 DATE: []


NAVFAC HAWAII
 JOINT BASE PEARL HARBOR HICOM (RED HILL)
 FT116 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN -
 AREA 68 - LOWER LEVEL

FT136


SHEET NO. 1306-13
 CONTRACT NO. []
 DRAWING NO. []
 PROJECT NO. []
 DATE: 10/25/17

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORK SHALL BE INSTALLED AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34"
REDUCED PRINT - USE GRAPHIC SCALES



PARTIAL FIRE PROTECTION NEW PLAN - AREA 69 - LOWER LEVEL
 SCALE 1/8" = 1'-0"



AS BUILT

SYMBOL	IN	ORIFICE	ACTOR	FRAM	PLATE	TEMP.	GRAM	STAND.
○	1/2	S.A.	BRASS	N/A	175°	5	STAND.	
○	1/2	S.A.	BRASS	N/A	284°	136	STAND.	
○	1/2	S.A.	BRASS	N/A	284°	449	STAND.	
○	1/2	S.A.	BRASS	SFC CHN	175°	5	STAND.	
△	1/2	S.A.	BRASS	NONE	175°	2	STAND.	

TOTAL SPRINGERS THIS LEVEL: 417

SEE SHEET FT134 FOR CONTINUATION

NAVAFAC HAWAII

JOINT BASE PEARL HARBOR HILOAH (RED HILL) OAHU, HAWAII
 FT15 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN - AREA 69 - LOWER LEVEL

DATE	10-18-17
BY	10-20-17
CHKD	8-28-17
APP'D	8-11-17
REV	7-28-17
DATE	5-4-18

PROJECT NO. 1326143

CONTRACT NO. 1326143

REVISED BY: []

DATE: []


SCALE: 1/8" = 1'-0"

PROJECT: FT137

DATE: 10-18-17

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORKING TIMES AS NECESSARY TO AVOID CONFLICTS AND TO COMPLETE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



SEE SHEET FT137 FOR CONTINUATION

SEE SHEET FT139 FOR CONTINUATION

PARTIAL FIRE PROTECTION NEW PLAN - AREA 70 - LOWER LEVEL
SCALE 1/8" = 1'-0"



AS BUILT


SPRINKLER HEAD LEGEND:	SYMBOL	IN	ORIFICE	ACTOR	FRAM	GLASS	TEMP	CEILING	SHIELD
STANDARD RESP UPFRIGHT	⊙	1/2	5.4	BRASS	N/A	N/A	175°	8	STANDARD
STANDARD RESP UPRIGHT	○	1/2	5.4	BRASS	N/A	N/A	284°	136	CONVEX COVER, N.L.
STANDARD RESP UPRIGHT ON SPRIG	⊙	1/2	5.4	BRASS	N/A	N/A	284°	449	
STANDARD RESP ENDING W/ PLATE	⊙	1/2	5.4	BRASS	SFC CHN	175°	8		
STANDARD RESP FOR ZENITH SIDEWALL	△	1/2	5.4	BRASS	NONE	NONE	175°	2	

TOTAL SPRINKERS THIS LEVEL: 417

10-16-17 10-2-17 8-28-17 8-11-17 7-28-17 8-4-18 8-18-18	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100
I CERTIFY THAT THIS DRAWING WAS PREPARED BY ME OR UNDER MY CLOSE PERSONAL SUPERVISION.				
CREDITABLE PROJECT, INC. 888 KAWAHAU STREET HONOLULU, HAWAII 96819				
TEL: (808) 935-0300 FAX: (808) 935-2301 E-MAIL: info@creditable.com				
PROJECT NO.: 1326143 SHEET NO.: FT138				
CONTRACTOR:				
DESIGNED BY:				
CHECKED BY:				
APPROVED BY:				
DATE:				
PROJECT LOCATION:				
PROJECT DESCRIPTION:				
PROJECT NO.:				
SHEET NO.:				


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORK SHALL BE INSTALLED AS NECESSARY TO AVOID CONFLICTS AND TO BE INSTALLED WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



PARTIAL FIRE PROTECTION NEW PLAN - AREA 71 - LOWER LEVEL

SCALE 1/8" = 1' 0"



AS BUILT

SPRINGER HEAD LEGEND	SYMBOL	IN	ORIFICE	ACTOR	HEAD	GLASS	TEMP.	GRAM	STAND
STANDARD RESP. UPRIGHT	⊙	1/2	5.8	BRASS	N/A	178°	8		
STANDARD RESP. UPRIGHT	⊙	1/2	5.8	BRASS	N/A	284°	136		
STANDARD RESP. UPRIGHT ON SPIGOT	⊙	1/2	5.8	BRASS	N/A	284°	449		
STAND RESP. P. ENDING w/ PLATE	⊙	1/2	5.8	BRASS	SFC CHN	178°	8		
STAND RESP. RISE SIGNAL SIDEWALL	⊙	1/2	5.8	BRASS	NONE	178°	2		

TOTAL SPR. HEADS THIS LEVEL: 417

NO. 10-10-17	NO. 10-10-17	NO. 10-10-17	NO. 10-10-17	NO. 10-10-17	NO. 10-10-17	NO. 10-10-17	NO. 10-10-17
1	2	3	4	5	6	7	8
10-10-17	10-10-17	10-10-17	10-10-17	10-10-17	10-10-17	10-10-17	10-10-17

NAVAFAC HAWAII
 CIVIL ENGINEERING
 1000 S. BAYVIEW AVE., SUITE 100
 HONOLULU, HAWAII 96813
 TEL: (808) 933-0300
 FAX: (808) 933-2001


PROJECT: FT 139
 SHEET: FT 139-013
 DATE: 10/17/17

DESIGNED BY: MJC
 DRAWN BY: JCY
 CHECKED BY: JCY
 IN CHARGE: JCY

REVISIONS:
 1. 10/17/17 - REVISED PER COMMENTS FROM NAVAFAC HAWAII
 2. 10/17/17 - REVISED PER COMMENTS FROM NAVAFAC HAWAII
 3. 10/17/17 - REVISED PER COMMENTS FROM NAVAFAC HAWAII
 4. 10/17/17 - REVISED PER COMMENTS FROM NAVAFAC HAWAII
 5. 10/17/17 - REVISED PER COMMENTS FROM NAVAFAC HAWAII
 6. 10/17/17 - REVISED PER COMMENTS FROM NAVAFAC HAWAII
 7. 10/17/17 - REVISED PER COMMENTS FROM NAVAFAC HAWAII
 8. 10/17/17 - REVISED PER COMMENTS FROM NAVAFAC HAWAII

PROJECT: FT 139
 SHEET: FT 139-013
 DATE: 10/17/17

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.



PARTIAL FIRE PROTECTION NEW PLAN - AREA 72 - LOWER LEVEL
 SCALE 1/8" = 1'-0"

KEY PLAN
 NO

AS BUILT

SYMBOL	IN	ORIFICE	ACTOR	FRAM	PLATE	TEMP	GRAM	STAND
○	1/2	S.A.	BRASS	N/A	178°	8		
○	1/2	S.A.	BRASS	N/A	284°	136		
○	1/2	S.A.	BRASS	N/A	284°	449		
○	1/2	S.A.	BRASS	SFC CHN	178°	8		
△	1/2	S.A.	BRASS	NONE	178°	2		

TOTAL SPR NGERS THIS LEVEL: 417


NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17

NAVAFAC HAWAII
 MAJOR FACILITIES ENGINEERING COMMAND
 LEADERSHIP OF THE NAVY
 CIVIL ENGINEER
 OAHU, HAWAII
 FT 16 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN - AREA 72 - LOWER LEVEL

PROJECT NO. 1320143
 SHEET NO. 449
 DATE 08/08/10
 FT140

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORK SHALL BE INSTALLED AS NECESSARY TO AVOID CONFLICTS AND TO BE INSTALLED WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



PARTIAL FIRE PROTECTION NEW PLAN - AREA 73 - LOWER LEVEL

SCALE 1/8" = 1'-0"

0 2' 4' 8' 16'
SCALE 1/8" = 1'-0"

KEY PLAN

AS BUILT

SYMBOL	IN	ORIFICE	ACTOR	FRAG	GLASS	TEMP.	CEILING	STAND
○	1/2	S.A.	BRASS	N/A	178°	8	STAND	
○	1/2	S.A.	BRASS	N/A	284°	136	STAND	
○	1/2	S.A.	BRASS	N/A	284°	449	STAND	
○	1/2	S.A.	BRASS	SFC CHN	178°	8	STAND	
△	1/2	S.A.	BRASS	NONE	178°	2	STAND	

TOTAL SPR HEADS THIS LEVEL: 417


10-18-17	10-20-17	8-23-17	8-23-17	8-23-17	8-23-17	8-23-17	8-23-17	8-23-17	8-23-17
REV	REV	REV	REV	REV	REV	REV	REV	REV	REV
1	2	3	4	5	6	7	8	9	10
ADD	ADD	ADD	ADD	ADD	ADD	ADD	ADD	ADD	ADD
BY	BY	BY	BY	BY	BY	BY	BY	BY	BY
CHK	CHK	CHK	CHK	CHK	CHK	CHK	CHK	CHK	CHK
APP	APP	APP	APP	APP	APP	APP	APP	APP	APP

NAVIFAC HAWAII
1041, HAWAII
FUEL SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FIRE PROTECTION NEW PLAN -
AREA 73 - LOWER LEVEL

PROJECT NO. 1306143
SHEET NO. FT141


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORKING TIMES AS NECESSARY TO AVOID CONFLICTS AND TO THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



PARTIAL FIRE PROTECTION NEW PLAN - AREA 74 - LOWER LEVEL

SCALE 1/8" = 1' 0"



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	IN	ORIFICE	ACTOR	FRAG. CLASS	GLASS	TEMP.	CEILING	STAND.
STANDARD RESP. UPRIGHT	⊙	1/2	5.4	BRASS	N/A	179°	8	STAND.	1320E-43
STANDARD RESP. UPRIGHT	⊙	1/2	5.4	BRASS	N/A	284°	136	STAND.	1320E-43
STANDARD RESP. UPRIGHT CH. SPRIG	⊙	1/2	5.4	BRASS	N/A	284°	44P	STAND.	1320E-43
STAND RESP. ENDING W/ PLATE	⊙	1/2	5.4	BRASS	SFC CHN	179°	8	STAND.	1320E-43
STAND RESP. HORN SIGNAL SIDEWALL	⊙	1/2	5.4	BRASS	HORN	179°	2	STAND.	1320E-43

NAVIFAC HAWAII

ENGINEERING CONSULTANTS

1000 KALANIANA'OHU BLVD., SUITE 1000, HONOLULU, HI 96813

TEL: (808) 953-8888 FAX: (808) 953-2000

PROJECT NO. 1713

DATE: 01/15/2010

DESIGNED BY: JMC

DRAWN BY: JMC

CHECKED BY: JMC

PROJECT: JOINT BASE PEARL HARBOR HICOM (RED HILL) OAHU, HAWAII

DESCRIPTION: F115 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

PARTIAL FIRE PROTECTION NEW PLAN - AREA 74 - LOWER LEVEL

REVISIONS:

NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMITS	10-15-10
2	ISSUED FOR CONSTRUCTION	10-20-10
3	REV - ADD TO THE DRAW PLAN REVISION	11-11-10
4	REV - ADD TO THE DRAW PLAN REVISION	1-20-11
5	REV - ADD TO THE DRAW PLAN REVISION	3-24-11
6	REV - ADD TO THE DRAW PLAN REVISION	5-24-11

SCALE: 1/8" = 1' 0"

THIS SHEET

FOOTNOTES:

1. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

2. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

3. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

4. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

5. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

6. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

7. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

8. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

9. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

10. VERIFY THAT THE DRIVING AND RECEIVING CONTRACTOR HAS OBTAINED ALL NECESSARY PERMITS.

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE LOCATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


1 2 3 4 5

D

C

B

A




PARTIAL FIRE PROTECTION NEW PLAN - AREA 75 - LOWER LEVEL



SCALE 1/8" = 1' 0"



KEY PLAN



AS BUILT

SPRINGER HEAD LEGEND:	SYMBOL	IN	ORIFICE	GACTOR	FRAG	GLASS	TEMP.	REAM
STANDARD RESP UPRIGHT	⊙	1 1/2	E.A.	B.R.A.S.S.	N/A	178°	6	
STANDARD RESP UPRIGHT	○	1 1/2	E.A.	B.R.A.S.S.	N/A	284°	136	
STANDARD RESP UPRIGHT ON SPING	⊙	1 1/2	E.A.	B.R.A.S.S.	N/A	284°	449	
STANDARD RESP ENDING W/ PLATE	⊙	1 1/2	E.A.	B.R.A.S.S.	S.P.C. CHN	178°	6	
STANDARD RESP FOR SIGNAL SIGNALWALL	◁	1 1/2	E.A.	B.R.A.S.S.	NONE	178°	2	

TOTAL SPR HEADS THIS LEVEL: 417

16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17
16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17
16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17
16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17	16-16-17

NAVFAC HAWAII

JOINT BASE PEARL HARBOR HILOAH (RED HILL) OAHU, HAWAII
 FT 15 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN -
 AREA 75 - LOWER LEVEL

PROJECT NO. 1326143

DATE: 08/20/18

BY: [Signature]

CHECKED: [Signature]

APPROVED: [Signature]

SCALE: 1/8" = 1' 0"

PROJECT NUMBER: 1326143

DATE: 08/20/18

BY: [Signature]

CHECKED: [Signature]

APPROVED: [Signature]

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORK SHALL BE AS NECESSARY TO AVOID CONFLICTS AND TO BE INSTALLED WITHIN THE AVAILABLE SPACE.

D

C

B

A


1

2

3


4

5



27 to band
3 to door

SEE SHEET FT162 FOR CONTINUATION



SEE SHEET FT152 FOR CONTINUATION




PARTIAL FIRE PROTECTION NEW PLAN - AREA 1 & 2 - UPPER LEVEL

SCALE: 1/8" = 1' 0"



SCALE: 1/8" = 1' 0"



AS BUILT

SPRINKLER HEAD LEGEND:								QUANTITY	TOTAL
SYMBOL	SIZE	ORIFICE	GASKET	TYPE	TEMP.	CLASS.	TEMP.		
○	VK100	1/2"	5.6	BRASS	N/A	254°	S	5	
○	VK300	3/4"	11.3	BRASS	N/A	254°	T21	1	
○	VK302	1/2"	5.6	BRASS	2FC CHR	158°	-	-	

TOTAL SPRINKLERS THIS LEVEL 726

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO ENSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

10-24-17	AS BUILT	10-23-17
8	1	3
1	1	1
1	1	1
1	1	1
1	1	1
1	1	1
1	1	1

UNIVERSITY PROJECT, INC.
300 SHANAHAN STREET
DUNELAH, INDIANA 46829

TEL: 9380 855-0300
FAX: 9380 855-0301

REV	DATE	DESCRIPTION
001	08/09/17	ISSUED FOR CONSTRUCTION

PROJECT: FT 151

DRAWN BY: [Redacted]

CHECKED BY: [Redacted]

DATE: 12/28/17

SCALE: AS SHOWN

PROJECT LOCATION:
ONAMI, HAWAII
PEARL HARBOR HIGWAY (RED HILL)
FY18 P-1851 (DESC-1851), UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

PARTIAL FIRE PROTECTION NEW PLAN -
AREA 1 & 2 - UPPER LEVEL - ADD 4

CONTRACT NO.:	1326143
CONTROL NO.:	721
REVISED NO.:	-
FT151	

D

C

B

A

1

2

3

4


1 2 3 4 5

D

C

B

A



SEE SHEET FT151 FOR CONTINUATION

SEE SHEET FT152 FOR CONTINUATION




FD100 FT/52 SCALE: 1/8" = 1' 0"



PARTIAL FIRE PROTECTION NEW PLAN - AREA 3 - UPPER LEVEL

- TALLATION NOTES:
- COLOR CODE FOR PIPE IN TANK GALLERY FROM TANK 1 TO TANK 10 IS CURTAIN.
 - THE LETTERS A, B, AND C RUNNING ALONG THE BOTTOM OF THE TUNNEL ARE MAIN PIPE NUMBERS FOR THE NOT OTHER OTHER PIECES THAT ARE NOT ONE OF THESE 3 TYPICAL PIECES ARE DIFFERENTIALLY NUMBERED WHERE THEY OCCUR.
 - TYPICAL BRACKETS ARE HELD OUT BY HOSE WIPERS THAT HOLD TO 1" PIPE SUPPLYING MANUAL HEADS.




AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	SN	CONTR	GARDEN	HEAD	TEMP	QUANT	NOTES
STANDARD RESP UPRIGHT	○	VE100	1/2"	5.4	BRASS	N/A	284	5
STANDARD RESP UPRIGHT ON SPRIG	⊗	VE300	3/4"	11.3	BRASS	N/A	284	721
QUICK RESP PENDENT	●	VE302	1/2"	5.4	BRASS	2FC CBR	158*	-

TOTAL SPRINKLERS THIS LEVEL: 726


10-14-17	AS BUILT
10-27-17	REV. 1 - FINAL CHECKS FOR DESIGN REVISIONS
4-28-17	REV. 2 - REVISED IN THE TANK TANK AREA 1023
8-11-17	REV. 3 - REVISED IN THE TANK TANK AREA 1023
8-23-17	REV. 4 - REVISED AS BUILT FROM THE TANK TANK AREA 1023
8-23-17	REV. 5 - REVISED AS BUILT FROM THE TANK TANK AREA 1023
8-23-17	REV. 6 - REVISED AS BUILT FROM THE TANK TANK AREA 1023



CPI
 1100 W. OAK ST. SUITE 100
 DENVER, CO 80202
 TEL: (303) 955-0000
 FAX: (303) 955-0000
 WWW: WWW.CPI-INC.COM

CONTRACTOR OF THE NAVY
 NAVFAC HAWAII
 PERM NUMBER: 15011
 OHU, HAWAII
 JOINT BASE PEARL AND HERMES HOBAR (RED HILL)
 PYS 15 P-1501 (DESC-1501), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN -
 AREA 3 - UPPER LEVEL

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO COMPLETE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.



ONLY 4 LINES INSTALLED IN ACCESS TUNNEL TO TK 1

LAST HANGER NOT INSTALLED ON BRANCH LINE SPRING TO SPRINKLER APPROX 24" PHOTOS 100-0109 & 100-0110

ONLY 5 LINES IN ACCESS TUNNEL TO TK 3

INSTALLATION NOTES:

1. COLOR CODE FOR PIPE IN TANK GALLERY FROM TANK 1 TO TANK 10 IS USABLE - LINES A, B AND C HANGING ALONG TOP OF THE TUNNEL ARE MAIN HANGERS FOR THE NET SYSTEM EXES THAT ARE NOT ONE OF TYPICAL PIECES ARE INDIVIDUALLY IDENTIFIED WHERE THEY OCCUR.
2. TYPICAL BRANCH LINES ARE FIELD CUT 1/8" ROSE HANGERS THAT REPLACE 1" PFC SUPPLYING INDIVIDUAL HEADS.

SPRING IS APPROX 4'-10" WITH NO LATERAL SUPPORT 100-0112

NO VALVED OUTLET FOR GAUGE PROVIDED



NO HANGER ON BRANCH LINE OR SPRIG 100-0118

SPRING IS APPROX 4'-10" WITH NO LATERAL SUPPORT 100-0112

ONLY 5 LINES IN ACCESS TUNNEL TO TK 4

TANK 2
ONLY 3 LINES INSTALLED DOWN TK2 ACCESS TUNNEL

PARTIAL FIRE PROTECTION NEW PLAN - AREA 4 - UPPER LEVEL



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	SH	ORIF	GAWD/C	WATER	ALIAS	TEMP	QUANT
STANDARD RESP UPRIGHT	○	VE100	1/2"	5.6	BRASS	N/A	284°	5
STANDARD RESP UPRIGHT ON SPRIG	⊙	VE300	3/4"	11.2	BRASS	N/A	284°	721
QUICK RESP PENDENT	⊕	VE302	1/2"	5.6	BRASS	2FC CHR	155°	-

TOTAL SPRINKLERS THIS LEVEL 726

NAVAFAC

CPI

UNITED STATES OF AMERICA
DEPARTMENT OF THE NAVY
NAVFAC HAWAII

PROJECT NO. 1306143


CONTRACT NO. N624-01-000000000000

NAVFAC DESIGN NO. FT153


DATE: 12 AUG 2013

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO PROVIDE FOR THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



- INSTALLATION NOTES:**
- COLOR CODE FOR PIPE IN TANK GALLERY FROM TANK 1 TO TANK 10 IS BLUE.
 - THE LETTERS A, B, AND C RUNNING ALONG THE BOTTOM OF THE TUNNEL ARE MAIN PIPE NUMBERS FOR THE RED SYSTEM. OTHER PIPES THAT ARE NOT ONE OF THESE 3 TYPICAL PIPES ARE INDIVIDUALLY NUMBERED WHERE THEY OCCUR.
 - TYPICAL BRANCHES ARE FIELD CUT UP REED. THIS REED IS 1" NPS SUPPLYING INDIVIDUAL HEADS.



PARTIAL FIRE PROTECTION NEW PLAN - AREA 5 - UPPER LEVEL



AS BUILT

REV	DATE	DESCRIPTION
1	10-14-17	AS BUILT
2	10-27-17	REVISED FOR DESIGN RESPONSE
3	4-24-17	REVISED FOR DESIGN RESPONSE
4	4-24-17	REVISED FOR DESIGN RESPONSE
5	4-24-17	REVISED FOR DESIGN RESPONSE
6	4-24-17	REVISED FOR DESIGN RESPONSE
7	4-24-17	REVISED FOR DESIGN RESPONSE
8	4-24-17	REVISED FOR DESIGN RESPONSE
9	4-24-17	REVISED FOR DESIGN RESPONSE
10	4-24-17	REVISED FOR DESIGN RESPONSE
11	4-24-17	REVISED FOR DESIGN RESPONSE
12	4-24-17	REVISED FOR DESIGN RESPONSE
13	4-24-17	REVISED FOR DESIGN RESPONSE
14	4-24-17	REVISED FOR DESIGN RESPONSE
15	4-24-17	REVISED FOR DESIGN RESPONSE
16	4-24-17	REVISED FOR DESIGN RESPONSE
17	4-24-17	REVISED FOR DESIGN RESPONSE
18	4-24-17	REVISED FOR DESIGN RESPONSE

NAVFAC

CPI

UNIVERSITY PROJECT, INC.
100 WILSON STREET
DUNELM, ILLINOIS 60118

TEL: (800) 955-0500
FAX: (800) 955-0501

DESIGNED BY: []
CHECKED BY: []
IN CHARGE: []
PROJECT MANAGER: []
SUPERVISOR: []
DRAWN BY: []
DATE: []


NAVFAC HAWAII
LAWSON, HAWAII
1000 W. WILSON STREET
DUNELM, ILLINOIS 60118

CONTRACT NO. 1306143

CONTRACT DATE: 1/21

NAVFAC DRAWING NO. FT154



REVISED FOR DESIGN RESPONSE



INSTALLATION NOTES:

1. COLOR CODE FOR PIPE IN TANK GALLERY FROM TANK 1 TO TANK 10 IS BLUE.
2. THE LETTERS A, B, AND C MARKS ALONG THE BOTTOM OF THE TUNNEL ARE MARK FIELD NUMBERS FOR THE NET SYSTEM.
3. OTHER PIECES THAT ARE NOT ONE OF THESE 3 TYPICAL PIECES ARE INDIVIDUALLY NUMBERED WHERE THEY OCCUR.
4. THICK BRACKETS ARE FIELD CUT UP PIPE FITTINGS THAT REDUCE TO 1" PIPE SUPPLYING INDIVIDUAL HEADS.


PARTIAL FIRE PROTECTION NEW PLAN - AREA 6 - UPPER LEVEL



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	SN	ORIFICE	WATER	TEMP.	QUANTITY	REMARKS
STANDARD RESP UPRIGHT	⊙	VI130	1/2"	5.4	BRASS	N/A	284°
STANDARD RESP UPRIGHT ON SPRIG	⊙	VI302	3/4"	11.2	BRASS	N/A	284°
QUICK RESP PENDENT	⊙	VI302	1/2"	5.4	BRASS	2FC CHR	158°
TOTAL SPRINKLERS THIS LEVEL							724

10-14-17	REV
10-2-17	REV
8-28-17	REV
8-11-17	REV
7-28-17	REV
5-4-17	REV
5-4-17	REV




CPI
 CIVIL ENGINEERING
 1001 W. PINE AVE. SUITE 100
 HONOLULU, HAWAII 96819
 TEL: (808) 955-0500
 FAX: (808) 955-0501

DATE	DATE	DATE

NAVFAC HAWAII
 CIVIL ENGINEERING COMMAND
 PERM. PROJECT NO. 1326143
 ONI, HAWAII
 FY18 P-1851 (DESC-1851), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN -
 AREA 6 - UPPER LEVEL


DATE PLOTTED: 10 JUL 2018
FT155

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO PROVIDE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.
 IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES




INSTALLATION NOTES:

- COLOR CODE FOR PIPE IN TANK GALLERY FROM TANK 1 TO TANK 10 IS CUBBLE.
- THE LETTERS A, B, AND C RUNNING ALONG THE BOTTOM OF THE TUNNEL ARE MAIN PIPE NUMBERS FOR THE NET SYSTEM.
- OTHER PIECES THAT ARE NOT ONE OF THESE 3 TYPICAL PIECES ARE INDIVIDUALLY NUMBERED WHERE THEY OCCUR.
- TYPICAL BRACKETS ARE FIELD CUT IN HOSE BRACKETS THAT OCCUR TO 1" PIPE SUPPLYING INDIVIDUAL HEADS.



PARTIAL FIRE PROTECTION NEW PLAN - AREA 7 - UPPER LEVEL



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	IN	ORIFICE	GALLONS	TEMP	QUANTITY
STANDARD RESP UPRIGHT	○	1/2"	5.4	BRASS	N/A	284
STANDARD RESP UPRIGHT ON SPRIG	⊙	3/4"	11.2	BRASS	N/A	721
QUICK RESP PENDENT	⊗	1/2"	5.4	BRASS	27C CHR	157

TOTAL SPINKLERS THIS LEVEL 1162

REV	DATE	BY	CHKD
10-14-17			
10-2-17			
8-28-17			
8-11-17			
7-28-17			
5-8-16			

NAVAFAC

CPI

UNIVERSITY PROJECT, INC.
10800 SHAWNEE STREET
DOWNEY, CALIFORNIA 90240

TEL: 656-955-0500
FAX: 656-955-0501

DATE: 10/14/17

PROJECT: FT157 JOIL CONTINUATION

DESIGNED BY: []
CHECKED BY: []
DATE: []

PROJECT NO: []
JOB NO: []
SHEET NO: []

ENGINEER OF THE WORK: []
NAVFAC HAWAII

JOINT BASE PEARL HARBOR HONOLULU (RED HILL)
OHU, HAWAII
FY18 P-1851 (DESC-1851), UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FIRE PROTECTION NEW PLAN -
AREA 7 - UPPER LEVEL


CONTRACT NO: 1326143
CONTRACTOR: []
NAVFAC DRAWING NO: []

FT156

ISSUED: 10/14/17

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



SEE SHEET FT156 FOR CONTINUATION

10-14-17	10-2-17	8-28-17	8-11-17	8-1-17	8-1-17
AS BUILT	CONTRACT FOR DESIGN REVISION	ISSUE IN THE CON PLAN REVISION	ISSUE IN THE CON PLAN REVISION	ISSUE IN THE CON PLAN REVISION	ISSUE IN THE CON PLAN REVISION
10-14-17	10-2-17	8-28-17	8-11-17	8-1-17	8-1-17
AS BUILT	CONTRACT FOR DESIGN REVISION	ISSUE IN THE CON PLAN REVISION	ISSUE IN THE CON PLAN REVISION	ISSUE IN THE CON PLAN REVISION	ISSUE IN THE CON PLAN REVISION

NAVAFAC

CPI

UNIVERSITY PROJECT, INC.
404 SHAWANEE STREET
IDEALHILL, HAWAII 96849

TEL: (808) 955-0500
FAX: (808) 955-0501

DESIGNED BY: []
CHECKED BY: []
DATE: []

CONTRACT NO. OF THE NAVY: []
PROJECT NO.: []
JOB NO.: []
SHEET NO.: []

CONTRACTOR: []
SUBCONTRACTOR: []
GENERAL CONTRACTOR: []

NAVAFAC HAWAII
ONHI, H
JOINT BASE PEARL-HARBOR HOBAM (RED HILL)
PY15 P-1581 (DESC-1581), UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FIRE PROTECTION NEW PLAN -
AREA 8 - UPPER LEVEL


CONTRACT NO.: 1326143
CONTRACTOR: []
NAVAFAC DRAWING NO.: []

FT157


ISSUED: []

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO COMPLETE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



- INSTALLATION NOTES:**
1. COLOR CODE FOR PIPE IN TANK GALLERY FROM TANK 11 TO TANK 20 IS BLUE.
 2. THE LETTERS A, B, AND C RUNNING ALONG THE BOTTOM OF THE TUNNEL ARE MAIN PIPE HANGERS FOR THE NET SYSTEM. OTHER PIPES THAT ARE NOT ONE OF THESE 3 TYPICAL PIPES ARE INDIVIDUALLY NUMBERED WHERE THEY OCCUR.
 3. TYPICAL BRANCHES ARE FIELD CUT OUT FROM MAINS THAT OCCUR TO 1" PIPE SUPPLYING INDIVIDUAL HEADS.



PARTIAL FIRE PROTECTION NEW PLAN - AREA 9 - UPPER LEVEL




AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	QTY	COMP.	FACTORY	CLASS	TEMP.	QUANTITY	NOTES
STANDARD RESP UPRIGHT	⊙	16100	1/2"	5.4	BRASS	144°	5	
STANDARD RESP UPRIGHT ON SPRIG	⊙	16300	3/4"	11.2	BRASS	144°	721	
QUICK RESP PENDENT	⊙	16302	1/2"	5.4	BRASS	27C CBR	153*	
TOTAL SPRINKLERS THIS LEVEL								726

REV	DATE	BY	CHKD	
1	10-14-17	AS BUILT		
2	10-2-17	FINAL CHECK FOR DESIGN REVISION		
3	8-28-17	REV - ADD IN THE TANK TANK 20		
4	8-11-17	REV - ADD IN THE TANK TANK 20		
5	7-21-17	REV - ADD IN THE TANK TANK 20		
6	7-21-17	REV - ADD IN THE TANK TANK 20		
7	7-21-17	REV - ADD IN THE TANK TANK 20		
8	7-21-17	REV - ADD IN THE TANK TANK 20		
9	7-21-17	REV - ADD IN THE TANK TANK 20		
10	7-21-17	REV - ADD IN THE TANK TANK 20		
11	7-21-17	REV - ADD IN THE TANK TANK 20		
12	7-21-17	REV - ADD IN THE TANK TANK 20		
13	7-21-17	REV - ADD IN THE TANK TANK 20		
14	7-21-17	REV - ADD IN THE TANK TANK 20		
15	7-21-17	REV - ADD IN THE TANK TANK 20		
16	7-21-17	REV - ADD IN THE TANK TANK 20		
17	7-21-17	REV - ADD IN THE TANK TANK 20		
18	7-21-17	REV - ADD IN THE TANK TANK 20		
19	7-21-17	REV - ADD IN THE TANK TANK 20		
20	7-21-17	REV - ADD IN THE TANK TANK 20		
NAVAFAC				
CPI				
CITYFIELD PROJECT, INC. ONE SHAWNEE STREET DOWNEY, ILLINOIS 60429				
TEL: 630-953-0800 FAX: 630-953-0801				
DATE: 10/14/17				
PROJECT: PARTIAL FIRE PROTECTION NEW PLAN - AREA 9 - UPPER LEVEL				
DRAWN BY: [Name]				
CHECKED BY: [Name]				
APPROVED BY: [Name]				
SCALE: 1/8" = 1'-0"				
TOTAL SPRINKLERS THIS LEVEL: 726				
FT158				


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK WITH ALL OTHER TRADES AS NECESSARY TO AVOID CONFLICTS AND TO PROVIDE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE. IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



INSTALLATION NOTES:

1. COLOR CODE FOR PIPE IN TANK GALLERY FROM TANK 11 TO TANK 20 IS AS FOLLOWS:
2. THE LETTERS A, B, AND C RUNNING ALONG THE BOTTOM OF THE TUNNEL ARE MAIN PIPE HANGERS FOR THE NET SYSTEM. OTHER PIPES THAT ARE NOT ONE OF THESE 3 TYPICAL PIPES ARE INDIVIDUALLY NUMBERED WHERE THEY OCCUR.
3. TYPICAL BRACKETS ARE PROVIDED FOR EACH HANGER THAT RECEIVES 1" NPTC SUPPLYING INDIVIDUAL HEADS.

KEY PLAN



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	SN	ORIFICE	GALLONS	HEAD CLASS	TEMP.	QUANTITY
STANDARD RESP UPRIGHT	○	VE100	1/2"	5.4	BRASS	N/A	284
STANDARD RESP UPRIGHT ON SPRIG	⊙	VE300	3/4"	11.2	BRASS	N/A	721
QUICK RESP PENDENT	⊖	VE302	1/2"	5.4	BRASS	25C CHR	153

TOTAL SPRINKLERS THIS LEVEL 724

REV	DATE	BY	DESCRIPTION
1	10-2-17
2	10-2-17
3	10-2-17
4	10-2-17
5	10-2-17
6	10-2-17
7	10-2-17
8	10-2-17
9	10-2-17
10	10-2-17
11	10-2-17
12	10-2-17
13	10-2-17
14	10-2-17
15	10-2-17
16	10-2-17
17	10-2-17
18	10-2-17
19	10-2-17
20	10-2-17

NAVAFAC HAWAII

CONTRACT NO. 1306143

CONTR. CONTR. NO.


NAVAFAC DRAWING NO.

FT159

REVISIONS: 10 JULY 2015


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES




INSTALLATION NOTES:

- COLOR CODE FOR PIPE IN TANK GALLERY FROM TANK 11 TO TANK 20 IS BLUE.
- LETTERS A, B, AND C RUNNING ALONG THE BOTTOM OF THE TUNNEL ARE MAIN PIPE MARKERS FOR THE RYS SYSTEM.
- OTHER PIECES THAT ARE NOT ONE OF THESE 3 TYPES, PIECES ARE INDIVIDUALLY NUMBERED WHERE THEY OCCUR.
- TYPICAL BRANCHLINES ARE FIELD CUT 1/2" BESS WELVES THAT REDUCE TO 1" PIPES SUPPLYING INDIVIDUAL HEADS.



PARTIAL FIRE PROTECTION NEW PLAN - AREA 11 - UPPER LEVEL



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	SH	ORIFICE	GALLONS	TEMP.	QUANT.		
STANDARD RESP UPRIGHT	○	VE100	1/2"	5.4	BRASS	N/A	284"	5
STANDARD RESP UPRIGHT ON SPING	⊙	VE300	3/4"	11.2	BRASS	N/A	284"	721
QUICK RESP PENDENT	⊗	VE302	1/2"	5.4	BRASS	2FC CHR	158"	-

TOTAL SPRINKLERS THIS LEVEL 726


REVISED: 10-14-17
 10-23-17
 4-24-17
 8-11-17
 4-24-17
 4-24-17

AS BUILT
 1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100

NAVFAC
 ONI, HAWAII
 1326143
 721
 FT160
 1326143



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO PROVIDE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



INSTALLATION NOTES:

1. WET RISER ZONE UT#1
2. NOT INSTALLED IN LOCATION SHOWN ON DWG 100-0166 TO 0168
3. NUMBERED WHERE THEY OCCUR.
4. TYPICAL BRANCHES ARE RIGID OUT AT HEAD BRANCHES THAT RELIEVE TO 7\"/>



- RISER LEGEND**
1. 6" GRY WIND EASY RISER WITH GAUGE, FLOW SWITCH, RELOCATE THE 2" TEST/HORN WITH AN OFFICE AND 175 PSI PRESSURE RELIEF TO THE LOW POINT OF THE SYSTEM
 2. 6" FLANGED OS&Y WITH TAMPER SWITCH
 3. 1" AUX DRAIN W/ SIGN
 4. PIPE STAND

SPRINKLER HEAD LEGEND:	SYMBOL	QTY	CONC	GALV	W/CD	W/CD	TEMP	QUANT
STANDARD RESP UPRIGHT	⊙	16100	1/2"	5.6	BRASS	N/A	284°	5
STANDARD RESP UPRIGHT ON SPRIG	⊙	16300	3/4"	11.3	BRASS	N/A	284°	721
QUICK RESP PENDENT	⊙	16302	1/2"	5.6	BRASS	2FC CHR	158°	-
TOTAL SPRINKLERS THIS LEVEL								726

NO.	REV.	DATE	BY	CHKD.
1	AS BUILT	10-14-17
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100





CPI
 CONTRACTORS
 10000 WILSON BLVD
 SUITE 100
 FORT WORTH, TX 76154
 TEL: (817) 551-1111
 FAX: (817) 551-1112
 WWW: CPI.COM

DESIGNED BY: [Blank]
 DRAWN BY: [Blank]
 CHECKED BY: [Blank]
 IN CHARGE: [Blank]



CONTRACT NO. 1326143
 NAVFAC HAWAII
 JOINT BASE PEARL HARBOR HONOLULU (RED HILL)
 PEARL HARBOR, HAWAII
 FY18 P-1851 (DESC-1851), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN -
 AREA 12 - UPPER LEVEL

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.
 IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



1 2 3 4 5







PARTIAL FIRE PROTECTION NEW PLAN
AREA 13 (b) (3) (A) UPPER LEVEL
 SCALE: 1/8" = 1' 0"
 SCALE: 1/8" = 1' 0"
 FD100 FT180



SECTION VIEW OF (b) (3) (A)
 LOOKING TOWARD EXTERIOR DOORS



SECTION VIEW OF (b) (3) (A)
 LOOKING TOWARD EXTERIOR DOORS



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	SIZE	ORIFICE	GRADE	TEMP.	QUANTITY
STANDARD RESP UPRIGHT	○	1/2"	5.6	BRASS	N/A	284
STANDARD RESP UPRIGHT ON SPRIG	⊙	3/4"	11.2	BRASS	N/A	721
QUICK RESP PENDENT	⊙	1/2"	5.6	BRASS	2FC CHR	158

TOTAL SPRINKLERS THIS LEVEL 724

PROJECT NO. 1326143
 CONTRACTOR: NAVFAC HAWAII
 SHEET: FT162

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

NAVFAC

CPI

UNIVERSITY PROJECT, INC.
 1000 KALANANAKUHI STREET
 HONOLULU, HAWAII 96813


TEL: (808) 955-0500
 FAX: (808) 955-0501

DATE: 10/11/10

REVISIONS:

NO.	DATE	DESCRIPTION
1	10/11/10	ISSUE FOR PERMITS
2	10/11/10	ISSUE FOR PERMITS
3	10/11/10	ISSUE FOR PERMITS
4	10/11/10	ISSUE FOR PERMITS
5	10/11/10	ISSUE FOR PERMITS

CONTRACTOR OF THE NAVY
 NAVFAC HAWAII
 PEARL HARBOR, HAWAII
 JOINT BASE PEARL HARBOR HONOLULU (RED HILL)
 FY13 P-1181 (DESC 1181), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN
 ADT 5 - UPPER LEVEL



AREA 13 (b) (3) (A) NORTH
SCALE 1/8" = 1' 0"

AREA 13 - (b) - MIDDLE
SCALE 1/8" = 1' 0"

AREA 13 - (b) - SOUTH
SCALE 1/8" = 1' 0"

AS BUILT

NO. REV.	DATE	BY	DESCRIPTION
1	10-18-17
2	10-20-17
3	10-20-17
4	10-20-17
5	10-20-17
6	10-20-17
7	10-20-17
8	10-20-17
9	10-20-17
10	10-20-17
11	10-20-17
12	10-20-17
13	10-20-17
14	10-20-17
15	10-20-17
16	10-20-17
17	10-20-17
18	10-20-17
19	10-20-17
20	10-20-17
21	10-20-17
22	10-20-17
23	10-20-17
24	10-20-17
25	10-20-17
26	10-20-17
27	10-20-17
28	10-20-17
29	10-20-17
30	10-20-17
31	10-20-17
32	10-20-17
33	10-20-17
34	10-20-17
35	10-20-17
36	10-20-17
37	10-20-17
38	10-20-17
39	10-20-17
40	10-20-17
41	10-20-17
42	10-20-17
43	10-20-17
44	10-20-17
45	10-20-17
46	10-20-17
47	10-20-17
48	10-20-17
49	10-20-17
50	10-20-17
51	10-20-17
52	10-20-17
53	10-20-17
54	10-20-17
55	10-20-17
56	10-20-17
57	10-20-17
58	10-20-17
59	10-20-17
60	10-20-17
61	10-20-17
62	10-20-17
63	10-20-17
64	10-20-17
65	10-20-17
66	10-20-17
67	10-20-17
68	10-20-17
69	10-20-17
70	10-20-17
71	10-20-17
72	10-20-17
73	10-20-17
74	10-20-17
75	10-20-17
76	10-20-17
77	10-20-17
78	10-20-17
79	10-20-17
80	10-20-17
81	10-20-17
82	10-20-17
83	10-20-17
84	10-20-17
85	10-20-17
86	10-20-17
87	10-20-17
88	10-20-17
89	10-20-17
90	10-20-17
91	10-20-17
92	10-20-17
93	10-20-17
94	10-20-17
95	10-20-17
96	10-20-17
97	10-20-17
98	10-20-17
99	10-20-17
100	10-20-17

FT163

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORK SHALL BE INSTALLED AS NECESSARY TO AVOID CONFLICTS AND TO BE INSTALLED WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D

C

B


A

D

C



B

A



UPPER LEVEL - WET RISER DETAIL

SCALE: 1/2" = 1' 0"



(b) (3) (A) - UPPER LEVELS


(b) (3) (A) - PIPING

NO.	DATE	DESCRIPTION
1	08-14-17	ISSUE FOR PERMITS
2	09-27-17	REVISED FOR PERMITS
3	02-07-17	REVISED FOR PERMITS
4	02-07-17	REVISED FOR PERMITS
5	02-07-17	REVISED FOR PERMITS
6	02-07-17	REVISED FOR PERMITS
7	02-07-17	REVISED FOR PERMITS
8	02-07-17	REVISED FOR PERMITS
9	02-07-17	REVISED FOR PERMITS
10	02-07-17	REVISED FOR PERMITS
11	02-07-17	REVISED FOR PERMITS
12	02-07-17	REVISED FOR PERMITS
13	02-07-17	REVISED FOR PERMITS
14	02-07-17	REVISED FOR PERMITS
15	02-07-17	REVISED FOR PERMITS
16	02-07-17	REVISED FOR PERMITS
17	02-07-17	REVISED FOR PERMITS
18	02-07-17	REVISED FOR PERMITS
19	02-07-17	REVISED FOR PERMITS
20	02-07-17	REVISED FOR PERMITS
21	02-07-17	REVISED FOR PERMITS
22	02-07-17	REVISED FOR PERMITS
23	02-07-17	REVISED FOR PERMITS
24	02-07-17	REVISED FOR PERMITS
25	02-07-17	REVISED FOR PERMITS
26	02-07-17	REVISED FOR PERMITS
27	02-07-17	REVISED FOR PERMITS
28	02-07-17	REVISED FOR PERMITS
29	02-07-17	REVISED FOR PERMITS
30	02-07-17	REVISED FOR PERMITS
31	02-07-17	REVISED FOR PERMITS
32	02-07-17	REVISED FOR PERMITS
33	02-07-17	REVISED FOR PERMITS
34	02-07-17	REVISED FOR PERMITS
35	02-07-17	REVISED FOR PERMITS
36	02-07-17	REVISED FOR PERMITS
37	02-07-17	REVISED FOR PERMITS
38	02-07-17	REVISED FOR PERMITS
39	02-07-17	REVISED FOR PERMITS
40	02-07-17	REVISED FOR PERMITS
41	02-07-17	REVISED FOR PERMITS
42	02-07-17	REVISED FOR PERMITS
43	02-07-17	REVISED FOR PERMITS
44	02-07-17	REVISED FOR PERMITS
45	02-07-17	REVISED FOR PERMITS
46	02-07-17	REVISED FOR PERMITS
47	02-07-17	REVISED FOR PERMITS
48	02-07-17	REVISED FOR PERMITS
49	02-07-17	REVISED FOR PERMITS
50	02-07-17	REVISED FOR PERMITS
51	02-07-17	REVISED FOR PERMITS
52	02-07-17	REVISED FOR PERMITS
53	02-07-17	REVISED FOR PERMITS
54	02-07-17	REVISED FOR PERMITS
55	02-07-17	REVISED FOR PERMITS
56	02-07-17	REVISED FOR PERMITS
57	02-07-17	REVISED FOR PERMITS
58	02-07-17	REVISED FOR PERMITS
59	02-07-17	REVISED FOR PERMITS
60	02-07-17	REVISED FOR PERMITS
61	02-07-17	REVISED FOR PERMITS
62	02-07-17	REVISED FOR PERMITS
63	02-07-17	REVISED FOR PERMITS
64	02-07-17	REVISED FOR PERMITS
65	02-07-17	REVISED FOR PERMITS
66	02-07-17	REVISED FOR PERMITS
67	02-07-17	REVISED FOR PERMITS
68	02-07-17	REVISED FOR PERMITS
69	02-07-17	REVISED FOR PERMITS
70	02-07-17	REVISED FOR PERMITS
71	02-07-17	REVISED FOR PERMITS
72	02-07-17	REVISED FOR PERMITS
73	02-07-17	REVISED FOR PERMITS
74	02-07-17	REVISED FOR PERMITS
75	02-07-17	REVISED FOR PERMITS
76	02-07-17	REVISED FOR PERMITS
77	02-07-17	REVISED FOR PERMITS
78	02-07-17	REVISED FOR PERMITS
79	02-07-17	REVISED FOR PERMITS
80	02-07-17	REVISED FOR PERMITS
81	02-07-17	REVISED FOR PERMITS
82	02-07-17	REVISED FOR PERMITS
83	02-07-17	REVISED FOR PERMITS
84	02-07-17	REVISED FOR PERMITS
85	02-07-17	REVISED FOR PERMITS
86	02-07-17	REVISED FOR PERMITS
87	02-07-17	REVISED FOR PERMITS
88	02-07-17	REVISED FOR PERMITS
89	02-07-17	REVISED FOR PERMITS
90	02-07-17	REVISED FOR PERMITS
91	02-07-17	REVISED FOR PERMITS
92	02-07-17	REVISED FOR PERMITS
93	02-07-17	REVISED FOR PERMITS
94	02-07-17	REVISED FOR PERMITS
95	02-07-17	REVISED FOR PERMITS
96	02-07-17	REVISED FOR PERMITS
97	02-07-17	REVISED FOR PERMITS
98	02-07-17	REVISED FOR PERMITS
99	02-07-17	REVISED FOR PERMITS
100	02-07-17	REVISED FOR PERMITS

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

FT305A



1" NITROGEN SUPPLY LINE AND 3" FOAM SUPPLY RUN DOWN SHAFT IN OPPOSITE DIAGONAL CORNER PIPE USING SIMILAR METHODS

HANGER DETAIL #32 - UNISTRUT
N.T.S.
USE FOR VERTICAL PIPING IN SHAFT

10-16-17	10-16-17		
10-16-17	10-16-17		
10-16-17	10-16-17		
10-16-17	10-16-17		
10-16-17	10-16-17		
10-16-17	10-16-17		
10-16-17	10-16-17		
I CERTIFY THAT THE DRAWING HAS BEEN PREPARED BY ME OR UNDER MY DIRECT SUPERVISION.			
CPI COMMERCIAL INSULATION CO., INC. 304 PARKWAY STREET HENNELLS, FRISCO, TEXAS TEL: (972) 251-8800 FAX: (972) 251-2806 WWW.CPI-INSULATION.COM		DATE: _____ TIME: _____ PROJECT: _____ REVISIONS: NO. _____ DATE _____ BY _____ APPROVED BY: _____ DESIGNED BY: _____ CHECKED BY: _____	
MEMBER OF THE AIA MEMBER OF THE ASHRAE MEMBER OF THE ASHRAE HAWAII MEMBER OF THE ASHRAE HONOLULU MEMBER OF THE ASHRAE WEST COAST		NAVAFAC HAWAII JOINT BASE PEARL HARBOR HONOLULU (RED HILL) OAHU, HAWAII FY16 P-181 (DESC 1851), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY NEW FIRE PROTECTION SECTIONS ELEVATOR 73 LOWER LEVEL	
SHEET NO. 1305143 CONTRACT NO. FT305B DRAWING NO. FT305B		FT305B PROJECT NO. 1305143	

(b) (3) (A) MIDDLE LEVELS
SCALE: 3/16" = 1'-0"


(b) (3) (A) - PIPING
SCALE: 3/16" = 1'-0"

(b) (3) (A) LEVEL
SCALE: 1/4" = 1'-0"

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.
IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

RISER LEGEND


1. 2½" GRV VIKING EASY RISER WITH GAUGE, FLOW SWITCH, AND 1¼" TEST/DRAIN WITH ½" ORIFICE AND 175 PSI PRESSURE RELIEF
2. 2½" FLANGED OS&Y WITH TAMPER SWITCH
3. 1" AUX DRAIN W/ SIGN
4. PIPE STAND




1 LOWER LEVEL - "GAUGER" RISER
 FT305 SCALE: 1/2" = 1' 0"

RISER LEGEND

1. 4" SUPPLY PIPING FROM 8" FIRE PROTECTION MAIN
2. RISER CLAMP OR UNISTRUT THE 4" DROP TO WALL
3. 2½" BRONZE ANGLE PATTERN HOSE VALVE WITH ADJUSTABLE PRESSURE RESTRICTION
4. 4" GRV BUTTERFLY VALVE W/TAMPER




1 FIRE HOSE VALVE STATIONS
 FT305 SCALE: 1/2" = 1' 0"



HANGER DETAIL #32 - UNISTRUT
 N.T.S.
 USE FOR VERTICAL PIPING IN SHAFT

MATCHLINE

MATCHLINE




(b) (3) (A) LOWER LEVEL
 SCALE: 3/16" = 1' 0"

(b) (3) (A) PIPING
 SCALE: 3/16" = 1' 0"

AS BUILT


10-18-17					
10-23-17					
8-22-17					
8-11-17					
7-27-17					
8-2-17					
DATE	BY	CHECKED	APP. NO.	REVISION	
NAVFAC					
I CERTIFY THAT THE DRAWING WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION. CPI CONTRACTOR IN CHARGE 2007 KOLUMBIAN AVENUE, SUITE 200 HONOLULU, HAWAII 96813 TEL: (808) 553-0000 FAX: (808) 553-0200					
DATE	BY	CHECKED	APP. NO.	REVISION	
ENGINEER OF THE WORK NAVFAC HAWAII PERM. ENGINEER 0441, HAWAII 1715 P-151 (DESC 151), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY NEW FIRE PROTECTION SECTIONS ELEVATOR 73 LOWER LEVEL					
SHEET NO.	1305143				
TITLE					
FT305C					



PREACTION RISERS SYSTEMS 1 AND 2

RISER LEGEND


- 6" FLANGED OS&Y WITH TAMPER SWITCH
- 6" ANSUL FLOWMAX PPNW PROPORIONER W/HYDRAULIC CONCENTRATE CONTROL VALVE
- 6" VIKING DELUGE VALVE SET UP AS SINGLE INTERLOCK PREACTION VALVE WITH ELECTRIC RELEASE
- 6" GRV BUTTERFLY VALVE W/TAMPER
- 1" AUX DRAIN W/ SIGN
- PIPE CLAMP RODDED INTO FLOOR (USE 3/4")
- 6" GRV CHECK VALVE



PREACTION RISER SYSTEM 3

RISER LEGEND

- 8" FLANGED OS&Y WITH TAMPER SWITCH
- 8" ANSUL FLOWMAX PPNW PROPORIONER W/HYDRAULIC CONCENTRATE CONTROL VALVE
- 6" VIKING DELUGE VALVE SET UP AS SINGLE INTERLOCK PREACTION VALVE WITH ELECTRIC RELEASE
- 6" GRV BUTTERFLY VALVE W/TAMPER
- 1" AUX DRAIN W/ SIGN
- PIPE CLAMP RODDED INTO FLOOR
- 6" GRV CHECK VALVE




PREACTION RISERS SYSTEMS 4 AND 5

RISER LEGEND


- 8" FLANGED OS&Y WITH TAMPER SWITCH
- 8" ANSUL FLOWMAX PPNW PROPORIONER W/HYDRAULIC CONCENTRATE CONTROL VALVE
- 8" VIKING DELUGE VALVE SET UP AS SINGLE INTERLOCK PREACTION VALVE WITH ELECTRIC RELEASE
- 8" GRV BUTTERFLY VALVE W/TAMPER
- 1" AUX DRAIN W/ SIGN
- PIPE CLAMP RODDED INTO FLOOR
- 6" GRV CHECK VALVE

LOWER LEVEL - "GAUGER" RISER
SCALE: 1/2" = 1' 0"



RISER LEGEND

- 2 1/2" GRV VIKING EASY RISER WITH GAUGE, FLOW SWITCH, AND 1 1/4" TEST DRAIN WITH 3/8" ORIFICE AND 175 PSI PRESSURE RELIEF
- 2 1/2" FLANGED OS&Y WITH TAMPER SWITCH
- 1" AUX DRAIN W/ SIGN
- PIPE STAND



RISER LEGEND

- 4" SUPPLY PIPING FROM 8" FIRE PROTECTION MAIN
- RISER CLAMP OR UNISTRUT TIE 4" DROP TO WALL
- 2 1/2" BRONZE ANGLE PATTERN HOSE VALVE WITH ADJUSTABLE PRESSURE RESTRICTION
- 4" GRV BUTTERFLY VALVE W/TAMPER

FIRE HOSE VALVE STATIONS
SCALE: 1/2" = 1' 0"

AS BUILT

10-16-17	10-17-17	10-18-17	10-19-17	10-20-17	10-21-17	10-22-17	10-23-17	10-24-17	10-25-17
10-26-17	10-27-17	10-28-17	10-29-17	10-30-17	10-31-17	10-32-17	10-33-17	10-34-17	10-35-17
10-36-17	10-37-17	10-38-17	10-39-17	10-40-17	10-41-17	10-42-17	10-43-17	10-44-17	10-45-17

1. I CERTIFY THAT THE DRAWING WAS PREPARED BY ME OR UNDER MY CLOSEST SUPERVISION.

CPI

COMMERCIAL PROJECT, INC.
364 PARKWAY STREET
HONOLULU, HAWAII 96808

TEL: (808) 852-8800
FAX: (808) 852-8801

DATE: 10/16/17

PROJECT: [REDACTED]

THE DRAWING DATE: [REDACTED]

DESIGN: [REDACTED]

APPROVED BY: [REDACTED]

SCALE: [REDACTED]

PROJECT LOCATION: [REDACTED]

DRAWING NUMBER: [REDACTED]

REVISED BY: [REDACTED]

DATE: [REDACTED]

SCALE: [REDACTED]

PROJECT: [REDACTED]

CONTRACT NO.: 1305143

CONTRACTOR: [REDACTED]

DATE: [REDACTED]

SCALE: [REDACTED]

PROJECT: [REDACTED]

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


1 2 3 4 5

D



C

B

A



NEED TO REMOVE WEEDS AROUND FGD 100-020R TO 021B



(b) (3) (A)

P.R.V. & F.D.C. STATION LEGEND

1. 8" ZURN 209FP (GRV-HP RV OPTION) PRESSURE REDUCING VALVE WITH GAUGE ON INLET SIDE AND GAUGE/ MONITORING PRESSURE SWITCH ON OUTLET SIDE. (WIRING BY OTHERS)
2. 8" GRV TYCO CY-1F GRV CHECK VALVE WITH WATTS FPS3L 175 PSI PRESSURE RELIEF INSTALLED ON SYSTEM SIDE
3. 8" NIBCO GD-4865-8N (300 PSI) GRV BUTTERFLY VALVE W/TAMPER
4. 8" NIBCO GD-4865-C-8N (300 PSI) GRV BUTTERFLY VALVE W/TAMPER (NORM CLOSED)
5. 2 1/2" ROUGH BRASS ANGLE PATTERN HOSE VALVES W/RED PLASTIC CAPS (6 RED'D)
6. PIPE STAND WITH FULL PIPE CLAMP BOLTED TO CONC. PAD (BY OTHERS) AND RODDED (2x) THROUGH EARS TO ADDITIONAL CLAMP FOR 8" PIPE ABOVE
7. 2 1/2" INLET x 3" OUTLET FPPI UL LISTED F.D.C. CHECK SMOOT (6 RED'D) W/RED PLASTIC PLUGS
8. 3" CLA-VAL 90G-21 PRESSURE REDUCING VALVE WITH GAUGE ON INLET SIDE AND GAUGE/ MONITORING PRESSURE SWITCH ON OUTLET SIDE. (WIRING BY OTHERS)
9. 3" NIBCO GD-4865-4N (300 PSI) GRV BUTTERFLY VALVE W/OUT TAMPER (2 RED'D)


- NOTES:
- PIPING IS GALVANIZED SCHEDULE 40
 - FITTINGS ARE FACTORY PAINTED (ORANGE)
 - GROOVED FITTINGS ARE STANDARD RADIUS
 - ALL UNDERGROUND AND MONUMENT BY OTHERS
 - WIRING OF FLOW AND TAMPER SWITCHES BY OTHERS
 - SEE ADIT ENTRY DRAWINGS FOR LOCATION

(b) (3) (A) - REFERENCE PLAN

SCALE 1/8" = 1'-0"

AS BUILT

10-18-17	REV
10-2-17	REV
8-28-17	REV
8-11-17	REV
7-28-17	REV
5-2-17	REV



I CERTIFY THAT THIS DRAWING WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION.



CREATED BY: JACOB, JACOB, INC.
 904 KAWAHAU STREET
 HONOLULU, HAWAII 96819

TEL: (808) 953-0908
 FAX: (808) 953-0205

DATE: 10/18/17

PROJECT: FT401

FOR SUBMITTED WORK: FT401

REVISIONS BY: NTC

REV	DATE	BY

DESIGNATION OF THE WORK: NAVAFIC HAWAII

PROJECT: FT401

PROJECT LOCATION: FT401, HAWAII

PROJECT DESCRIPTION: JOINT BASE PEARL HARBOR HIGHWAY (RED HILL) FT16 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

PARTIAL FIRE PROTECTION NEW PLAN - ENTRY TO ADIT 3

SCALE: AS SHOWN

PROJECT NO.: 1326143

DATE: 10/18/17

PROJECT NO.: FT401

1 2 3 4 5

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE NECESSARY TIES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D

C

B

A

10-16-17	AS BUILT	REV
10-2-17		
8-28-17		
8-11-17		
8-1-17		
8-8-18		
8-8-18		
8-8-18		
8-8-18		
8-8-18		
8-8-18		



UNIVERSITY PROJECT, INC.
2850 KAWAHAU STREET
HONOLULU, HAWAII 96819



TEL: (808) 955-0500
FAX: (808) 955-0505

OWNER: []
DESIGNER: []
CONTRACT NO.: 1326143


NAVFAC DRAWING NO. []

FT402

ISSUED: 10 JULY 2015



PHOTOS 100-0092 - 100-0107





(b) (3) (A)

P.R.V. & F.D.C. STATION LEGEND





- 8" ZURN 209FP (GRV-HP RV OPTION) PRESSURE REDUCING VALVE WITH GAUGE ON INLET SIDE AND GAUGE/ MONITORING PRESSURE SWITCH ON OUTLET SIDE. (WIRING BY OTHERS)
- PRESSURE REDUCING VALVE WITH GAUGES
- 8" GRV TYCO CV-1F GRV CHECK VALVE WITH WAITS FPS3L 175 PSI PRESSURE RELIEF INSTALLED ON SYSTEM SIDE
- 8" NIBCO GD-4865-BN (300 PSI) GRV BUTTERFLY VALVE W/TAMPER
- 8" NIBCO GD-4865-C-BN (300 PSI) GRV BUTTERFLY VALVE W/TAMPER (NORM CLOSED)
- 2 1/2" ROUGH BRASS ANGLE PATTERN HOSE VALVES W/RED PLASTIC CAPS (6 REQ'D)
- PIPE STAND WITH FULL PIPE CLAMP BOLTED TO CONC. PAD (BY OTHERS) AND RODDED (2x) THROUGH EARS TO ADDITIONAL CLAMP FOR 8" PIPE ABOVE
- 2 1/2" INLET x 3" OUTLET FPPI UL LISTED F.D.C. CHECK SNOOT (6 REQ'D) W/RED PLASTIC PLUGS
- 3" CLA-WAL 90C-21 PRESSURE REDUCING VALVE WITH GAUGE ON INLET SIDE AND GAUGE/ MONITORING PRESSURE SWITCH ON OUTLET SIDE. (WIRING BY OTHERS)
- 3" NIBCO GD-4865-4N (300 PSI) GRV BUTTERFLY VALVE W/OUT TAMPER (2 REQ'D)

- NOTES:
- PIPING IS GALVANIZED SCHEDULE 40
 - FITTINGS ARE FACTORY PAINTED (ORANGE)
 - GROOVED FITTINGS ARE STANDARD RADIUS
 - ALL UNDERGROUND AND MONUMENT BY OTHERS
 - WIRING OF FLOW AND TAMPER SWITCHES BY OTHERS
 - SEE ADIT ENTRY DRAWINGS FOR LOCATION





THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

AS BUILT



- ### ADIT #6 P.R.V. & F.D.C. STATION LEGEND
- 8" CIA-VAL 90-21 GRV PRESSURE REDUCING VALVE WITH GAUGE ON INLET SIDE AND GAUGE/MONITORING PRESSURE SWITCH ON OUTLET SIDE. (WIRING BY OTHERS)
 - 8" GRV TYPED CP-1F GRV CHECK VALVE WITH MATES PFDOL 175 PS PRESSURE RELIEF INSTALLED ON SYSTEM SIDE
 - 8" INRICO CD-4785-IN (300 PSI) GRV BUTTERFLY VALVE W/OUT TAMPER (4 REV'0)
 - 8" INRICO CD-4785-IN (300 PSI) GRV BUTTERFLY VALVE W/OUT TAMPER (NORM CLOSED)
 - 2 1/2" ROUGH BRASS ANGLE PATTERN HOSE VALVES W/RED PLASTIC CAPS (6 REV'0) TO BE INSTALLED WITH OUTLETS FACING FORWARD
 - PIPE STAND WITH FULL PIPE CLAMP BOLTED TO CONC. PAD (PAD PROVIDED BY OTHERS) AND RODDED (24) THROUGH ENDS TO ADDITIONAL CLAMP FOR 8" PIPE ABOVE
 - 2 1/2" INLET x 3" OUTLET FPP1 UL LISTED F.D.C. CHECK SMOOT (12 REV'0) W/RED PLASTIC FLUGS
 - PIPE STAND WITH FULL PIPE CLAMP BOLTED TO CONC. PAD (PAD PROVIDED BY OTHERS)
 - 8" SHARPOINT 726 GROOVED STRAINER
- NOTES:
- PIPING IS GALVANIZED SCHEDULE 40
 - FITTINGS ARE FACTORY PAINTED (ORANGE)
 - GROOVED FITTINGS ARE STANDARD RADIIUS
 - ALL UNDERGROUND AND MONUMENT BY OTHERS
 - WIRING OF FLOW AND TAMPER SWITCHES BY OTHERS
 - SEE ADIT ENTRY DRAWINGS FOR LOCATION
 - EACH F.D.C. TO BE LABELED TO SPECIFICALLY IDENTIFY THE LEVEL OF THE TUNNEL THAT IS BEING SUPPLIED



AS BUILT

10-16-17	10-2-17	8-20-17	8-11-17	7-28-17	3-2-17	REV
BY REV	BY REV	BY REV	BY REV	BY REV	BY REV	BY REV
1	2	3	4	5	6	7
10-16-17	10-2-17	8-20-17	8-11-17	7-28-17	3-2-17	REV
BY REV	BY REV	BY REV	BY REV	BY REV	BY REV	BY REV
1	2	3	4	5	6	7
10-16-17	10-2-17	8-20-17	8-11-17	7-28-17	3-2-17	REV
BY REV	BY REV	BY REV	BY REV	BY REV	BY REV	BY REV
1	2	3	4	5	6	7
10-16-17	10-2-17	8-20-17	8-11-17	7-28-17	3-2-17	REV
BY REV	BY REV	BY REV	BY REV	BY REV	BY REV	BY REV
1	2	3	4	5	6	7

NAVAFAC HAWAII

JOINT BASE PEARL HARBOR HICOM (RED HILL)
F116 P-1581 (DCSB-1581), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
FIRE PROTECTION SYSTEM PLAN -
FIRE PUMP HOUSE TO ADIT 6

REVISED BY: MKC
DATE: 10/16/17
DESIGNED BY: MKC
DATE: 10/16/17
CHECKED BY: MKC
DATE: 10/16/17
DRAWN BY: MKC
DATE: 10/16/17

PROJECT NO. 1326143
CONTRACT NO. 1326143
DRAWING NO. FT404

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORKING TIMES AS NECESSARY TO AVOID CONFLICTS AND TO COMPLETE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" x 34" REDUCED PRINT - USE GRAPHIC SCALES



**APPENDIX B. SITE SURVEY NOTES PREACTION FOAM/WATER
SPRINKLER SYSTEM**



FIRE PROTECTION GENERAL NOTES

- INSTALLATION SHALL CONFORM TO NFPA 13 2013.
- ALL MATERIALS INSTALLED SHALL BE NEW, UL LISTED AND/ OR F.M. APPROVED FOR FIRE PROTECTION USE.
- SWAY BRACING TO BE PER NFPA 13, 2013 EDITION.
 - LATERAL BRACING MAY BE OMITTED FROM PIPES INDIVIDUALLY SUPPORTED BY ROOFS LESS THEN 6' LONG.
 - THE DISTANCE BETWEEN THE LAST BRACE AND THE END OF THE PIPE SHALL NOT EXCEED 6'-0" ON A FEED OR CROSS MAIN SHALL BE PROVIDED WITH A LATERAL BRACE.
 - LATERAL BRACES MAY ACT AS LONGITUDINAL BRACES ONLY WHEN INSTALLED WITHIN 2'-0" OF THE PIPE BEING BRACED.
- LONGITUDINAL
 - THE FOUR WAY BRACE SHALL BE ATTACHED ABOVE THE FLEXIBLE CONNECTION REQUIRED FOR THE RISER, AND TO THE WALL STRUCTURE.
 - THE END SPRINKLER ON A BRANCH LINE SHALL BE RESTRAINED AGAINST EXCESSIVE MOVEMENT BY USE OF A WRAP AROUND U-HOOK OR OTHER APPROVED MEANS.
 - ALL BRACES ARE CALCULATED. SEE CALCULATION AND DETAIL SHEET FP-4.
- THE SYSTEM IS OVER 100 PSI AND MUST HAVE THE LAST HANGER ON THE END OF BRANCHLINES SUPPLYING PENDENT SPRINKLERS AT DROPPED CEILING INSTALLED WITHIN 12" OF THE END OF THE LINE PER 9.2.3.4.4.
- ALL SPRINKLER SYSTEM CONTROL VALVES SHALL BE PROVIDED WITH TAMPER SWITCHES. ALL SYSTEMS SHALL BE EQUIPPED WITH A FLOW SWITCH. ALL TAMPERS AND FLOW SWITCHES SHALL BE MONITORED BY AN OFF-SITE PROPRIETARY STATION, U.L. LISTED AND/ OR F.M. APPROVED AND INSTALLED BY OTHERS.
- ALL GROOVED COUPLINGS INSTALLED SHALL BE RIGID TYPE. (U.N.O.)
- THE USE OF GROOVED FITTINGS WILL BE LIMITED TO PIPES HAVING A NOMINAL DIAMETERS OF 1 1/2 INCHES OR LARGER.
- COUPLINGS AND FITTINGS MAY BE CAST IRON, MALLEABLE IRON OR DUCTILE IRON.
- GENERAL CONTRACTOR SHALL MAKE PIPING ABOVE SUSPENDED CEILING ACCESSIBLE FOR VISUAL INSPECTION AS A CONDITION OF FINAL APPROVAL.
- ALL NEW ABOVEGROUND PIPING WILL BE BLK SCH 40 EXCEPT FOR FOAM CONCENTRATE PIPING THAT SHALL BE STAINLESS STEEL AND PVC DRAIN LINES.
- ALL NEW SYSTEMS SHALL BE HYDROSTATICALLY TESTED AT 200 PSI OR 50 PSI IN EXCESS OF THE MAXIMUM PRESSURE, WHEN THE MAXIMUM PRESSURE TO BE MAINTAINED IN EXCESS OF 150 PSI.
- FLEXIBLE COUPLINGS TO BE INSTALLED WITHIN 12" OF EITHER SIDE OF MASONRY OR CONCRETE WALLS. FLEXIBLE COUPLINGS TO BE INSTALLED WITHIN 12" ABOVE AND WITHIN 24" BELOW FLOORS, A FLEXIBLE COUPLING TO BE INSTALLED ON RISERS MORE THAN 3' & LESS THAN 7". IN RISERS MORE THAN 7", FLEXIBLE COUPLINGS TO BE INSTALLED WITHIN 24" OF THE TOP AND BOTTOM OF THE RISER.
- SPRINKLER HEADS IN CEILING TILES ARE NOT REQUIRED TO BE CENTER OF TILE.
- ALL PIPING PENETRATIONS IN FIRE RATED WALLS/FLOORS OTHER THAN MASONRY/CONCRETE SHALL BE SIZED AS FOLLOWS:
 - NOMINALLY 2" LARGER THAN PIPE FOR 1" TO 3" NOMINAL PIPE DIAMETERS.
 - FOR PIPING 4" AND LARGER, THE HOLE DIAMETER IS TO BE 4" LARGER THAN NOMINAL PIPE DIAMETER.
- NO CLEARANCE IS REQUIRED FOR NON-FIRE RATED WALLS/FLOORS OTHER THAN MASONRY/CONCRETE.
- ALL PREACTION SYSTEM MAIN PIPING TO BE SLOPED AS THE NATURAL SLOPE OF THE TUNNELS ALLOW. LINE PIPING TO BE SLOPED PER NFPA-13.

FIRE PROTECTION DESIGN CRITERIA

THE FIRE PROTECTION SYSTEM SHALL BE HYDRAULICALLY DESIGNED AND INSTALLED IN ACCORDANCE WITH THE FOLLOWING CRITERIA:

UPPER TUNNEL (TANKS COMPARTMENT)

DESIGN DENSITY: 0.4 GPM/SF [NFPA 13: EXTRA HAZARD GROUP 2]
 DESIGN AREA: 2,500 SF (UPPER TUNNEL UP TO ADIT 5 DOOR AND ADIT 4 DOOR.)
 HOSE STREAM: 500 GPM DURATION: 90 MINUTES

THE ZONES TO BE COVERED ARE SHOWN ON THE LAYOUTS.

UPPER TUNNEL STANDPIPE

FLOW DEMAND: 1000 GPM
 PRESSURE: MIN 100 PSI AT NOZZLE
 DURATION: 90 MINUTES

LOWER TUNNEL (TANKS COMPARTMENTS)

DESIGN DENSITY: 0.16 GPM/SF [NFPA 16, SINGLE INTERLOCK ELECTRIC RELEASE PRE-ACTION SYSTEM, 3% AFFF MIL-F 24385 PREACTION AFFF SYSTEMS ARE ACTUATED BY CROSSE-ZONE TRIPLE IR DETECTION]
 DESIGN AREA: COMPARTMENT AREA (APPROXIMATELY 10,000 SF)
 HOSE STREAM: 1000 GPM

DURATION: 15 MINUTES OF FOAM (NFPA 30)/ 60 MINUTES OF WATER
 THE ZONES TO BE COVERED ARE SHOWN ON THE LAYOUTS.

TESTING TO BE DONE AT THE PROPORTIONER'S MINIMUM FLOW RATE AND AT A FLOW RATE OF 4 TIMES THE MINIMUM PER SPECIFICATION. PERFORM THIS IN ACCORDANCE W/NFPA 16.

LOWER TUNNEL (GAUGER OFFICE AND ELECTRICAL ROOM)

DESIGN DENSITY: 0.2 GPM/SF [NFPA 13: ORDINARY HAZARD GROUP 2]
 DESIGN AREA: 1,500 SF
 HOSE STREAM: 250 GPM
 DURATION: 60 MINUTES

THE ZONE TO BE COVERED IS SHOWN ON THE LAYOUT

LOWER TUNNEL STANDPIPE



FLOW DEMAND: 1000 GPM
 PRESSURE: MIN 100 PSI AT VALVE
 DURATION: 60 MINUTES

FIRE PUMP BUILDING (ELECTRICAL ROOM, FIRE PUMP ROOM, AND AFFF PUMP ROOM, GENERATOR ROOM)


DESIGN DENSITY: 0.2 GPM/SF [NFPA 13: ORDINARY HAZARD GROUP 2]
 DESIGN AREA: 1,500 SF
 HOSE STREAM: 250 GPM
 DURATION: 60 MINUTES

CONTRACT DEVIATIONS & COORDINATION


- THE CONTRACT DOCUMENTS SHOW 2 JOCKEY PUMPS. NFPA REQUIRES ONLY ONE. TOTAL FIRE SYSTEMS, INC. WILL SUPPLY AND PROVIDE THE SECOND JOCKEY PUMP / CONTROLLER AS A SPARE AND NOT INSTALL IT AS SHOWN. THEY WILL BE LEFT IN THE LOCATION AS DIRECTED.
- WE HAVE DELETED THE INDIVIDUAL PRV'S FOR THE RHV'S AND SPRINKLER RISER'S AND INSTALLING A MASTER PRV WITH BACKUP FOR BOTH THE LOWER AND UPPER TUNNEL. NFPA REQUIRES TESTING OF THESE DEVICES BOTH AT THE PROJECT COMPLETION AND ANNUALLY. THERE ARE NO PROVISIONS FOR THEIR TESTING SHOWN AND OR CALLED FOR. THE DESIGN USING MASTER PRV'S WILL REDUCE THE FUTURE MAINTENANCE AND WILL IMPROVE THE SYSTEM OVERALL.
- DELETION OF THE FDC AND ITS PIPING AS SHOWN FOR THE AFFF FOAM SYSTEMS. NFPA PROHIBITS THE FDC TO BE SUPPLIED ABOVE THE SHUT OFF ON MULTIPLE RISER SYSTEMS AS SHOWN. FURTHER THE FDC'S SUPPLYING THE 8" SUPPLY HAVE AN FDC SHOWN AT ADIT'S 3, 4, 5, & 6 AS REQUIRED BY NFPA BELOW THE CONTROL VALVE.
- REDESIGN OF THE FIRE PUMP ROOM DUE TO THE PIPING BEING RUN OVERHEAD HAS RESULTED IN CHANGES TO THE FLOOR DRAIN, ALLOWABLE LIGHT FIXTURE LOCATIONS, POWER HOOKUP LOCATIONS, AND WATER SERVICE ENTRY LOCATION AND CONFIGURATION. OTHER TRADES WILL NEED TO MODIFY THEIR SCOPE OF WORK TO ACCOMMODATE THIS RECONFIGURATION.
- EXTERIOR BACKFLOW PREVENTORS (IN SITE CONTRACTOR'S SCOPE) HAVE BEEN ELIMINATED AND ARE NOT INCLUDED IN OUR HYDRAULIC CALCULATIONS ON THE DISCHARGE SIDE OF THE PUMP. ONE BACKFLOW IN THE LINE FROM THE TANK TO THE FIRE PUMP HAS BEEN ACCOUNTED FOR BY REDUCING THE AVAILABLE WATER FROM THE CALCULATED WATER FLOW TEST BY 12 PSI REFLECTED IN THE SUBSEQUENT CALCULATIONS FOR UPPER AND LOWER TUNNELS.




HANGER DETAIL - TOP BEAM CLAMP
 N.T.S.
 USE ONLY WHERE HANGING TO EXISTING I-BEAM STRUCTURE WITHIN TUNNEL.




HANGER DETAIL - UP TO 4\"/>




HANGER DETAIL - UP TO 6\"/>



HANGER DETAIL #52 - SIDE SAMMY
 N.T.S.
 TYP. FOR BRANCHLINES UNDER RAIN CATCH CEILING AREAS




HANGER DETAIL #51 - BOTTOM SAMMY
 N.T.S.
 ALTERNATE FOR BRANCHLINES UNDER RAIN CATCH CEILING AREAS



PIPE STAND DETAIL
 N.T.S.

AS BUILT

10-10-17	10-10-17	8-20-17	8-11-17	7-28-17	5-2-17	N.T.S.
6	5	4	3	2	1	REVISIONS
1	2	3	4	5	6	DESCRIPTION
CREDITFIELD PROJECT, INC. 844 KAWAHAU STREET HONOLULU, HAWAII 96819						
TEL: (808) 953-0300 FAX: (808) 953-2300						
PROJECT NO.: 1501						
SHEET NO.: 1501-01						
DRAWN BY: MJC PLS/PL TITLE: PROTECTION CHECKED BY: MJC DATE: 10/10/17						
CONTRACTOR: NAVFAC HAWAII PROJECT: OAHU, HIWHL TITLE: UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY FIRE PROTECTION GENERAL NOTES						
SHEET NO.: 1501-01						
NAVFAC DRAWING NO.:						
F-001						



ALL TYPE 2 N2-BLAST MUST BE WALL MOUNTED. WALL MOUNTING BRACKETS ARE INCLUDED WITH UNIT
1/4" MNPT FILTER DRAIN CONNECTIONS

FILTERS ARE TO BE CHANGED ANNUALLY

1" AIR / NITROGEN SUPPLY TO FPS PIPING

28 GALLON NITROGEN STORAGE TANK PROVIDED WITH WALL BRACKETS AND STRAP

110V / 60Hz / 1PHASE NITROGEN GENERATOR HAS A 1/2" CONDUIT KNOCKOUT UNDERNEATH CABINET'S PANEL FOR POWER SUPPLY TO ELECTRICAL PANEL. REFER TO DRAWING ES-TYP2M FOR PROPER CONNECTIONS

5HP AIR COMP. WITH MIN 80 GAL REC. TANK
1/4" NPT TANK DRAIN

REFRIGERATED AIR DRYER
3/8" OD DRAIN LINE

PRE-ACTION SYSTEM CAPACITIES:

ZONE 1:	614 GALLONS
ZONE 2:	573 GALLONS
ZONE 3:	629 GALLONS
ZONE 4:	646 GALLONS
ZONE 5:	649 GALLONS
1" SUPPLY LINE:	112.5 GALLONS
TOTAL CAPACITY:	3,223.5 GALLONS

MODEL PROVIDED: FPS-6000
(6,000 GALLON CAPACITY)

FIRE PUMP ROOM - NITROGEN INJECTION SYSTEM SCHEMATIC

AS BUILT

NO.	DATE	DESCRIPTION
1	10-24-17	AS BUILT
2	10-24-17	FINAL CHECKED FOR DESIGN ERRORS
3	10-24-17	REV - ISSUED FOR FINAL CHECK
4	10-24-17	REV - ISSUED FOR FINAL CHECK
5	10-24-17	REV - ISSUED FOR FINAL CHECK
6	10-24-17	REV - ISSUED FOR FINAL CHECK
7	10-24-17	REV - ISSUED FOR FINAL CHECK
8	10-24-17	REV - ISSUED FOR FINAL CHECK
9	10-24-17	REV - ISSUED FOR FINAL CHECK
10	10-24-17	REV - ISSUED FOR FINAL CHECK
11	10-24-17	REV - ISSUED FOR FINAL CHECK
12	10-24-17	REV - ISSUED FOR FINAL CHECK
13	10-24-17	REV - ISSUED FOR FINAL CHECK
14	10-24-17	REV - ISSUED FOR FINAL CHECK
15	10-24-17	REV - ISSUED FOR FINAL CHECK
16	10-24-17	REV - ISSUED FOR FINAL CHECK
17	10-24-17	REV - ISSUED FOR FINAL CHECK
18	10-24-17	REV - ISSUED FOR FINAL CHECK
19	10-24-17	REV - ISSUED FOR FINAL CHECK
20	10-24-17	REV - ISSUED FOR FINAL CHECK
21	10-24-17	REV - ISSUED FOR FINAL CHECK
22	10-24-17	REV - ISSUED FOR FINAL CHECK
23	10-24-17	REV - ISSUED FOR FINAL CHECK
24	10-24-17	REV - ISSUED FOR FINAL CHECK
25	10-24-17	REV - ISSUED FOR FINAL CHECK
26	10-24-17	REV - ISSUED FOR FINAL CHECK
27	10-24-17	REV - ISSUED FOR FINAL CHECK
28	10-24-17	REV - ISSUED FOR FINAL CHECK
29	10-24-17	REV - ISSUED FOR FINAL CHECK
30	10-24-17	REV - ISSUED FOR FINAL CHECK
31	10-24-17	REV - ISSUED FOR FINAL CHECK
32	10-24-17	REV - ISSUED FOR FINAL CHECK
33	10-24-17	REV - ISSUED FOR FINAL CHECK
34	10-24-17	REV - ISSUED FOR FINAL CHECK
35	10-24-17	REV - ISSUED FOR FINAL CHECK
36	10-24-17	REV - ISSUED FOR FINAL CHECK
37	10-24-17	REV - ISSUED FOR FINAL CHECK
38	10-24-17	REV - ISSUED FOR FINAL CHECK
39	10-24-17	REV - ISSUED FOR FINAL CHECK
40	10-24-17	REV - ISSUED FOR FINAL CHECK
41	10-24-17	REV - ISSUED FOR FINAL CHECK
42	10-24-17	REV - ISSUED FOR FINAL CHECK
43	10-24-17	REV - ISSUED FOR FINAL CHECK
44	10-24-17	REV - ISSUED FOR FINAL CHECK
45	10-24-17	REV - ISSUED FOR FINAL CHECK
46	10-24-17	REV - ISSUED FOR FINAL CHECK
47	10-24-17	REV - ISSUED FOR FINAL CHECK
48	10-24-17	REV - ISSUED FOR FINAL CHECK
49	10-24-17	REV - ISSUED FOR FINAL CHECK
50	10-24-17	REV - ISSUED FOR FINAL CHECK
51	10-24-17	REV - ISSUED FOR FINAL CHECK
52	10-24-17	REV - ISSUED FOR FINAL CHECK
53	10-24-17	REV - ISSUED FOR FINAL CHECK
54	10-24-17	REV - ISSUED FOR FINAL CHECK
55	10-24-17	REV - ISSUED FOR FINAL CHECK
56	10-24-17	REV - ISSUED FOR FINAL CHECK
57	10-24-17	REV - ISSUED FOR FINAL CHECK
58	10-24-17	REV - ISSUED FOR FINAL CHECK
59	10-24-17	REV - ISSUED FOR FINAL CHECK
60	10-24-17	REV - ISSUED FOR FINAL CHECK
61	10-24-17	REV - ISSUED FOR FINAL CHECK
62	10-24-17	REV - ISSUED FOR FINAL CHECK
63	10-24-17	REV - ISSUED FOR FINAL CHECK
64	10-24-17	REV - ISSUED FOR FINAL CHECK
65	10-24-17	REV - ISSUED FOR FINAL CHECK
66	10-24-17	REV - ISSUED FOR FINAL CHECK
67	10-24-17	REV - ISSUED FOR FINAL CHECK
68	10-24-17	REV - ISSUED FOR FINAL CHECK
69	10-24-17	REV - ISSUED FOR FINAL CHECK
70	10-24-17	REV - ISSUED FOR FINAL CHECK
71	10-24-17	REV - ISSUED FOR FINAL CHECK
72	10-24-17	REV - ISSUED FOR FINAL CHECK
73	10-24-17	REV - ISSUED FOR FINAL CHECK
74	10-24-17	REV - ISSUED FOR FINAL CHECK
75	10-24-17	REV - ISSUED FOR FINAL CHECK
76	10-24-17	REV - ISSUED FOR FINAL CHECK
77	10-24-17	REV - ISSUED FOR FINAL CHECK
78	10-24-17	REV - ISSUED FOR FINAL CHECK
79	10-24-17	REV - ISSUED FOR FINAL CHECK
80	10-24-17	REV - ISSUED FOR FINAL CHECK
81	10-24-17	REV - ISSUED FOR FINAL CHECK
82	10-24-17	REV - ISSUED FOR FINAL CHECK
83	10-24-17	REV - ISSUED FOR FINAL CHECK
84	10-24-17	REV - ISSUED FOR FINAL CHECK
85	10-24-17	REV - ISSUED FOR FINAL CHECK
86	10-24-17	REV - ISSUED FOR FINAL CHECK
87	10-24-17	REV - ISSUED FOR FINAL CHECK
88	10-24-17	REV - ISSUED FOR FINAL CHECK
89	10-24-17	REV - ISSUED FOR FINAL CHECK
90	10-24-17	REV - ISSUED FOR FINAL CHECK
91	10-24-17	REV - ISSUED FOR FINAL CHECK
92	10-24-17	REV - ISSUED FOR FINAL CHECK
93	10-24-17	REV - ISSUED FOR FINAL CHECK
94	10-24-17	REV - ISSUED FOR FINAL CHECK
95	10-24-17	REV - ISSUED FOR FINAL CHECK
96	10-24-17	REV - ISSUED FOR FINAL CHECK
97	10-24-17	REV - ISSUED FOR FINAL CHECK
98	10-24-17	REV - ISSUED FOR FINAL CHECK
99	10-24-17	REV - ISSUED FOR FINAL CHECK
100	10-24-17	REV - ISSUED FOR FINAL CHECK


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

FB504

66

6



SEE SHEET FT133 FOR CONTINUATION


SEE SHEET FT133 FOR CONTINUATION



FD100 FT134

PARTIAL FIRE PROTECTION NEW PLAN - AREA 66 - LOWER LEVEL


SCALE 1/8" = 1' 0"



AS BUILT

TYPE	SYMBOL	SIZE	MATERIAL	HEAD	FLARE	THICK	OR AM
STANDARD RESP SPRINGER	(Symbol)	1/2"	S.A.	BRASS	N/A	170"	2
STANDARD RESP SPRINGER	(Symbol)	1/2"	S.A.	BRASS	N/A	284"	126
STANDARD RESP SPRINGER OR SPR G	(Symbol)	1/2"	S.A.	BRASS	N/A	284"	449
STANDARD RESP PENDANT W/PLATE	(Symbol)	1/2"	S.A.	BRASS	JPC CHN	170"	4
STANDARD RESP HORIZONTAL DOWNWALL	(Symbol)	1/2"	S.A.	BRASS	NONE	170"	2

<p style="text-align: center;">NAVIFAC</p> <p style="text-align: center;">CPI</p> <p style="font-size: small;">CPI ENGINEERING, INC. 1834 HANAWALE STREET HONOLULU, HAWAII 96813</p> <p style="font-size: x-small;">TEL: (808) 953-2989 FAX: (808) 953-7800</p> <p style="font-size: x-small;">DES: [] REV: [] DATE: []</p> <p style="font-size: x-small;">FOR ISSUED SHEET: []</p> <p style="font-size: x-small;">APPROVED TO DATE: [] DESIGN: [] CHECK: [] REV: []</p> <p style="font-size: x-small;">PROJECT: [] SHEET NUMBER: []</p> <p style="font-size: x-small;">DRAWN BY: []</p>	<p style="font-size: x-small;">REVISIONS:</p> <table border="1" style="width: 100%;"> <tr><th>NO.</th><th>DATE</th><th>DESCRIPTION</th><th>BY</th></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td></tr> </table> <p style="font-size: x-small;">REVISIONS TO BE MADE BY THE USER AT HIS OWN RISK</p> <p style="font-size: x-small;">NAVIFAC HAWAII LOCAL OFFICE: HONOLULU, HAWAII</p> <p style="font-size: x-small;">JOINT BASE PEARL AND HERMES HICKAM (RED HILL) FY15 P-1551 (DESC: 1551) UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY</p> <p style="font-size: x-small;">PARTIAL FIRE PROTECTION NEW PLAN - AREA 66 - LOWER LEVEL</p> <p style="font-size: x-small;">REVISIONS TO BE MADE BY THE USER AT HIS OWN RISK</p>	NO.	DATE	DESCRIPTION	BY																
NO.	DATE	DESCRIPTION	BY																		




PARTIAL FIRE PROTECTION NEW PLAN - AREA 67 - LOWER LEVEL



FD100 FT134 SCALE 1/8" = 1' 0"

SCALE 1/8" = 1' 0"



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	IN	ORIFICE	ACTOR	FRAG. PRESS.	GLASS	TEMP.	CEILING
STANDARD RESP. UPRIGHT	⊙	1/2	5.4	BRASS	N/A	170°	8	
STANDARD RESP. UPRIGHT	○	1/2	5.4	BRASS	N/A	284°	136	
STANDARD RESP. UPRIGHT ON SPIGOT	⊙	1/2	5.4	BRASS	N/A	284°	449	
STANDARD RESP. ENDWIRE W/ PLATE	⊙	1/2	5.4	BRASS	SFC CHR	170°	8	
STANDARD RESP. HORN SIGNAL SIDEWALL	◁	1/2	5.4	BRASS	NONE	170°	2	

TOTAL SPR. HEADS THIS LEVEL: 417

NO. 1	10-16-17	REV.
NO. 2	10-16-17	REV.
NO. 3	10-16-17	REV.
NO. 4	10-16-17	REV.
NO. 5	10-16-17	REV.
NO. 6	10-16-17	REV.
NO. 7	10-16-17	REV.
NO. 8	10-16-17	REV.
NO. 9	10-16-17	REV.
NO. 10	10-16-17	REV.
NO. 11	10-16-17	REV.
NO. 12	10-16-17	REV.
NO. 13	10-16-17	REV.
NO. 14	10-16-17	REV.
NO. 15	10-16-17	REV.
NO. 16	10-16-17	REV.
NO. 17	10-16-17	REV.
NO. 18	10-16-17	REV.
NO. 19	10-16-17	REV.
NO. 20	10-16-17	REV.
NO. 21	10-16-17	REV.
NO. 22	10-16-17	REV.
NO. 23	10-16-17	REV.
NO. 24	10-16-17	REV.
NO. 25	10-16-17	REV.
NO. 26	10-16-17	REV.
NO. 27	10-16-17	REV.
NO. 28	10-16-17	REV.
NO. 29	10-16-17	REV.
NO. 30	10-16-17	REV.
NO. 31	10-16-17	REV.
NO. 32	10-16-17	REV.
NO. 33	10-16-17	REV.
NO. 34	10-16-17	REV.
NO. 35	10-16-17	REV.
NO. 36	10-16-17	REV.
NO. 37	10-16-17	REV.
NO. 38	10-16-17	REV.
NO. 39	10-16-17	REV.
NO. 40	10-16-17	REV.
NO. 41	10-16-17	REV.
NO. 42	10-16-17	REV.
NO. 43	10-16-17	REV.
NO. 44	10-16-17	REV.
NO. 45	10-16-17	REV.
NO. 46	10-16-17	REV.
NO. 47	10-16-17	REV.
NO. 48	10-16-17	REV.
NO. 49	10-16-17	REV.
NO. 50	10-16-17	REV.
NO. 51	10-16-17	REV.
NO. 52	10-16-17	REV.
NO. 53	10-16-17	REV.
NO. 54	10-16-17	REV.
NO. 55	10-16-17	REV.
NO. 56	10-16-17	REV.
NO. 57	10-16-17	REV.
NO. 58	10-16-17	REV.
NO. 59	10-16-17	REV.
NO. 60	10-16-17	REV.
NO. 61	10-16-17	REV.
NO. 62	10-16-17	REV.
NO. 63	10-16-17	REV.
NO. 64	10-16-17	REV.
NO. 65	10-16-17	REV.
NO. 66	10-16-17	REV.
NO. 67	10-16-17	REV.
NO. 68	10-16-17	REV.
NO. 69	10-16-17	REV.
NO. 70	10-16-17	REV.
NO. 71	10-16-17	REV.
NO. 72	10-16-17	REV.
NO. 73	10-16-17	REV.
NO. 74	10-16-17	REV.
NO. 75	10-16-17	REV.
NO. 76	10-16-17	REV.
NO. 77	10-16-17	REV.
NO. 78	10-16-17	REV.
NO. 79	10-16-17	REV.
NO. 80	10-16-17	REV.
NO. 81	10-16-17	REV.
NO. 82	10-16-17	REV.
NO. 83	10-16-17	REV.
NO. 84	10-16-17	REV.
NO. 85	10-16-17	REV.
NO. 86	10-16-17	REV.
NO. 87	10-16-17	REV.
NO. 88	10-16-17	REV.
NO. 89	10-16-17	REV.
NO. 90	10-16-17	REV.
NO. 91	10-16-17	REV.
NO. 92	10-16-17	REV.
NO. 93	10-16-17	REV.
NO. 94	10-16-17	REV.
NO. 95	10-16-17	REV.
NO. 96	10-16-17	REV.
NO. 97	10-16-17	REV.
NO. 98	10-16-17	REV.
NO. 99	10-16-17	REV.
NO. 100	10-16-17	REV.

FT135

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORK SHALL BE INSTALLED AS NECESSARY TO AVOID CONFLICTS AND TO THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

PROJECT NUMBER: 1326143

DATE: 10/16/17

PROJECT: FT135

CLIENT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135


PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135

PROJECT: FT135



PARTIAL FIRE PROTECTION NEW PLAN - AREA 68 - LOWER LEVEL
 SCALE 1/8" = 1' 0"

KEY PLAN

AS BUILT

SYMBOL	IN	DIMETER	MATERIAL	FRAMING	CLASS	TEMP	QTY
(Symbol)	1/2"	S.A.	BRASS	N/A	178°	8	
(Symbol)	1/2"	S.A.	BRASS	N/A	284°	136	
(Symbol)	1/2"	S.A.	BRASS	N/A	284°	449	
(Symbol)	1/2"	S.A.	BRASS	SPC CHN	178°	8	
(Symbol)	1/2"	S.A.	BRASS	NONE	178°	2	


TOTAL SPR HEADS THIS LEVEL: 417

10-18-17	10-21-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17
10-18-17	10-21-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17
10-18-17	10-21-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17
10-18-17	10-21-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17
10-18-17	10-21-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17
10-18-17	10-21-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17	8-28-17


NAVAFAC HAWAII

JOINT BASE PEARL HARBOR HONOLULU (RED HILL) HAWAII, HAWAII
 FT 15 P-1581 (DESC-1581), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN - AREA 68 - LOWER LEVEL

PROJECT NO. 1326143
 SHEET NO. FT136



PARTIAL FIRE PROTECTION NEW PLAN - AREA 69 - LOWER LEVEL
 SCALE 1/8" = 1'-0"



AS BUILT

SYMBOL	IN	ORIFICE	ACTOR	FRAM	PLATE	TEMP.	REAM
○	1/2	6.4	BRASS	N/A	178°	8	
○	1/2	6.4	BRASS	N/A	284°	136	
○	1/2	6.4	BRASS	N/A	284°	449	
○	1/2	6.4	BRASS	SFC CHN	178°	8	
△	1/2	6.4	BRASS	NONE	178°	2	

TOTAL SPR HEADS THIS LEVEL: 417

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORKING TIMES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

SEE SHEET FT138 FOR CONTINUATION

NAVAFAC HAWAII
 MAJOR FACILITIES ENGINEERING COMMAND
 EQUIPMENT OF THE NAVY


JOINT BASE PEARL HARBOR HILOAH (RED HILL) OAHU, HAWAII
 FT15 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN - AREA 69 - LOWER LEVEL

PROJECT NO. 1326143
 DRAWING NO. FT137

NO. 10-16-17	NO. 10-2-17	NO. 8-23-17	NO. 8-11-17	NO. 7-28-17	NO. 6-4-17
BY	BY	BY	BY	BY	BY
CHECKED	CHECKED	CHECKED	CHECKED	CHECKED	CHECKED


DATE: 10/13/17

SCALE: 1/8" = 1'-0"



PARTIAL FIRE PROTECTION NEW PLAN - AREA 70 - LOWER LEVEL

SCALE 1/8" = 1'-0"



AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	IN	ORIFICE	ACTOR	FRAM	GLASS	TEMP	CEILING	SHIELD
STANDARD RESP UPFRIGHT	⊙	1/2	E.A.	BRASS	N/A	170°	8		
STANDARD RESP UPRIGHT	○	1/2	E.A.	BRASS	N/A	284°	136		
STANDARD RESP UPRIGHT ON SPRIG	⊙	1/2	E.A.	BRASS	N/A	284°	449		
STANDARD RESP ENDING W/ PLATE	⊙	1/2	E.A.	BRASS	SFC CHN	170°	8		
STANDARD RESP FOR ZENITH SIDEWALL	△	1/2	E.A.	BRASS	NONE	170°	8		

TOTAL SPR HEADS THIS LEVEL: 417

NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17	NO. 10-17
REV	DATE	BY	CHKD	APP'D	DESCRIPTION	DATE	BY	CHKD	APP'D
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

NAVTRAC

CPI

GENERAL ENGINEERING COMPANY
1041, HAWAII
1515 P-1561 (DESC-1561), UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FIRE PROTECTION NEW PLAN -
AREA 70 - LOWER LEVEL


PROJECT NO. 1326143

DATE: 08/14/13

SCALE: 1/8" = 1'-0"


PROJECT: FT 138

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORK SHALL BE INSTALLED AS NECESSARY TO AVOID CONFLICTS AND TO BE INSTALLED WITHIN THE AVAILABLE SPACE.



SCALE 1/8" = 1' 0"

PARTIAL FIRE PROTECTION NEW PLAN - AREA 71 - LOWER LEVEL



KEY PLAN

AS BUILT

SPRINKLER HEAD LEGEND:	SYMBOL	IN	ORIFICE	ACTOR	FRAM	GLASS	TEMP.	CEILING
STANDARD RESP-FRUIT	⊙	1/2	5.4	BRASS	N/A	170°	8	
STANDARD RESP-FRUIT	⊙	1/2	5.4	BRASS	N/A	284°	136	
STANDARD RESP-FRUIT ON SPIG	⊙	1/2	5.4	BRASS	N/A	284°	449	
STAND RESP-FRUIT w/ PLATE	⊙	1/2	5.4	BRASS	SFC CHN	170°	8	
STAND RESP-RICH ZENITH SIDEWALL	△	1/2	5.4	BRASS	NONE	170°	8	

TOTAL SPR HEADS THIS LEVEL: 417

NO. 10-16-17	NO. 10-17-17	NO. 10-18-17	NO. 10-19-17	NO. 10-20-17	NO. 10-21-17	NO. 10-22-17	NO. 10-23-17	NO. 10-24-17	NO. 10-25-17
BY	BY	BY	BY	BY	BY	BY	BY	BY	BY
CHKD	CHKD	CHKD	CHKD	CHKD	CHKD	CHKD	CHKD	CHKD	CHKD
DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE	DATE

NAVAFAC HAWAII

JOINT BASE PEARL HARBOR HONOLULU (RED HILL) OAHU, HAWAII
 FT 15 P-1561 (DESC-1561), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN - AREA 71 - LOWER LEVEL


PROJECT NO. 1326143

NAVAFAC HAWAII



FT 139

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



PARTIAL FIRE PROTECTION NEW PLAN - AREA 72 - LOWER LEVEL
 SCALE 1/8" = 1' 0"
 NAVFAC HAWAII
 FT100 FT134



AS BUILT

SYMBOL	IN	DIMENSIONS	FRAMING	PLATE	TEMP.	GRAM	STAND
SPRINKLER HEAD (ROUND)							
STANDARD RESP. UPRIGHT	VL100	1/2" S.A.	BRASS	N/A	179"	8	STAND
STANDARD RESP. UPRIGHT	VL100	1/2" S.A.	BRASS	N/A	284"	136	STAND
STANDARD RESP. UPRIGHT ON SPEIG	VL100	1/2" S.A.	BRASS	N/A	284"	449	STAND
STANDARD RESP. ENDING w/ PLATE	VL100	1/2" S.A.	BRASS	SFC CHN	179"	8	STAND
STANDARD RESP. HORN SIGNAL SIDEWALL	TY9811	1/2" S.A.	BRASS	HORN	179"	2	STAND


SEE SHEET FT141 FOR CONTINUATION

NAVAFAC HAWAII
 MAJOR FACILITIES ENGINEERING DIVISION
 CIVIL ENGINEERING SECTION
 CIVIL ENGINEER: [Signature]
 PROJECT NO. 1308143
 SHEET NO. FT140

DATE	NOV-16-17	NOV-16-17	NOV-16-17	NOV-16-17	NOV-16-17
BY	[Signature]	[Signature]	[Signature]	[Signature]	[Signature]
CHKD	[Signature]	[Signature]	[Signature]	[Signature]	[Signature]
APPV	[Signature]	[Signature]	[Signature]	[Signature]	[Signature]


D
C
B
A

D
C
B
A



PARTIAL FIRE PROTECTION NEW PLAN - AREA 73 - LOWER LEVEL

SCALE 1/8" = 1'-0"



AS BUILT

SYMBOL	QTY	DESCRIPTION	UNIT	PRICE	TOTAL
(Symbol)	1	STANDARD RESP. UPRIGHT	EA	170*	170*
(Symbol)	1	STANDARD RESP. UPRIGHT	EA	284*	284*
(Symbol)	1	STANDARD RESP. UPRIGHT ON SPIGOT	EA	284*	284*
(Symbol)	1	STANDARD RESP. ENDING W/ FLANGE	EA	170*	170*
(Symbol)	1	STANDARD RESP. HORN	EA	170*	170*

NO. 13-17	NO. 14-17	NO. 15-17	NO. 16-17	NO. 17-17	NO. 18-17
NO. 19-17	NO. 20-17	NO. 21-17	NO. 22-17	NO. 23-17	NO. 24-17

NAVAFAC

CPI

GENERAL CONTRACTOR: HAWAIIAN FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY PARTIAL FIRE PROTECTION NEW PLAN - AREA 73 - LOWER LEVEL

NAVAFAC HAWAII

PROJECT: JOINT BASE PEARL AND HERMES HARBOUR HONOLULU (RED HILL) FUEL STORAGE FACILITY PARTIAL FIRE PROTECTION NEW PLAN - AREA 73 - LOWER LEVEL


DATE: 12/20/17

PROJECT NO.: 1306143

NAVAFAC DRAWING NO.: FT141

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND SHALL MAKE NECESSARY CHANGES TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



PARTIAL FIRE PROTECTION NEW PLAN - AREA 74 - LOWER LEVEL

SCALE 1/8" = 1' 0"

KEY PLAN

AS BUILT

SYMBOL	IN	DRIVE	FACTORY	FRAG	CLASS	TEMP	Q/REAM	STAND
○	1/2	S.A.	BRASS	N/A	175°	8	STAND	
○	1/2	S.A.	BRASS	N/A	284°	136	STAND	
○	1/2	S.A.	BRASS	N/A	284°	449	STAND	
○	1/2	S.A.	BRASS	SFC CHR	175°	8	STAND	
△	1/2	S.A.	BRASS	NONE	175°	2	STAND	

TOTAL SPR HEADS THIS LEVEL: 417

NO. 15-17	NO. 15-17	NO. 15-17	NO. 15-17	NO. 15-17	NO. 15-17
NO. 15-17	NO. 15-17	NO. 15-17	NO. 15-17	NO. 15-17	NO. 15-17

NAVAFAC

CPI

CREATED BY: MTC
 DESIGNED BY: MTC
 CHECKED BY: MTC
 DATE: 1/13

PROJECT: FT142


CONTRACT NO.: 1326143

NAVAFAC HAWAII

JOINT BASE PEARL HARBOR HICOM (RED HILL) OAHU, HAWAII
 FT16 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN - AREA 74 - LOWER LEVEL

FT142


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.



PARTIAL FIRE PROTECTION NEW PLAN - AREA 75 - LOWER LEVEL



SCALE 1/8" = 1' 0"



KEY PLAN

AS BUILT

SYMBOL	IN	ORIFICE	ACTOR	FRAG	GLASS	TEMP.	GRAM	STAND
○	1/2	S.A.	BRASS	N/A	170°	5	STANDARD RESP UPFRIGHT	
○	1/2	S.A.	BRASS	N/A	284°	136	STANDARD RESP UPFRIGHT	
○	1/2	S.A.	BRASS	N/A	284°	449	STANDARD RESP UPFRIGHT ON SPRING	
○	1/2	S.A.	BRASS	SFC CHN	170°	5	STAND RESP ENDING W/ PLATE	
△	1/2	S.A.	BRASS	NONE	170°	2	STAND RESP FOR SIGNAL SIDEWALL	

TOTAL SPR HEADS THIS LEVEL: 417

NO. 10-10-17	NO. 10-2-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17
ALL RISES	PIPE EXTENSION FOR SYSTEM MODIFICATION	NEW - RISES IN THE DOWN DRAIN RISES	NEW - ADDED W/ NEW W/ NEW W/ NEW	NEW - ADDED W/ NEW W/ NEW W/ NEW	NEW - ADDED W/ NEW W/ NEW W/ NEW	NEW - ADDED W/ NEW W/ NEW W/ NEW	NEW - ADDED W/ NEW W/ NEW W/ NEW
NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17
NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17	NO. 10-11-17

NAVAFAC

CPI

CREATED BY: MTC
 DATE: 10/11/17
 CHECKED BY: JCY
 SCALE: 1/8" = 1' 0"


NAVAFAC HAWAII

JOINT BASE PEARL HARBOR HICOM (RED HILL)
 FT 15 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FIRE PROTECTION NEW PLAN -
 AREA 75 - LOWER LEVEL

FT143

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORKING TIMES AS NECESSARY TO AVOID CONFLICTS AND TO THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



NO. REV.	DATE	BY	CHKD.
1	10-10-17		
2	10-10-17		
3	10-10-17		
4	10-10-17		
5	10-10-17		
6	10-10-17		
7	10-10-17		
8	10-10-17		
9	10-10-17		
10	10-10-17		
11	10-10-17		
12	10-10-17		
13	10-10-17		
14	10-10-17		
15	10-10-17		
16	10-10-17		
17	10-10-17		
18	10-10-17		
19	10-10-17		
20	10-10-17		
21	10-10-17		
22	10-10-17		
23	10-10-17		
24	10-10-17		
25	10-10-17		
26	10-10-17		
27	10-10-17		
28	10-10-17		
29	10-10-17		
30	10-10-17		
31	10-10-17		
32	10-10-17		
33	10-10-17		
34	10-10-17		
35	10-10-17		
36	10-10-17		
37	10-10-17		
38	10-10-17		
39	10-10-17		
40	10-10-17		
41	10-10-17		
42	10-10-17		
43	10-10-17		
44	10-10-17		
45	10-10-17		
46	10-10-17		
47	10-10-17		
48	10-10-17		
49	10-10-17		
50	10-10-17		

AS BUILT

FT163

PROJECT NO. 1306143

DATE: 10/10/17

SCALE: AS SHOWN

DESIGNED BY: [Redacted]

CHECKED BY: [Redacted]

APPROVED BY: [Redacted]

PROJECT: PEARL HARBOR HOBAN (RED HILL) FT 163 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY PARTIAL FIRE PROTECTION NEW PLAN. AREA 13 - ADIT 6

NAVFAC HAWAII


NAVFAC ENGINEERING COMMAND

PEARL HARBOR, HAWAII

JOINT BASE PEARL HARBOR HOBAN (RED HILL) FT 163 P-1551 (DESC-1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY PARTIAL FIRE PROTECTION NEW PLAN. AREA 13 - ADIT 6

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



PREACTION RISERS SYSTEMS 1 AND 2

RISER LEGEND


- 6" FLANGED OS&Y WITH TAMPER SWITCH
- 6" ANSUL FLOWMAX PPW PROPORIONER W/HYDRAULIC CONCENTRATE CONTROL VALVE
- 6" VIKING DELUGE VALVE SET UP AS SINGLE INTERLOCK PREACTION VALVE WITH ELECTRIC RELEASE
- 6" GRV BUTTERFLY VALVE W/TAMPER
- 1" AUX DRAIN W/ SIGN
- PIPE CLAMP RODDED INTO FLOOR (USE 3/4")
- 6" GRV CHECK VALVE



PREACTION RISER SYSTEM 3

RISER LEGEND

- 8" FLANGED OS&Y WITH TAMPER SWITCH
- 8" ANSUL FLOWMAX PPW PROPORIONER W/HYDRAULIC CONCENTRATE CONTROL VALVE
- 6" VIKING DELUGE VALVE SET UP AS SINGLE INTERLOCK PREACTION VALVE WITH ELECTRIC RELEASE
- 6" GRV BUTTERFLY VALVE W/TAMPER
- 1" AUX DRAIN W/ SIGN
- PIPE CLAMP RODDED INTO FLOOR
- 6" GRV CHECK VALVE



PREACTION RISERS SYSTEMS 4 AND 5



RISER LEGEND

- 8" FLANGED OS&Y WITH TAMPER SWITCH
- 8" ANSUL FLOWMAX PPW PROPORIONER W/HYDRAULIC CONCENTRATE CONTROL VALVE
- 8" VIKING DELUGE VALVE SET UP AS SINGLE INTERLOCK PREACTION VALVE WITH ELECTRIC RELEASE
- 8" GRV BUTTERFLY VALVE W/TAMPER
- 1" AUX DRAIN W/ SIGN
- PIPE CLAMP RODDED INTO FLOOR
- 6" GRV CHECK VALVE

LOWER LEVEL - "GAUGER" RISER

RISER LEGEND

- 2 1/2" GRV VIKING EASY RISER WITH GAUGE, FLOW SWITCH, AND 1 1/4" TEST ON DRAIN WITH 3/8" ORIFICE AND 175 PSI PRESSURE RELIEF
- 2 1/2" FLANGED OS&Y WITH TAMPER SWITCH
- 1" AUX DRAIN W/ SIGN
- PIPE STAND



RISER LEGEND

- 4" SUPPLY PIPING FROM 8" FIRE PROTECTION MAIN
- RISER CLAMP OR UNISTRUT THE 4" DROP TO WALL
- 2 1/2" BRONZE ANGLE PATTERN HOSE VALVE WITH ADJUSTABLE PRESSURE RESTRICTION
- 4" GRV BUTTERFLY VALVE W/TAMPER

FIRE HOSE VALVE STATIONS

AS BUILT

DATE	10-14-17	10-14-17	10-14-17	10-14-17	10-14-17
BY	ALM	ALM	ALM	ALM	ALM
CHK					
APP					
DESC	FINAL DESIGN FOR SYSTEM ADDRESS	REV. 1 - ADD ON TTY PANEL AND RAMP	REV. 2 - ADD ON TTY PANEL AND RAMP	REV. 3 - ADD ON TTY PANEL AND RAMP	REV. 4 - ADD ON TTY PANEL AND RAMP
PROJ	NAVFAC HAWAII				
<p>I CERTIFY THAT THE DRAWING AND SPECIFICATIONS HEREON ARE THE WORK OF AN ENGINEER REGISTERED IN THE STATE OF HAWAII.</p>					
<p>CUSTOMER: NAVY FACULTY BLDG. 300 EAST PARKWAY STREET HONOLULU, HAWAII 96813</p> <p>TEL: (808) 825-8000 FAX: (808) 825-8990</p>					
DATE	10/14/17				
BY	ALM				
CHK					
APP					
DESC	NAVFAC HAWAII				
<p>JOINT BASE PEARL HARBOR HONOLULU (H2H) HAWAII</p> <p>PY16 P-181 (DESC 1851) UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY</p> <p>NEW FIRE PROTECTION SECTIONS LOWER LEVEL RISER DETAILS</p>					
SCALE	1:3205143				
DATE	10/14/17				
FT305R					


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



APPENDIX C. SITE SURVEY NOTES FIRE PUMP SYSTEM





SIZE H10XK17FL
TYPE 8100
SERIAL NUMBER 16-078785-01-101QY941
GPM 2500 AT FT HD 162 AND 70 PSI
RPM 1785 IMP DIA 13.75 NO STAGES 1
MAX NET PRESSURE DEVELOPED 87 PSI
NET PRESSURE AT 150% CAPACITY 47 PSI
MAX BHP 143.7
MAX POSITIVE SUCTION PRESSURE 313 PSI
INB. BRG 6309
OUT BRG 5308

SIZE H10XK17FL
TYPE 8100
SERIAL NUMBER 16-078785-01-101QY941
GPM 2500 AT FT HD 162 AND 70 PSI
RPM 1785 IMP DIA 13.75 NO STAGES 1
MAX NET PRESSURE DEVELOPED 88 PSI
NET PRESSURE AT 150% CAPACITY 47 PSI
MAX BHP 143.8
MAX POSITIVE SUCTION PRESSURE 314 PSI
INB. BRG 6309
OUT BRG 5308

DESIGN DRAWINGS
8 DAY'S TANKS, 500
GAL OR EQUAL

345768
CERTIFIED BY AMTROL INC. SPT14
MAWP 275 PSI AT 240 DEG F
MOMT +18 DEG F AT 275 PSI
MFG. SER. NO 345767 YEAR BUILT 2016
SIZE 106 GALS

345767
CERTIFIED BY AMTROL INC. SPT14
MAWP 275 PSI AT 240 DEG F
MOMT +18 DEG F AT 275 PSI
MFG. SER. NO 345767 YEAR BUILT 2016
SIZE 106 GALS

FIRE PUMP ROOM - EQUIPMENT LEGEND

1. 10" VICTAULIC 771H GRV OS&Y VALVE W/TAMPER (250PSI)
2. 12" TYCO BV-N WAFER BUTTERFLY WITH TAMPER (250PS)
3. 12" TYCO CV-1F GRV CHECK VALVE (300PS)
4. FIRE PUMP CONTROLLER W/TRANSFER SWITCH
5. ELECTRIC FIRE PUMP - 2,500 GPM @ 70 PSI
6. 1" AUX DRAIN
7. 10" NIBCO GD-6765-BN BUTTERFLY VALVE WITH TAMPER SWITCH
8. 8" NIBCO GD-4765-BN BUTTERFLY VALVE WITH TAMPER SWITCH
9. 8" FLOW METER
10. JOCKEY PUMP CONTROLLER
11. 25 GPM @ 125 PSI JOCKEY PUMP
12. 1 1/4" MILWAUKEE BB-SC100 BUTTERBALL VALVE (NO TAMPER STANDARD 175 PSI)
13. NOT USED
14. 1 1/4" MILWAUKEE BB-SC100 BUTTERBALL VALVE (NO TAMPER - SPEC. ORDER 350 PSI NYC)
15. 1 1/4" FPM THREADED CHECK VALVE (UL)
16. SPT-14 - 106 GAL FIRE PUMP SURGE TANK - SIZED PER MANU. FORMULA
17. 4" GROOVED B-FLY VALVE WITH TAMPER - NIBCO GD-4765-BN 300PSI
18. 3/4" 175 PSI PRESSURE RELIEF VALVE (PIPE TO DRAIN)
19. 300 PSI WATER PRESSURE GAUGE
20. AUTOMATIC AIR RELEASE VALVE
21. 4" WIKING M-2 GRV CHECK VALVE (250 PSI)
22. CROKER 6410-PB POLISHED BRASS DOUBLE CLAPPER 2-WAY FIRE DEPARTMENT CONNECTION W/ ROUND PLATE "AUTO SPKR" & PLUGS
23. 3" KENNEDY KS-FW FLG NON RISING STEM GATE VALVE (200 PSI) WITH WALL POST INDICATOR AND SUPERVISORY SWITCH
24. 3" WIKING J-1 FLG-GRV ALARM VALVE WITH VERT VARIABLE PRESSURE TRIM + RETARD + PRESSURE SWITCH (300 PSI)
25. WATER MOTOR & ALARM GONG ON OUTSIDE OF BUILDING
26. 10" NIBCO GD-6765-BN BUTTERFLY VALVE WITH TAMPER SWITCH (300PS)
27. 10" TYCO CV-1F GRV CHECK VALVE (300PS)
28. AUTOMATIC AIR RELEASE
29. 3/4" CASING RELIEF SET TO 240 PSI - PIPE TO FLOOR DRAIN
30. 300 PSI OIL FILLED WATER PRESSURE GAUGE
31. AIR COMPRESSOR
32. AIR DRYER
33. NITROGEN GENERATOR
34. NITROGEN TANK
35. AIR MAINTENANCE DEVICE

NOTE: PROVIDE SIGNAGE ON VALVES INDICATING NORMAL OPERATING POSITION. (OPEN OR CLOSED) - CHAIN & LOCK ALL
SEE SHEET FB-503 FOR PUMP SCHEDULES


FIRE PUMP ROOM - GROUND LEVEL / LOW PIPING

AS BUILT

16-04-27	AS BUILT	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17	10-2-17
1	1	1	1	1	1	1	1	1	1
CHECKED BY: [Signature] DATE: [Date] TITLE: [Title]									
PROJECT: [Project Name] SHEET: [Sheet Number]									
CONTRACTOR: [Contractor Name] ADDRESS: [Address]									
PROJECT LOCATION: [Location]									
DRAWING NO.: [Drawing Number]									
SCALE: [Scale]									
DATE: [Date]									

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES



FIRE PUMP ROOM - OVERHEAD / HIGH PIPING

FIRE PUMP ROOM - EQUIPMENT LEGEND

1. 10" VICTAULIC 771H GRV OS&Y VALVE W/TAMPER (250PSI)
2. 12" TYCO BFV-N WAFER BUTTERFLY WITH TAMPER (250PSI)
3. 12" TYCO CV-1F GRV CHECK VALVE (300PSI)
4. FIRE PUMP CONTROLLER W/TRANSFER SWITCH
5. ELECTRIC FIRE PUMP - 2,500 GPM @ 70 PSI
6. 1" AUX DRAIN
7. 10" NIBCO GD-6765-BN BUTTERFLY VALVE WITH TAMPER SWITCH
8. 8" NIBCO GD-4765-BN BUTTERFLY VALVE WITH TAMPER SWITCH
9. 8" FLOW METER
10. JOCKEY PUMP CONTROLLER
11. 25 GPM @ 125 PSI JOCKEY PUMP
12. 1 1/4" MILWAUKEE BB-SC100 BUTTERBALL VALVE (NO TAMPER STANDARD 175 PSI)
13. NOT USED
14. 1 1/4" MILWAUKEE BB-SC100 BUTTERBALL VALVE (NO TAMPER - SPEC. ORDER 350 PSI NYC)
15. 1 1/2" FPM THREADED CHECK VALVE (UL)
16. SPT-14 - 106 GAL FIRE PUMP SURGE TANK - SIZED PER MANU. FORMULA
17. 4" GROOVED B-FLY VALVE WITH TAMPER - NIBCO GD-4765-BN 300PSI
18. 1/2" 175 PSI PRESSURE RELIEF VALVE (PIPE TO DRAIN)
19. 300 PSI WATER PRESSURE GAUGE
20. AUTOMATIC AIR RELEASE VALVE
21. 4" VIKING M-2 GRV CHECK VALVE (250 PSI)
22. CROKER 6410-PB POLISHED BRASS DOUBLE CLAPPER 2-WAY FIRE DEPARTMENT CONNECTION W/ ROUND PLATE "AUTO SPKR" & PLUGS
23. 3" KENNEDY KS-FW FLG NON RISING STEM GATE VALVE (200 PSI) WITH WALL POST INDICATOR AND SUPERVISORY SWITCH
24. 3" VIKING J-1 FLG-GRV ALARM VALVE WITH VERT VARIABLE PRESSURE TRIM + RETARD + PRESSURE SWITCH (300 PSI)
25. WATER MOTOR & ALARM GONG ON OUTSIDE OF BUILDING
26. 10" NIBCO GD-6765-BN BUTTERFLY VALVE WITH TAMPER SWITCH (300PSI)
27. 10" TYCO CV-1F GRV CHECK VALVE (300PSI)
28. AUTOMATIC AIR RELEASE
29. 3/4" CASING RELIEF SET TO 240 PSI - PIPE TO FLOOR DRAIN
30. 300 PSI OIL FILLED WATER PRESSURE GAUGE
31. AIR COMPRESSOR
32. AIR DRYER
33. NITROGEN GENERATOR
34. NITROGEN TANK
35. AIR MAINTENANCE DEVICE

NOTE: PROVIDE SIGNAGE ON VALVES INDICATING NORMAL OPERATING POSITION. (OPEN OR CLOSED) - CHAIN & LOCK ALL
SEE SHEET FB-503 FOR PUMP SCHEDULES


AS BUILT

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

REV	DATE	DESCRIPTION
1	10-14-17	AS BUILT
2	10-27-17	FINAL OFFERS FOR EXTERIOR PAVING
3	11-28-17	ADD - 106 GAL FIRE PUMP SURGE TANK
4	1-11-17	REV - ADDS 106 GAL SURGE TANK
5	1-23-17	REV - ADDS AIR MAINT. FROM TRAILER
6	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
7	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
8	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
9	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
10	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
11	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
12	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
13	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
14	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
15	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
16	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
17	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
18	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
19	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
20	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
21	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
22	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
23	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
24	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
25	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
26	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
27	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
28	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
29	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
30	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
31	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
32	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
33	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
34	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER
35	1-24-17	REV - ADDS AIR MAINT. FROM TRAILER

FB101C


REVISED WORK IS ALL 2017



FIRE PUMP - SECTION FACING EAST (B-B)

FIRE PUMP ROOM - EQUIPMENT LEGEND

1. 10" VICTAULIC 771H GRV OS&Y VALVE W/TAMPER (250PSI)
 2. 12" TYCO BFV-N WAFER BUTTERFLY WITH TAMPER (250PSI)
 3. 12" TYCO CV-1F GRV CHECK VALVE (300PSI)
 4. FIRE PUMP CONTROLLER W/TRANSFER SWITCH
 5. ELECTRIC FIRE PUMP - 2,500 GPM @ 70 PSI
 6. 1" AUX DRAIN
 7. 10" NIBCO GD-6765-BN BUTTERFLY VALVE WITH TAMPER SWITCH
 8. 8" NIBCO GD-4765-BN BUTTERFLY VALVE WITH TAMPER SWITCH
 9. 8" FLOW METER
 10. JOCKEY PUMP CONTROLLER
 11. 25 GPM @ 125 PSI JOCKEY PUMP
 12. 1 1/2" MILWAUKEE BB-SC100 BUTTERBALL VALVE (NO TAMPER STANDARD 175 PSI)
 13. NOT USED
 14. 1 1/2" MILWAUKEE BB-SC100 BUTTERBALL VALVE (NO TAMPER - SPEC. ORDER 350 PSI NYC)
 15. 1 1/2" FPMI THREADED CHECK VALVE (UL)
 16. SPT-14 - 106 GAL FIRE PUMP SURGE TANK - SIZED PER MANU. FORMULA
 17. 4" GROOVED B-FLY VALVE WITH TAMPER - NIBCO GD-4765-BN 300PSI
 18. 1/2" 175 PSI PRESSURE RELIEF VALVE (PIPE TO DRAIN)
 19. 300 PSI WATER PRESSURE GAUGE
 20. AUTOMATIC AIR RELEASE VALVE
 21. 4" VIKING M-2 GRV CHECK VALVE (250 PSI)
 22. CROKER 6410-PB POLISHED BRASS DOUBLE CLAPPER 2-WAY FIRE DEPARTMENT CONNECTION W/ ROUND PLATE "AUTO SPKR" & PLUGS
 23. 3" KENNEDY KS-FW FLG NON RISING STEM GATE VALVE (200 PSI) WITH WALL POST INDICATOR AND SUPERVISORY SWITCH
 24. 3" VIKING J-1 FLG-GRV ALARM VALVE WITH VERT VARIABLE PRESSURE TRIM + RETARD + PRESSURE SWITCH (300 PSI)
 25. WATER MOTOR & ALARM GONG ON OUTSIDE OF BUILDING
 26. 10" NIBCO GD-6765-BN BUTTERFLY VALVE WITH TAMPER SWITCH (300PSI)
 27. 10" TYCO CV-1F GRV CHECK VALVE (300PSI)
 28. AUTOMATIC AIR RELEASE
 29. 3" CASING RELIEF SET TO 240 PSI - PIPE TO FLOOR DRAIN
 30. 300 PSI OIL FILLED WATER PRESSURE GAUGE
 31. AIR COMPRESSOR
 32. AIR DRYER
 33. NITROGEN GENERATOR
 34. NITROGEN TANK
 35. AIR MAINTENANCE DEANCE
- NOTE: PROVIDE SIGNAGE ON VALVES INDICATING NORMAL OPERATING POSITION. (OPEN OR CLOSED) - CHAIN & LOCK ALL.
SEE SHEET FB-503 FOR PUMP SCHEDULES



FIRE PUMP ROOM - SECTION FACING SOUTH (A-A)

16-11-17	10-17-17	1-11-17	1-11-17	1-11-17	1-11-17
AS BUILT	AS BUILT	AS BUILT	AS BUILT	AS BUILT	AS BUILT
1	2	3	4	5	6
1. FINAL CHECK FOR DESIGN REVISION	2. AS-BUILT IN THE FIELD	3. AS-BUILT IN THE FIELD	4. AS-BUILT IN THE FIELD	5. AS-BUILT IN THE FIELD	6. AS-BUILT IN THE FIELD
1	2	3	4	5	6
1. AS-BUILT IN THE FIELD	2. AS-BUILT IN THE FIELD	3. AS-BUILT IN THE FIELD	4. AS-BUILT IN THE FIELD	5. AS-BUILT IN THE FIELD	6. AS-BUILT IN THE FIELD
1	2	3	4	5	6
1. AS-BUILT IN THE FIELD	2. AS-BUILT IN THE FIELD	3. AS-BUILT IN THE FIELD	4. AS-BUILT IN THE FIELD	5. AS-BUILT IN THE FIELD	6. AS-BUILT IN THE FIELD
1	2	3	4	5	6
1. AS-BUILT IN THE FIELD	2. AS-BUILT IN THE FIELD	3. AS-BUILT IN THE FIELD	4. AS-BUILT IN THE FIELD	5. AS-BUILT IN THE FIELD	6. AS-BUILT IN THE FIELD
1	2	3	4	5	6
1. AS-BUILT IN THE FIELD	2. AS-BUILT IN THE FIELD	3. AS-BUILT IN THE FIELD	4. AS-BUILT IN THE FIELD	5. AS-BUILT IN THE FIELD	6. AS-BUILT IN THE FIELD

1. I HEREBY CERTIFY THAT THIS DRAWING WAS PREPARED BY ME OR UNDER MY CLOSE PERSONAL SUPERVISION.

CPI

CONTRACT NO. 1326143

DATE: 11/11/17

PROJECT: NAVFAC HAWAII

CONTRACTOR: NAVFAC HAWAII

DESIGNER: NAVFAC HAWAII

CLIENT: NAVFAC HAWAII

PROJECT: JOINT BASE PEARL HARBOR HOBOM (RED HILL) PY18 P-1851 (DESC 1951), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY



FIRE PUMP ROOM SECTIONS

NEW FIRE PUMP BUILDING

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

FB101D



PUMP HOUSE HANGER / SWAY THROUGH BOLTS

INCLUDES 4" AND LARGER HANGERS AND ALL SWAY BRACES
 DOES NOT INCLUDE 3" AND SMALLER ATTACHMENTS

HANGER DETAIL #41 - THRU ROD ANCHOR
 N.T.S.

AS BUILT

REV	DATE	DESCRIPTION
1	10-2-17	AS BUILT
2	10-2-17	FINAL OFFERS FOR DESIGN RESPONSE
3	8-28-17	REV - ISSUE IN THE CONJ. PUMP K232
4	8-11-17	REV - ADDS HANGERS AND SWAY TO THE
5	8-11-17	REV - ADDS AS BUILT FROM THE 1000
6	8-11-17	REV PER PERMITS
7	8-11-17	REV PERMITS
8	8-11-17	REV PERMITS

NAVAFAC

UNIVERSITY PROJECT, INC.
 800 SHAWNEE STREET
 IDEALHILL, INDIANAPOLIS 46209

TEL: (317) 955-0500
 FAX: (317) 955-0501

DATE: 10/2/17

PROJECT: NEW FIRE PUMP BUILDING

CONTRACT NO.: 1326143

CONTRACT OWNER: NAVAFAC HAWAII

CONTRACTOR: JOINT BASE PEARL HARBOR HONOLULU (RED HILL) PEARL HARBOR, HAWAII

PROJECT: P.Y. 18 P-1181 (DESC. 1181), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

PROJECT: FIRE PROTECTION OVERHEAD HANGERS

PROJECT: NEW FIRE PUMP BUILDING

SPRINKLER HEAD LEGEND:	SYMBOL	QTY	COMP.	GRADE	HEAD	GLASS	TEMP.	QUANTITY
QUICK RESP PENDENT w/OUT PLATE	⊙	VE302	1/2"	6.4	BRASS	NONE	178°	34
TOTAL SPRINKLERS THIS LEVEL								34

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22" X 34"
 REDUCED PRINT - USE GRAPHIC SCALES



APPENDIX D. SITE SURVEY NOTES FOAM PUMP SYSTEM



FOAM TANK CAPACITY NOTES:
 2309 GPM SOLUTION x 3% = 69.27 GPM x 15 MIN
 EQUALS 1039 GALLONS OF FOAM CONCENTRATE REQ'D.
 1450 GALLON TANK PROVIDES 139% REQUIRED CAPACITY




FOAM PUMP ROOM - LOW PIPING

FOAM PUMP ROOM - EQUIPMENT LEGEND

1. 1450 GALLON FOAM CONCENTRATE TANK
2. STAINLESS STEEL BALL VALVE WITH TAMPER SWITCH STRAINER
3. BALL VALVE
4. 146 GPM @ 150 PSI FOAM PUMP
5. JOCKEY PUMP 3 GPM @ 160
6. PRESSURE RELIEF VALVE
7. PRESSURE SUSTAINING VALVE
8. COMPOUND PRESSURE GAUGE
9. PRESSURE GAUGE
10. FOAM PUMP CONTROLLER W/A.T.S.
11. FOAM JOCKEY PUMP CONTROLLER
12. DISCHARGE TO UNDERGROUND
13. NOT USED
14. CHECK VALVE - 3" NIBCO T-433-B

NOTE: PUMP SKID TO BE FILLED WITH CONCRETE PER MANUFACTURER'S RECOMMENDATIONS.

12" DIAMETER FLOOR SLEEVE FOR 4" FOAM LINE WITH 6" CONTAINMENT (PIPED BY OTHERS)



FOAM PUMP ROOM - HIGH PIPING AS BUILT


REV	DATE	DESCRIPTION
1	10-14-27	AS BUILT
2	10-27-27	REV. OFFERS FOR EXTRA REVISIONS
3	10-27-27	REV. - 1450 GALLON FOAM TANK
4	11-17-27	REV. - 1450 GALLON TANK
5	11-17-27	REV. - 1450 GALLON TANK
6	11-17-27	REV. - 1450 GALLON TANK
7	11-17-27	REV. - 1450 GALLON TANK
8	11-17-27	REV. - 1450 GALLON TANK
9	11-17-27	REV. - 1450 GALLON TANK
10	11-17-27	REV. - 1450 GALLON TANK
11	11-17-27	REV. - 1450 GALLON TANK
12	11-17-27	REV. - 1450 GALLON TANK
13	11-17-27	REV. - 1450 GALLON TANK
14	11-17-27	REV. - 1450 GALLON TANK
15	11-17-27	REV. - 1450 GALLON TANK
16	11-17-27	REV. - 1450 GALLON TANK
17	11-17-27	REV. - 1450 GALLON TANK
18	11-17-27	REV. - 1450 GALLON TANK
19	11-17-27	REV. - 1450 GALLON TANK
20	11-17-27	REV. - 1450 GALLON TANK
21	11-17-27	REV. - 1450 GALLON TANK
22	11-17-27	REV. - 1450 GALLON TANK
23	11-17-27	REV. - 1450 GALLON TANK
24	11-17-27	REV. - 1450 GALLON TANK
25	11-17-27	REV. - 1450 GALLON TANK
26	11-17-27	REV. - 1450 GALLON TANK
27	11-17-27	REV. - 1450 GALLON TANK
28	11-17-27	REV. - 1450 GALLON TANK
29	11-17-27	REV. - 1450 GALLON TANK
30	11-17-27	REV. - 1450 GALLON TANK
31	11-17-27	REV. - 1450 GALLON TANK
32	11-17-27	REV. - 1450 GALLON TANK
33	11-17-27	REV. - 1450 GALLON TANK
34	11-17-27	REV. - 1450 GALLON TANK
35	11-17-27	REV. - 1450 GALLON TANK
36	11-17-27	REV. - 1450 GALLON TANK
37	11-17-27	REV. - 1450 GALLON TANK
38	11-17-27	REV. - 1450 GALLON TANK
39	11-17-27	REV. - 1450 GALLON TANK
40	11-17-27	REV. - 1450 GALLON TANK
41	11-17-27	REV. - 1450 GALLON TANK
42	11-17-27	REV. - 1450 GALLON TANK
43	11-17-27	REV. - 1450 GALLON TANK
44	11-17-27	REV. - 1450 GALLON TANK
45	11-17-27	REV. - 1450 GALLON TANK
46	11-17-27	REV. - 1450 GALLON TANK
47	11-17-27	REV. - 1450 GALLON TANK
48	11-17-27	REV. - 1450 GALLON TANK
49	11-17-27	REV. - 1450 GALLON TANK
50	11-17-27	REV. - 1450 GALLON TANK
51	11-17-27	REV. - 1450 GALLON TANK
52	11-17-27	REV. - 1450 GALLON TANK
53	11-17-27	REV. - 1450 GALLON TANK
54	11-17-27	REV. - 1450 GALLON TANK
55	11-17-27	REV. - 1450 GALLON TANK
56	11-17-27	REV. - 1450 GALLON TANK
57	11-17-27	REV. - 1450 GALLON TANK
58	11-17-27	REV. - 1450 GALLON TANK
59	11-17-27	REV. - 1450 GALLON TANK
60	11-17-27	REV. - 1450 GALLON TANK
61	11-17-27	REV. - 1450 GALLON TANK
62	11-17-27	REV. - 1450 GALLON TANK
63	11-17-27	REV. - 1450 GALLON TANK
64	11-17-27	REV. - 1450 GALLON TANK
65	11-17-27	REV. - 1450 GALLON TANK
66	11-17-27	REV. - 1450 GALLON TANK
67	11-17-27	REV. - 1450 GALLON TANK
68	11-17-27	REV. - 1450 GALLON TANK
69	11-17-27	REV. - 1450 GALLON TANK
70	11-17-27	REV. - 1450 GALLON TANK
71	11-17-27	REV. - 1450 GALLON TANK
72	11-17-27	REV. - 1450 GALLON TANK
73	11-17-27	REV. - 1450 GALLON TANK
74	11-17-27	REV. - 1450 GALLON TANK
75	11-17-27	REV. - 1450 GALLON TANK
76	11-17-27	REV. - 1450 GALLON TANK
77	11-17-27	REV. - 1450 GALLON TANK
78	11-17-27	REV. - 1450 GALLON TANK
79	11-17-27	REV. - 1450 GALLON TANK
80	11-17-27	REV. - 1450 GALLON TANK
81	11-17-27	REV. - 1450 GALLON TANK
82	11-17-27	REV. - 1450 GALLON TANK
83	11-17-27	REV. - 1450 GALLON TANK
84	11-17-27	REV. - 1450 GALLON TANK
85	11-17-27	REV. - 1450 GALLON TANK
86	11-17-27	REV. - 1450 GALLON TANK
87	11-17-27	REV. - 1450 GALLON TANK
88	11-17-27	REV. - 1450 GALLON TANK
89	11-17-27	REV. - 1450 GALLON TANK
90	11-17-27	REV. - 1450 GALLON TANK
91	11-17-27	REV. - 1450 GALLON TANK
92	11-17-27	REV. - 1450 GALLON TANK
93	11-17-27	REV. - 1450 GALLON TANK
94	11-17-27	REV. - 1450 GALLON TANK
95	11-17-27	REV. - 1450 GALLON TANK
96	11-17-27	REV. - 1450 GALLON TANK
97	11-17-27	REV. - 1450 GALLON TANK
98	11-17-27	REV. - 1450 GALLON TANK
99	11-17-27	REV. - 1450 GALLON TANK
100	11-17-27	REV. - 1450 GALLON TANK

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE WORKING TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

FIRE PUMP SCHEDULE

UNIT	TYPE	FLOW RATE	1.5 MIN. (PSI)	1 MIN. (PSI)	UNIT	FITTINGS		
						FL	TR	AMP'S
FP-1	N-LINE ELECTRICALLY STARTED CENTRIFUGAL FIRE PUMP	2500 GPM	20	125		480	3	
FP-2	N-LINE ELECTRICALLY STARTED CENTRIFUGAL FIRE PUMP	2500 GPM	20	125		480	3	
AP-1	ELECTRIC IN-LINE WATER SUPPLY CHECK VALVE ASSEMBLY PUMP	250 GPM	30	3		480	3	
AP-2	ELECTRIC IN-LINE WATER SUPPLY CHECK VALVE ASSEMBLY PUMP	250 GPM	30	3		480	3	
AF1P-1	ANTI-COASTAL PUMP	150 GPM	150	30		480	3	
AF2P-2	ANTI-COASTAL PUMP	150 GPM	150	30		480	3	
AF1-1	ANTI-COASTAL PUMP	3 GPM	180	3		7	3	
AF1-2	ANTI-COASTAL PUMP	3 GPM	180	3		7	3	



FIRE PUMP ISOMETRIC



FOAM PUMP ISOMETRIC

AS BUILT

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AND THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICTS AND TO ENSURE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.
IF SHEET IS LESS THAN 22" X 34" REDUCED PRINT - USE GRAPHIC SCALES

NAVAFAC
NAVAFAC HAWAII
JOINT BASE PEARL HARBOR HOOKAH (RED HILL) OHAI, HAWAII
FY18 P4-1851 (DESC: 1851), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
FIRE PUMP AND FOAM PUMP ISOMETRIC DRAWINGS
NEW FIRE PUMP BUILDING
DATE: 1/18/21
CONTRACT NO.: 1306143
CONTRACT OWNER: NA
SYMBOLS: NA
FB503
REVISED: 12/22/20



APPENDIX E. SITE SURVEY NOTES FIRE ALARM/MNS SYSTEM




Red Hill Fire Alarm RFI
Current as of 11/21/2016

RFI #	Subject	Summary
0013	Design Intent Confirmation for Fire Alarm System	1) VDU shall be housed in a NEMA X enclosure and on the exterior of the tunnel as shown. 2) Intelligible shall indeed be required and shall conform to UFC - 021.
0015	Fire Alarm Connect on Between Buildings	Intelligent purshouse fire alarm protection design. To comply w/ replace all fire alarm components in the underground purshouse with new FA/MNS system. Existing fire protection speaker cabinet system remains unchanged and is controlled by the new FA system instead of the old system.
0016	Fire Alarm Monitoring of Existing Fans and Control Panels	Scope of work shall include replacing the existing fan control system, include replacing existing UL86 panels and annunciators with new UGRU system that is Class 1 Div 2 to be integrated with new fire alarm panels. Note: scope requirements: 28.31.76.2.3, and 2.3.2.1, 2.4, 2.5.
0017	Interface Relay Box Clarification	Contractor to field coordinate with relay to make terminations to accomplish the two fire alarm inputs and one fire alarm output that are called for on PFD.
0018	Spot Type Heat Detector on	Spot type heat detectors is the basis of design. Linear detection can be provided if there is not additional cost or minimal cost (if approved by government).
0052	Infrared Flame Detection Field of View	Det Thionia 90 degree horizontal field of view flame detection can be provided in lieu of the spec requirement for a system that provides 120 degree horizontal.
0053	Explosion Proof/Fire Alarm Speakers W/amp Requirements	Explosion proof speaker w/amps can be provided with the following options: 1, 2, 7, and 15 watts in lieu of the current spec requirements.
005	Jockey Pump Status Monitoring	Jockey pump status monitoring by the fire alarm system shall ONLY consist of monitoring: Jockey Pump Controller Switch in Off or Manual Position in lieu of the advanced multiple monitoring points shown on the matrix.
0063	Class 1 Div. 2 Fire Alarm Panel Mount	Fire alarm devices/enclosures can be provided within an aluminum enclosure when the UL listing would be voided by the manufacturer (not installed in an engineered custom box that where design offer requires that it be installed in such).
0070	Mount and Pathway Requirements for Fire Alarm	Mounting between monitor modules and initiating devices can be done in
0082 (rev2)	Fire Alarm UPS for Visual Display Units & DCC System	VDUs shall be powered by UPS battery backup providing 2 hours of backup.
0089	Fire Alarm Junction Box Labeling	It is acceptable to provide fire alarm junction boxes with red face plates in lieu of spec requirement to paint the entire junction box red.
0092	Heat Detectors Exterior Indicators and Wiring Requirements	1) Test fixed temperature heat detectors per manufacturer's recommendations - NOT by heat test method. 2) Exterior indicators are not required for any NEMA 3R or Class 1 Div 2 fixed temperature heat detectors.
0097	Class 1 Division 2 Hazardous Location Boundaries	The following areas are not hazardous class 1 division 2 areas: gauge station oil, gauge station electric room, and office/control room in the underground pump house.
0100	Heat Detector Temperature Ratings	1) Provide 200 deg F rated heat detectors in the lower tunnel, harbor tunnel, upper tunnel and underground purshouse. 2) Provide 135 deg F rated heat detectors in the elevator shaft, machine room, control room, mechanical rooms, electric rooms, and fire pump building.
0101	Fire Alarm Battery Calculation on Conduits	Fire alarm battery calculations will be based on 2 watt tap usage of explosion proof speakers in lieu of spec requirement. Also calculate based on highest watt tap available of device.
0105.1	Existing Tunnel Power Survey for Fire Alarm	New fire alarm power panels require power circuit however there are numerous instances where existing electrical system does not have available breakers to provide this power. In the instances where less than four circuits are required to come off an existing panel, provide new enclosed circuit breakers (QEA-F) tapped off the existing panel basing for each required circuit. For instances in which four or more circuits are needed, add an explosion proof panelboard by tapping off the existing panel busing.
0106	25% Spare Capacity for Class 1 Division 2 Fire Alarm Devices	Spec requires all fire alarm circuits to maintain 25% spare capacity. In the lower tunnel each strobe takes up 66% capacity and are installed on dedicated fire alarm circuits as a result. If each strobe takes up 66% capacity on a dedicated circuit then the only way to provide 25% overall spare capacity would be to expand the # of circuits on each panel by 26%. The designer has confirmed that we are only required to provide additional capacity at power points to allow for a panel to be replaced.
0113	Fire Alarm DCC, Electrical System Cancellations	1) Review fire alarm matrix: Row Line Item: Sump Pump SP-DOOR-12.3 or 5.9 min.; requires the aux line function Shutdown Sump Pump SP-DOOR-15(MC) (5-9). This is not required. Instead, a new corresponding function shall be Shutdown AI Grandstand Pumps. 2) Review fire alarm matrix: Row line item for Sump Pump SP-DOOR-12.3 or 5.9 min.; the requirement to Shutdown Fire SP-2A2B is no longer required. 3) Review fire alarm matrix: Row Line Item: Oil Light Door: Door Remote Input is no longer required to accomplish the remote open function. Only remotely close is required. 4) Review fire alarm matrix: Row line item: New Compartments: Doors at Adit 546 (1 EA at Each Location) Remote Input; current requires corresponding function to remotely re-open these doors. This function is no longer required. 5) Review fire alarm matrix: (and four plans if necessary): Both the top doors and single entry doors at the new compartment well doors at Adit 5 & Adit 6 shall be monitored and controlled by the fire alarm system. 6) Review fire alarm matrix: Row line item: New Compartments: Doors 1-4 (2 EA Personnel Door) EA Row Up at (East Location) Remote Input; Currently requires the auxiliary function to remotely re-open the doors. This is no longer required.
011	Rate of Rise and Fixed Heat Heat Detector	In lieu of specified dual function heat and rate of rise of type heat detectors, self restoring heat detectors with 19 deg F fixed heat detection with rate compensation equal to the Thermotech 302-series heat detectors fire.
0115	MBPF Hangers and Anchors	Stainless steel anchors are required for all MBE PFPFA installations. Other type steel hangers are permitted to be used in conjunction with the stainless steel hangers, however if the metal used are steel it is a pre-emptive coating must be provided conforming to MPR 79.
0128	Explosion Proof/Flex for Fire Alarm Panels	Explosion proof flexible conduit approved or use in short lengths for connections into the fire alarm panels.

RFI #	Subject	Summary
0138	Fire Alarm System Support	It is acceptable to mount new/replaceable devices from existing cable tray rack. Conduits may be supported of the main support members of the cable tray rack. Heat detectors shall install in the lowest bay of ceiling.
0139	Fire Alarm Pull Station on Locations	Pull stations may be surface mounted to wall at typical harbor tunnel detail provided in this RFI: ...which are above, and behind a 36" pipe, obstructed. In addition, double-acton makes operation very difficult while reaching over pipe.
017	Fire Alarm Mass Notification and Zoning	1) Fire alarm system shall be zoned per the following breakdowns: UGRH (No Adit) Harbor Tunnel (No Adit 2), Lower Access Tunnel (No Adit 13) Upper Access Tunnel (No Adit 16), and the Fire Pump Building. Alarm signals shall be transmitted to the fire department per building for each zone as per Fire Alarm Access Ion of Fire or in writing. 2) The following messages shall be used for the mass notification system: Fire Emergency / Fire Alarm Message: Temporal 3 repeat 2 cycles with a 1.5 second delay between cycles followed by a fire emergency has occurred; please leave the building by the nearest exit. (repeat message) Valid: Turn on strobe. Text Message: NCA Standard alert tone - 1050 Hz (8 seconds) to be followed by Text, Text, Text. This is an emergency notification audio system test; You may continue normal operations, Text, Text, Text. Valid: Turn on strobe. 4) Clear Chp Done (one cycle) followed by The Emergency has been resolved; return to normal operations (repeat message) Valid: None While only these 3 messages are recommended by CI 7, it does not change the requirement that the system have a full necessary components to support up to 8 recorded messages, as noted in section 215.5.2 of spec for on 28.3176, so that the messages can be added as needed as it is in use. 3) Specified test on 28.3176.2.15.5.2.4 (1-9) requires a 2 second pause between each mass notification message, followed by repeating the message. Please advise how many times the message shall repeat if the message will be repeated indefinitely during an alarm condition. 3) When a message is activated in the mass notification system, the message shall run for minimum 10 minutes. The following requirements shall apply: Allow the MNS to temporarily override fire alarm audible messages and visual signals, and to provide intelligible voice commands during simultaneous fire and terrorist events. All other features of the fire alarm system, including the transfer on signals to the fire department, shall function properly. MNS messages shall take priority and can be used to override fire alarm audible messages and the MNS messages is either manually or automatically entered. If not manually entered, the MNS message will automatically and after 10 minutes.
0150	Fire Alarm Wiring Requirements	Use of THHN not permitted for fire alarm wiring, use FPL type wiring in accordance with specification 28.3176
0152	Fire Alarm Certifications at UGRH	1A. In the under tunnel, lower level, and, there are multiple areas/levels within that do not require heat detection - follow the shop drawings. Locations of heat detectors do not mount additional 1B. All existing detection devices that tie in to the existing AFFP remain FM 200 Cheesha panel in the underground purshouse shall remain. The new fire alarm system shall only monitor this existing panel for three points. The new fire alarm system shall NOT be capable of releasing the AFFP or FM 200 system through the Cheesha panel control. The three points to be monitored are: Fire alarm from any of the existing heat detectors, AFFP discharge system discharge, and fire alarm/release a stem trouble at rest 2) Existing heat detectors shall remain in the underground purshouse electrical room. All existing detection devices that tie in to the existing AFFP release of FM 200 Cheesha panel in the underground purshouse shall remain. The new fire alarm system shall only monitor this existing panel for three points. The new fire alarm system shall NOT be capable of releasing the AFFP or FM 200 system through the Cheesha panel control. The three points to be monitored are: Fire alarm from any of the existing heat detectors, FM200 stem discharge, and fire alarm/release a stem trouble at rest 3) Clarification: New devices shall be provided as shown on shop drawing. In both the under tunnel, lower level, and, there are multiple areas/levels within that do not require heat detection - follow the shop drawings. Locations of heat detectors do not mount additional 3) Fire alarm panels that are currently shown to be inside the control room in the underground purshouse may be re-located to the hallway outside the control room with the exception of the main fire alarm panel, and network workstation. 4) Manual override device for AFFP form systems are not required. 5) An existing pathway does not exist that would permit a new fiber optic cable to be installed in building 1757. There is however a existing multi-mode fiber cable that goes to 1757. Contractor shall utilize the existing multi-mode fiber and make necessary modifications to the fire alarm system to convert from single-mode fiber workstation facilities to multi-mode fiber.
0153	Fire Alarm Field Cancellations	RFI 0153 - Fire Alarm and Fire Protection Field Clarifications 1) It is acceptable to mount the fire alarm devices at 63 in the UGRH lower level beneath the grating due to the over ceiling. Due to lowering these devices, follow NFPA 72 - 18.5.2.2 reduction in coverage and adjust spacing of devices as needed to ensure full coverage. 2) In the UGRH over level, shop drawing sheet FF-145, along drawing sector A1 through A3 area, these heat detectors are permitted to be mounted on the wall as long as they are a minimum of 12" and no greater than 12" below the ceiling.
0159	Obstructions to Fields of View for Flame Detectors	*See provided as sheet RFI 0159 sketch alternate layouts for flame detector placement in the lower tunnel tank gery
0162	FDC Pressure Switch Locations	Pressure switches shall be added at Adit FDC locations. One pressure switch shall send a supervisory condition of FDC High Pressure and the other pressure switch shall send supervisory condition of FDC High Pressure Failure. (2) Pressure switches each at each one of Adit 3 and Adit 1 and () pressure switches shall be located at Adit 6.
0167	Flame Detector Sequence of Operation	Add line item in fire alarm system sequence of operation for an event of Lower Access Tunnel Triple IR Detector Single Dev or Activated and Low N Fogen Pressure. The corresponding sequence of operation shall mirror the condition of Lower Access Tunnel Triple IR DETECTOR Two Devs Activated. In addition, the fire alarm system sequence of operation shall be modified to change the audible functions column description per the following CHANGE: Close Fire Smoke Dampers at Lower Tunnel Door 1 TO ALL Lower Tunnel Door 5 and Existing Door C CHANGE: Release Doors at Lower Tunnel Door 1 TO ALL Lower Tunnel Door 5 and Existing Door C
0169	Cheesha Panel Controls at UGRH	The following are in the underground purshouse are a part of existing control scheme managed by the existing Cheesha fire alarm panel and the existing IRB interface relay box. These fans shall not be individually monitored or controlled by the new fire alarm system. The new fire alarm system shall monitor the existing Cheesha panel which in turn monitors and controls these fans in order to provide a complete integrated system.

UNCLASSIFIED/FOR OFFICIAL USE ONLY

UNCLASSIFIED/FOR OFFICIAL USE ONLY



NAVFAC HAWAII
JOINT BASE PEARL HARBOR RICKMAN (RED HILL)
FY15 P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
RED HILL FIRE ALARM RFI SUMMARY

DATE: 11/21/2016
REV: 01
BY: [Redacted]
APP: [Redacted]

FA.0.1

1 2 3 4 5

D

C

B

A

D

C

B

A


STATUS AS OF SURVEYING - FRIDAY MARCH 25 2022:

Remaining areas -

1. Upper Tunnel from (b) (3) (A) intersection to Tanks 19/20 End
2. UGPH - Both Upper and Lower Levels
3. Harbor Tunnel ((b) (3) (A))
4. Fire Pump House
5. Fire Water Tanks
6. AFFF effluence Retention Tank

REPEATS

- Lower Tunnel Elec Rooms at (b) (3) (A)
- Upper Tunnel top of Tank 1 (NEED FALL PROTECTION)



PARTIAL SITE ISOMETRIC
SCALE: NTS

PARTIAL SITE ISOMETRIC
SCALE: NTS

NO. 1	NO. 2	NO. 3	NO. 4	NO. 5	NO. 6	NO. 7	NO. 8	NO. 9	NO. 10	NO. 11	NO. 12	NO. 13	NO. 14	NO. 15	NO. 16	NO. 17	NO. 18	NO. 19	NO. 20	NO. 21	NO. 22	NO. 23	NO. 24	NO. 25	NO. 26	NO. 27	NO. 28	NO. 29	NO. 30	NO. 31	NO. 32	NO. 33	NO. 34	NO. 35	NO. 36	NO. 37	NO. 38	NO. 39	NO. 40	NO. 41	NO. 42	NO. 43	NO. 44	NO. 45	NO. 46	NO. 47	NO. 48	NO. 49	NO. 50
-------	-------	-------	-------	-------	-------	-------	-------	-------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Honeywell FSG

1. TITLE: NAVAL FACILITY RESEARCH CENTER (NAFAC) HAWAII
2. PROJECT: NAVAL FACILITY RESEARCH CENTER (NAFAC) HAWAII
3. DRAWING: PARTIAL SITE ISOMETRIC
4. SHEET: FA0.6
5. DATE: 1/28/21
6. SCALE: NTS
7. DRAWN BY: [Redacted]
8. CHECKED BY: [Redacted]
9. APPROVED BY: [Redacted]

NAVAL FACILITY RESEARCH CENTER (NAFAC) HAWAII
JOINT BASE PEARL HARBOR BICKAM (RED HILL) OAHU, HAWAII
FY15 P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL SITE ISOMETRIC

FA0.6

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO MAINTAIN THE POSITION OF ALL WORK WITHIN THE AVAILABLE SPACE.
IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES


UNCLASSIFIED/FOR OFFICIAL USE ONLY

Section of tunnel from UGPH to Harbor Tunnel intersections needs to be as built.

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET FNO-3
SYSTEM NOTES	SEE SHEET FNO-3
WIRE LEGEND	SEE SHEET FT-300
EQUIPMENT #	SEE SHEET FT-500.1
EQUIPMENT #	SEE SHEET FT-512
EQUIPMENT #	SEE SHEET FT-600
EQUIPMENT #	SEE SHEET FT-700
EQUIPMENT #	SEE SHEET FT-812

NOTES	
FIRE ALARM EQUIPMENT TO BE ENCLOSED IN A CLASS 1 DIV 2 CABINET OR ENCLOSURE MANUFACTURED BY OTHERS.	

NO.	DATE	BY	DESCRIPTION
1	08/14/19	JM	ISSUED FOR PERMITS
2	08/14/19	JM	ISSUED FOR PERMITS
3	08/14/19	JM	ISSUED FOR PERMITS
4	08/14/19	JM	ISSUED FOR PERMITS
5	08/14/19	JM	ISSUED FOR PERMITS




1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO MAINTAIN THE POSITION OF ALL WORK WITHIN THE AVAILABLE SPACE.

Honeywell FSG
 1200 PEARL HARBOR BLVD, SUITE 400
 FORT BELLEVILLE, ILLINOIS 62204
 TEL: 618.438.3000 FAX: 618.438.3001
 WWW.HONEYWELLSG.COM

PROJECT NO.	130813
DATE	08/14/19
SCALE	AS SHOWN
DATE	08/14/19
SCALE	AS SHOWN
DATE	08/14/19
SCALE	AS SHOWN

Address 32 in field. All off by "one" up to Harbor Tunnel intersection



Strobes do not cover, obstructed from each other

DETECTOR ADDRESSES FROM HERE TO HARBOR TUNNEL INTERSECTION ARE OFF BY ONE

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 1 - LOWER LEVEL



SCALE 1/8" = 1'-0"



SCALE 1/8" = 1'-0"



383 FA Cab 4/5 @ PS679

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 2 - LOWER LEVEL



SCALE 1/8" = 1'-0"



SCALE 1/8" = 1'-0"

DEPARTMENT OF TRANSPORTATION
 SPECIAL INSTRUCTIONS
 HONOLULU, HAWAII
 JOINT BASE PEARL HARBOR BICKAM (RED HILL)
 FTIS P-151 (DESC 155), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 1 & 2 - LOWER LEVEL

SCALE	AS SHOWN
PROJECT NO.	130813
DATE	08/14/19
SCALE	AS SHOWN
DATE	08/14/19
SCALE	AS SHOWN

FT-101

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO MAINTAIN THE POSITION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D


C

B

A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F403
5 WET DR NOTHS	SEE SHEET F403
WET DR SIGN	SEE SHEET F403
SOP CAB #69	SEE SHEET F1616
SOP CAB #69	SEE SHEET F1616
SOP CAB #69	SEE SHEET F1620
SOP CAB #69B	SEE SHEET F162
SOP CAB #69B	SEE SHEET F1600
SOP CAB #70	SEE SHEET F1612
SOP CAB #70	SEE SHEET F1616
SOP CAB #71	SEE SHEET F1617
SOP CAB #71	SEE SHEET F1600
SOP CAB #72	SEE SHEET F1616
SOP CAB #72	SEE SHEET F1600
SOP CAB #72	SEE SHEET F1600
HWB #6	SEE SHEET F1616
YOU	SEE SHEET F1616

NOTES
FIRE ALARM EQUIPMENT TO BE ENCLOSED IN A CLASS 1 DIV 2 CABINET OR ENCLOSURE MANUFACTURED BY OTHERS.




FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 74 - LOWER LEVEL

SCALE 1" = 10'

SCALE 1" = 10'

NO.	DATE	BY	CHKD.	DESCRIPTION
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				



100% 1. ALL REQUIREMENTS OF THE HAWAIIAN FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY PARTIAL FLOOR PLAN - AREA 74 - LOWER LEVEL

NO.	DATE	BY	CHKD.	DESCRIPTION
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

NAVFAC HAWAII
JOINT BASE PEARL AND HERMES HICKAM (RED HILL) FUEL STORAGE FACILITY
UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FLOOR PLAN - AREA 74 - LOWER LEVEL

NO.	DATE	BY	CHKD.	DESCRIPTION
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

FT-142

RECORD DRAWING - SEE OTHER SHEETS FOR DIMENSIONS AND REVISIONS
F SHEET IS LESS THAN 22 X 33
REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D

C

B

A

D

C

B

A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F140.3
SYSTEM NOTES	SEE SHEET F140.3
WIRE LOGGING	SEE SHEET F140.3
EQUIPMENT #1	SEE SHEET F140.3
EQUIPMENT #2	SEE SHEET F140.3
EQUIPMENT #3	SEE SHEET F140.3
EQUIPMENT #4	SEE SHEET F140.3
EQUIPMENT #5	SEE SHEET F140.3
EQUIPMENT #6	SEE SHEET F140.3
EQUIPMENT #7	SEE SHEET F140.3

NOTES	
FIRE ALARM EQUIPMENT TO BE ENCLOSED IN A CLASS 1 DIV 2 CABINET OR ENCLOSURE MANUFACTURED BY OTHERS.	

AFFZ ZONE 1


TANK 19

ADIT 6 ABOVE

DETAIL A

DETAIL B

DETAIL C



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 75 - LOWER LEVEL


SCALE 1/8\"/>

SCALE 1/8\"/>

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROGRESS OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

NO.	DATE	DESCRIPTION
1	10/15/10	ISSUED FOR PERMIT
2	11/15/10	REVISED PER COMMENTS
3	12/15/10	REVISED PER COMMENTS
4	01/15/11	REVISED PER COMMENTS
5	02/15/11	REVISED PER COMMENTS
6	03/15/11	REVISED PER COMMENTS
7	04/15/11	REVISED PER COMMENTS
8	05/15/11	REVISED PER COMMENTS
9	06/15/11	REVISED PER COMMENTS
10	07/15/11	REVISED PER COMMENTS
11	08/15/11	REVISED PER COMMENTS
12	09/15/11	REVISED PER COMMENTS
13	10/15/11	REVISED PER COMMENTS
14	11/15/11	REVISED PER COMMENTS
15	12/15/11	REVISED PER COMMENTS
16	01/15/12	REVISED PER COMMENTS
17	02/15/12	REVISED PER COMMENTS
18	03/15/12	REVISED PER COMMENTS
19	04/15/12	REVISED PER COMMENTS
20	05/15/12	REVISED PER COMMENTS
21	06/15/12	REVISED PER COMMENTS
22	07/15/12	REVISED PER COMMENTS
23	08/15/12	REVISED PER COMMENTS
24	09/15/12	REVISED PER COMMENTS
25	10/15/12	REVISED PER COMMENTS
26	11/15/12	REVISED PER COMMENTS
27	12/15/12	REVISED PER COMMENTS
28	01/15/13	REVISED PER COMMENTS
29	02/15/13	REVISED PER COMMENTS
30	03/15/13	REVISED PER COMMENTS
31	04/15/13	REVISED PER COMMENTS
32	05/15/13	REVISED PER COMMENTS
33	06/15/13	REVISED PER COMMENTS
34	07/15/13	REVISED PER COMMENTS
35	08/15/13	REVISED PER COMMENTS
36	09/15/13	REVISED PER COMMENTS
37	10/15/13	REVISED PER COMMENTS
38	11/15/13	REVISED PER COMMENTS
39	12/15/13	REVISED PER COMMENTS
40	01/15/14	REVISED PER COMMENTS
41	02/15/14	REVISED PER COMMENTS
42	03/15/14	REVISED PER COMMENTS
43	04/15/14	REVISED PER COMMENTS
44	05/15/14	REVISED PER COMMENTS
45	06/15/14	REVISED PER COMMENTS
46	07/15/14	REVISED PER COMMENTS
47	08/15/14	REVISED PER COMMENTS
48	09/15/14	REVISED PER COMMENTS
49	10/15/14	REVISED PER COMMENTS
50	11/15/14	REVISED PER COMMENTS
51	12/15/14	REVISED PER COMMENTS
52	01/15/15	REVISED PER COMMENTS
53	02/15/15	REVISED PER COMMENTS
54	03/15/15	REVISED PER COMMENTS
55	04/15/15	REVISED PER COMMENTS
56	05/15/15	REVISED PER COMMENTS
57	06/15/15	REVISED PER COMMENTS
58	07/15/15	REVISED PER COMMENTS
59	08/15/15	REVISED PER COMMENTS
60	09/15/15	REVISED PER COMMENTS
61	10/15/15	REVISED PER COMMENTS
62	11/15/15	REVISED PER COMMENTS
63	12/15/15	REVISED PER COMMENTS
64	01/15/16	REVISED PER COMMENTS
65	02/15/16	REVISED PER COMMENTS
66	03/15/16	REVISED PER COMMENTS
67	04/15/16	REVISED PER COMMENTS
68	05/15/16	REVISED PER COMMENTS
69	06/15/16	REVISED PER COMMENTS
70	07/15/16	REVISED PER COMMENTS
71	08/15/16	REVISED PER COMMENTS
72	09/15/16	REVISED PER COMMENTS
73	10/15/16	REVISED PER COMMENTS
74	11/15/16	REVISED PER COMMENTS
75	12/15/16	REVISED PER COMMENTS
76	01/15/17	REVISED PER COMMENTS
77	02/15/17	REVISED PER COMMENTS
78	03/15/17	REVISED PER COMMENTS
79	04/15/17	REVISED PER COMMENTS
80	05/15/17	REVISED PER COMMENTS
81	06/15/17	REVISED PER COMMENTS
82	07/15/17	REVISED PER COMMENTS
83	08/15/17	REVISED PER COMMENTS
84	09/15/17	REVISED PER COMMENTS
85	10/15/17	REVISED PER COMMENTS
86	11/15/17	REVISED PER COMMENTS
87	12/15/17	REVISED PER COMMENTS
88	01/15/18	REVISED PER COMMENTS
89	02/15/18	REVISED PER COMMENTS
90	03/15/18	REVISED PER COMMENTS
91	04/15/18	REVISED PER COMMENTS
92	05/15/18	REVISED PER COMMENTS
93	06/15/18	REVISED PER COMMENTS
94	07/15/18	REVISED PER COMMENTS
95	08/15/18	REVISED PER COMMENTS
96	09/15/18	REVISED PER COMMENTS
97	10/15/18	REVISED PER COMMENTS
98	11/15/18	REVISED PER COMMENTS
99	12/15/18	REVISED PER COMMENTS
100	01/15/19	REVISED PER COMMENTS



NAVAFAC HAWAII
 JOINT BASE PEARL HARBOR BICKAM (RED HILL)
 OAHU, HAWAII
 FTIS P-155 (DESC 155), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 75 - LOWER LEVEL

DATE	07/15/10
BY	130013
REV	1501002
DATE	01/15/11

FT-143

1 2 3 4 5

D

C

B


A

D

C

B


A



REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F40.3
SYSTEM NOTES	SEE SHEET F40.3
WIRE LOGGING	SEE SHEET F40.3
NWS #	SEE SHEET F40.3
VDU	SEE SHEET F40.3

NOTES
 NETWORK WORKSTATION PC LOCATED IN THE TUNNEL TOUCH SCREEN MONITOR TO BE MOUNTED OUTSIDE OF THE BUILDING IN CLIMATE CONTROLLED ROOM. A ENCLOSURE.

NO.	DATE	BY	DESCRIPTION
1	10/11/10
2
3
4
5



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 76A (b) (3) (A) - LOWER LEVEL

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 76B (b) (3) (A) - LOWER LEVEL

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 76 (b) (3) (A) - LOWER LEVEL



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AND NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR BICKAM (RED HILL)
 FTIS P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 76 (ADIT 2) - LOWER LEVEL

SCALE: 1/8" = 1'-0"

DATE: 10/11/10

BY: [Signature]

FT-144

1 2 3 4 5

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F40.3
SYSTEM NOTES	SEE SHEET F40.3
WIRE LOGGING	SEE SHEET F40.3
EQUIPMENT	SEE SHEET F40.3
EQUIPMENT	SEE SHEET F40.3

NOTES	
FIRE ALARM EQUIPMENT TO BE ENCLOSED IN A CLASS 1 DIV 2 CABINET OR ENCLOSURE MANUFACTURED BY OTHERS.	

No visual obstruction of EXP strobes in HAZ side or on entry side except first one at entry

Non-hazardous

Class I Div 2

104 - both std SV and strobe w/EXP speaker

WATER PUMP ROOM; NO DEVICES

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 77 (b) (3) (A) - LOWER LEVEL


SCALE: 1/8" = 1'-0"



105

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 78 (b) (3) (A) - LOWER LEVEL

SCALE: 1/8" = 1'-0"



NO.	DATE	BY	CHKD.	DESCRIPTION
1	08/14/18
2	08/14/18
3	08/14/18
4	08/14/18
5	08/14/18
6	08/14/18
7	08/14/18
8	08/14/18
9	08/14/18
10	08/14/18



DATE	08/14/18
BY	...
CHKD.	...
APP.	...
REV.	...

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR BICKAM (RED HILL)
 FTIS P-155 (DESC 155), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 77 & 78 (A013) - LOWER LEVEL

DATE	08/14/18
BY	...
CHKD.	...
APP.	...
REV.	...

FT-145

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AND NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET FT-103
SYSTEM NOTES	SEE SHEET FT-103
WIRE LOGGING	SEE SHEET FT-103
NWB #S	SEE SHEET FT-109
VDU	SEE SHEET FT-109
EOP CAB # 6A	SEE SHEET FT-105
EOP CAB # 6B	SEE SHEET FT-102

NOTES
 NETWORK WORKSTATION PC LOCATED IN THE TUNNEL TOUCH SCREEN MONITOR TO BE MOUNTED OUTSIDE OF THE BUILDING IN CLIMATE CONTROLLED ROOM. A ENCLOSURE.

NO.	DATE	DESCRIPTION
1	10/1/10	ISSUED FOR CONSTRUCTION
2	10/1/10	ISSUED FOR CONSTRUCTION
3	10/1/10	ISSUED FOR CONSTRUCTION
4	10/1/10	ISSUED FOR CONSTRUCTION
5	10/1/10	ISSUED FOR CONSTRUCTION



1000 1/4" = 1'-0" (SEE DRAWING FOR DETAILS)
 HONEYWELL FSG
 1000 1/4" = 1'-0" (SEE DRAWING FOR DETAILS)

NO.	DATE	DESCRIPTION
1	10/1/10	ISSUED FOR CONSTRUCTION
2	10/1/10	ISSUED FOR CONSTRUCTION
3	10/1/10	ISSUED FOR CONSTRUCTION
4	10/1/10	ISSUED FOR CONSTRUCTION
5	10/1/10	ISSUED FOR CONSTRUCTION


1000 1/4" = 1'-0" (SEE DRAWING FOR DETAILS)
 HONEYWELL FSG
 1000 1/4" = 1'-0" (SEE DRAWING FOR DETAILS)

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR HICKAM (RED HILL)
 FT 15 P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 79 (ADT 3) - LOWER LEVEL

SCALE: 1/8" = 1'-0"
 SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"
 SCALE: 1/8" = 1'-0"


FT-146



PARTIAL FIRE PROTECTION - LOWER LEVEL - (b) (3) (A)
 SEE FIRE PROTECTION SHEET FT401 FOR DETAILS



PARTIAL FIRE ALARM SYSTEM - LOWER LEVEL (b) (3)
 (b) (3) P.R.V & F.D.C. LOCATION



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 79 (b) (3) (A) - LOWER LEVEL

THIS IS NOT TO PROPER SCALE OR ACCURATE RENDERING

SCALE: 1/8" = 1'-0"



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE...
 THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE...
 THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE...

IF SHEET IS LESS THAN 22 X 33
 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D

D

C

C

B

B

A

A

1 2 3 4 5

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F40.3
SYSTEM NOTES	SEE SHEET F40.3
WIRE LEGEND	SEE SHEET F40.3
NWB #	SEE SHEET FT 919
VDU	SEE SHEET FT 919

NOTES
 NETWORK WORKSTATION PC LOCATED IN THE TUNNEL TOUCH SCREEN MONITOR TO BE MOUNTED OUTSIDE OF THE BUILDING IN CLIMATE CONTROLLED ROOM. A ENCLOSURE.

NO.	DATE	DESCRIPTION
1	08/14/18	ISSUED FOR PERMITS
2	08/14/18	ISSUED FOR PERMITS
3	08/14/18	ISSUED FOR PERMITS
4	08/14/18	ISSUED FOR PERMITS
5	08/14/18	ISSUED FOR PERMITS



1. THE 1" = 1/8" SCALE DRAWING SHALL BE USED FOR ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED.
 2. THE 1" = 1/8" SCALE DRAWING SHALL BE USED FOR ALL DIMENSIONS UNLESS OTHERWISE SPECIFIED.








NO.	DATE	DESCRIPTION
1	08/14/18	ISSUED FOR PERMITS
2	08/14/18	ISSUED FOR PERMITS
3	08/14/18	ISSUED FOR PERMITS
4	08/14/18	ISSUED FOR PERMITS
5	08/14/18	ISSUED FOR PERMITS

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR RICKMAN (RED HILL)
 OAHU, HAWAII
 FTIS P-151 (DESC 155), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 1 & 2 (ADIT 4) - UPPER LEVEL

DATE	08/14/18
PROJECT NO.	13001.3
REV. NO.	01
REV. DATE	08/14/18
SCALE	1/8" = 1'-0"

FT-147

D
C
B
A




THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES


1 2 3 4 5

D
C
B
A

REFERENCE	
ADDRESS LABEL/CLAMP CATXN	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03
EQP CAB #106	SEE SHEET FT-01
EQP CAB #106	SEE SHEET FT-018
EQP CAB #106	SEE SHEET FT-400
EQP CAB #107	SEE SHEET FT-512
EQP CAB #107	SEE SHEET FT-617
EQP CAB #107B	SEE SHEET FT-523
EQP CAB #107B	SEE SHEET FT-617



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 3 - UPPER LEVEL



SCALE: 1/8" = 1'-0"



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO MAINTAIN THE LOCATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

NO.	DATE	BY	CHKD	DESCRIPTION
1	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
2	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
3	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
4	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
5	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
6	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
7	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
8	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
9	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
10	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION

NAVFAC HAWAII
 SPECIAL INSTRUCTIONS:
 JOINT BASE PEARL HARBOR HICKAM (RED HILL) OAHU, HAWAII
 FTIS P-155 (DESC ISS), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 3 - UPPER LEVEL


NO.	DATE	BY	CHKD	DESCRIPTION
1	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
2	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
3	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
4	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
5	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
6	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
7	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
8	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
9	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION
10	10/15/10	J. H. HARRIS	J. H. HARRIS	ISSUED FOR CONSTRUCTION

FT-148.1



REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PAD.3
SYSTEM NOTES	SEE SHEET PAD.3
WIRE LEGEND	SEE SHEET PAD.3

NO.	DATE	DESCRIPTION
1	10/14/10	ISSUED FOR PERMITS
2	10/14/10	ISSUED FOR CONSTRUCTION
3	10/14/10	ISSUED FOR AS-BUILT
4	10/14/10	ISSUED FOR RECORD



1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROGRESS OF ALL WORK WITHIN THE AVAILABLE SPACE.



PROJECT NO.	130013
DATE	10/14/10
SCALE	1/8" = 1'-0"
DRAWN BY	...
CHECKED BY	...
DATE	...

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR RICKMAN (RED HILL) OAHU, HAWAII
 FTIS P-151 (DESC ISS1), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 4 - UPPER LEVEL

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 4 - UPPER LEVEL



SCALE: 1/8" = 1'-0"



1 2 3 4 5

D

C

B

A


D

C

B

A

REFERENCE	
ADDRESS LABEL/CLARIFICATION	SEE SHEET PA0.3
SYSTEM NOTES	SEE SHEET PA0.3
WIRE LEGEND	SEE SHEET PA0.3



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 4 - UPPER LEVEL




FT10 FT1 R2

SCALE: 1/8" = 1'-0"



NO.	DATE	BY	CHKD.	DESCRIPTION
1	10/1/10	J. J. J.	J. J. J.	ISSUED FOR CONSTRUCTION
2	10/1/10	J. J. J.	J. J. J.	ISSUED FOR CONSTRUCTION
3	10/1/10	J. J. J.	J. J. J.	ISSUED FOR CONSTRUCTION
4	10/1/10	J. J. J.	J. J. J.	ISSUED FOR CONSTRUCTION
5	10/1/10	J. J. J.	J. J. J.	ISSUED FOR CONSTRUCTION



1. THE DESIGNER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.



1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.


1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

1 2 3 4 5

THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOR THE ACCURACY OF ALL INFORMATION PROVIDED TO THE CONTRACTOR.

IF SHEET IS LESS THAN 22 X 3
REDUCED PRINT - USE GRAPHIC SCALES

FT-149 2



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 5 - UPPER LEVEL

SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"



REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA0.3
SYSTEM NOTES	SEE SHEET PA0.3
WIRE LEGEND	SEE SHEET PA0.3

NO. 1	DATE	BY	CHKD.	APP'D.
1	10/11/10	J. L. HARRIS		
2	10/11/10	J. L. HARRIS		
3	10/11/10	J. L. HARRIS		
4	10/11/10	J. L. HARRIS		
5	10/11/10	J. L. HARRIS		
6	10/11/10	J. L. HARRIS		
7	10/11/10	J. L. HARRIS		
8	10/11/10	J. L. HARRIS		
9	10/11/10	J. L. HARRIS		
10	10/11/10	J. L. HARRIS		
11	10/11/10	J. L. HARRIS		
12	10/11/10	J. L. HARRIS		
13	10/11/10	J. L. HARRIS		
14	10/11/10	J. L. HARRIS		
15	10/11/10	J. L. HARRIS		
16	10/11/10	J. L. HARRIS		
17	10/11/10	J. L. HARRIS		
18	10/11/10	J. L. HARRIS		
19	10/11/10	J. L. HARRIS		
20	10/11/10	J. L. HARRIS		
21	10/11/10	J. L. HARRIS		
22	10/11/10	J. L. HARRIS		
23	10/11/10	J. L. HARRIS		
24	10/11/10	J. L. HARRIS		
25	10/11/10	J. L. HARRIS		
26	10/11/10	J. L. HARRIS		
27	10/11/10	J. L. HARRIS		
28	10/11/10	J. L. HARRIS		
29	10/11/10	J. L. HARRIS		
30	10/11/10	J. L. HARRIS		
31	10/11/10	J. L. HARRIS		
32	10/11/10	J. L. HARRIS		
33	10/11/10	J. L. HARRIS		
34	10/11/10	J. L. HARRIS		
35	10/11/10	J. L. HARRIS		
36	10/11/10	J. L. HARRIS		
37	10/11/10	J. L. HARRIS		
38	10/11/10	J. L. HARRIS		
39	10/11/10	J. L. HARRIS		
40	10/11/10	J. L. HARRIS		
41	10/11/10	J. L. HARRIS		
42	10/11/10	J. L. HARRIS		
43	10/11/10	J. L. HARRIS		
44	10/11/10	J. L. HARRIS		
45	10/11/10	J. L. HARRIS		
46	10/11/10	J. L. HARRIS		
47	10/11/10	J. L. HARRIS		
48	10/11/10	J. L. HARRIS		
49	10/11/10	J. L. HARRIS		
50	10/11/10	J. L. HARRIS		
51	10/11/10	J. L. HARRIS		
52	10/11/10	J. L. HARRIS		
53	10/11/10	J. L. HARRIS		
54	10/11/10	J. L. HARRIS		
55	10/11/10	J. L. HARRIS		
56	10/11/10	J. L. HARRIS		
57	10/11/10	J. L. HARRIS		
58	10/11/10	J. L. HARRIS		
59	10/11/10	J. L. HARRIS		
60	10/11/10	J. L. HARRIS		
61	10/11/10	J. L. HARRIS		
62	10/11/10	J. L. HARRIS		
63	10/11/10	J. L. HARRIS		
64	10/11/10	J. L. HARRIS		
65	10/11/10	J. L. HARRIS		
66	10/11/10	J. L. HARRIS		
67	10/11/10	J. L. HARRIS		
68	10/11/10	J. L. HARRIS		
69	10/11/10	J. L. HARRIS		
70	10/11/10	J. L. HARRIS		
71	10/11/10	J. L. HARRIS		
72	10/11/10	J. L. HARRIS		
73	10/11/10	J. L. HARRIS		
74	10/11/10	J. L. HARRIS		
75	10/11/10	J. L. HARRIS		
76	10/11/10	J. L. HARRIS		
77	10/11/10	J. L. HARRIS		
78	10/11/10	J. L. HARRIS		
79	10/11/10	J. L. HARRIS		
80	10/11/10	J. L. HARRIS		
81	10/11/10	J. L. HARRIS		
82	10/11/10	J. L. HARRIS		
83	10/11/10	J. L. HARRIS		
84	10/11/10	J. L. HARRIS		
85	10/11/10	J. L. HARRIS		
86	10/11/10	J. L. HARRIS		
87	10/11/10	J. L. HARRIS		
88	10/11/10	J. L. HARRIS		
89	10/11/10	J. L. HARRIS		
90	10/11/10	J. L. HARRIS		
91	10/11/10	J. L. HARRIS		
92	10/11/10	J. L. HARRIS		
93	10/11/10	J. L. HARRIS		
94	10/11/10	J. L. HARRIS		
95	10/11/10	J. L. HARRIS		
96	10/11/10	J. L. HARRIS		
97	10/11/10	J. L. HARRIS		
98	10/11/10	J. L. HARRIS		
99	10/11/10	J. L. HARRIS		
100	10/11/10	J. L. HARRIS		


FT-150.1

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AND AGENCIES TO AVOID CONFLICTS AND TO MAINTAIN THE LOCATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D
C
B
A




REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA0.3
SYSTEM NOTES	SEE SHEET PA0.3
WIRE LEGEND	SEE SHEET PA0.3

NO.	DATE	BY	CHKD.
1	10/14/10	J. J. [unclear]	[unclear]
2	10/14/10	J. J. [unclear]	[unclear]
3	10/14/10	J. J. [unclear]	[unclear]
4	10/14/10	J. J. [unclear]	[unclear]
5	10/14/10	J. J. [unclear]	[unclear]
6	10/14/10	J. J. [unclear]	[unclear]
7	10/14/10	J. J. [unclear]	[unclear]
8	10/14/10	J. J. [unclear]	[unclear]
9	10/14/10	J. J. [unclear]	[unclear]
10	10/14/10	J. J. [unclear]	[unclear]
11	10/14/10	J. J. [unclear]	[unclear]
12	10/14/10	J. J. [unclear]	[unclear]
13	10/14/10	J. J. [unclear]	[unclear]
14	10/14/10	J. J. [unclear]	[unclear]
15	10/14/10	J. J. [unclear]	[unclear]
16	10/14/10	J. J. [unclear]	[unclear]
17	10/14/10	J. J. [unclear]	[unclear]
18	10/14/10	J. J. [unclear]	[unclear]
19	10/14/10	J. J. [unclear]	[unclear]
20	10/14/10	J. J. [unclear]	[unclear]
21	10/14/10	J. J. [unclear]	[unclear]
22	10/14/10	J. J. [unclear]	[unclear]
23	10/14/10	J. J. [unclear]	[unclear]
24	10/14/10	J. J. [unclear]	[unclear]
25	10/14/10	J. J. [unclear]	[unclear]
26	10/14/10	J. J. [unclear]	[unclear]
27	10/14/10	J. J. [unclear]	[unclear]
28	10/14/10	J. J. [unclear]	[unclear]
29	10/14/10	J. J. [unclear]	[unclear]
30	10/14/10	J. J. [unclear]	[unclear]
31	10/14/10	J. J. [unclear]	[unclear]
32	10/14/10	J. J. [unclear]	[unclear]
33	10/14/10	J. J. [unclear]	[unclear]
34	10/14/10	J. J. [unclear]	[unclear]
35	10/14/10	J. J. [unclear]	[unclear]
36	10/14/10	J. J. [unclear]	[unclear]
37	10/14/10	J. J. [unclear]	[unclear]
38	10/14/10	J. J. [unclear]	[unclear]
39	10/14/10	J. J. [unclear]	[unclear]
40	10/14/10	J. J. [unclear]	[unclear]
41	10/14/10	J. J. [unclear]	[unclear]
42	10/14/10	J. J. [unclear]	[unclear]
43	10/14/10	J. J. [unclear]	[unclear]
44	10/14/10	J. J. [unclear]	[unclear]
45	10/14/10	J. J. [unclear]	[unclear]
46	10/14/10	J. J. [unclear]	[unclear]
47	10/14/10	J. J. [unclear]	[unclear]
48	10/14/10	J. J. [unclear]	[unclear]
49	10/14/10	J. J. [unclear]	[unclear]
50	10/14/10	J. J. [unclear]	[unclear]
51	10/14/10	J. J. [unclear]	[unclear]
52	10/14/10	J. J. [unclear]	[unclear]
53	10/14/10	J. J. [unclear]	[unclear]
54	10/14/10	J. J. [unclear]	[unclear]
55	10/14/10	J. J. [unclear]	[unclear]
56	10/14/10	J. J. [unclear]	[unclear]
57	10/14/10	J. J. [unclear]	[unclear]
58	10/14/10	J. J. [unclear]	[unclear]
59	10/14/10	J. J. [unclear]	[unclear]
60	10/14/10	J. J. [unclear]	[unclear]
61	10/14/10	J. J. [unclear]	[unclear]
62	10/14/10	J. J. [unclear]	[unclear]
63	10/14/10	J. J. [unclear]	[unclear]
64	10/14/10	J. J. [unclear]	[unclear]
65	10/14/10	J. J. [unclear]	[unclear]
66	10/14/10	J. J. [unclear]	[unclear]
67	10/14/10	J. J. [unclear]	[unclear]
68	10/14/10	J. J. [unclear]	[unclear]
69	10/14/10	J. J. [unclear]	[unclear]
70	10/14/10	J. J. [unclear]	[unclear]
71	10/14/10	J. J. [unclear]	[unclear]
72	10/14/10	J. J. [unclear]	[unclear]
73	10/14/10	J. J. [unclear]	[unclear]
74	10/14/10	J. J. [unclear]	[unclear]
75	10/14/10	J. J. [unclear]	[unclear]
76	10/14/10	J. J. [unclear]	[unclear]
77	10/14/10	J. J. [unclear]	[unclear]
78	10/14/10	J. J. [unclear]	[unclear]
79	10/14/10	J. J. [unclear]	[unclear]
80	10/14/10	J. J. [unclear]	[unclear]
81	10/14/10	J. J. [unclear]	[unclear]
82	10/14/10	J. J. [unclear]	[unclear]
83	10/14/10	J. J. [unclear]	[unclear]
84	10/14/10	J. J. [unclear]	[unclear]
85	10/14/10	J. J. [unclear]	[unclear]
86	10/14/10	J. J. [unclear]	[unclear]
87	10/14/10	J. J. [unclear]	[unclear]
88	10/14/10	J. J. [unclear]	[unclear]
89	10/14/10	J. J. [unclear]	[unclear]
90	10/14/10	J. J. [unclear]	[unclear]
91	10/14/10	J. J. [unclear]	[unclear]
92	10/14/10	J. J. [unclear]	[unclear]
93	10/14/10	J. J. [unclear]	[unclear]
94	10/14/10	J. J. [unclear]	[unclear]
95	10/14/10	J. J. [unclear]	[unclear]
96	10/14/10	J. J. [unclear]	[unclear]
97	10/14/10	J. J. [unclear]	[unclear]
98	10/14/10	J. J. [unclear]	[unclear]
99	10/14/10	J. J. [unclear]	[unclear]
100	10/14/10	J. J. [unclear]	[unclear]

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 5 - UPPER LEVEL



SCALE 1/8" = 1'-0"




1 2 3 4 5

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AND NEARBY STRUCTURES TO AVOID CONFLICTS AND TO MAINTAIN THE LOCATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

FT-150.2



REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA63
SYSTEM NOTES	SEE SHEET PA63
WIRE LEGEND	SEE SHEET PA63
FACP CAB #10	SEE SHEET FT 611
FACP CAB #10	SEE SHEET FT 610
FACP CAB #10	SEE SHEET FT 611
FACP CAB #10	SEE SHEET FT 616
FACP CAB #10	SEE SHEET FT 620
FACP CAB #10	SEE SHEET FT 612
FACP CAB #10	SEE SHEET FT 617
FACP CAB #1000	SEE SHEET FT 623
FACP CAB #1000	SEE SHEET FT 617

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 6 - UPPER LEVEL

SCALE 1/8" = 1'-0"

SCALE 1/8" = 1'-0"

NO.	DATE	DESCRIPTION
1	10/1/20	ISSUED FOR PERMITTING
2	10/15/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT
3	10/20/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT
4	10/25/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT
5	11/5/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT
6	11/15/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT
7	11/25/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT
8	12/5/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT
9	12/15/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT
10	12/25/20	REVISED TO ADD COMMENTS FROM THE ARCHITECT

Honeywell FSG
1000 KALANIANA'OHU BLVD, SUITE 1000
HONOLULU, HI 96813
TEL: 808.551.1000 FAX: 808.551.1001

DESIGNED BY	DATE
CHECKED BY	DATE
IN CHARGE	DATE
PROJECT NO.	DATE
DRAWING NO.	DATE
SCALE	DATE

DEPARTMENT OF THE NAVY
NAVFAC HAWAII
SPECIAL LANDMARK
ONAHU, HAWAII
JOINT BASE PEARL HARBOR BICKAM (RED HILL)
FT15 P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FLOOR PLAN - AREA 6 - UPPER LEVEL

SCALE 1/8" = 1'-0"

FT-151.1

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D

C

B

A

D

C

B

A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA0.3
SYSTEM NOTES	SEE SHEET PA0.3
WIRE LEGEND	SEE SHEET PA0.3

NO.	DATE	BY	CHKD.	DESCRIPTION
1	10/11/12
2




PROJECT NO.	...
DATE	...
BY	...
CHKD.	...
APP.	...
DATE	...

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR HICKAM (RED HILL)
 OAHU, HAWAII
 FTIS P-151 (DESC 151), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 6 - UPPER LEVEL

SCALE	1" = 10'
DATE	13001 3
BY	...
CHKD.	...
DATE	1300 01


FT-151 2



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 6 - UPPER LEVEL

SCALE 1/8" = 1'-0"

SCALE 1/8" = 1'-0"



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

1

2

3

4

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA03
SYSTEM NOTICES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03

NO.	DATE	BY	CHKD.	DESCRIPTION
1	10/11/10
2
3
4
5



100% PROTECTIVE APPROVAL FOR THE
 100% PROTECTIVE APPROVAL FOR THE
 100% PROTECTIVE APPROVAL FOR THE

DATE: 10/11/10

BY: [Signature]

CHKD: [Signature]

SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"


SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"


SCALE: 1/8" = 1'-0"

UNCLASSIFIED//FOR OFFICIAL USE ONLY

UNCLASSIFIED//FOR OFFICIAL USE ONLY



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 7 - UPPER LEVEL




THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO MAINTAIN THE POSITION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

UNCLASSIFIED//FOR OFFICIAL USE ONLY

FT-152.1

1 2 3 4 5



REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA03
SYSTEM NOTBS	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03

NO.	DATE	BY	CHKD.	DESCRIPTION
1	10/11/10
2	10/11/10
3	10/11/10
4	10/11/10
5	10/11/10




1	2	3	4	5
6	7	8	9	10
11	12	13	14	15
16	17	18	19	20
21	22	23	24	25
26	27	28	29	30
31	32	33	34	35
36	37	38	39	40
41	42	43	44	45
46	47	48	49	50
51	52	53	54	55
56	57	58	59	60
61	62	63	64	65
66	67	68	69	70
71	72	73	74	75
76	77	78	79	80
81	82	83	84	85
86	87	88	89	90
91	92	93	94	95
96	97	98	99	100

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 7 - UPPER LEVEL




SCALE 1/8" = 1'-0"



1 2 3 4 5

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AND NEARBY STRUCTURES AND TO MAINTAIN THE LOCATION OF ALL WORK WITHIN THE AVAILABLE SPACE. IF SHEET IS LESS THAN 22 X 3 REDUCED PRINT - USE GRAPHIC SCALES

FT-152 2



REFERENCE		
ADDRESS LABEL CLARIFICATION	SEE SHEET PS-153.3	
SYSTEM NOTES	SEE SHEET PS-153.3	
WIRE LEGEND	SEE SHEET PS-153.3	

NO.	DATE	BY	CHKD.	DESCRIPTION
1	10/11/10
2
3
4
5



1. THE DESIGNER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL, STATE, AND FEDERAL AUTHORITIES. THE DESIGNER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS FROM THE LOCAL, STATE, AND FEDERAL AUTHORITIES.



NO.	DATE	BY	CHKD.	DESCRIPTION
1
2
3
4
5



FIRE ALARM SYSTEM - WORK PLAN - AREA 8 - UPPER LEVEL

SCALE 1/8" = 1'-0"



NO.	DATE	BY	CHKD.	DESCRIPTION
1
2
3
4
5

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR RICKMAN (RED HILL) OAHU, HAWAII
 FT15 P-1531 (DESC 1531), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 8 - UPPER LEVEL


THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UT STATIONS AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE KNOWLEDGE OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES


1 2 3 4 5

D
C
B
A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA0.3
SYSTEM NOTBS	SEE SHEET PA0.3
WIRE LEGEND	SEE SHEET PA0.3



NO.	DATE	BY	CHKD.	REV.
1	15/09/2021
2
3
4
5



1. THE DESIGN AND CONSTRUCTION OF THIS SYSTEM SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) 72, 2019 EDITION, AND THE U.S. MARINE CORPS (MCMR) 1152.1. THE DESIGN SHALL BE SUBJECT TO THE APPROVAL OF THE COMMANDING OFFICER AND THE NAVY FACILITY ENGINEER.



FOR FURTHER INFORMATION, CONTACT THE PROJECT MANAGER AT THE ADDRESS BELOW.

PROJECT MANAGER

DATE SUBMITTED

SCALE

BY

CHKD.

DATE

PROJECT NO.

REV.

DATE

BY

CHKD.

DATE

BY

CHKD.

DATE

BY

CHKD.

FIRE ALARM SYSTEM - WORK PLAN - AREA 8 - UPPER LEVEL


SCALE 1/8" = 1'-0"



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AND NECESSARY TO AVOID CONFLICTS AND TO MAINTAIN THE LOCATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

FT-153 2



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 9 - UPPER LEVEL

SCALE: 1/8" = 1'-0"



REFERENCE		
ADDRESS LABEL CLARIFICATION	SEE SHEET PA0.3	
SYSTEM NOTIS	SEE SHEET PA0.3	
WIRE LEGEND	SEE SHEET PA0.3	

NO.	REV.	DATE	BY	CHK.	APP.
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO MAINTAIN THE POSITION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33
REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D

C


B

A

REFERENCE	
ADDRESS LABEL/CLARIFICATION	SEE SHEET PA0.3
SYSTEM NOTES	SEE SHEET PA0.3
WIRE LEGEND	SEE SHEET PA0.3

NO.	REVISION	DATE

NO.	DESCRIPTION	DATE





CLASS 1 DIV 2 AREA
CLASS 1 DIV 2 AREA

DATE	
DRAWN BY	
CHECKED BY	
DATE	
SCALE	
NO.	

NAVFAC HAWAII
SPECIAL LANDLOCK JAWAHA
OAHU, HAWAII
JOINT BASE PEARL HARBOR BICKAM (RED HILL)
FT15 P-15S1 (DESC ISS), UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FLOOR PLAN - AREA 9 - UPPER LEVEL



NO. E P	0
NO. P CON IN	13001 3
NO. AT CON IN	190 0992
DATE	1 FEB 01

FT-154 2



TANK 12

MATCHLINE - SHEET F-154.2 AREA 9
MATCHLINE - SHEET F-154.2 AREA 9



TANK 14




FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 9 - UPPER LEVEL

SCALE: 1/8" = 1'-0"




SCALE: 1/8" = 1'-0"



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

NAVFAC HAWAII 11-165



REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA03
SYSTEM NOTBS	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03
EQP CAS #102	SEE SHEET FT-513
EQP CAS #102	SEE SHEET FT-618
EQP CAS #102	SEE SHEET FT-609
EQP CAS #103	SEE SHEET FT-512
EQP CAS #103	SEE SHEET FT-617

NO.	DATE	BY	CHKD	DESCRIPTION
1	10/1/10
2	10/1/10
3	10/1/10
4	10/1/10
5	10/1/10



PROJECT NO.	130013
DATE	10/1/10
SCALE	1/8" = 1'-0"
PROJECT NAME	JOINT BASE PEARL HARBOR RICKMAN (RED HILL) FTIS P-155 (DESC 155), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PROJECT LOCATION	PARTIAL FLOOR PLAN - AREA 10 - UPPER LEVEL

DESIGNER	NAVFAC HAWAII
CHECKED	...
DATE	...
PROJECT NO.	130013
DATE	10/1/10
SCALE	1/8" = 1'-0"
PROJECT NAME	JOINT BASE PEARL HARBOR RICKMAN (RED HILL) FTIS P-155 (DESC 155), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PROJECT LOCATION	PARTIAL FLOOR PLAN - AREA 10 - UPPER LEVEL

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 10 - UPPER LEVEL

SCALE 1/8" = 1'-0"

SCALE 1/8" = 1'-0"

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK, AMONG THE SUB CONTRACTORS AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE COMPLETION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

D

C

B

A


D

C

B

A

REFERENCE	
ADDRESS LABEL/CLARIFICATION	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 10 - UPPER LEVEL



SCALE 1/8" = 1'-0"



NO.	DATE	BY	CHKD.	DESCRIPTION
1	10/1/10	J. J. J.	K. K. K.	ISSUED FOR CONSTRUCTION
2	10/1/10	J. J. J.	K. K. K.	REVISED
3	10/1/10	J. J. J.	K. K. K.	REVISED
4	10/1/10	J. J. J.	K. K. K.	REVISED
5	10/1/10	J. J. J.	K. K. K.	REVISED

1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROGRESS OF ALL WORK WITHIN THE AVAILABLE SPACE.

2. IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

NAVFAC HAWAII
 SPECIAL INSTRUCTIONS
 OAHU, HAWAII
 JOINT BASE PEARL HARBOR BICKAM (RED HILL)
 FTIS P-151 (DESC 151), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 10 - UPPER LEVEL

SCALE 1/8" = 1'-0"

DATE: 10/1/10
 DRAWN BY: J. J. J.
 CHECKED BY: K. K. K.
 PROJECT NO: 130013
 SHEET NO: 151
 OF: 151
 DATE: 10/1/10

FT-155 2


1 2 3 4 5

1 2 3 4

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F7A03
SYSTEM NOTES	SEE SHEET F7A03
WIRE LEGEND	SEE SHEET F7A03

NOTES	
NETWORK P	SEE CROSS NO. MAINWAY CLASS A DEPARTION.


D
C
B
A



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 11 - UPPER LEVEL



NO.	DATE	BY	DESCRIPTION
1	08/11/2011
2	08/11/2011
3	08/11/2011
4	08/11/2011
5	08/11/2011




FORM 1 (Rev. 11-2009)
 THE U.S. GOVERNMENT
 HAS AUTHORITY TO REPRODUCE
 AND DISTRIBUTE REPRINTS
 OF GOVERNMENT WORKS
 NOTWITHSTANDING ANY
 COPYRIGHT NOTATION
 THEREON.

NAVFAC HAWAII
 4000 SANDWICH DRIVE
 HONOLULU, HI 96819
 (808) 432-2000

PROJECT NO. 13081.3
 DRAWING NO. 13081.3-01
 SHEET NO. 01

NAVFAC HAWAII
 ARBOR HICKAM (RED HILL)
 OAHU, HI
 ESC (S51) UPGRADE FIRE SUPPRESSION
 SYSTEMS, RED HILL FUEL STORAGE FACIL
 PARTIAL FLOOR PLAN - AREA 11 - UPPER LEVEL



REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PAD3
SYSTEM NOTES	SEE SHEET PAD3
WIRE LEGEND	SEE SHEET PAD3

NO. 1	DATE	BY	CHKD.
1	01/11/2024	J. S. JONES	M. L. SMITH
2	01/11/2024	J. S. JONES	M. L. SMITH
3	01/11/2024	J. S. JONES	M. L. SMITH
4	01/11/2024	J. S. JONES	M. L. SMITH
5	01/11/2024	J. S. JONES	M. L. SMITH
6	01/11/2024	J. S. JONES	M. L. SMITH
7	01/11/2024	J. S. JONES	M. L. SMITH
8	01/11/2024	J. S. JONES	M. L. SMITH
9	01/11/2024	J. S. JONES	M. L. SMITH
10	01/11/2024	J. S. JONES	M. L. SMITH
11	01/11/2024	J. S. JONES	M. L. SMITH
12	01/11/2024	J. S. JONES	M. L. SMITH
13	01/11/2024	J. S. JONES	M. L. SMITH
14	01/11/2024	J. S. JONES	M. L. SMITH
15	01/11/2024	J. S. JONES	M. L. SMITH
16	01/11/2024	J. S. JONES	M. L. SMITH
17	01/11/2024	J. S. JONES	M. L. SMITH
18	01/11/2024	J. S. JONES	M. L. SMITH
19	01/11/2024	J. S. JONES	M. L. SMITH
20	01/11/2024	J. S. JONES	M. L. SMITH
21	01/11/2024	J. S. JONES	M. L. SMITH
22	01/11/2024	J. S. JONES	M. L. SMITH
23	01/11/2024	J. S. JONES	M. L. SMITH
24	01/11/2024	J. S. JONES	M. L. SMITH
25	01/11/2024	J. S. JONES	M. L. SMITH
26	01/11/2024	J. S. JONES	M. L. SMITH
27	01/11/2024	J. S. JONES	M. L. SMITH
28	01/11/2024	J. S. JONES	M. L. SMITH
29	01/11/2024	J. S. JONES	M. L. SMITH
30	01/11/2024	J. S. JONES	M. L. SMITH
31	01/11/2024	J. S. JONES	M. L. SMITH
32	01/11/2024	J. S. JONES	M. L. SMITH
33	01/11/2024	J. S. JONES	M. L. SMITH
34	01/11/2024	J. S. JONES	M. L. SMITH
35	01/11/2024	J. S. JONES	M. L. SMITH
36	01/11/2024	J. S. JONES	M. L. SMITH
37	01/11/2024	J. S. JONES	M. L. SMITH
38	01/11/2024	J. S. JONES	M. L. SMITH
39	01/11/2024	J. S. JONES	M. L. SMITH
40	01/11/2024	J. S. JONES	M. L. SMITH
41	01/11/2024	J. S. JONES	M. L. SMITH
42	01/11/2024	J. S. JONES	M. L. SMITH
43	01/11/2024	J. S. JONES	M. L. SMITH
44	01/11/2024	J. S. JONES	M. L. SMITH
45	01/11/2024	J. S. JONES	M. L. SMITH
46	01/11/2024	J. S. JONES	M. L. SMITH
47	01/11/2024	J. S. JONES	M. L. SMITH
48	01/11/2024	J. S. JONES	M. L. SMITH
49	01/11/2024	J. S. JONES	M. L. SMITH
50	01/11/2024	J. S. JONES	M. L. SMITH
51	01/11/2024	J. S. JONES	M. L. SMITH
52	01/11/2024	J. S. JONES	M. L. SMITH
53	01/11/2024	J. S. JONES	M. L. SMITH
54	01/11/2024	J. S. JONES	M. L. SMITH
55	01/11/2024	J. S. JONES	M. L. SMITH
56	01/11/2024	J. S. JONES	M. L. SMITH
57	01/11/2024	J. S. JONES	M. L. SMITH
58	01/11/2024	J. S. JONES	M. L. SMITH
59	01/11/2024	J. S. JONES	M. L. SMITH
60	01/11/2024	J. S. JONES	M. L. SMITH
61	01/11/2024	J. S. JONES	M. L. SMITH
62	01/11/2024	J. S. JONES	M. L. SMITH
63	01/11/2024	J. S. JONES	M. L. SMITH
64	01/11/2024	J. S. JONES	M. L. SMITH
65	01/11/2024	J. S. JONES	M. L. SMITH
66	01/11/2024	J. S. JONES	M. L. SMITH
67	01/11/2024	J. S. JONES	M. L. SMITH
68	01/11/2024	J. S. JONES	M. L. SMITH
69	01/11/2024	J. S. JONES	M. L. SMITH
70	01/11/2024	J. S. JONES	M. L. SMITH
71	01/11/2024	J. S. JONES	M. L. SMITH
72	01/11/2024	J. S. JONES	M. L. SMITH
73	01/11/2024	J. S. JONES	M. L. SMITH
74	01/11/2024	J. S. JONES	M. L. SMITH
75	01/11/2024	J. S. JONES	M. L. SMITH
76	01/11/2024	J. S. JONES	M. L. SMITH
77	01/11/2024	J. S. JONES	M. L. SMITH
78	01/11/2024	J. S. JONES	M. L. SMITH
79	01/11/2024	J. S. JONES	M. L. SMITH
80	01/11/2024	J. S. JONES	M. L. SMITH
81	01/11/2024	J. S. JONES	M. L. SMITH
82	01/11/2024	J. S. JONES	M. L. SMITH
83	01/11/2024	J. S. JONES	M. L. SMITH
84	01/11/2024	J. S. JONES	M. L. SMITH
85	01/11/2024	J. S. JONES	M. L. SMITH
86	01/11/2024	J. S. JONES	M. L. SMITH
87	01/11/2024	J. S. JONES	M. L. SMITH
88	01/11/2024	J. S. JONES	M. L. SMITH
89	01/11/2024	J. S. JONES	M. L. SMITH
90	01/11/2024	J. S. JONES	M. L. SMITH
91	01/11/2024	J. S. JONES	M. L. SMITH
92	01/11/2024	J. S. JONES	M. L. SMITH
93	01/11/2024	J. S. JONES	M. L. SMITH
94	01/11/2024	J. S. JONES	M. L. SMITH
95	01/11/2024	J. S. JONES	M. L. SMITH
96	01/11/2024	J. S. JONES	M. L. SMITH
97	01/11/2024	J. S. JONES	M. L. SMITH
98	01/11/2024	J. S. JONES	M. L. SMITH
99	01/11/2024	J. S. JONES	M. L. SMITH
100	01/11/2024	J. S. JONES	M. L. SMITH

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 11 - UPPER LEVEL

SCALE 1/8" = 1'-0"



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO MAINTAIN THE OPERATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 3 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5


D

C

B

A

REFERENCE	
ADDRESS LABEL/CLARIF. CATXON	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03
EOP CAS #100	SEE SHEET FT-012
EOP CAS #100	SEE SHEET FT-018



No detectors or any evidence of FSDs, despite penetrating elev lobby, elev shaft, and next tank door.

EMR is spkld, why no shunt trip? Check Gauger Office.

ALL EXP LIGHTS WERE OUT EXCEPT AT TOP OF TANK-EXTREMELY D M

Above grating on true ceiling

32 feet from wall

35 feet from wall

Swapped

DETAIL A

DETAIL B

DETAIL C

DETAIL D

246 Completely inaccessible for maintenance

249 DD with exposed wiring (no jacket, individual conductors); installed in an elbow; manual inside housing; UL violation

FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 12 - UPPER LEVEL

SCALE 1/8" = 1'-0"

SCALE 1/8" = 1'-0"

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROGRESS OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

NO.	REV.	DATE	DESCRIPTION
1	1	10/1/10	ISSUED FOR PERMITS
2	1	10/1/10	ISSUED FOR PERMITS
3	1	10/1/10	ISSUED FOR PERMITS
4	1	10/1/10	ISSUED FOR PERMITS
5	1	10/1/10	ISSUED FOR PERMITS
6	1	10/1/10	ISSUED FOR PERMITS
7	1	10/1/10	ISSUED FOR PERMITS
8	1	10/1/10	ISSUED FOR PERMITS
9	1	10/1/10	ISSUED FOR PERMITS
10	1	10/1/10	ISSUED FOR PERMITS


HONEYWELL FSG
 FIRE ALARM SYSTEMS
 10000 W. 10TH AVENUE, SUITE 100
 DENVER, CO 80202
 TEL: 303.751.1000 FAX: 303.751.1001
 WWW.HONEYWELLFSG.COM

NAVFAC HAWAII
 ONI, HAWAII
 JOINT BASE PEARL HARBOR BICAKA (RED HILL)
 FTIS P-155 (DESC ISS), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 12 - UPPER LEVEL

SHEET NO. FT-157.1
 OF 130
 DATE 1/10/10
 DRAWN BY J. B. HARRIS
 CHECKED BY J. B. HARRIS
 APPROVED BY J. B. HARRIS

1 2 3 4 5

REFERENCE	
ADDRESS LABEL/CLAMP CAT/CR	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03




FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 12 - UPPER LEVEL



SCALE 1/8" = 1'-0"



NO.	REV.	DATE
1	ISSUED FOR CONSTRUCTION	08/11/2010
2	FOR PERMITS	09/21/2010
3	FOR CONSTRUCTION	09/29/2010



Honeywell FSG

ON COMMAND SECURITY

ON-CALL SERVICE

24 HOURS A DAY

72 HOURS A DAY

NAVFAC HAWAII
 HARBOR BICRAM (RED HILL)
 OAHU, HAWAII
 SPECIAL HAZARDOUS ENVIRONMENTAL
 PROTECTION
 FT15 P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 12 - UPPER LEVEL

DATE	11/11/2010
BY	100 0205
NO.	01

FT-157 2

1 2 3 4 5

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UNITS AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 3 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

REF	DESCRIPTION	DATE	BY
REV 1	ISSUE FOR CONSTRUCTION	11/11/10	...
REV 2
REV 3
REV 4
REV 5
REV 6
REV 7
REV 8
REV 9
REV 10
REV 11
REV 12
REV 13
REV 14
REV 15
REV 16

NOTE: The Backgrounds for these areas are not scaled per actual conditions, devices in these areas are all shown, however all devices are shown for clarification only do not use for scaling purposes.

ADDRESS LABEL CLARIFICATION	SEE SHEET
SYSTEM NOTES	SEE SHEET FNO.3
WIRE LEGEND	SEE SHEET FNO.3
EQUIPMENT	SEE SHEET FT 510
EQUIPMENT	SEE SHEET FT 610
EQUIPMENT	SEE SHEET FT 618
EQUIPMENT	SEE SHEET FT 620
WIRE	SEE SHEET FT 519
WIRE	SEE SHEET FT 519
SIGNAL	SEE SHEET FT 520

NOTES	
A KNOX FISHER RADIO TRANSMITTER AND A MASS NOTIFICATION TRANSMITTER, BY OTHERS	
NETWORK WORKSTATION PC LOCATED IN THE TUNNEL TOUCH SCREEN MONITOR TORE MOUNTED OUTSIDE THE BUILDING IN CLIMATE CONTROLLED NEMA 2 ENCLOSURE.	

D

C

B


A

D

C


B

A




FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 13 - UPPER LEVEL - (b) (3) (A)

Spacing ranges from 20-30 feet for HDs in this segment



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 13 - UPPER LEVEL (b) (3) (A)



NO. 1	DATE	BY	CHKD.	APP'D.
1	11/11/10
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

Honeywell FSG

1. ILLUSTRATION SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) 720, 721, 722, 723, 724, 725, 726, 727, 728, 729, 730, 731, 732, 733, 734, 735, 736, 737, 738, 739, 740, 741, 742, 743, 744, 745, 746, 747, 748, 749, 750, 751, 752, 753, 754, 755, 756, 757, 758, 759, 760, 761, 762, 763, 764, 765, 766, 767, 768, 769, 770, 771, 772, 773, 774, 775, 776, 777, 778, 779, 780, 781, 782, 783, 784, 785, 786, 787, 788, 789, 790, 791, 792, 793, 794, 795, 796, 797, 798, 799, 800, 801, 802, 803, 804, 805, 806, 807, 808, 809, 810, 811, 812, 813, 814, 815, 816, 817, 818, 819, 820, 821, 822, 823, 824, 825, 826, 827, 828, 829, 830, 831, 832, 833, 834, 835, 836, 837, 838, 839, 840, 841, 842, 843, 844, 845, 846, 847, 848, 849, 850, 851, 852, 853, 854, 855, 856, 857, 858, 859, 860, 861, 862, 863, 864, 865, 866, 867, 868, 869, 870, 871, 872, 873, 874, 875, 876, 877, 878, 879, 880, 881, 882, 883, 884, 885, 886, 887, 888, 889, 890, 891, 892, 893, 894, 895, 896, 897, 898, 899, 900, 901, 902, 903, 904, 905, 906, 907, 908, 909, 910, 911, 912, 913, 914, 915, 916, 917, 918, 919, 920, 921, 922, 923, 924, 925, 926, 927, 928, 929, 930, 931, 932, 933, 934, 935, 936, 937, 938, 939, 940, 941, 942, 943, 944, 945, 946, 947, 948, 949, 950, 951, 952, 953, 954, 955, 956, 957, 958, 959, 960, 961, 962, 963, 964, 965, 966, 967, 968, 969, 970, 971, 972, 973, 974, 975, 976, 977, 978, 979, 980, 981, 982, 983, 984, 985, 986, 987, 988, 989, 990, 991, 992, 993, 994, 995, 996, 997, 998, 999, 1000

NAVFAC HAWAII

JOINT BASE PEARL HARBOR HICKAM (RED HILL), OAHU, HAWAII
 FTIS P-155 (DESC 155), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL FLOOR PLAN - AREA 13 (ADT 5) - UPPER LEVEL

SCALE: 1/2" = 1'-0"

DATE: 11/11/10

PROJECT NO: 130013

REV: 172 01

FT-158

1 2 3 4 5

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.


IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5


NOTE: The Backgrounds for these areas are not scaled per actual conditions, devices in these areas are all shown, however all devices are shown for clarification only do not use for scaling purposes.

ADDRESS LABEL CLARIFICATION	SEE SHEET FNO. 3
SYSTEM NOTES	SEE SHEET FNO. 3
WIRE LEGEND	SEE SHEET FNO. 3
EQP CAB #110	SEE SHEET FT 509
EQP CAB #110	SEE SHEET FT 611
EQP CAB #110	SEE SHEET FT 618
EQP CAB #110	SEE SHEET FT 620
WNS #7	SEE SHEET FT 519
WNS	SEE SHEET FT 519


NOTES
NETWORK WORKSTATION PC LOCATED IN THE TUNNEL TOUCH SCREEN MONITOR TO BE MOUNTED OUTSIDE OF THE BUILDING IN CLIMATE CONTROLLED ROOM. A ENCLOSED.



No SD, there is one HD on elev side of door. NOT ACCEPTABLE ALT. Only one duct and one FSD



PARTIAL FIRE ALARM SYSTEM - UPPER LEVEL (b) (3) (A)
(b) (3) (A) P.R.V & F.D.C. LOCATION



FIRE ALARM SYSTEM - PARTIAL FLOOR PLAN - AREA 14 - UPPER LEVEL - (b) (3) (A)



Not installed

NO.	DATE	DESCRIPTION
1	10/11/18	ISSUED FOR PERMIT
2	10/11/18	ISSUED FOR PERMIT
3	10/11/18	ISSUED FOR PERMIT
4	10/11/18	ISSUED FOR PERMIT
5	10/11/18	ISSUED FOR PERMIT
6	10/11/18	ISSUED FOR PERMIT
7	10/11/18	ISSUED FOR PERMIT
8	10/11/18	ISSUED FOR PERMIT
9	10/11/18	ISSUED FOR PERMIT
10	10/11/18	ISSUED FOR PERMIT



1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE SUB CONTRACTORS AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE COMPLETION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

NAVFAC HAWAII
JOINT BASE PEARL HARBOR HICKAM (RED HILL)
FTIS P-151 (DESC 155), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
PARTIAL FLOOR PLAN - AREA 14 - UPPER LEVEL - ADIT-5

SCALE: 1/8" = 1'-0"


NOT INSTALLED

FT-159

1 2 3 4 5

REFERENCE	
ADDRESS LABEL/CLAMP CATCH	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03


Completely inaccessible to survey or maintain





FIRE ALARM SYSTEM - PARTIAL PUMP HOUSE - LOWER LEVEL




268' Concrete beam running length of tunnel



FIRE ALARM SYSTEM - PARTIAL PUMP HOUSE - LOWER LEVEL



NO.	DATE	BY	CHKD.	DESCRIPTION
1	08/14/13	HTB	HTB	ISSUED FOR CONSTRUCTION
2	08/14/13	HTB	HTB	REVISED FOR CONSTRUCTION
3	08/14/13	HTB	HTB	REVISED FOR CONSTRUCTION
4	08/14/13	HTB	HTB	REVISED FOR CONSTRUCTION
5	08/14/13	HTB	HTB	REVISED FOR CONSTRUCTION



1. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE SUB CONTRACTORS AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROGRESS OF ALL WORK WITHIN THE AVAILABLE SPACE.

DESIGNED BY	HTB
CHECKED BY	HTB
DATE	08/14/13
SCALE	AS SHOWN
PROJECT NO.	130013
REVISED BY	HTB
DATE	08/14/13
SCALE	AS SHOWN

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR BICAKAI (RED HILL) OAHU, HAWAII
 FTYS P-151 (DESC 151), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL PUMP HOUSE - LOWER LEVEL

SCALE	AS SHOWN
PROJECT NO.	130013
REVISED BY	HTB
DATE	08/14/13
SCALE	AS SHOWN

FT-160

1 2 3 4 5

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE SUB CONTRACTORS AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROGRESS OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

Two strobes; both obstructed

Inaccessible for maintenance

264-267
SV behind wall of conduit

Totally inaccessible for maintenance; behind wall of conduit in crawl space

Strobes on Lower Level completely obstructed BUT this is a crawl space below open grating and not normally occupied; NOT required

Did not access; less than 2 feet head clearance

Inaccessible for maintenance

EXP JB missing cover (NOT FA system)

1 3 4 5

D

D

C


C

B

B


A

A



REFERENCE	
ADDRESS LABEL/CALF CATXN	SEE SHEET FA03
SYSTEM NOTES	SEE SHEET FA03
WIRE LEGEND	SEE SHEET FA03

NO.	REV.	DATE	DESCRIPTION
1			



NO.	REV.	DATE	DESCRIPTION
1			


NO.	REV.	DATE	DESCRIPTION
1			

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR HICKAM (RED HILL)
 FTIS P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL PUMP HOUSE - LOWER LEVEL

DATE OF ISSUE	130013
SCALE	AS SHOWN
REV. 175-D-01	1500-0073
DATE	175-D-01

FT-161
 10-1-2011

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK, AMONG THE UNITS, TO ENSURE THAT ALL TRADES ARE RECEIVING TO AVOID CONFLICTS AND TO MAINTAIN THE POSITION OF ALL WORK WITHIN THE AVAILABLE SPACE.
 IF SHEET IS LESS THAN 22 X 33
 REDUCED PRINT - USE GRAPHIC SCALES



FIRE ALARM SYSTEM - PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL
SCALE: 1/8" = 1'-0"

FIRE ALARM SYSTEM - PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL
SCALE: 1/8" = 1'-0"

REV	DATE	BY	DESCRIPTION
01			ISSUED FOR CONSTRUCTION
02			ADD TO ADDITIONAL WORK
03			ADD TO ADDITIONAL WORK
04			ADD TO ADDITIONAL WORK
05			ADD TO ADDITIONAL WORK
06			ADD TO ADDITIONAL WORK
07			ADD TO ADDITIONAL WORK
08			ADD TO ADDITIONAL WORK
09			ADD TO ADDITIONAL WORK
10			ADD TO ADDITIONAL WORK
11			ADD TO ADDITIONAL WORK
12			ADD TO ADDITIONAL WORK
13			ADD TO ADDITIONAL WORK
14			ADD TO ADDITIONAL WORK
15			ADD TO ADDITIONAL WORK
16			ADD TO ADDITIONAL WORK
17			ADD TO ADDITIONAL WORK
18			ADD TO ADDITIONAL WORK
19			ADD TO ADDITIONAL WORK
20			ADD TO ADDITIONAL WORK

REFERENCE	DESCRIPTION
ADDRESS LABEL/CLARIFICATION	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03
NAME #2	SEE SHEET PT-019
NOV	SEE SHEET PT-019
CONTROL ROOM	SEE SHEET PT-162.2
CONTROL ROOM DETAIL	SEE SHEET PT-162
FEDERAL SIGNAL DETAIL	SEE SHEET PT-021
KING FISHER DETAIL	SEE SHEET PT-020
EQP CAB #2	SEE SHEET PT-006.1
EQP CAB #2	SEE SHEET PT-003
EQP CAB #2	SEE SHEET PT-003
EQP CAB #3	SEE SHEET PT-012
EQP CAB #3	SEE SHEET PT-001
EQP CAB #3B	SEE SHEET PT-023
EQP CAB #3B	SEE SHEET PT-001

NOTES
NETWORK MONITORATION FC LOCATED IN THE TUNNEL TOUCH SCREEN MONITOR TO BE MOUNTED OUTSIDE OF THE BUILDING IN CLIMATE CONTROLLED ROOM - X ENCLOSEURE

NOTES
A KING FISHER RADIO TRANSMITTER AND A MASS NOTIFICATION TRANSMITTER BY OTHERS

NOTE
THIS FAN IS BEING CONTROLLED BY EXISTING INTERFACE BY SW ROOM

NOTE
EXISTING KING FISHER REPORTING POINTS IN THIS LOCATION THE EXISTING KING FISHER PANEL IS NOT CONTROLLED BY THE FIRE ALARM SYSTEM AND SHALL NOT BE MODIFIED

NOTE
NEW KING FISHER PANEL AND MASS NOTIFICATION PANEL LOCATED EXTERIOR (SEE SHEET PA03)

NOTE
EXISTING KING FISHER REPORTING POINTS IN THIS LOCATION THE EXISTING KING FISHER PANEL IS NOT CONTROLLED BY THE FIRE ALARM SYSTEM AND SHALL NOT BE MODIFIED

NOTE
NEW FOAM PUMP HOUSE SPRINKLER
FIRE & FOAM PUMP RUNNING
STORAGE TANK MANUAL TRIP
SPRINKLERS 4 U V
FACP MANUAL TRIP
HALON SYSTEMS (FM20)

NOTE
EXISTING KING FISHER REPORTING POINTS IN THIS LOCATION THE EXISTING KING FISHER PANEL IS NOT CONTROLLED BY THE FIRE ALARM SYSTEM AND SHALL NOT BE MODIFIED

NOTE
NEW KING FISHER PANEL AND MASS NOTIFICATION PANEL LOCATED EXTERIOR (SEE SHEET PA03)

NOTE
EXISTING KING FISHER REPORTING POINTS IN THIS LOCATION THE EXISTING KING FISHER PANEL IS NOT CONTROLLED BY THE FIRE ALARM SYSTEM AND SHALL NOT BE MODIFIED


NOTE
NEW KING FISHER PANEL AND MASS NOTIFICATION PANEL LOCATED EXTERIOR (SEE SHEET PA03)

NOTE
EXISTING KING FISHER REPORTING POINTS IN THIS LOCATION THE EXISTING KING FISHER PANEL IS NOT CONTROLLED BY THE FIRE ALARM SYSTEM AND SHALL NOT BE MODIFIED


NOTE
NEW KING FISHER PANEL AND MASS NOTIFICATION PANEL LOCATED EXTERIOR (SEE SHEET PA03)

DATE	1/1/2020
BY	1/1/2020
CHKD	1/1/2020
APPD	1/1/2020
SCALE	1/8" = 1'-0"
TITLE	FT-162.1
PROJECT	PEARL HARBOR RICKAM (RED HILL)
LOCATION	PEARL HARBOR RICKAM (RED HILL)
DESCRIPTION	UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL
DESIGNER	NAVFAC HAWAII
DATE	1/1/2020
BY	1/1/2020
CHKD	1/1/2020
APPD	1/1/2020
SCALE	1/8" = 1'-0"
TITLE	FT-162.1
PROJECT	PEARL HARBOR RICKAM (RED HILL)
LOCATION	PEARL HARBOR RICKAM (RED HILL)
DESCRIPTION	UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL
DESIGNER	NAVFAC HAWAII

1 2 3 4 5




Unable to physically verify connection



REFERENCE	
ADDRESS LABEL/CLAR. CATION	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03
FACU#1	SEE SHEET FT-501
FACU#1	SEE SHEET FT-601
FACU#1	SEE SHEET FT-602
FACU#1	SEE SHEET FT-602
FACU#1	SEE SHEET FT-601
FACU#2	SEE SHEET FT-603
RPS#1	SEE SHEET FT-516
RPS#1	SEE SHEET FT-602
INCC	SEE SHEET FT-603
INCC	SEE SHEET FT-602
INCC	SEE SHEET FT-603
NMS #3	SEE SHEET FT-519
NOU	SEE SHEET FT-519

DETAIL E



DETAIL D

(SEE SHEET FT-162.1)

FIRE ALARM SYSTEM - PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL



REV	DATE	BY	CHKD	APP'D
1	10/11/10
2	11/11/10
3	12/11/10
4	01/12/11
5	02/12/11
6	03/12/11
7	04/12/11
8	05/12/11
9	06/12/11
10	07/12/11
11	08/12/11
12	09/12/11
13	10/12/11
14	11/12/11
15	12/12/11

NAVFAC HAWAII

JOINT BASE PEARL HARBOR HICKAM (RED HILL) OAHU, HAWAII

FTIS P-155 (DESC 155), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL

SCALE: 1" = 1'-0"


DATE: 11/10/10

REV: 172, 0, 01

FT-162.2

1 2 3 4 5


REFERENCE	
ADDRESS LABEL/CLAMP CATCH	SEE SHEET PA-03
SYSTEM NOTES	SEE SHEET PA-03
WIRE LEGEND	SEE SHEET PA-03
EQP CAB #1	SEE SHEET FT-00
EQP CAB #1B	SEE SHEET FT-002
EQP CAB #1S	SEE SHEET FT-005
EQP CAB #1S	SEE SHEET FT-002




FIRE ALARM SYSTEM- PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL

SCALE: 1/8" = 1'-0"

SCALE: 1/8" = 1'-0"



NO.	DATE	BY	CHKD.	DESCRIPTION
1	10/11/10
2



1. REV. 1 - 10/11/10 - REVISED PER...
 2. REV. 2 - 10/11/10 - REVISED PER...
 3. REV. 3 - 10/11/10 - REVISED PER...
 4. REV. 4 - 10/11/10 - REVISED PER...
 5. REV. 5 - 10/11/10 - REVISED PER...

NO.	DATE
1	10/11/10
2	...
3	...
4	...
5	...

NAVAL FACILITY DESIGN CENTER HONOLULU HONOLULU, HAWAII	ONAHI, HAWAII FTYS P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL
DATE: 10/11/10 PROJECT NO: 130013 REV: 01 DATE: 10/11/10	FT-163 10/11/10

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK, AMONG THE...
 THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK, AMONG THE...
 THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK, AMONG THE...

IF SHEET IS LESS THAN 22 X 33
 REDUCED PRINT - USE GRAPHIC SCALES

1 2 3 4 5

REFERENCE	
ADDRESS LABEL/CLEAR CATYON	SEE SHEET PA0.3
SYSTEM NOTES	SEE SHEET PA0.3
WIRE LEGEND	SEE SHEET PA0.3

D

C

B


A

D


C

B


A



FIRE ALARM SYSTEM - PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL




FIRE ALARM SYSTEM - PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AND AGENCIES INVOLVED TO AVOID CONFLICTS AND TO MAINTAIN THE LOCATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

NO.	DATE	BY	CHKD.	APP'D.
1	08/14/13	J. J. [Signature]	[Signature]	[Signature]
2	08/14/13	[Signature]	[Signature]	[Signature]
3	08/14/13	[Signature]	[Signature]	[Signature]
4	08/14/13	[Signature]	[Signature]	[Signature]
5	08/14/13	[Signature]	[Signature]	[Signature]



NO.	DATE	BY	CHKD.	APP'D.
1	08/14/13	[Signature]	[Signature]	[Signature]
2	08/14/13	[Signature]	[Signature]	[Signature]
3	08/14/13	[Signature]	[Signature]	[Signature]
4	08/14/13	[Signature]	[Signature]	[Signature]
5	08/14/13	[Signature]	[Signature]	[Signature]

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR BICKAM (RED HILL)
 FTYS P-15ST (DESC ISS), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 PARTIAL PUMP HOUSE (PH-59) - UPPER LEVEL

NO.	DATE	BY	CHKD.	APP'D.
1	08/14/13	[Signature]	[Signature]	[Signature]
2	08/14/13	[Signature]	[Signature]	[Signature]
3	08/14/13	[Signature]	[Signature]	[Signature]
4	08/14/13	[Signature]	[Signature]	[Signature]
5	08/14/13	[Signature]	[Signature]	[Signature]

FT-164

1 2 3 4 5

D

D

C

C

B

B

A

A

REV	DATE	DESCRIPTION
1	11/20/2014	ISSUED FOR PERMITTING
2	11/20/2014	REVISED TO ADD COMMENTS
3	11/20/2014	REVISED TO ADD COMMENTS
4	11/20/2014	REVISED TO ADD COMMENTS
5	11/20/2014	REVISED TO ADD COMMENTS
6	11/20/2014	REVISED TO ADD COMMENTS
7	11/20/2014	REVISED TO ADD COMMENTS
8	11/20/2014	REVISED TO ADD COMMENTS
9	11/20/2014	REVISED TO ADD COMMENTS
10	11/20/2014	REVISED TO ADD COMMENTS
11	11/20/2014	REVISED TO ADD COMMENTS
12	11/20/2014	REVISED TO ADD COMMENTS
13	11/20/2014	REVISED TO ADD COMMENTS
14	11/20/2014	REVISED TO ADD COMMENTS
15	11/20/2014	REVISED TO ADD COMMENTS
16	11/20/2014	REVISED TO ADD COMMENTS
17	11/20/2014	REVISED TO ADD COMMENTS
18	11/20/2014	REVISED TO ADD COMMENTS
19	11/20/2014	REVISED TO ADD COMMENTS
20	11/20/2014	REVISED TO ADD COMMENTS

- NOTES
- TO MONITOR LOW AIR PRESSURE SWITCH
 - TO MONITOR HIGH AIR PRESSURE SWITCH
 - TO MONITOR GENERATOR ON PHASE REVERSAL
 - TO MONITOR GENERATOR ON RUNNING
 - TO MONITOR GENERATOR ON PUMP LOSS
 - TO MONITOR FIRE PUMP FOR RUNNING, LOSS OF PHASE, PHASE REVERSAL, AND CONTROLLER CONNECTED TO ALTERNATE SOURCE
 - AFF PUMP MOTOR RUNNING, AFF PUMP CONTROLLER SWITCH IN OFF OR MANUAL POSITION, AFF PUMP CONTROLLER TROUBLE, AFF PUMP PHASE REVERSAL, POWER LOSS/PHASE LOSS/NO T OR OVERLOAD, AFF TANK LEVEL LOW
 - TO 120VAC DEDICATED BRANCH. NOTE: BREAKER REQUIRES A LOCK
 - TO MONITOR AFF JOCKEY PUMP CONTROLLER
 - TO MONITOR FIRE PUMP JOCKEY PUMP CONTROLLER

REFERENCE

ADDRESS LABEL/CLEAR CATXN	SEE SHEET
SYSTEM NOTES	SEE SHEET PA0.3
WIRE LEGEND	SEE SHEET PA0.3
EQP CAS #72	SEE SHEET FT-015
EQP CAS #72	SEE SHEET FT-009
EQP CAS #72	SEE SHEET FT-009
EQP CAS #711	SEE SHEET FT-008
EQP CAS #711	SEE SHEET FT-018
EQP CAS #711	SEE SHEET FT-020

NO.	DATE	BY	CHKD	APP'D	DATE
1	11/20/2014
2	11/20/2014
3	11/20/2014
4	11/20/2014
5	11/20/2014
6	11/20/2014
7	11/20/2014
8	11/20/2014
9	11/20/2014
10	11/20/2014



NO.	DATE	BY	CHKD	APP'D	DATE
1	11/20/2014
2	11/20/2014
3	11/20/2014
4	11/20/2014
5	11/20/2014
6	11/20/2014
7	11/20/2014
8	11/20/2014
9	11/20/2014
10	11/20/2014

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR BICAKA (RED HILL)
 FT15 P-151 (DESC 155), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 FLOOR PLAN - FIRE PUMP BUILDING

FIRE ALARM SYSTEM - FLOOR PLAN - FIRE PUMP BUILDING



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK, AMONG THE TRADES AS NECESSARY TO AVOID CONFLICTS AND TO INSURE THE PROTECTION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 33 REDUCED PRINT - USE GRAPHIC SCALES

EP 2FP, ckt 9 is FACP, padlocked breaker

397-401 DDC-8

384/385
 FA Cab 111 w/ fan, damper, and door status/control
 386-394 Copy of MT003 (Amendment 0002, dated 11/20/2014)
 Overall Red Hill Ventilation System


395
 Undocumented N2 Generator, tied to FA system

Lower than 90° to top; appx. 86°

Tied to FA conduit, can't verify it is monitored (typ. 2)

Cannot confirm presence/number of modules

Lower than 90° to top; appx. 86°



1 2 3 4 5


1 2 3 4 5

D


C

B

A



As built should state where it is located.



KING FISHER RADIO


© King. Mbo. wmlwsked.02.01.01

Part Name	Part No.	Qty	Notes
NEW PCH-5	MBO-2	1	MAINT OR FA PANEL
MBO-2	MBO-2	1	2MMCO-REF
KING FISHER RAD INTERFACE PANEL	KING FISHER RAD INTERFACE PANEL	1	
ANTENNA	ANTENNA	1	
120V AC	120V AC	1	

© King. Mbo. wmlwsked.02.01.01

Part Name	Part No.	Qty	Notes
M1	M1	1	Radio Module 1
M2	M2	1	Radio Module 2
M3	M3	1	Radio Module 3
M4	M4	1	Radio Module 4

NO.	REV.	DATE	BY
1	1	10/10/00	...



10/10/00 10:00 AM



NO.	REV.	DATE	BY
1	1	10/10/00	...

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR BICKAM (RED HILL)
 FTIS P-151 (DESC 151), UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 KING FISHER RADIO & CALL BOX
 DETAIL

1 2 3 4 5

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE SUB CONTRACTORS AND SHALL BE RESPONSIBLE TO AVOID CONFLICTS AND TO MAINTAIN THE POSITION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 3
 REDUCED PRINT - USE GRAPHIC SCALES

FT-520

1 2 3 4 5

D

C

B


A

D

C

B

A



FEDERAL SIGNAL ULTRAVOICE REMOTE INTERFACE CONTROLLER

DC POWER CONNECTION
 THE BATTERY IS LOCATED UNDER THE CONTROL BOARD MOUNTING PLATE AND IS PRE-WIRED TO THE UVRI. CONNECT DC POWER TO THE UVRI BY PLUGGING IN THE TWO POSITION POWER CONNECTOR AT JP3 ON THE MOTHERBOARD AS SHOWN IN FIGURE 7.5.

AUDIO OUTPUT CONNECTION
 CONNECT THE AUDIO OUTPUT OF THE UVRI TO THE AUDIO INPUT OF THE REMOTE FIRE ALARM SYSTEM AT JP4 ON THE MOTHERBOARD AS SHOWN IN FIGURE 7.5 BELOW. ADJUST THE AUDIO OUTPUT LEVEL POTENTIOMETER TO THE DESIRED OUTPUT LEVEL. THE POT IS LOCATED NEXT TO THE AUDIO SIGNAL OUTPUT CONNECTOR (JP4).

120 VAC ELECTRICAL SERVICE WIRING
 1. INSTALL A DEDICATED 15A CIRCUIT BREAKER IN AN EXISTING BREAKER PANEL OR INSTALL A NEW BREAKER PANEL IF NECESSARY FOR THE UVRI.

2. INSTALL CONDUIT FROM THE BREAKER PANEL TO THE 1/2" CONDUIT ENTRANCE IN THE BOTTOM OF THE UVRI.

3. ROUTE USER-SUPPLIED 12-14 AWG WIRES (1 BLACK, 1 WHITE, 1 GREEN) THROUGH THE CONDUIT FROM THE UVRI CABINET AND THE FUSED BREAKER PANEL.

4. CONNECT THE WHITE NEUTRAL WIRE FROM THE BREAKER PANEL NEUTRAL TO THE DIN RAIL MOUNTED TERMINAL BLOCK LABELED L1 IN THE UVRI CONTROL CABINET.

5. CONNECT THE BLACK LINE WIRE FROM THE 15A BREAKER TO THE DIN RAIL MOUNTED TERMINAL BLOCK LABELED L2 IN THE UVRI CONTROL CABINET.


6. OPTIONALLY, CONNECT A GREEN GROUND WIRE FROM THE BREAKER PANEL EARTH GROUND TO THE GREEN GROUND BLOCK IN THE UVRI CABINET OR RUN A GROUND LEAD FROM THE EXTERNAL 1/4" GROUND STUD ON THE UVRI CABINET TO EARTH GROUND.

GROUNDING REQUIREMENTS
 1. THE UVRI CABINET MUST BE PROPERLY CONNECTED TO AN EARTH GROUND. THE CABINET CONTAINS AN EXTERNAL 1/4" GROUND STUD FOR MAKING THIS CONNECTION.
 2. EXTERNALLY INSTALLED ANTENNAS REQUIRE A DEDICATED GROUND TO EITHER A GROUND ROD OR BUILDING STEEL BELOW GRADE IN ADDITION TO THE UVRI CABINET GROUND.

DIN RAIL TERMINAL BLOCKS
 THESE POINTS PROVIDE A CONVENIENT LOCATION FOR MAKING THE AC POWER CONNECTIONS. A SMALL SCREWDRIVER MUST BE PUSHED INTO THE SQUARE OPENING IN THE TERMINAL BLOCK TO OPEN THE CONTACT OF THE BLOCK. WITH THE WIRE INSERTED, THE BLOCK WILL CLAMP THE WIRE WITH A SPRING-LOADED CONNECTION WHEN THE SCREWDRIVER IS REMOVED FROM THE TERMINAL BLOCK. EACH TERMINAL BLOCK ACCEPTS BARE 12-14 AWG WIRE. THE TERMINAL BLOCKS ARE LABELED L1 AND L2.


OMNI ANTENNA INSTALLATION
 FIBERGLASS, NO TUNE MODELS
 1. SEE FIGURE 7.7 FOR REFERENCE. INSTALL ANTENNA (USING INSTALLATION BRACKET OR EQUIVALENT) AS HIGH AS POSSIBLE. THAT THE ANTENNA CABLE AND OBSTACLES WILL ALLOW, AND INSTALL ON SIDE OF POLE CLOSEST TO THE RECEIVING STATION. AT MINIMUM, MOUNT OMNI ANTENNA 4 FEET ABOVE THE EARTH, ABOVE THE TUNNEL.

NOTE A OBJECTS AROUND THE ANTENNA WILL AFFECT THE ANTENNA. KEEP ANTENNA AWAY FROM OBJECTS.
 2. ENSURE ANTENNA CABLE CONNECTIONS ARE TIGHT. SEAL ALL CONNECTION POINTS WITH HEAT SHRINK OR TAPE AND SEAL WITH SCOTCH COAT, OR EQUIVALENT.



INTERFACE FEDERAL SIGNAL ULTRAVOICE CONTROLLER AUDIO OUTPUT TO E3 PHONE PAGE AUDIO INPUT
 (REQUIRES A CONTACT CLOSURE INPUT FROM ULTRAVOICE CONTROLLER TO AN AOM TEL MODULE WIRING TO AN IN-TO-CONTROL ACTIVATION)

USE NO. 10 AWG COPPER AS GROUND WIRE FOR BOTH MAST AND LEAD IN
 SECURE LEAD IN CABLE FROM ANTENNA TO ANTENNA DISCHARGE UNIT AND MAST GROUND WIRES TO HOUSE WITH STAND OFF INSULATORS, SPACED FROM 4 FEET TO 6 FEET APART.
 MOUNT ANTENNA DISCHARGE UNITS AS CLOSE TO WHERE LEAD IN CABLE ENTERS HOUSE AS POSSIBLE



DITEK DTK-TSS4D
 NOTE FOR OPTIMUM PERFORMANCE OF THE REMOTE INTERFACER SEE ARTICLES 100 AND 200 OF THE MFG. HANDBOOK FOR MANUFACTURER AND ILS REQUIREMENTS.

REPLACE WITH A 200 OHM THERMISTOR (R2) IN THE AOM TEL MODULE. THE THERMISTOR SHOULD BE LABELED. NOTE: 200 OHM THERMISTOR IS NOT SUPPLIED BY THE MANUFACTURER.


CAPACITORS FROM 2R-C AOM TEL FILTERS WITHOUT THE RESISTORS. NOTE: THESE ARE NON-POLARIZED. ISOLATED AUDIO TO AOM TEL.

AUDIO INPUT (1 VOLT PEAK TO PEAK MAX)

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE UTILITIES AND IS RESPONSIBLE TO AVOID CONTACTS AND TO MAINTAIN THE LOCATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

IF SHEET IS LESS THAN 22 X 3 REDUCED PRINT - USE GRAPHIC SCALES

NO.	REV.	DATE	BY	CHKD.
1	01	01/01/01		



1	2	3	4	5	6	7	8	9	10


Honeywell		FSG	
FEDERAL SIGNAL ULTRAVOICE REMOTE INTERFACE CONTROLLER			
NO.	REV.	DATE	BY
1	01	01/01/01	

NAVFAC HAWAII	OMHU, HAWAII
JOINT BASE PEARL HARBOR RICKMAN (RED HILL)	FY15 P-1551 (DESC 1551), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
FEDERAL SIGNAL ULTRAVOICE REMOTE INTERFACE CONTROLLER	

NO.	REV.	DATE	BY	CHKD.
1	01	01/01/01		

FT-521

DOC OR EQUIP ION	Wiring	Wiring	A DOC	A DOC
	ADD	DEL	Change	Del/Re-Add
NO	NO	NO	NO	NO
MMI-10F #1	MM-10F	MM-10F	MM-10F	MM-10F
MMI-10F #2	MM-10F	MM-10F	MM-10F	MM-10F
MMI-10F #3	MM-10F	MM-10F	MM-10F	MM-10F
MMI-10F #4	MM-10F	MM-10F	MM-10F	MM-10F
MMI-10F #5	MM-10F	MM-10F	MM-10F	MM-10F
MMO-6RF #1	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF
MMO-6RF #2	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF
MMO-6RF #3	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF
MMO-6RF #4	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF
MMO-6RF #5	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF



REFERENCE	
DDP CAB #8	SEE SHEET FT 4 6
DDP CAB #9	SEE SHEET FT 407
DDP CAB #90	SEE SHEET FT 4 2
DDP CAB #90	SEE SHEET FT 609

NAV FACILITY DESIGN/INSTALLATION COMMAND

NAVFAC HAWAII

JOINT BASE PEARL HARBOR RICKMAN (RED HILL) OAHU, HAWAII

FT15 P-155 (DESC 155), UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

EQUIPMENT CABINET WIRING DIAGRAM

EQP CAB #468 & 698 - NEMA-3R ENCLOSURE


DEPARTMENT OF THE NAVY

DATE: 13001 3

SCALE: 1/8" = 1'-0"

REV: 01

FT-524



Wire Designation	A	Wiring	Wiring	Wiring	Wiring	Wiring	Wiring
	ADD	DEL	DEL	DEL	DEL	DEL	DEL
	NO	NO	NO	NO	NO	NO	NO
MMI-10F #1	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F
MMI-10F #2	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F
MMI-10F #3	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F
MMI-10F #4	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F
MMI-10F #5	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F	MM-10F
MMO-6RF #1	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF
MMO-6RF #2	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF
MMO-6RF #3	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF
MMO-6RF #4	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF
MMO-6RF #5	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF	MMO-6RF

Wires present, address, no label


REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA63
SYSTEM NOTES	SEE SHEET PA63
WIRE LEGEND	SEE SHEET PA63
PACU#1	SEE SHEET FT-162.2
PACU#1	SEE SHEET FT-601
PACU#2	SEE SHEET FT-162.2
PACU#3	SEE SHEET FT-602
PACU#4	SEE SHEET FT-603

D

C

B

A



NO. 1	NO. 2	NO. 3	NO. 4	NO. 5	NO. 6	NO. 7	NO. 8	NO. 9	NO. 10	NO. 11	NO. 12	NO. 13	NO. 14	NO. 15	NO. 16	NO. 17	NO. 18	NO. 19	NO. 20

100% TESTED AND APPROVED FOR THE U.S. NAVY AND U.S. MARINE CORPS

Honeywell FSG

100% TESTED AND APPROVED FOR THE U.S. NAVY AND U.S. MARINE CORPS

DATE: 01/11/18

BY: [Signature]

FOR: [Signature]

NO. 1

NO. 2

NO. 3

NO. 4

NO. 5

NO. 6

NO. 7

NO. 8

NO. 9

NO. 10

NO. 11

NO. 12

NO. 13

NO. 14

NO. 15

NO. 16

NO. 17

NO. 18

NO. 19


NO. 20


3 THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE NAVY AND MARINE CORPS TO AVOID CONFLICT AND TO ENSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

4 F. SHEET IS LESS THAN 22 X 3 REDUCED PRINT - USE GRAPHIC SCALES

1 TO FEDERAL SIGNAL ULTRA VOICE

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F403
SYSTEM NOTES	SEE SHEET F403
WIRE LEGEND	SEE SHEET F403
EQ P CAB #1	SEE SHEET FT-103
EQ P CAB #1	SEE SHEET FT-100
EQ P CAB #1B	SEE SHEET FT-103
EQ P CAB #1B	SEE SHEET FT-106
RPS #1	SEE SHEET FT-102.2
RPS #1	SEE SHEET FT-106
RPO	SEE SHEET FT-102.2
RPO	SEE SHEET FT-100
RPO	SEE SHEET FT-100



REVISIONS	
NO.	DATE
1	08/11/10
2	08/11/10
3	08/11/10
4	08/11/10
5	08/11/10
6	08/11/10
7	08/11/10
8	08/11/10
9	08/11/10
10	08/11/10
DRAWN: [Name]	
CHECKED: [Name]	
DATE: 08/11/10	
SCALE: 1/8" = 1'-0"	
SHEET NO. 01	
PROJECT NO. FT-100	
	
HONEYWELL FSG 1001 N. MILWAUKEE AVENUE, SUITE 100 MILWAUKEE, WI 53233-4000 TEL: 414.766.5000 FAX: 414.766.5001 WWW.HONEYWELLFSG.COM	
NAUFAC HAWAII 1001 N. MILWAUKEE AVENUE, SUITE 100 MILWAUKEE, WI 53233-4000 TEL: 414.766.5000 FAX: 414.766.5001 WWW.NAUFAC.HAWAII.MIL	
TITLE: FT-100 PROJECT: FT-100 SHEET: FT-100 SCALE: 1/8" = 1'-0"	
DATE: 08/11/10 DRAWN: [Name] CHECKED: [Name] DATE: 08/11/10	
SHEET NO. 01 PROJECT NO. FT-100	

3 THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE TRADES NECESSARY TO AVOID CONFLICT AND TO INSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

4 F SHEET IS LESS THAN 22 X 34 REDUCED PRINT - USE GRAPHIC SCALES

D

C

B

A


D

C


B

A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F403
SYSTEM NOTES	SEE SHEET F403
WIRE LEGEND	SEE SHEET F403
EQ P CABLE #2	SEE SHEET FT-161
EQ P CABLE #2	SEE SHEET FT-160.1
EQ P CABLE #2	SEE SHEET FT-160
EQ P CABLE #3	SEE SHEET FT-161
EQ P CABLE #3	SEE SHEET FT-160
EQ P CABLE #3B	SEE SHEET FT-161
EQ P CABLE #3B	SEE SHEET FT-160



100% TESTED AND APPROVED BY:
 HONEYWELL
 FSG
 11111 11111 11111 11111 11111 11111
 77777777



1

2

3

4

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AND NECESSARY TO AVOID CONFLICT AND TO INSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

F-SHEET IS LESS THAN 22 X 3
 REDUCED PRINT - USE GRAPHIC SCALES

NAVFAC HAWAII
 NAVAL FACILITY ENGINEERING COMMAND
 JOINT BASE PEARL HARBOR HICKAM (RED HILL)
 OAHU, HAWAII
 FTIS P-151 (DEC 155) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 FIRE ALARM RISER DIAGRAM - SLC - UPPER PUMP HOUSE

SCALE: 1/8" = 1'-0"
 13001-3
 01

FT-603

D


C

B

A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PAB3
SYSTEM NOTES	SEE SHEET PAB3
WIRE LEGEND	SEE SHEET PAB3
EDP CAN #1	SEE SHEET FT-600.1
EDP CAN #2	SEE SHEET FT-600.2
EDP CAN #3	SEE SHEET FT-600.3
EDP CAN #4	SEE SHEET FT-600.4

NO.	DATE	BY	CHKD.	APP.	DESCRIPTION
1	08/11/2011
2	08/11/2011
3	08/11/2011
4	08/11/2011
5	08/11/2011
6	08/11/2011
7	08/11/2011
8	08/11/2011
9	08/11/2011
10	08/11/2011



100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.



100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.


NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.



(SEE SHEET FT-600)

(SEE SHEET FT-600)

1

2

3

4

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE NAVY CONTRACTORS AND NECESSARY TO AVOID CONFLICTS AND TO INSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

F SHEET IS LESS THAN 22 X 3
REDUCED PRINT - USE GRAPHIC SCALES

FT-604

NO. 100% TEST AND RECORDING REQUIRED. ALL TESTS TO BE CONDUCTED IN THE PRESENCE OF THE CONTRACTOR.

D


C

B

A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F403
SYSTEM NOTES	SEE SHEET F403
WIRE LEGEND	SEE SHEET F403
EDP CAN #00	SEE SHEET FT-12
EDP CAN #01	SEE SHEET FT-000.3
EDP CAN #02	SEE SHEET FT-01
EDP CAN #03	SEE SHEET FT-000

NO. 1	NO. 2	NO. 3	NO. 4	NO. 5	NO. 6	NO. 7	NO. 8	NO. 9	NO. 10



100% TEST REPORT APPROVED BY:
 11/11/10 11:58 AM
 7/29/2010

NO. 1
 NO. 2
 NO. 3
 NO. 4
 NO. 5
 NO. 6
 NO. 7
 NO. 8
 NO. 9
 NO. 10

NAVFAC HAWAII
 JOINT BASE PEARL HARBOR HICKAM (RED HILL) CANAL HAWAII
 FT-5-151 (DESC 151) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 FIRE ALARM RISER DIAGRAM - SLG - LOWER TUNNEL

FT-606

(SEE SHEET FT-600)

(SEE SHEET FT-601)

1 THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AND NECESSARY TO AVOID CONFLICT AND TO INSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

2

3

4 F-SHEET IS LESS THAN 22 X 3
 REDUCED PRINT - USE GRAPHIC SCALES

D


C

B

A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PAD
SYSTEM NOTES	SEE SHEET PAD
TUNE LOGS	SEE SHEET PAD
EQ OP CAS #9	SEE SHEET PT-137
EQ OP CAS #9	SEE SHEET PT-0041
EQ OP CAS #9	SEE SHEET PT-614
EQ OP CAS #9	SEE SHEET PT-625

NO.	DATE	BY	CHKD	DESCRIPTION
1	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
2	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
3	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
4	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
5	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION



10/15/11 11:45 AM CONSTRUCTION
 J. H. HARRIS, PROJECT ENGINEER
 J. H. HARRIS, PROJECT ENGINEER



NO.	DATE	BY	CHKD	DESCRIPTION
1	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
2	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
3	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
4	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
5	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION

NO.	DATE	BY	CHKD	DESCRIPTION
1	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
2	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
3	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
4	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
5	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION


NAVFAC HAWAII
 NAVAL AIR FORCE ENGINEERING COMMAND
 CHARL HAWAII
 LOWT BASE REAR HARBOR HICKAM (RED HILL)
 FY14-P-1551 (DESC-1551) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

FIRE ALARM RISER DIAGRAM - SIC - LOWER TUNNEL

NO.	DATE	BY	CHKD	DESCRIPTION
1	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
2	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
3	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
4	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
5	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION

NO.	DATE	BY	CHKD	DESCRIPTION
1	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
2	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
3	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
4	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION
5	10/15/11	J. H. HARRIS		ISSUED FOR CONSTRUCTION

27-00
 10/15/11



IF SHEET IS LESS THAN 22 X 31 REDUCED PRINT - USE GRAPHIC SCALES



D

C

B



A

D



C

B



A

NO. OF	NO.	DESCRIPTION
NO. 1	1	NO. 1
NO. 2	2	NO. 2
NO. 3	3	NO. 3
NO. 4	4	NO. 4
NO. 5	5	NO. 5
NO. 6	6	NO. 6
NO. 7	7	NO. 7
NO. 8	8	NO. 8
NO. 9	9	NO. 9
NO. 10	10	NO. 10
NO. 11	11	NO. 11
NO. 12	12	NO. 12
NO. 13	13	NO. 13
NO. 14	14	NO. 14
NO. 15	15	NO. 15
NO. 16	16	NO. 16
NO. 17	17	NO. 17
NO. 18	18	NO. 18
NO. 19	19	NO. 19
NO. 20	20	NO. 20
NO. 21	21	NO. 21
NO. 22	22	NO. 22
NO. 23	23	NO. 23
NO. 24	24	NO. 24
NO. 25	25	NO. 25
NO. 26	26	NO. 26
NO. 27	27	NO. 27
NO. 28	28	NO. 28
NO. 29	29	NO. 29
NO. 30	30	NO. 30
NO. 31	31	NO. 31
NO. 32	32	NO. 32
NO. 33	33	NO. 33
NO. 34	34	NO. 34
NO. 35	35	NO. 35
NO. 36	36	NO. 36
NO. 37	37	NO. 37
NO. 38	38	NO. 38
NO. 39	39	NO. 39
NO. 40	40	NO. 40
NO. 41	41	NO. 41
NO. 42	42	NO. 42
NO. 43	43	NO. 43
NO. 44	44	NO. 44
NO. 45	45	NO. 45
NO. 46	46	NO. 46
NO. 47	47	NO. 47
NO. 48	48	NO. 48
NO. 49	49	NO. 49
NO. 50	50	NO. 50
NO. 51	51	NO. 51
NO. 52	52	NO. 52
NO. 53	53	NO. 53
NO. 54	54	NO. 54
NO. 55	55	NO. 55
NO. 56	56	NO. 56
NO. 57	57	NO. 57
NO. 58	58	NO. 58
NO. 59	59	NO. 59
NO. 60	60	NO. 60
NO. 61	61	NO. 61
NO. 62	62	NO. 62
NO. 63	63	NO. 63
NO. 64	64	NO. 64
NO. 65	65	NO. 65
NO. 66	66	NO. 66
NO. 67	67	NO. 67
NO. 68	68	NO. 68
NO. 69	69	NO. 69
NO. 70	70	NO. 70
NO. 71	71	NO. 71
NO. 72	72	NO. 72
NO. 73	73	NO. 73
NO. 74	74	NO. 74
NO. 75	75	NO. 75
NO. 76	76	NO. 76
NO. 77	77	NO. 77
NO. 78	78	NO. 78
NO. 79	79	NO. 79
NO. 80	80	NO. 80
NO. 81	81	NO. 81
NO. 82	82	NO. 82
NO. 83	83	NO. 83
NO. 84	84	NO. 84
NO. 85	85	NO. 85
NO. 86	86	NO. 86
NO. 87	87	NO. 87
NO. 88	88	NO. 88
NO. 89	89	NO. 89
NO. 90	90	NO. 90
NO. 91	91	NO. 91
NO. 92	92	NO. 92
NO. 93	93	NO. 93
NO. 94	94	NO. 94
NO. 95	95	NO. 95
NO. 96	96	NO. 96
NO. 97	97	NO. 97
NO. 98	98	NO. 98
NO. 99	99	NO. 99
NO. 100	100	NO. 100

ADDRESS LABEL CLARIFICATION	REFERENCE
ADDRESS LABEL CLARIFICATION	SEE SHEET PAB3
SYSTEM NOTES	SEE SHEET PAB3
WIRE LEGEND	SEE SHEET PAB3
BDP CAN #59	SEE SHEET FT-139
BDP CAN #60	SEE SHEET FT-517
BDP CAN #61	SEE SHEET FT-137
BDP CAN #62	SEE SHEET FT-517
BDP CAN #63	SEE SHEET FT-139
BDP CAN #64	SEE SHEET FT-517
BDP CAN #65	SEE SHEET FT-139
BDP CAN #66	SEE SHEET FT-517
BDP CAN #67	SEE SHEET FT-139
BDP CAN #68	SEE SHEET FT-517
BDP CAN #69	SEE SHEET FT-139
BDP CAN #70	SEE SHEET FT-517
BDP CAN #71	SEE SHEET FT-139
BDP CAN #72	SEE SHEET FT-517
BDP CAN #73	SEE SHEET FT-139
BDP CAN #74	SEE SHEET FT-517
BDP CAN #75	SEE SHEET FT-139
BDP CAN #76	SEE SHEET FT-517
BDP CAN #77	SEE SHEET FT-139
BDP CAN #78	SEE SHEET FT-517
BDP CAN #79	SEE SHEET FT-139
BDP CAN #80	SEE SHEET FT-517
BDP CAN #81	SEE SHEET FT-139
BDP CAN #82	SEE SHEET FT-517
BDP CAN #83	SEE SHEET FT-139
BDP CAN #84	SEE SHEET FT-517
BDP CAN #85	SEE SHEET FT-139
BDP CAN #86	SEE SHEET FT-517
BDP CAN #87	SEE SHEET FT-139
BDP CAN #88	SEE SHEET FT-517
BDP CAN #89	SEE SHEET FT-139
BDP CAN #90	SEE SHEET FT-517
BDP CAN #91	SEE SHEET FT-139
BDP CAN #92	SEE SHEET FT-517
BDP CAN #93	SEE SHEET FT-139
BDP CAN #94	SEE SHEET FT-517
BDP CAN #95	SEE SHEET FT-139
BDP CAN #96	SEE SHEET FT-517
BDP CAN #97	SEE SHEET FT-139
BDP CAN #98	SEE SHEET FT-517
BDP CAN #99	SEE SHEET FT-139
BDP CAN #100	SEE SHEET FT-517

PROJECT NO. 130013

DATE: 11/11/11

PROJECT NAME: NAUFAC HAWAII

CLIENT: HONOLULU POLICE DEPARTMENT

DESIGNER: HONEYWELL FSG

SCALE: 1/8" = 1'-0"

PROJECT LOCATION: HONOLULU, HI

PROJECT PHASE: DESIGN

PROJECT START DATE: 11/11/11

PROJECT END DATE: 11/11/11

PROJECT STATUS: DESIGN

PROJECT DESCRIPTION: JOINT BASE PEARL HARBOR HICKAM (RED HILL) CANAL TUNNEL FT-15-151 (DEC 15-1) UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY AND FIRE ALARM RISER DIAGRAM - SLG - LOWER TUNNEL

PROJECT NO. 130013

DATE: 11/11/11

PROJECT NAME: NAUFAC HAWAII

CLIENT: HONOLULU POLICE DEPARTMENT

DESIGNER: HONEYWELL FSG

SCALE: 1/8" = 1'-0"

PROJECT LOCATION: HONOLULU, HI

PROJECT PHASE: DESIGN

PROJECT START DATE: 11/11/11

PROJECT END DATE: 11/11/11

PROJECT STATUS: DESIGN

PROJECT DESCRIPTION: JOINT BASE PEARL HARBOR HICKAM (RED HILL) CANAL TUNNEL FT-15-151 (DEC 15-1) UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY AND FIRE ALARM RISER DIAGRAM - SLG - LOWER TUNNEL

1

2

3

4

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AND BE RESPONSIBLE TO AVOID CONFLICTS AND TO ENSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.


F-SHEET IS LESS THAN 22" X 3" REDUCED PRINT - USE GRAPHIC SCALES

FT-609

1 2 3 4 5

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03
EQP CAB #101	SEE SHEET PT-106
EQP CAB #101	SEE SHEET PT-610
EQP CAB #101	SEE SHEET PT-609
EQP CAB #101	SEE SHEET PT-611
EQP CAB #110	SEE SHEET PT-106
EQP CAB #110	SEE SHEET PT-609
EQP CAB #110	SEE SHEET PT-616
EQP CAB #110	SEE SHEET PT-609

NO.	REVISION	DATE	BY	CHKD
1	ISSUED FOR CONSTRUCTION	12/15/11
2
3
4
5




100% DESIGN AND CONSTRUCTION DOCUMENTS
 100% DESIGN AND CONSTRUCTION DOCUMENTS
 100% DESIGN AND CONSTRUCTION DOCUMENTS

NO.	REVISION	DATE	BY	CHKD
1	ISSUED FOR CONSTRUCTION	12/15/11
2
3
4
5

PROJECT: NAVFAC HAWAII
 JOINT BASE PEARL AND HERMES HICKAM (RED HILL)
 FT-611 (ISSUE 151) UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY AND WIRE FIRE ALARM RISER DIAGRAM - S.C. - UPPER TUNNEL

FT-611



1 2 3 4 5

THE CON'OR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AS NECESSARY. COORDINATION IS SAID TO BE THE RESPONSIBILITY OF THE CONTRACTOR.

IF SHEET IS LESS THAN 22 X 34 REDUCED PRINT - USE GRAPHIC SCALES

D


C

B

A

REFERENCE	
ADDRESS LABEL CLARIFICATION	SEE SHEET F603
SYSTEM NOTES	SEE SHEET F603
WIRE LEGEND	SEE SHEET F603
EOP CAB#	SEE SHEET FT-401
EOP CAB#	SEE SHEET FT-6061
EOP CAB#	SEE SHEET FT-620
EOP CAB#	SEE SHEET FT-401
EOP CAB#	SEE SHEET FT-60
EOP CAB#	SEE SHEET FT-403
EOP CAB#	SEE SHEET FT-609
EOP CAB#	SEE SHEET FT-60
EOP CAB#	SEE SHEET FT-620
EOP CAB#	SEE SHEET FT-403
EOP CAB#	SEE SHEET FT-40
EOP CAB#	SEE SHEET FT-6061
EOP CAB#	SEE SHEET FT-620
EOP CAB#	SEE SHEET FT-40
EOP CAB#	SEE SHEET FT-60
EOP CAB#	SEE SHEET FT-60

REFERENCE	
EOP CAB#10	SEE SHEET FT-106
EOP CAB#10	SEE SHEET FT-506.1
EOP CAB#10	SEE SHEET FT-620
EOP CAB#11	SEE SHEET FT-106
EOP CAB#11	SEE SHEET FT-506
EOP CAB#12	SEE SHEET FT-107
EOP CAB#12	SEE SHEET FT-506.1
EOP CAB#12	SEE SHEET FT-620
EOP CAB#13	SEE SHEET FT-107
EOP CAB#13	SEE SHEET FT-506
EOP CAB#1	SEE SHEET FT-106
EOP CAB#1	SEE SHEET FT-506.1
EOP CAB#1	SEE SHEET FT-620
EOP CAB#15	SEE SHEET FT-106
EOP CAB#15	SEE SHEET FT-506



1

2


3

4

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AND NECESSARY TO AVOID CONFLICT AND TO INSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

F-SHEET IS LESS THAN 22 X 3 REDUCED PRINT - USE GRAPHIC SCALES

NO.	DATE	BY	CHKD.	APP'D.
1	11/11/11
2
3
4


 NAVFAC HAWAII
 JOINT BASE PEARL HARBOR HICKAM (RED HILL) CANAL HAWAII
 FTIS P-151 (DESG 1551) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 FIRE ALARM RISER DIAGRAM - MAC - LOWER TUNNEL

SCALE: R 0
 R 00 R 01 R 02
 13001 3
 0000 R 000 R 01
 01
 01

FT-612
 01 02

D

C

B

A

D


C

B


A

REFERENCE	
ADDRESS LABEL CLAMP POSITION	SEE SHEET F603
SYSTEM NOTES	SEE SHEET F603
WIRE LEGEND	SEE SHEET F603
EQP CAB #16	SEE SHEET FT 410
EQP CAB #16	SEE SHEET FT 6061
EQP CAB #16	SEE SHEET FT 620
EQP CAB #17	SEE SHEET FT 410
EQP CAB #17	SEE SHEET FT 600
EQP CAB #17	SEE SHEET FT 611
EQP CAB #19	SEE SHEET FT 6061
EQP CAB #19	SEE SHEET FT 620
EQP CAB #19	SEE SHEET FT 411
EQP CAB #19	SEE SHEET FT 600
EQP CAB #19	SEE SHEET FT 412
EQP CAB #20	SEE SHEET FT 6061
EQP CAB #20	SEE SHEET FT 620
EQP CAB #21	SEE SHEET FT 412
EQP CAB #21	SEE SHEET FT 600
EQP CAB #22	SEE SHEET FT 413
EQP CAB #22	SEE SHEET FT 6062
EQP CAB #22	SEE SHEET FT 605
EQP CAB #22	SEE SHEET FT 620
EQP CAB #23	SEE SHEET FT 413
EQP CAB #23	SEE SHEET FT 600

REFERENCE	
EQP CAB #2	SEE SHEET FT 115
EQP CAB #2	SEE SHEET FT 506.1
EQP CAB #2	SEE SHEET FT 600
EQP CAB #5	SEE SHEET FT 115
EQP CAB #5	SEE SHEET FT 500
EQP CAB #5	SEE SHEET FT 116
EQP CAB #5	SEE SHEET FT 506.1
EQP CAB #7	SEE SHEET FT 600
EQP CAB #7	SEE SHEET FT 115
EQP CAB #7	SEE SHEET FT 500
EQP CAB #8	SEE SHEET FT 117
EQP CAB #8	SEE SHEET FT 500
EQP CAB #8	SEE SHEET FT 506.1
EQP CAB #8	SEE SHEET FT 600
EQP CAB #8	SEE SHEET FT 117
EQP CAB #8	SEE SHEET FT 500
EQP CAB #8	SEE SHEET FT 506.1
EQP CAB #8	SEE SHEET FT 600
EQP CAB #8	SEE SHEET FT 115
EQP CAB #8	SEE SHEET FT 506.1
EQP CAB #8	SEE SHEET FT 600
EQP CAB #8	SEE SHEET FT 115
EQP CAB #8	SEE SHEET FT 500



(SEE SHEET FT 612)




(SEE SHEET FT 41)

3 THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICT AND TO INSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

4 F-SHEET IS LESS THAN 22 X 3 REDUCED PRINT - USE GRAPHIC SCALES

NO. 1	NO. 2	NO. 3	NO. 4	NO. 5	NO. 6	NO. 7	NO. 8	NO. 9	NO. 10



USER: J. W. HONEYWELL INC.
 REVISION: HONEYWELL
 DATE: 08/11/00

Honeywell FSG

DATE	08/11/00
BY	J. W. HONEYWELL
CHECKED	J. W. HONEYWELL
APPROVED	J. W. HONEYWELL
SCALE	AS SHOWN

NAVFAC HAWAII
 JOINT BASE PEARL AND HERMES (RED HILL)
 CANAL HAWAII
 FTIS P-151 (DEC 155) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 FIRE ALARM RISER DIAGRAM - NAAC - LOWER TUNNEL


SCALE: H 0
 DATE: 08/11/00
 DRAWING NO: 13001.3
 SHEET NO: 01

D


C

B

A



1 2



3 4

REFERENCE	
ADDRESS LABEL CLAMP POSITION	SEE SHEET PA03
SYSTEM NOTES	SEE SHEET PA03
WIRE LEGEND	SEE SHEET PA03
EQP CAR #02	SEE SHEET FT 420
EQP CAR #02	SEE SHEET FT 6061
EQP CAR #02	SEE SHEET FT 620
EQP CAR #03	SEE SHEET FT 420
EQP CAR #03	SEE SHEET FT 60
EQP CAR #03	SEE SHEET FT 421
EQP CAR #05	SEE SHEET FT 6061
EQP CAR #01	SEE SHEET FT 620
EQP CAR #05	SEE SHEET FT 421
EQP CAR #05	SEE SHEET FT 60
EQP CAR #05	SEE SHEET FT 422
EQP CAR #06	SEE SHEET FT 6061
EQP CAR #06	SEE SHEET FT 620
EQP CAR #07	SEE SHEET FT 422
EQP CAR #07	SEE SHEET FT 60

REFERENCE	
RQP CAR #08	SEE SHEET FT 112
RQP CAR #08	SEE SHEET FT 500.3
RQP CAR #08	SEE SHEET FT 600
RQP CAR #09	SEE SHEET FT 420
RQP CAR #09	SEE SHEET FT 500
RQP CAR # 0	SEE SHEET FT 125
RQP CAR # 0	SEE SHEET FT 500.1
RQP CAR # 0	SEE SHEET FT 600
RQP CAR # 1	SEE SHEET FT 125
RQP CAR # 1	SEE SHEET FT 500
RQP CAR # 2	SEE SHEET FT 500.1
RQP CAR # 2	SEE SHEET FT 600
RQP CAR # 3	SEE SHEET FT 125
RQP CAR # 3	SEE SHEET FT 500

NO.	REV.	DESCRIPTION	DATE


NAVFAC HAWAII

NAVAL FACILITY OF ENGINEERING COMMAND
 NAVAL AIR STATION
 HONOLULU, HAWAII 96814

JOINT BASE PEARL HARBOR HICKAM (RED HILL) CANAL HAWAII
 FTIS P-151 (DEC 155) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 FIRE ALARM RISER DIAGRAM - NAAC - LOWER TUNNEL

DRAWN BY	CHECKED BY	DATE

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AS NECESSARY TO AVOID CONFLICT AND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.



REFERENCE	
ADDRESS LABEL CLAMP POSITION	SEE SHEET FT-603
SYSTEM NOTES	SEE SHEET FT-603
WIRE LEGEND	SEE SHEET FT-603
EQP CAB #	SEE SHEET FT-427
EQP CAB #	SEE SHEET FT-606
EQP CAB #	SEE SHEET FT-600
EQP CAB #	SEE SHEET FT-427
EQP CAB #	SEE SHEET FT-60
EQP CAB #	SEE SHEET FT-428
EQP CAB #	SEE SHEET FT-602
EQP CAB #	SEE SHEET FT-600
EQP CAB #	SEE SHEET FT-428
EQP CAB #	SEE SHEET FT-600
EQP CAB #	SEE SHEET FT-428
EQP CAB #	SEE SHEET FT-429
EQP CAB #	SEE SHEET FT-606
EQP CAB #	SEE SHEET FT-600

REFERENCE	
EQP CAB #	SEE SHEET FT-129
EQP CAB #	SEE SHEET FT-50
EQP CAB #	SEE SHEET FT-131
EQP CAB #	SEE SHEET FT-606
EQP CAB #	SEE SHEET FT-600
EQP CAB #	SEE SHEET FT-131
EQP CAB #	SEE SHEET FT-50
EQP CAB #	SEE SHEET FT-132
EQP CAB #	SEE SHEET FT-606
EQP CAB #	SEE SHEET FT-600
EQP CAB #	SEE SHEET FT-132
EQP CAB #	SEE SHEET FT-132
EQP CAB #	SEE SHEET FT-506
EQP CAB #	SEE SHEET FT-600
EQP CAB #	SEE SHEET FT-132
EQP CAB #	SEE SHEET FT-50
EQP CAB #	SEE SHEET FT-132
EQP CAB #	SEE SHEET FT-13
EQP CAB #	SEE SHEET FT-506
EQP CAB #	SEE SHEET FT-600
EQP CAB #	SEE SHEET FT-132
EQP CAB #	SEE SHEET FT-13
EQP CAB #	SEE SHEET FT-506
EQP CAB #	SEE SHEET FT-600

NAVFAC HAWAII
NAVFAC HAWAII ENGINEERING DIVISION
NAVFAC HAWAII
NAVFAC HAWAII

**JOINT BASE PEARL HARBOR HICKAM (RED HILL) CANAL HAWAII
FY15 P-151 (DEC 155) UPGRADE FIRE SUPPRESSION
AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
FIRE ALARM RISER DIAGRAM - NAAC - LOWER TUNNEL**

SCALE: R 0
R 00 R 00 R 00 13001 3
CONC: R 03P R 00
NAAC 00000000
DATE: 22 0 01

FT-615

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AND BE RESPONSIBLE TO AVOID CONFLICT AND TO ENSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

F-SHEET IS LESS THAN 22 X 3
REDUCED PRINT - USE GRAPHIC SCALES

D

C



B

A

REFERENCE	REFERENCE	REFERENCE
ADDRESS LABEL CLARIFICATION SEE SHEET NA.3	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.1.1
SYSTEM NOTES SEE SHEET NA.3	EOP CAB #69 SEE SHEET FT.438	EOP CAB #69 SEE SHEET FT.506.1
WIRE LEGEND SEE SHEET NA.3	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.600
EOP CAB #65 SEE SHEET FT.13	EOP CAB #69 SEE SHEET FT.440	EOP CAB #67 SEE SHEET FT.1
EOP CAB #65 SEE SHEET FT.100.1	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.100
EOP CAB #65 SEE SHEET FT.400	EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.1.2
EOP CAB #65 SEE SHEET FT.13	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.519
EOP CAB #65 SEE SHEET FT.90	EOP CAB #69 SEE SHEET FT.465	EOP CAB #69 SEE SHEET FT.600
EOP CAB #65 SEE SHEET FT.136	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.1.2
EOP CAB #65 SEE SHEET FT.100.1	EOP CAB #69 SEE SHEET FT.466.1	EOP CAB #69 SEE SHEET FT.512
EOP CAB #67 SEE SHEET FT.600	EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.1.3
EOP CAB #67 SEE SHEET FT.136	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.600
EOP CAB #67 SEE SHEET FT.90	EOP CAB #69 SEE SHEET FT.460	EOP CAB #67 SEE SHEET FT.1.3
EOP CAB #67 SEE SHEET FT.136	EOP CAB #69 SEE SHEET FT.439	EOP CAB #67 SEE SHEET FT.506.1
EOP CAB #67 SEE SHEET FT.90	EOP CAB #69 SEE SHEET FT.465	EOP CAB #67 SEE SHEET FT.600

REFERENCE	REFERENCE	REFERENCE
EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.1.1
EOP CAB #69 SEE SHEET FT.438	EOP CAB #69 SEE SHEET FT.438	EOP CAB #69 SEE SHEET FT.506.1
EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.600
EOP CAB #69 SEE SHEET FT.440	EOP CAB #69 SEE SHEET FT.440	EOP CAB #67 SEE SHEET FT.1
EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.100
EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.1.2
EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.519
EOP CAB #69 SEE SHEET FT.465	EOP CAB #69 SEE SHEET FT.465	EOP CAB #69 SEE SHEET FT.600
EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.1.2
EOP CAB #69 SEE SHEET FT.466.1	EOP CAB #69 SEE SHEET FT.466.1	EOP CAB #69 SEE SHEET FT.512
EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.1.3
EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.600
EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.460	EOP CAB #67 SEE SHEET FT.1.3
EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.439	EOP CAB #67 SEE SHEET FT.506.1
EOP CAB #69 SEE SHEET FT.465	EOP CAB #69 SEE SHEET FT.465	EOP CAB #67 SEE SHEET FT.600

REFERENCE	REFERENCE	REFERENCE
EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.1.1
EOP CAB #69 SEE SHEET FT.438	EOP CAB #69 SEE SHEET FT.438	EOP CAB #69 SEE SHEET FT.506.1
EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.600
EOP CAB #69 SEE SHEET FT.440	EOP CAB #69 SEE SHEET FT.440	EOP CAB #67 SEE SHEET FT.1
EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.100
EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.1.2
EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.437	EOP CAB #69 SEE SHEET FT.519
EOP CAB #69 SEE SHEET FT.465	EOP CAB #69 SEE SHEET FT.465	EOP CAB #69 SEE SHEET FT.600
EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.1.2
EOP CAB #69 SEE SHEET FT.466.1	EOP CAB #69 SEE SHEET FT.466.1	EOP CAB #69 SEE SHEET FT.512
EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.1.3
EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.600
EOP CAB #69 SEE SHEET FT.460	EOP CAB #69 SEE SHEET FT.460	EOP CAB #67 SEE SHEET FT.1.3
EOP CAB #69 SEE SHEET FT.439	EOP CAB #69 SEE SHEET FT.439	EOP CAB #67 SEE SHEET FT.506.1
EOP CAB #69 SEE SHEET FT.465	EOP CAB #69 SEE SHEET FT.465	EOP CAB #67 SEE SHEET FT.600




THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE VARIOUS TRADES AND BE RESPONSIBLE TO AVOID CONFLICT OF HAND TO INSURE THE INSTALLATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

F-SHEET IS LESS THAN 22 X 3
REDUCED PRINT - USE GRAPHIC SCALES


NO.	DATE	DESCRIPTION
1	11/11/11	ISSUED FOR PERMIT
2	11/11/11	ISSUED FOR PERMIT
3	11/11/11	ISSUED FOR PERMIT
4	11/11/11	ISSUED FOR PERMIT
5	11/11/11	ISSUED FOR PERMIT
6	11/11/11	ISSUED FOR PERMIT
7	11/11/11	ISSUED FOR PERMIT
8	11/11/11	ISSUED FOR PERMIT
9	11/11/11	ISSUED FOR PERMIT
10	11/11/11	ISSUED FOR PERMIT


 NAVFAC HAWAII
 NAVAL FACILITY ENGINEERING COMMAND
 JOINT BASE PEARL HARBOR HICKAM (RED HILL) CANAL HAWAII
 FTIS P-151 (DEC 155) UPGRADE FIRE SUPPRESSION
 AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY
 FIRE ALARM RISER DIAGRAM - MAC - LOWER TUNNEL
 SCALE: 1" = 10'
 SHEET NO. 225 OF 01
 DATE: 11/11/11
 DRAWN BY: [Name]
 CHECKED BY: [Name]
 APPROVED BY: [Name]



THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE MANY SUBTRADES AS NECESSARY TO AVOID CONFLICT AND TO INSURE THE REGULATION OF ALL WORK WITHIN THE AVAILABLE SPACE.

F SHEET IS LESS THAN 22 X 3 REDUCED PRINT - USE GRAPHIC SCALES



CODE	DESCRIPTION	DATE
001	ISSUE	11/11/2020
002	REVISED	11/11/2020
003	REVISED	11/11/2020
004	REVISED	11/11/2020

- SYSTEM NOTES**
- ① TO MONITOR LOW AIR PRESSURE SWITCH
 - ② TO MONITOR HIGH AIR PRESSURE SWITCH
 - ③ TO MONITOR GENERATOR PHASE REVERSAL
 - ④ TO MONITOR GENERATOR RUNNING
 - ⑤ TO MONITOR GENERATOR POWER LOSS
 - ⑥ TO MONITOR FIRE PUMP FOR RUNNING, LOSS OF PHASE, PHASE REVERSAL, AND CONTROLLER CONNECTED TO ALTERNATE SOURCE
 - ⑦ TO MONITOR AIR/F PUMP FOR RUNNING, LOSS OF PHASE, PHASE REVERSAL, AND CONTROLLER CONNECTED TO ALTERNATE SOURCE
 - ⑧ TO 12VDC DEDICATED BRANCH NOTE: BATTERY REQ REB A LOCK

REFERENCE

ADDRESS LABEL CLARIFICATION	SEE SHEET F403
SYSTEM NOTES	SEE SHEET F403
WIRE LEGEND	SEE SHEET F403
EQ P-CAB #11	SEE SHEET F8-001
EQ P-CAB #11	SEE SHEET FT-600
EQ P-CAB #11	SEE SHEET FT-603



12571 104 182 (REVISED) HONEYWELL
 REVISED: 11/11/2020 09:00
 BY: J. K. HARRIS

Honeywell FSG

12571 104 182 (REVISED) HONEYWELL
 REVISED: 11/11/2020 09:00
 BY: J. K. HARRIS

NO	DATE	DESCRIPTION
1	11/11/2020	ISSUE
2	11/11/2020	REVISED
3	11/11/2020	REVISED
4	11/11/2020	REVISED
5	11/11/2020	REVISED

NAVFAC HAWAII

JOINT BASE PEARL HARBOR HICKAM (RED HILL) CAMP HAWAII

FT IS-151 (DEC 155) UPGRADE FIRE SUPPRESSION AND VENTILATION SYSTEMS, RED HILL FUEL STORAGE FACILITY

FIRE ALARM RISER DIAGRAM - NAC & SLC - FIRE PUMP BUILDING

REVISED: 11/11/2020 09:00

NO	DATE	DESCRIPTION
1	11/11/2020	ISSUE
2	11/11/2020	REVISED
3	11/11/2020	REVISED
4	11/11/2020	REVISED
5	11/11/2020	REVISED

NO: 228-01-01


FT-619

D

C

B

A



1

2


3

4

THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING THE WORK AMONG THE NAVY CONTRACTORS AND SHALL BE RESPONSIBLE TO AVOID CONFLICT AND TO ENSURE THE RETENTION OF ALL WORK WITHIN THE AVAILABLE SPACE.

F SHEET IS LESS THAN 22 X 3
REDUCED PRINT - USE GRAPHIC SCALES

NO.	DESCRIPTION	DATE
1	ISSUED FOR CONSTRUCTION	01/11/11
2	REVISED FOR TUNNEL AREA 10	01/11/11
3	REVISED FOR TUNNEL AREA 11	01/11/11
4	REVISED FOR TUNNEL AREA 12	01/11/11
5	REVISED FOR TUNNEL AREA 13	01/11/11
6	REVISED FOR TUNNEL AREA 9	01/11/11



11257.1 - 11257.20000000
REVISED FOR TUNNEL AREA 10
REVISED FOR TUNNEL AREA 11
REVISED FOR TUNNEL AREA 12
REVISED FOR TUNNEL AREA 13
REVISED FOR TUNNEL AREA 9




NO.	DESCRIPTION	DATE
1	ISSUED FOR CONSTRUCTION	01/11/11
2	REVISED FOR TUNNEL AREA 10	01/11/11
3	REVISED FOR TUNNEL AREA 11	01/11/11
4	REVISED FOR TUNNEL AREA 12	01/11/11
5	REVISED FOR TUNNEL AREA 13	01/11/11
6	REVISED FOR TUNNEL AREA 9	01/11/11

NAVFAC HAWAII
JCS/NAFAC HAWAII/NAFAC HAWAII
NAVY FACILITY ENGINEERING COMMAND
11257.1 - 11257.20000000
REVISED FOR TUNNEL AREA 10
REVISED FOR TUNNEL AREA 11
REVISED FOR TUNNEL AREA 12
REVISED FOR TUNNEL AREA 13
REVISED FOR TUNNEL AREA 9


NAVFAC HAWAII
JCS/NAFAC HAWAII/NAFAC HAWAII
NAVY FACILITY ENGINEERING COMMAND
11257.1 - 11257.20000000
REVISED FOR TUNNEL AREA 10
REVISED FOR TUNNEL AREA 11
REVISED FOR TUNNEL AREA 12
REVISED FOR TUNNEL AREA 13
REVISED FOR TUNNEL AREA 9

NAVY FACILITY ENGINEERING COMMAND
11257.1 - 11257.20000000
REVISED FOR TUNNEL AREA 10
REVISED FOR TUNNEL AREA 11
REVISED FOR TUNNEL AREA 12
REVISED FOR TUNNEL AREA 13
REVISED FOR TUNNEL AREA 9

FT-620
11257.1 - 11257.20000000
REVISED FOR TUNNEL AREA 10
REVISED FOR TUNNEL AREA 11
REVISED FOR TUNNEL AREA 12
REVISED FOR TUNNEL AREA 13
REVISED FOR TUNNEL AREA 9



NO.	DATE	BY	CHKD.	APP'D.
1	10/15/10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
2	10/15/10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
3	10/15/10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS
4	10/15/10	J. H. HARRIS	J. H. HARRIS	J. H. HARRIS



100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

Honeywell
FSG

100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

100% COMPLETE
 100% COMPLETE
 100% COMPLETE
 100% COMPLETE

This page is intentionally left blank.

