

The results set forth herein are provided by SGS North America Inc.

*e-Hardcopy 2.0*  
*Automated Report*

## Technical Report for

**AECOM, INC.**

**N6274223F0104 RH Fire Suppression System**

**60697810**

**SGS Job Number: FC3558**

**Sampling Date: 03/17/23**



### Report to:

**AECOM, Inc**  
**7595 Technology Way**  
**Denver, CO 80237**  
**katie.abbott@aecom.com; mark.kromis@aecom.com;**  
**watson.tanji@aecom.com; kristin.rutherford@aecom.com**  
**ATTN: Katie Abbott**

**Total number of pages in report: 35**



Test results contained within this data package meet the requirements of the National Environmental Laboratory Accreditation Program and/or state specific certification programs as applicable.

**Norm Farmer**  
**Technical Director**

**Client Service contact: Elvin Kumar 407-425-6700**

Certifications: FL(E83510), LA(03051), KS(E-10327), NC(573), NJ(FL002), NY(12022), SC(96038001)  
DoD ELAP(ANAB L2229), AZ(AZ0806), CA(2937), TX(T104704404), PA(68-03573), VA(460177),  
AL, AK, AR, CT, IA, KY, MA, MI, MS, ND, NH, NV, OK, OR, IL, UT, VT, WA, WI, WV

This report shall not be reproduced, except in its entirety, without the written approval of SGS.  
Test results relate only to samples analyzed.

# Table of Contents

-1-

<b>Section 1: Sample Summary</b> .....	<b>3</b>
<b>Section 2: Case Narrative/Conformance Summary</b> .....	<b>4</b>
<b>Section 3: Summary of Hits</b> .....	<b>5</b>
<b>Section 4: Sample Results</b> .....	<b>6</b>
<b>4.1:</b> FC3558-1: AF-RHMW17-WGN01LF-2303W2 .....	7
<b>4.2:</b> FC3558-2: AF-RHMW17D-WGN01LF-2303W2 .....	10
<b>4.3:</b> FC3558-3: AF-RHMW17D-WQFB01-2303W2 .....	13
<b>Section 5: Misc. Forms</b> .....	<b>16</b>
<b>5.1:</b> Chain of Custody .....	17
<b>5.2:</b> QC Evaluation: DOD QSM5.x Limits .....	20
<b>Section 6: MS Semi-volatiles - QC Data Summaries</b> .....	<b>21</b>
<b>6.1:</b> Method Blank Summary .....	22
<b>6.2:</b> Blank Spike Summary .....	28
<b>6.3:</b> Matrix Spike Summary .....	32
<b>6.4:</b> Duplicate Summary .....	34

1

2

3

4

5

6



### Sample Summary

AECOM, INC.

Job No: FC3558

N6274223F0104 RH Fire Suppression System  
Project No: 60697810

Sample Number	Collected Date	Time By	Received	Matrix Code	Type	Client Sample ID
FC3558-1	03/17/23	12:00	OSAY 03/18/23	AQ	Ground Water	AF-RHMW17-WGN01LF-2303W2
FC3558-2	03/17/23	10:55	OSAY 03/18/23	AQ	Ground Water	AF-RHMW17D-WGN01LF-2303W2
FC3558-3	03/17/23	09:45	OSAY 03/18/23	AQ	Field Blank Water	AF-RHMW17D-WQFB01-2303W2

## SAMPLE DELIVERY GROUP CASE NARRATIVE

**Client:** AECOM, INC.

**Job No:** FC3558

**Site:** N6274223F0104 RH Fire Suppression System

**Report Date:** 3/22/2023 2:06:33 PM

On 03/18/2023, 2 Sample(s), 0 Trip Blank(s) and 1 Field Blank(s) were received at SGS North America Inc - Orlando. at a maximum corrected temperature of 3.7 C. Samples were intact and chemically preserved, unless noted below. A SGS North America Inc. - Orlando Job Number of FC3558 was assigned to the project.

Laboratory sample ID, client sample ID and dates of sample collection are detailed in the report's Results Summary Section. Specified quality control criteria were achieved for this job except as noted below. For more information, please refer to the analytical results and QC summary pages.

### MS Semi-volatiles By Method EPA DRAFT 1633

**Matrix:** AQ

**Batch ID:** OP95968

Sample(s) FC3558-2MS, FC3558-3DUP were used as the QC samples indicated.

SGS North America Inc. - Orlando certifies that data reported for samples received, listed on the associated custody chain or analytical task order, were produced to specifications meeting the Quality System precision, accuracy and completeness objectives except as noted. Estimated non-standard method measurement uncertainty data is available on request, based on quality control bias and implicit for standard methods. Acceptable uncertainty requires tested parameter quality control data to meet method criteria. SGS North America Inc.- Orlando is not responsible for data quality assumptions if partial reports are used and recommends that this report be used in its entirety.

Narrative prepared by:

---

Kim Benham, Client Services (*Signature on File*)

## Summary of Hits

**Job Number:** FC3558  
**Account:** AECOM, INC.  
**Project:** N6274223F0104 RH Fire Suppression System  
**Collected:** 03/17/23



Lab Sample ID	Client Sample ID	Result/ Qual	LOQ	LOD	Units	Method
---------------	------------------	-----------------	-----	-----	-------	--------

**FC3558-1**      **AF-RHMW17-WGN01LF-2303W2**

Perfluorobutanoic acid	3.2 J	19	3.7	ng/l	EPA DRAFT 1633
Perfluoropentanoic acid	9.6	9.3	1.9	ng/l	EPA DRAFT 1633
Perfluorohexanoic acid	5.6	4.6	0.93	ng/l	EPA DRAFT 1633
Perfluoroheptanoic acid	1.0 J	4.6	0.93	ng/l	EPA DRAFT 1633

**FC3558-2**      **AF-RHMW17D-WGN01LF-2303W2**

No hits reported in this sample.

**FC3558-3**      **AF-RHMW17D-WQFB01-2303W2**

No hits reported in this sample.

**Sample Results**

---

**Report of Analysis**

---

# Report of Analysis

Client Sample ID:	AF-RHMW17-WGN01LF-2303W2		
Lab Sample ID:	FC3558-1	Date Sampled:	03/17/23
Matrix:	AQ - Ground Water	Date Received:	03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids:	n/a
Project:	N6274223F0104 RH Fire Suppression System		

Run #	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	6Q15112.D	1	03/21/23 17:19	MV	03/20/23 09:00	OP95968	S6Q229
Run #2							

Run #	Initial Volume	Final Volume
Run #1	540 ml	5.0 ml
Run #2		

CAS No.	Compound	Result	LOQ	LOD	DL	Units	Q
---------	----------	--------	-----	-----	----	-------	---

**PERFLUOROALKYL CARBOXYLIC ACIDS**

375-22-4	Perfluorobutanoic acid	3.2	19	3.7	1.8	ng/l	J
2706-90-3	Perfluoropentanoic acid	9.6	9.3	1.9	0.87	ng/l	
307-24-4	Perfluorohexanoic acid	5.6	4.6	0.93	0.46	ng/l	
375-85-9	Perfluoroheptanoic acid	1.0	4.6	0.93	0.46	ng/l	J
335-67-1	Perfluorooctanoic acid	0.93 U	4.6	0.93	0.46	ng/l	
375-95-1	Perfluorononanoic acid	1.9 U	4.6	1.9	0.56	ng/l	
335-76-2	Perfluorodecanoic acid	0.93 U	4.6	0.93	0.46	ng/l	
2058-94-8	Perfluoroundecanoic acid	1.9 U	4.6	1.9	0.56	ng/l	
307-55-1	Perfluorododecanoic acid	1.9 U	4.6	1.9	0.56	ng/l	
72629-94-8	Perfluorotridecanoic acid	1.9 U	4.6	1.9	0.78	ng/l	
376-06-7	Perfluorotetradecanoic acid	0.93 U	4.6	0.93	0.46	ng/l	

**PERFLUOROALKYL SULFONIC ACIDS**

375-73-5	Perfluorobutanesulfonic acid	0.93 U	4.6	0.93	0.46	ng/l	
2706-91-4	Perfluoropentanesulfonic acid	3.7 U	4.6	3.7	1.0	ng/l	
355-46-4	Perfluorohexanesulfonic acid	1.9 U	4.6	1.9	0.65	ng/l	
375-92-8	Perfluoroheptanesulfonic acid	0.93 U	4.6	0.93	0.46	ng/l	
1763-23-1	Perfluorooctanesulfonic acid	1.9 U	4.6	1.9	0.50	ng/l	
68259-12-1	Perfluorononanesulfonic acid	1.9 U	4.6	1.9	0.53	ng/l	
335-77-3	Perfluorodecanesulfonic acid	1.9 U	4.6	1.9	0.59	ng/l	
79780-39-5	Perfluorododecanesulfonic aci	3.7 U	4.6	3.7	1.1	ng/l	

**FLUOROTELOMER SULFONIC ACIDS**

757124-72-4	4:2 Fluorotelomer sulfonate	7.4 U	19	7.4	3.0	ng/l	
27619-97-2	6:2 Fluorotelomer sulfonate	7.4 U	19	7.4	3.2	ng/l	
39108-34-4	8:2 Fluorotelomer sulfonate	7.4 U	19	7.4	3.8	ng/l	

**PERFLUOROOCCTANE SULFONAMIDES**

754-91-6	PFOSA	1.9 U	4.6	1.9	0.62	ng/l	
31506-32-8	MeFOSA	1.9 U	4.6	1.9	0.93	ng/l	
4151-50-2	EtFOSA	1.9 U	4.6	1.9	0.93	ng/l	

U = Not detected      LOD = Limit of Detection      J = Indicates an estimated value  
 LOQ = Limit of Quantitation      DL = Detection Limit      B = Indicates analyte found in associated method blank  
 E = Indicates value exceeds calibration range      N = Indicates presumptive evidence of a compound

4.1  
4

# Report of Analysis

Client Sample ID:	AF-RHMW17-WGN01LF-2303W2		
Lab Sample ID:	FC3558-1	Date Sampled:	03/17/23
Matrix:	AQ - Ground Water	Date Received:	03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids:	n/a
Project:	N6274223F0104 RH Fire Suppression System		

CAS No.	Compound	Result	LOQ	LOD	DL	Units	Q
---------	----------	--------	-----	-----	----	-------	---

**PERFLUOROOCCTANE SULFONAMIDOACETIC ACIDS**

2355-31-9	MeFOSAA	3.7 U	4.6	3.7	0.93	ng/l	
2991-50-6	EtFOSAA	3.7 U	4.6	3.7	1.2	ng/l	

**PERFLUOROOCCTANE SULFONAMIDO ETHANOLS**

24448-09-7	MeFOSE	9.3 U	46	9.3	4.1	ng/l	
1691-99-2	EtFOSE	19 U	46	19	6.9	ng/l	

**PER and POLYFLUOROETHER CARBOXYLIC ACIDS**

13252-13-6	HFPO-DA (GenX)	3.7 U	19	3.7	0.93	ng/l	
919005-14-4	ADONA	3.7 U	19	3.7	1.7	ng/l	
377-73-1	PFMPA	1.9 U	9.3	1.9	0.93	ng/l	
863090-89-5	PFMBA	3.7 U	9.3	3.7	1.1	ng/l	
151772-58-6	NFDHA	3.7 U	9.3	3.7	1.1	ng/l	

**PER and POLYFLUOROETHER SULFONIC ACIDS**

756426-58-1	9Cl-PF3ONS (F-53B Major)	3.7 U	19	3.7	1.3	ng/l	
763051-92-9	11Cl-PF3OUdS (F-53B Minor)	3.7 U	19	3.7	1.6	ng/l	
113507-82-7	PFEESA	1.9 U	9.3	1.9	0.72	ng/l	

**FLUOROTELOMER CARBOXYLIC ACIDS**

356-02-5	3:3 Fluorotelomer carboxylate	9.3 U	23	9.3	4.2	ng/l	
914637-49-3	5:3 Fluorotelomer carboxylate	19 U	120	19	8.1	ng/l	
812-70-4	7:3 Fluorotelomer carboxylate	19 U	120	19	7.3	ng/l	

CAS No.	ID Standard Recoveries	Run# 1	Run# 2	Limits
	13C4-PFBA	110%		20-150%
	13C5-PFPeA	102%		20-150%
	13C5-PFHxA	101%		20-150%
	13C4-PFHpA	105%		20-150%
	13C8-PFOA	109%		20-150%
	13C9-PFNA	106%		20-150%
	13C6-PFDA	94%		20-150%
	13C7-PFUnDA	78%		20-150%
	13C2-PFDoDA	65%		20-150%
	13C2-PFTeDA	52%		20-150%
	13C3-PFBS	111%		20-150%
	13C3-PFHxS	108%		20-150%

U = Not detected      LOD = Limit of Detection      J = Indicates an estimated value  
 LOQ = Limit of Quantitation      DL = Detection Limit      B = Indicates analyte found in associated method blank  
 E = Indicates value exceeds calibration range      N = Indicates presumptive evidence of a compound

4.1  
4



## Report of Analysis

Client Sample ID:	AF-RHMW17-WGN01LF-2303W2	
Lab Sample ID:	FC3558-1	Date Sampled: 03/17/23
Matrix:	AQ - Ground Water	Date Received: 03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids: n/a
Project:	N6274223F0104 RH Fire Suppression System	

CAS No.	ID Standard Recoveries	Run# 1	Run# 2	Limits
	13C8-PFOS	90%		20-150%
	13C8-FOSA	96%		20-150%
	d3-MeFOSA	77%		20-150%
	d5-EtFOSA	75%		20-150%
	d3-MeFOSAA	93%		20-150%
	d5-EtFOSAA	95%		20-150%
	d7-MeFOSE	79%		20-150%
	d9-EtFOSE	81%		20-150%
	13C2-4:2FTS	131%		20-150%
	13C2-6:2FTS	120%		20-150%
	13C2-8:2FTS	88%		20-150%
	13C3-HFPO-DA	99%		20-150%

U = Not detected

LOD = Limit of Detection

J = Indicates an estimated value

LOQ = Limit of Quantitation

DL = Detection Limit

B = Indicates analyte found in associated method blank

E = Indicates value exceeds calibration range

N = Indicates presumptive evidence of a compound

# Report of Analysis

Client Sample ID:	AF-RHMW17D-WGN01LF-2303W2		
Lab Sample ID:	FC3558-2	Date Sampled:	03/17/23
Matrix:	AQ - Ground Water	Date Received:	03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids:	n/a
Project:	N6274223F0104 RH Fire Suppression System		

Run #	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	6Q15113.D	1	03/21/23 17:33	MV	03/20/23 09:00	OP95968	S6Q229
Run #2							

Run #	Initial Volume	Final Volume
Run #1	560 ml	5.0 ml
Run #2		

CAS No.	Compound	Result	LOQ	LOD	DL	Units	Q
---------	----------	--------	-----	-----	----	-------	---

**PERFLUOROALKYL CARBOXYLIC ACIDS**

375-22-4	Perfluorobutanoic acid	3.6 U	18	3.6	1.7	ng/l	
2706-90-3	Perfluoropentanoic acid	1.8 U	8.9	1.8	0.84	ng/l	
307-24-4	Perfluorohexanoic acid	0.89 U	4.5	0.89	0.45	ng/l	
375-85-9	Perfluoroheptanoic acid	0.89 U	4.5	0.89	0.45	ng/l	
335-67-1	Perfluorooctanoic acid	0.89 U	4.5	0.89	0.45	ng/l	
375-95-1	Perfluorononanoic acid	1.8 U	4.5	1.8	0.54	ng/l	
335-76-2	Perfluorodecanoic acid	0.89 U	4.5	0.89	0.45	ng/l	
2058-94-8	Perfluoroundecanoic acid	1.8 U	4.5	1.8	0.54	ng/l	
307-55-1	Perfluorododecanoic acid	1.8 U	4.5	1.8	0.54	ng/l	
72629-94-8	Perfluorotridecanoic acid	1.8 U	4.5	1.8	0.75	ng/l	
376-06-7	Perfluorotetradecanoic acid	0.89 U	4.5	0.89	0.45	ng/l	

**PERFLUOROALKYL SULFONIC ACIDS**

375-73-5	Perfluorobutanesulfonic acid	0.89 U	4.5	0.89	0.45	ng/l	
2706-91-4	Perfluoropentanesulfonic acid	3.6 U	4.5	3.6	1.0	ng/l	
355-46-4	Perfluorohexanesulfonic acid	1.8 U	4.5	1.8	0.62	ng/l	
375-92-8	Perfluoroheptanesulfonic acid	0.89 U	4.5	0.89	0.45	ng/l	
1763-23-1	Perfluorooctanesulfonic acid	1.8 U	4.5	1.8	0.48	ng/l	
68259-12-1	Perfluorononanesulfonic acid	1.8 U	4.5	1.8	0.51	ng/l	
335-77-3	Perfluorodecanesulfonic acid	1.8 U	4.5	1.8	0.57	ng/l	
79780-39-5	Perfluorododecanesulfonic aci	3.6 U	4.5	3.6	1.0	ng/l	

**FLUOROTELOMER SULFONIC ACIDS**

757124-72-4	4:2 Fluorotelomer sulfonate	7.1 U	18	7.1	2.9	ng/l	
27619-97-2	6:2 Fluorotelomer sulfonate	7.1 U	18	7.1	3.1	ng/l	
39108-34-4	8:2 Fluorotelomer sulfonate	7.1 U	18	7.1	3.7	ng/l	

**PERFLUOROOCCTANE SULFONAMIDES**

754-91-6	PFOSA	1.8 U	4.5	1.8	0.60	ng/l	
31506-32-8	MeFOSA	1.8 U	4.5	1.8	0.89	ng/l	
4151-50-2	EtFOSA	1.8 U	4.5	1.8	0.89	ng/l	

U = Not detected      LOD = Limit of Detection      J = Indicates an estimated value  
 LOQ = Limit of Quantitation      DL = Detection Limit      B = Indicates analyte found in associated method blank  
 E = Indicates value exceeds calibration range      N = Indicates presumptive evidence of a compound

# Report of Analysis

Client Sample ID:	AF-RHMW17D-WGN01LF-2303W2		
Lab Sample ID:	FC3558-2	Date Sampled:	03/17/23
Matrix:	AQ - Ground Water	Date Received:	03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids:	n/a
Project:	N6274223F0104 RH Fire Suppression System		

CAS No.	Compound	Result	LOQ	LOD	DL	Units	Q
---------	----------	--------	-----	-----	----	-------	---

**PERFLUOROOCCTANE SULFONAMIDOACETIC ACIDS**

2355-31-9	MeFOSAA	3.6 U	4.5	3.6	0.89	ng/l	
2991-50-6	EtFOSAA	3.6 U	4.5	3.6	1.2	ng/l	

**PERFLUOROOCCTANE SULFONAMIDO ETHANOLS**

24448-09-7	MeFOSE	8.9 U	45	8.9	3.9	ng/l	
1691-99-2	EtFOSE	18 U	45	18	6.6	ng/l	

**PER and POLYFLUOROETHER CARBOXYLIC ACIDS**

13252-13-6	HFPO-DA (GenX)	3.6 U	18	3.6	0.89	ng/l	
919005-14-4	ADONA	3.6 U	18	3.6	1.7	ng/l	
377-73-1	PFMPA	1.8 U	8.9	1.8	0.89	ng/l	
863090-89-5	PFMBA	3.6 U	8.9	3.6	1.0	ng/l	
151772-58-6	NFDHA	3.6 U	8.9	3.6	1.1	ng/l	

**PER and POLYFLUOROETHER SULFONIC ACIDS**

756426-58-1	9Cl-PF3ONS (F-53B Major)	3.6 U	18	3.6	1.2	ng/l	
763051-92-9	11Cl-PF3OUdS (F-53B Minor)	3.6 U	18	3.6	1.6	ng/l	
113507-82-7	PFEESA	1.8 U	8.9	1.8	0.70	ng/l	

**FLUOROTELOMER CARBOXYLIC ACIDS**

356-02-5	3:3 Fluorotelomer carboxylate	8.9 U	22	8.9	4.0	ng/l	
914637-49-3	5:3 Fluorotelomer carboxylate	18 U	110	18	7.8	ng/l	
812-70-4	7:3 Fluorotelomer carboxylate	18 U	110	18	7.0	ng/l	

CAS No.	ID Standard Recoveries	Run# 1	Run# 2	Limits
---------	------------------------	--------	--------	--------

	13C4-PFBA	97%		20-150%
	13C5-PFPeA	95%		20-150%
	13C5-PFHxA	94%		20-150%
	13C4-PFHpA	100%		20-150%
	13C8-PFOA	98%		20-150%
	13C9-PFNA	91%		20-150%
	13C6-PFDA	99%		20-150%
	13C7-PFUnDA	97%		20-150%
	13C2-PFDoDA	91%		20-150%
	13C2-PFTeDA	81%		20-150%
	13C3-PFBS	99%		20-150%
	13C3-PFHxS	95%		20-150%

U = Not detected      LOD = Limit of Detection      J = Indicates an estimated value  
 LOQ = Limit of Quantitation      DL = Detection Limit      B = Indicates analyte found in associated method blank  
 E = Indicates value exceeds calibration range      N = Indicates presumptive evidence of a compound

## Report of Analysis

Client Sample ID:	AF-RHMW17D-WGN01LF-2303W2		
Lab Sample ID:	FC3558-2	Date Sampled:	03/17/23
Matrix:	AQ - Ground Water	Date Received:	03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids:	n/a
Project:	N6274223F0104 RH Fire Suppression System		

CAS No.	ID Standard Recoveries	Run# 1	Run# 2	Limits
	13C8-PFOS	87%		20-150%
	13C8-FOSA	101%		20-150%
	d3-MeFOSA	91%		20-150%
	d5-EtFOSA	88%		20-150%
	d3-MeFOSAA	121%		20-150%
	d5-EtFOSAA	120%		20-150%
	d7-MeFOSE	106%		20-150%
	d9-EtFOSE	99%		20-150%
	13C2-4:2FTS	115%		20-150%
	13C2-6:2FTS	100%		20-150%
	13C2-8:2FTS	97%		20-150%
	13C3-HFPO-DA	88%		20-150%

U = Not detected      LOD = Limit of Detection      J = Indicates an estimated value  
 LOQ = Limit of Quantitation      DL = Detection Limit      B = Indicates analyte found in associated method blank  
 E = Indicates value exceeds calibration range      N = Indicates presumptive evidence of a compound

# Report of Analysis

Client Sample ID:	AF-RHMW17D-WQFB01-2303W2		
Lab Sample ID:	FC3558-3	Date Sampled:	03/17/23
Matrix:	AQ - Field Blank Water	Date Received:	03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids:	n/a
Project:	N6274223F0104 RH Fire Suppression System		

Run #	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	6Q15115.D	1	03/21/23 18:02	MV	03/20/23 09:00	OP95968	S6Q229
Run #2							

Run #	Initial Volume	Final Volume
Run #1	530 ml	5.0 ml
Run #2		

CAS No.	Compound	Result	LOQ	LOD	DL	Units	Q
---------	----------	--------	-----	-----	----	-------	---

**PERFLUOROALKYL CARBOXYLIC ACIDS**

375-22-4	Perfluorobutanoic acid	3.8 U	19	3.8	1.8	ng/l	
2706-90-3	Perfluoropentanoic acid	1.9 U	9.4	1.9	0.89	ng/l	
307-24-4	Perfluorohexanoic acid	0.94 U	4.7	0.94	0.47	ng/l	
375-85-9	Perfluoroheptanoic acid	0.94 U	4.7	0.94	0.47	ng/l	
335-67-1	Perfluorooctanoic acid	0.94 U	4.7	0.94	0.47	ng/l	
375-95-1	Perfluorononanoic acid	1.9 U	4.7	1.9	0.58	ng/l	
335-76-2	Perfluorodecanoic acid	0.94 U	4.7	0.94	0.47	ng/l	
2058-94-8	Perfluoroundecanoic acid	1.9 U	4.7	1.9	0.57	ng/l	
307-55-1	Perfluorododecanoic acid	1.9 U	4.7	1.9	0.57	ng/l	
72629-94-8	Perfluorotridecanoic acid	1.9 U	4.7	1.9	0.79	ng/l	
376-06-7	Perfluorotetradecanoic acid	0.94 U	4.7	0.94	0.47	ng/l	

**PERFLUOROALKYL SULFONIC ACIDS**

375-73-5	Perfluorobutanesulfonic acid	0.94 U	4.7	0.94	0.47	ng/l	
2706-91-4	Perfluoropentanesulfonic acid	3.8 U	4.7	3.8	1.1	ng/l	
355-46-4	Perfluorohexanesulfonic acid	1.9 U	4.7	1.9	0.66	ng/l	
375-92-8	Perfluoroheptanesulfonic acid	0.94 U	4.7	0.94	0.47	ng/l	
1763-23-1	Perfluorooctanesulfonic acid	1.9 U	4.7	1.9	0.51	ng/l	
68259-12-1	Perfluorononanesulfonic acid	1.9 U	4.7	1.9	0.54	ng/l	
335-77-3	Perfluorodecanesulfonic acid	1.9 U	4.7	1.9	0.60	ng/l	
79780-39-5	Perfluorododecanesulfonic aci	3.8 U	4.7	3.8	1.1	ng/l	

**FLUOROTELOMER SULFONIC ACIDS**

757124-72-4	4:2 Fluorotelomer sulfonate	7.5 U	19	7.5	3.0	ng/l	
27619-97-2	6:2 Fluorotelomer sulfonate	7.5 U	19	7.5	3.3	ng/l	
39108-34-4	8:2 Fluorotelomer sulfonate	7.5 U	19	7.5	3.9	ng/l	

**PERFLUOROOCCTANE SULFONAMIDES**

754-91-6	PFOSA	1.9 U	4.7	1.9	0.63	ng/l	
31506-32-8	MeFOSA	1.9 U	4.7	1.9	0.94	ng/l	
4151-50-2	EtFOSA	1.9 U	4.7	1.9	0.94	ng/l	

U = Not detected      LOD = Limit of Detection      J = Indicates an estimated value  
 LOQ = Limit of Quantitation      DL = Detection Limit      B = Indicates analyte found in associated method blank  
 E = Indicates value exceeds calibration range      N = Indicates presumptive evidence of a compound

# Report of Analysis

Client Sample ID:	AF-RHMW17D-WQFB01-2303W2		
Lab Sample ID:	FC3558-3	Date Sampled:	03/17/23
Matrix:	AQ - Field Blank Water	Date Received:	03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids:	n/a
Project:	N6274223F0104 RH Fire Suppression System		

CAS No.	Compound	Result	LOQ	LOD	DL	Units	Q
---------	----------	--------	-----	-----	----	-------	---

**PERFLUOROOCCTANE SULFONAMIDOACETIC ACIDS**

2355-31-9	MeFOSAA	3.8 U	4.7	3.8	0.94	ng/l	
2991-50-6	EtFOSAA	3.8 U	4.7	3.8	1.3	ng/l	

**PERFLUOROOCCTANE SULFONAMIDO ETHANOLS**

24448-09-7	MeFOSE	9.4 U	47	9.4	4.1	ng/l	
1691-99-2	EtFOSE	19 U	47	19	7.0	ng/l	

**PER and POLYFLUOROETHER CARBOXYLIC ACIDS**

13252-13-6	HFPO-DA (GenX)	3.8 U	19	3.8	0.94	ng/l	
919005-14-4	ADONA	3.8 U	19	3.8	1.8	ng/l	
377-73-1	PFMPA	1.9 U	9.4	1.9	0.94	ng/l	
863090-89-5	PFMBA	3.8 U	9.4	3.8	1.1	ng/l	
151772-58-6	NFDHA	3.8 U	9.4	3.8	1.1	ng/l	

**PER and POLYFLUOROETHER SULFONIC ACIDS**

756426-58-1	9Cl-PF3ONS (F-53B Major)	3.8 U	19	3.8	1.3	ng/l	
763051-92-9	11Cl-PF3OUdS (F-53B Minor)	3.8 U	19	3.8	1.7	ng/l	
113507-82-7	PFEESA	1.9 U	9.4	1.9	0.74	ng/l	

**FLUOROTELOMER CARBOXYLIC ACIDS**

356-02-5	3:3 Fluorotelomer carboxylate	9.4 U	24	9.4	4.3	ng/l	
914637-49-3	5:3 Fluorotelomer carboxylate	19 U	120	19	8.2	ng/l	
812-70-4	7:3 Fluorotelomer carboxylate	19 U	120	19	7.4	ng/l	

CAS No.	ID Standard Recoveries	Run# 1	Run# 2	Limits
	13C4-PFBA	107%		20-150%
	13C5-PFPeA	107%		20-150%
	13C5-PFHxA	112%		20-150%
	13C4-PFHpA	112%		20-150%
	13C8-PFOA	101%		20-150%
	13C9-PFNA	100%		20-150%
	13C6-PFDA	105%		20-150%
	13C7-PFUnDA	107%		20-150%
	13C2-PFDoDA	100%		20-150%
	13C2-PFTeDA	96%		20-150%
	13C3-PFBS	102%		20-150%
	13C3-PFHxS	102%		20-150%

U = Not detected      LOD = Limit of Detection      J = Indicates an estimated value  
 LOQ = Limit of Quantitation      DL = Detection Limit      B = Indicates analyte found in associated method blank  
 E = Indicates value exceeds calibration range      N = Indicates presumptive evidence of a compound

## Report of Analysis

Client Sample ID:	AF-RHMW17D-WQFB01-2303W2	
Lab Sample ID:	FC3558-3	Date Sampled: 03/17/23
Matrix:	AQ - Field Blank Water	Date Received: 03/18/23
Method:	EPA DRAFT 1633 EPA 1633 DRAFT	Percent Solids: n/a
Project:	N6274223F0104 RH Fire Suppression System	

CAS No.	ID Standard Recoveries	Run# 1	Run# 2	Limits
	13C8-PFOS	93%		20-150%
	13C8-FOSA	100%		20-150%
	d3-MeFOSA	88%		20-150%
	d5-EtFOSA	94%		20-150%
	d3-MeFOSAA	101%		20-150%
	d5-EtFOSAA	103%		20-150%
	d7-MeFOSE	99%		20-150%
	d9-EtFOSE	100%		20-150%
	13C2-4:2FTS	121%		20-150%
	13C2-6:2FTS	117%		20-150%
	13C2-8:2FTS	103%		20-150%
	13C3-HFPO-DA	107%		20-150%

U = Not detected      LOD = Limit of Detection      J = Indicates an estimated value  
 LOQ = Limit of Quantitation      DL = Detection Limit      B = Indicates analyte found in associated method blank  
 E = Indicates value exceeds calibration range      N = Indicates presumptive evidence of a compound

**Misc. Forms**

**Custody Documents and Other Forms**

---

**Includes the following where applicable:**

- Chain of Custody
- QC Evaluation: DOD QSM5.x Limits





SGS North America Inc - Orlando **FC3558**  
Chain of Custody  
SGS - ORLANDO JOB #:

4405 Vineland Road, Suite C-15 Orlando, FL 32811  
TEL: 407-425-6700 FAX: 407-425-0707  
www.sgs.com

COC #: 2303W2AFSG10

PAGE 1 OF 1

SGS - ORLANDO Quote # SKIFF #

Client / Reporting Information			Project Information					Analytical Information												Matrix Codes	
Company Name: AECOM			Project Name: N6274223F0104 RH Fire Suppression System					<div style="position: relative; height: 100px;"> <span style="position: absolute; top: 0; right: 0; font-size: 2em; opacity: 0.5;">Date</span> <span style="position: absolute; bottom: 0; left: 0; font-size: 1.5em;">3/17/23</span> </div>												DW - Drinking Water GW - Ground Water WW - Water SW - Surface Water SO - Soil SL - Sludge OI - Oil LIQ - Other Liquid AIR - Air SOL - Other Solid WP - Wipe	
Address: 1001 Bishop St. ste 1600			Street																	PFAS EPA Draft 1633	
City: Honolulu State: HI Zip: 96813			City HONOLULU State Hawaii																		
Project Contact: Katie Abbott Email: katie.abbott@aecom.com			Project # 60697810																		
Project Manager: Watson Tani Email: watson.tani@aecom.com			Fax #																		
Phone #: 303-796-4624 / 808-954-4512			Client Purchase Order #																		
Sampler(s) Name(s) (Printed) Sampler 1: Olivia Shively Sampler 2: Monica DeLeon																					
SGS Orlando Sample #	Field ID / Point of Collection	DATE	TIME	COLLECTION										MESH	LAB USE ONLY						
				DATE	TIME	SAMPLED BY	MATRIX	TOTAL # OF BOTTLES	OTHER	NONE	HCl	NH <sub>3</sub>	HNO <sub>3</sub>			H <sub>2</sub> SO <sub>4</sub>	NH <sub>4</sub> OH	DI WATER			
1	AF-RHMW17-WGN01LF-2303W2	3/17/23	1200	KS, M, W	GW	3		X													
Turnaround Time (Business days)			Data Deliverable Information					Comments / Remarks													
10 Day (Business) _____ 7 Day _____ <input checked="" type="checkbox"/> 5 Day _____ 3 Day RUSH _____ 2 Day RUSH _____ 1 Day RUSH _____ Other _____ Rush T/A Data Available VIA Email or Lablink			Approved By: / Date: _____ <input type="checkbox"/> COMMERCIAL "A" (RESULTS ONLY) <input type="checkbox"/> COMMERCIAL "B" (RESULTS PLUS QC) <input type="checkbox"/> REDT1 (EPA LEVEL 3) <input checked="" type="checkbox"/> FULLT1 (EPA LEVEL 4) <input checked="" type="checkbox"/> EDD'S					EDMS upload database: JBPHE EDMS Coverage: AFFF Assessment Sampling GW Under AWB 016-77148072													
Relinquished by Sampler/Affiliation			Date Time: 3/17/23					Received By/Affiliation					Date Time: 3/17/23		Received By/Affiliation						
1 Olivia Shively/AECom								2 GABRIEL ALLEN / ACCOR					3 GABRIEL ALLEN / ACCOR		4 [Signature]						
Relinquished by/Affiliation			Date Time: 3/17/23					Received By/Affiliation					Date Time: 3/17/23		Received By/Affiliation						
5								6					7		8 3/18/23 1530						
Lab Use Only: Cooler Temperature (s) Celsius (corrected):			4.8 AD					<a href="http://www.sgs.com/en/terms-and-conditions">http://www.sgs.com/en/terms-and-conditions</a>													

PFAS\_COCs\_ALL.xls Rev 031318



SGS North America Inc - Orlando  
Chain of Custody

4405 Vineland Road, Suite C-15 Orlando, FL 32811  
TEL: 407-425-6700 FAX: 407-425-0707  
www.sgs.com

FC3558  
SGS - ORLANDO JOB #:

COC #: 2303W2AFSG11  
PAGE 1 OF 1

Client / Reporting Information		Project Information		Analytical Information										Matrix Codes			
Company Name: AECOM		Project Name: N6274223F0104 RH Fire Suppression System		<div style="text-align: center;"> <p>PFAS EPA Draft 1633</p> <p>OKS 3/17/23</p> </div>										DW - Drinking Water GW - Ground Water WW - Water SW - Surface Water SO - Soil SL - Sludge OL - Oil LIQ - Other Liquid AIR - Air SOL - Other Solid WP - Wipe			
Address: 1001 Bishop St. Ste 1600		Street															
City: Honolulu State: HI Zip: 96813	City: Honolulu State: Hawaii																
Project Contact: Katie Abbott Email: katie.abbott@aecom.com	Project # 60697810																
Project Manager: Watson Tanji Email: watson.tanji@aecom.com	Fax #		Client Purchase Order #														
Sampler(s) Name(s) (Printed) Sampler 1: Olivia Shively Sampler 2: Mariana Dejeud																	
SGS Orlando Sample #	Field ID / Point of Collection	COLLECTION			CONTAINER INFORMATION										LAB USE ONLY		
		DATE	TIME	SAMPLED BY	MATRIX	TOTAL # OF BOTTLES	OTHER	NONE	HCl	NH3	HNO3	H2SO4	NH4OH-ZnAc	DI WATER		MEDI	
2	AF-RHMW17D-WGN01LF-2303W2	3/17/23	1655	OS.MD.P.	GW	3		X									X
3	AF-RHMW17D-WQFB01-2303W2	3/17/23	0945	OS.MD.P.	GW	3		X									X
Turnaround Time ( Business days)		Data Deliverable Information					Comments / Remarks										
10 Day (Business) 7 Day <input type="checkbox"/> 5 Day <input type="checkbox"/> 3 Day RUSH <input type="checkbox"/> 2 Day RUSH <input type="checkbox"/> 1 Day RUSH Other _____		Approved By: / Date:		<input type="checkbox"/> COMMERCIAL "A" (RESULTS ONLY) <input type="checkbox"/> COMMERCIAL "B" (RESULTS PLUS QC) <input type="checkbox"/> REDT1 (EPA LEVEL 3) <input checked="" type="checkbox"/> FULLT1 (EPA LEVEL 4) <input checked="" type="checkbox"/> EDD'S					EDMS upload database: JBPHE EDMS Coverage: AFFF Assessment Sampling GW United AWB-77148072								
Rush T/A Data Available VIA Email or Lablink												Sample Custody must be documented below each time samples change possession, including courier delivery.					
Relinquished by Sampler/Affiliation 1 Olivia Shively/AECOM		Date Time: 3/17/23		Received By/Affiliation 2 [Signature]		Date Time: 13:00		Relinquished By/Affiliation 3 [Signature]		Date Time: 15:00		Received By/Affiliation 4 [Signature]					
Relinquished by/Affiliation 5		Date Time:		Received By/Affiliation 6		Date Time:		Relinquished By/Affiliation 7		Date Time:		Received By/Affiliation 8 3/18/23					

Lab Use Only : Cooler Temperature (s) Celsius (corrected):

<http://www.sgs.com/en/terms-and-conditions>

PFAS\_COCS\_ALL.xls Rev 031318

FC3558: Chain of Custody

Page 2 of 3



## SGS Sample Receipt Summary

Job Number: FC3558

Client: AECOM

Project: N6274223F0104 RH Fire Suppression System

Date / Time Received: 3/18/2023 3:30:00 PM

Delivery Method: United Cargo/Airspace

Airbill #s: United Cargo AWB #: 016-77148072

Therm ID: IR 1;

Therm CF: -0.1;

# of Coolers: 1

Cooler Temps (Raw Measured) °C: Cooler 1: (3.8);

Cooler Temps (Corrected) °C: Cooler 1: (3.7);

**Cooler Information**

Y or N

- 1. Custody Seals Present
- 2. Custody Seals Intact
- 3. Temp criteria achieved
- 4. Cooler temp verification IR Gun
- 5. Cooler media Ice (Bag)

**Trip Blank Information**

Y or N N/A

- 1. Trip Blank present / cooler
  - 2. Trip Blank listed on COC
- W or S N/A
- 3. Type Of TB Received

**Sample Information**

Y or N N/A

- 1. Sample labels present on bottles
- 2. Samples preserved properly
- 3. Sufficient volume/containers recvd for analysis:
- 4. Condition of sample Intact
- 5. Sample recvd within HT
- 6. Dates/Times/IDs on COC match Sample Label
- 7. VOCs have headspace
- 8. Bottles received for unspecified tests
- 9. Compositing instructions clear
- 10. Voa Soil Kits/Jars received past 48hrs?
- 11. % Solids Jar received?
- 12. Residual Chlorine Present?

**Misc. Information**

Number of Encores: 25-Gram \_\_\_\_\_ 5-Gram \_\_\_\_\_  
 Test Strip Lot #s: pH 0-3 230315  
 Residual Chlorine Test Strip Lot #: \_\_\_\_\_

Number of 5035 Field Kits: \_\_\_\_\_  
 pH 10-12 219813A

Number of Lab Filtered Metals: \_\_\_\_\_  
 Other: (Specify) \_\_\_\_\_

Comments

SM001  
Rev. Date 05/24/17

Technician: NATHANS

Date: 3/18/2023 3:30:00 PM

Reviewer: CD

Date: 3/20/2023

**FC3558: Chain of Custody**

Page 3 of 3

# QC Evaluation: DOD QSM5.x Limits

**Job Number:** FC3558  
**Account:** AECOM, INC.  
**Project:** N6274223F0104 RH Fire Suppression System  
**Collected:** 03/17/23

QC Sample ID	CAS#	Analyte	Sample Result Type	Result Type	Units	Limits
--------------	------	---------	--------------------	-------------	-------	--------

No DOD QSM5.x Limits found for methods in this job.

---

\* Sample used for QC is not from job FC3558

5.2  
5

## MS Semi-volatiles

---

### QC Data Summaries

---

#### Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries

# Instrument Blank

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
S6Q229-IBLK	6Q15103.D	1	03/21/23	MV	n/a	n/a	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	Result	RL	MDL	Units	Q
375-22-4	Perfluorobutanoic acid	ND	0.020	0.0019	ug/l	
2706-90-3	Perfluoropentanoic acid	ND	0.010	0.00094	ug/l	
307-24-4	Perfluorohexanoic acid	ND	0.0050	0.00050	ug/l	
375-85-9	Perfluoroheptanoic acid	ND	0.0050	0.00050	ug/l	
335-67-1	Perfluorooctanoic acid	ND	0.0050	0.00050	ug/l	
375-95-1	Perfluorononanoic acid	ND	0.0050	0.00061	ug/l	
335-76-2	Perfluorodecanoic acid	ND	0.0050	0.00050	ug/l	
2058-94-8	Perfluoroundecanoic acid	ND	0.0050	0.00060	ug/l	
307-55-1	Perfluorododecanoic acid	ND	0.0050	0.00060	ug/l	
72629-94-8	Perfluorotridecanoic acid	ND	0.0050	0.00084	ug/l	
376-06-7	Perfluorotetradecanoic acid	ND	0.0050	0.00050	ug/l	
375-73-5	Perfluorobutanesulfonic acid	ND	0.0050	0.00050	ug/l	
2706-91-4	Perfluoropentanesulfonic acid	ND	0.0050	0.0011	ug/l	
355-46-4	Perfluorohexanesulfonic acid	ND	0.0050	0.00070	ug/l	
375-92-8	Perfluoroheptanesulfonic acid	ND	0.0050	0.00050	ug/l	
1763-23-1	Perfluorooctanesulfonic acid	ND	0.0050	0.00054	ug/l	
68259-12-1	Perfluorononanesulfonic acid	ND	0.0050	0.00057	ug/l	
335-77-3	Perfluorodecanesulfonic acid	ND	0.0050	0.00064	ug/l	
79780-39-5	Perfluorododecanesulfonic aci	ND	0.0050	0.0011	ug/l	
757124-72-44:2	Fluorotelomer sulfonate	ND	0.020	0.0032	ug/l	
27619-97-2	6:2 Fluorotelomer sulfonate	ND	0.020	0.0035	ug/l	
39108-34-4	8:2 Fluorotelomer sulfonate	ND	0.020	0.0041	ug/l	
754-91-6	PFOSA	ND	0.0050	0.00067	ug/l	
31506-32-8	MeFOSA	ND	0.0050	0.0010	ug/l	
4151-50-2	EtFOSA	ND	0.0050	0.0010	ug/l	
2355-31-9	MeFOSAA	ND	0.0050	0.0010	ug/l	
2991-50-6	EtFOSAA	ND	0.0050	0.0013	ug/l	
24448-09-7	MeFOSE	ND	0.050	0.0044	ug/l	
1691-99-2	EtFOSE	ND	0.050	0.0074	ug/l	
13252-13-6	HFPO-DA (GenX)	ND	0.020	0.0010	ug/l	
919005-14-4	ADONA	ND	0.020	0.0019	ug/l	
377-73-1	PFMPA	ND	0.010	0.0010	ug/l	
863090-89-5	PFMBA	ND	0.010	0.0011	ug/l	
151772-58-6	NFDHA	ND	0.010	0.0012	ug/l	
756426-58-19	Cl-PF3ONS (F-53B Major)	ND	0.020	0.0014	ug/l	
763051-92-91	Cl-PF3OUdS (F-53B Minor)	ND	0.020	0.0018	ug/l	

# Instrument Blank

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
S6Q229-IBLK	6Q15103.D	1	03/21/23	MV	n/a	n/a	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	Result	RL	MDL	Units	Q
113507-82-7	PFEESA	ND	0.010	0.00078	ug/l	
356-02-5	3:3 Fluorotelomer carboxylate	ND	0.025	0.0045	ug/l	
914637-49-35:3	Fluorotelomer carboxylate	ND	0.13	0.0087	ug/l	
812-70-4	7:3 Fluorotelomer carboxylate	ND	0.13	0.0079	ug/l	

CAS No.	ID Standard Recoveries	Limits
	13C4-PFBA	100% 20-150%
	13C5-PFPeA	95% 20-150%
	13C5-PFHxA	97% 20-150%
	13C4-PFHpA	94% 20-150%
	13C8-PFOA	104% 20-150%
	13C9-PFNA	96% 20-150%
	13C6-PFDA	96% 20-150%
	13C7-PFUnDA	101% 20-150%
	13C2-PFDoDA	101% 20-150%
	13C2-PFTeDA	105% 20-150%
	13C3-PFBS	103% 20-150%
	13C3-PFHxS	102% 20-150%
	13C8-PFOS	100% 20-150%
	13C8-FOSA	108% 20-150%
	d3-MeFOSA	102% 20-150%
	d5-EtFOSA	104% 20-150%
	d3-MeFOSAA	102% 20-150%
	d5-EtFOSAA	100% 20-150%
	d7-MeFOSE	108% 20-150%
	d9-EtFOSE	103% 20-150%
	13C2-4:2FTS	124% 20-150%
	13C2-6:2FTS	117% 20-150%
	13C2-8:2FTS	111% 20-150%
	13C3-HFPO-DA	94% 20-150%

6.1.1  
6

# Method Blank Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-MB	6Q15108.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	Result	RL	MDL	Units	Q
375-22-4	Perfluorobutanoic acid	ND	0.020	0.0019	ug/l	
2706-90-3	Perfluoropentanoic acid	ND	0.010	0.00094	ug/l	
307-24-4	Perfluorohexanoic acid	ND	0.0050	0.00050	ug/l	
375-85-9	Perfluoroheptanoic acid	ND	0.0050	0.00050	ug/l	
335-67-1	Perfluorooctanoic acid	ND	0.0050	0.00050	ug/l	
375-95-1	Perfluorononanoic acid	ND	0.0050	0.00061	ug/l	
335-76-2	Perfluorodecanoic acid	ND	0.0050	0.00050	ug/l	
2058-94-8	Perfluoroundecanoic acid	ND	0.0050	0.00060	ug/l	
307-55-1	Perfluorododecanoic acid	ND	0.0050	0.00060	ug/l	
72629-94-8	Perfluorotridecanoic acid	ND	0.0050	0.00084	ug/l	
376-06-7	Perfluorotetradecanoic acid	ND	0.0050	0.00050	ug/l	
375-73-5	Perfluorobutanesulfonic acid	ND	0.0050	0.00050	ug/l	
2706-91-4	Perfluoropentanesulfonic acid	ND	0.0050	0.0011	ug/l	
355-46-4	Perfluorohexanesulfonic acid	ND	0.0050	0.00070	ug/l	
375-92-8	Perfluoroheptanesulfonic acid	ND	0.0050	0.00050	ug/l	
1763-23-1	Perfluorooctanesulfonic acid	ND	0.0050	0.00054	ug/l	
68259-12-1	Perfluorononanesulfonic acid	ND	0.0050	0.00057	ug/l	
335-77-3	Perfluorodecanesulfonic acid	ND	0.0050	0.00064	ug/l	
79780-39-5	Perfluorododecanesulfonic aci	ND	0.0050	0.0011	ug/l	
757124-72-44:2	Fluorotelomer sulfonate	ND	0.020	0.0032	ug/l	
27619-97-2	6:2 Fluorotelomer sulfonate	ND	0.020	0.0035	ug/l	
39108-34-4	8:2 Fluorotelomer sulfonate	ND	0.020	0.0041	ug/l	
754-91-6	PFOSA	ND	0.0050	0.00067	ug/l	
31506-32-8	MeFOSA	ND	0.0050	0.0010	ug/l	
4151-50-2	EtFOSA	ND	0.0050	0.0010	ug/l	
2355-31-9	MeFOSAA	ND	0.0050	0.0010	ug/l	
2991-50-6	EtFOSAA	ND	0.0050	0.0013	ug/l	
24448-09-7	MeFOSE	ND	0.050	0.0044	ug/l	
1691-99-2	EtFOSE	ND	0.050	0.0074	ug/l	
13252-13-6	HFPO-DA (GenX)	ND	0.020	0.0010	ug/l	
919005-14-4	ADONA	ND	0.020	0.0019	ug/l	
377-73-1	PFMPA	ND	0.010	0.0010	ug/l	
863090-89-5	PFMBA	ND	0.010	0.0011	ug/l	
151772-58-6	NFDHA	ND	0.010	0.0012	ug/l	
756426-58-19	Cl-PF3ONS (F-53B Major)	ND	0.020	0.0014	ug/l	
763051-92-91	Cl-PF3OUdS (F-53B Minor)	ND	0.020	0.0018	ug/l	



# Method Blank Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-MB	6Q15108.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	Result	RL	MDL	Units	Q
113507-82-7	PFEESA	ND	0.010	0.00078	ug/l	
356-02-5	3:3 Fluorotelomer carboxylate	ND	0.025	0.0045	ug/l	
914637-49-35:3	Fluorotelomer carboxylate	ND	0.13	0.0087	ug/l	
812-70-4	7:3 Fluorotelomer carboxylate	ND	0.13	0.0079	ug/l	

CAS No.	ID Standard Recoveries	Limits
	13C4-PFBA	100% 20-150%
	13C5-PFPeA	97% 20-150%
	13C5-PFHxA	97% 20-150%
	13C4-PFHpA	98% 20-150%
	13C8-PFOA	102% 20-150%
	13C9-PFNA	103% 20-150%
	13C6-PFDA	97% 20-150%
	13C7-PFUnDA	90% 20-150%
	13C2-PFDoDA	75% 20-150%
	13C2-PFTeDA	74% 20-150%
	13C3-PFBS	98% 20-150%
	13C3-PFHxS	98% 20-150%
	13C8-PFOS	92% 20-150%
	13C8-FOSA	94% 20-150%
	d3-MeFOSA	78% 20-150%
	d5-EtFOSA	81% 20-150%
	d3-MeFOSAA	85% 20-150%
	d5-EtFOSAA	75% 20-150%
	d7-MeFOSE	91% 20-150%
	d9-EtFOSE	88% 20-150%
	13C2-4:2FTS	120% 20-150%
	13C2-6:2FTS	131% 20-150%
	13C2-8:2FTS	103% 20-150%
	13C3-HFPO-DA	95% 20-150%

6.1.2  
6

# Continuing Calibration Blank

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
S6Q229-ICCB	6Q15117.D	1	03/21/23	MV	n/a	n/a	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

OP95968-DUP

CAS No.	Compound	Result	RL	MDL	Units	Q
375-22-4	Perfluorobutanoic acid	ND	0.020	0.0019	ug/l	
2706-90-3	Perfluoropentanoic acid	ND	0.010	0.00094	ug/l	
307-24-4	Perfluorohexanoic acid	ND	0.0050	0.00050	ug/l	
375-85-9	Perfluoroheptanoic acid	ND	0.0050	0.00050	ug/l	
335-67-1	Perfluorooctanoic acid	ND	0.0050	0.00050	ug/l	
375-95-1	Perfluorononanoic acid	ND	0.0050	0.00061	ug/l	
335-76-2	Perfluorodecanoic acid	ND	0.0050	0.00050	ug/l	
2058-94-8	Perfluoroundecanoic acid	ND	0.0050	0.00060	ug/l	
307-55-1	Perfluorododecanoic acid	ND	0.0050	0.00060	ug/l	
72629-94-8	Perfluorotridecanoic acid	ND	0.0050	0.00084	ug/l	
376-06-7	Perfluorotetradecanoic acid	ND	0.0050	0.00050	ug/l	
375-73-5	Perfluorobutanesulfonic acid	ND	0.0050	0.00050	ug/l	
2706-91-4	Perfluoropentanesulfonic acid	ND	0.0050	0.0011	ug/l	
355-46-4	Perfluorohexanesulfonic acid	ND	0.0050	0.00070	ug/l	
375-92-8	Perfluoroheptanesulfonic acid	ND	0.0050	0.00050	ug/l	
1763-23-1	Perfluorooctanesulfonic acid	ND	0.0050	0.00054	ug/l	
68259-12-1	Perfluorononanesulfonic acid	ND	0.0050	0.00057	ug/l	
335-77-3	Perfluorodecanesulfonic acid	ND	0.0050	0.00064	ug/l	
79780-39-5	Perfluorododecanesulfonic aci	ND	0.0050	0.0011	ug/l	
757124-72-44:2	Fluorotelomer sulfonate	ND	0.020	0.0032	ug/l	
27619-97-2	6:2 Fluorotelomer sulfonate	ND	0.020	0.0035	ug/l	
39108-34-4	8:2 Fluorotelomer sulfonate	ND	0.020	0.0041	ug/l	
754-91-6	PFOSA	ND	0.0050	0.00067	ug/l	
31506-32-8	MeFOSA	ND	0.0050	0.0010	ug/l	
4151-50-2	EtFOSA	ND	0.0050	0.0010	ug/l	
2355-31-9	MeFOSAA	ND	0.0050	0.0010	ug/l	
2991-50-6	EtFOSAA	ND	0.0050	0.0013	ug/l	
24448-09-7	MeFOSE	ND	0.050	0.0044	ug/l	
1691-99-2	EtFOSE	ND	0.050	0.0074	ug/l	
13252-13-6	HFPO-DA (GenX)	ND	0.020	0.0010	ug/l	
919005-14-4	ADONA	ND	0.020	0.0019	ug/l	
377-73-1	PFMPA	ND	0.010	0.0010	ug/l	
863090-89-5	PFMBA	ND	0.010	0.0011	ug/l	
151772-58-6	NFDHA	ND	0.010	0.0012	ug/l	
756426-58-19	Cl-PF3ONS (F-53B Major)	ND	0.020	0.0014	ug/l	
763051-92-91	Cl-PF3OUdS (F-53B Minor)	ND	0.020	0.0018	ug/l	

# Continuing Calibration Blank

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
S6Q229-ICCB	6Q15117.D	1	03/21/23	MV	n/a	n/a	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

OP95968-DUP

CAS No.	Compound	Result	RL	MDL	Units	Q
113507-82-7	PFEESA	ND	0.010	0.00078	ug/l	
356-02-5	3:3 Fluorotelomer carboxylate	ND	0.025	0.0045	ug/l	
914637-49-35:3	Fluorotelomer carboxylate	ND	0.13	0.0087	ug/l	
812-70-4	7:3 Fluorotelomer carboxylate	ND	0.13	0.0079	ug/l	

CAS No.	ID Standard Recoveries	Limits
	13C4-PFBA	101% 20-150%
	13C5-PFPeA	96% 20-150%
	13C5-PFHxA	99% 20-150%
	13C4-PFHpA	98% 20-150%
	13C8-PFOA	101% 20-150%
	13C9-PFNA	104% 20-150%
	13C6-PFDA	95% 20-150%
	13C7-PFUnDA	100% 20-150%
	13C2-PFDoDA	102% 20-150%
	13C2-PFTeDA	109% 20-150%
	13C3-PFBS	98% 20-150%
	13C3-PFHxS	103% 20-150%
	13C8-PFOS	100% 20-150%
	13C8-FOSA	97% 20-150%
	d3-MeFOSA	96% 20-150%
	d5-EtFOSA	97% 20-150%
	d3-MeFOSAA	100% 20-150%
	d5-EtFOSAA	103% 20-150%
	d7-MeFOSE	104% 20-150%
	d9-EtFOSE	108% 20-150%
	13C2-4:2FTS	116% 20-150%
	13C2-6:2FTS	114% 20-150%
	13C2-8:2FTS	108% 20-150%
	13C3-HFPO-DA	93% 20-150%

# Blank Spike Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-LLBS	6Q15107.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	Spike ug/l	BSP ug/l	BSP %	Limits
375-22-4	Perfluorobutanoic acid	0.04	0.0360	90	40-150
2706-90-3	Perfluoropentanoic acid	0.02	0.0184	92	40-150
307-24-4	Perfluorohexanoic acid	0.01	0.0091	91	40-150
375-85-9	Perfluoroheptanoic acid	0.01	0.0093	93	40-150
335-67-1	Perfluorooctanoic acid	0.01	0.0099	99	40-150
375-95-1	Perfluorononanoic acid	0.01	0.0090	90	40-150
335-76-2	Perfluorodecanoic acid	0.01	0.0094	94	40-150
2058-94-8	Perfluoroundecanoic acid	0.01	0.0093	93	40-150
307-55-1	Perfluorododecanoic acid	0.01	0.0092	92	40-150
72629-94-8	Perfluorotridecanoic acid	0.01	0.0088	88	40-150
376-06-7	Perfluorotetradecanoic acid	0.01	0.0097	97	40-150
375-73-5	Perfluorobutanesulfonic acid	0.00887	0.0085	96	40-150
2706-91-4	Perfluoropentanesulfonic acid	0.00941	0.0085	90	40-150
355-46-4	Perfluorohexanesulfonic acid	0.00914	0.0085	93	40-150
375-92-8	Perfluoroheptanesulfonic acid	0.00953	0.0086	90	40-150
1763-23-1	Perfluorooctanesulfonic acid	0.00928	0.0087	94	40-150
68259-12-1	Perfluorononanesulfonic acid	0.00962	0.0093	97	40-150
335-77-3	Perfluorodecanesulfonic acid	0.00965	0.0094	97	40-150
79780-39-5	Perfluorododecanesulfonic aci	0.0097	0.0089	92	40-150
757124-72-44:2	Fluorotelomer sulfonate	0.0375	0.0359	96	40-150
27619-97-2	6:2 Fluorotelomer sulfonate	0.038	0.0362	95	40-150
39108-34-4	8:2 Fluorotelomer sulfonate	0.0384	0.0461	120	40-150
754-91-6	PFOSA	0.01	0.0104	104	40-150
31506-32-8	MeFOSA	0.01	0.0097	97	40-150
4151-50-2	EtFOSA	0.01	0.0095	95	40-150
2355-31-9	MeFOSAA	0.01	0.0099	99	40-150
2991-50-6	EtFOSAA	0.01	0.0082	82	40-150
24448-09-7	MeFOSE	0.1	0.0927	93	40-150
1691-99-2	EtFOSE	0.1	0.0939	94	40-150
13252-13-6	HFPO-DA (GenX)	0.04	0.0371	93	40-150
919005-14-4	ADONA	0.0378	0.0370	98	40-150
377-73-1	PFMPA	0.02	0.0186	93	40-150
863090-89-5	PFMBA	0.02	0.0186	93	40-150
151772-58-6	NFDHA	0.02	0.0191	96	40-150
756426-58-19	Cl-PF3ONS (F-53B Major)	0.0374	0.0360	96	40-150
763051-92-91	Cl-PF3OUdS (F-53B Minor)	0.0378	0.0342	90	40-150

\* = Outside of Control Limits.

# Blank Spike Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-LLBS	6Q15107.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	Spike ug/l	BSP ug/l	BSP %	Limits
113507-82-7	PFEESA	0.0178	0.0163	92	40-150
356-02-5	3:3 Fluorotelomer carboxylate	0.05	0.0472	94	40-150
914637-49-35:3	Fluorotelomer carboxylate	0.25	0.242	97	40-150
812-70-4	7:3 Fluorotelomer carboxylate	0.25	0.250	100	40-150

CAS No.	ID Standard Recoveries	BSP	Limits
	13C4-PFBA	105%	20-150%
	13C5-PFPeA	99%	20-150%
	13C5-PFHxA	99%	20-150%
	13C4-PFHpA	99%	20-150%
	13C8-PFOA	107%	20-150%
	13C9-PFNA	108%	20-150%
	13C6-PFDA	108%	20-150%
	13C7-PFUnDA	108%	20-150%
	13C2-PFDoDA	105%	20-150%
	13C2-PFTeDA	99%	20-150%
	13C3-PFBS	101%	20-150%
	13C3-PFHxS	103%	20-150%
	13C8-PFOS	97%	20-150%
	13C8-FOSA	105%	20-150%
	d3-MeFOSA	86%	20-150%
	d5-EtFOSA	85%	20-150%
	d3-MeFOSAA	104%	20-150%
	d5-EtFOSAA	98%	20-150%
	d7-MeFOSE	101%	20-150%
	d9-EtFOSE	96%	20-150%
	13C2-4:2FTS	118%	20-150%
	13C2-6:2FTS	119%	20-150%
	13C2-8:2FTS	107%	20-150%
	13C3-HFPO-DA	95%	20-150%

\* = Outside of Control Limits.

# Blank Spike Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-BS	6Q15106.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	Spike ug/l	BSP ug/l	BSP %	Limits
375-22-4	Perfluorobutanoic acid	0.1	0.0936	94	40-150
2706-90-3	Perfluoropentanoic acid	0.05	0.0483	97	40-150
307-24-4	Perfluorohexanoic acid	0.025	0.0240	96	40-150
375-85-9	Perfluoroheptanoic acid	0.025	0.0256	102	40-150
335-67-1	Perfluorooctanoic acid	0.025	0.0244	98	40-150
375-95-1	Perfluorononanoic acid	0.025	0.0234	94	40-150
335-76-2	Perfluorodecanoic acid	0.025	0.0216	86	40-150
2058-94-8	Perfluoroundecanoic acid	0.025	0.0229	92	40-150
307-55-1	Perfluorododecanoic acid	0.025	0.0229	92	40-150
72629-94-8	Perfluorotridecanoic acid	0.025	0.0240	96	40-150
376-06-7	Perfluorotetradecanoic acid	0.025	0.0235	94	40-150
375-73-5	Perfluorobutanesulfonic acid	0.0222	0.0201	91	40-150
2706-91-4	Perfluoropentanesulfonic acid	0.0235	0.0218	93	40-150
355-46-4	Perfluorohexanesulfonic acid	0.0229	0.0209	91	40-150
375-92-8	Perfluoroheptanesulfonic acid	0.0238	0.0233	98	40-150
1763-23-1	Perfluorooctanesulfonic acid	0.0232	0.0234	101	40-150
68259-12-1	Perfluorononanesulfonic acid	0.0241	0.0231	96	40-150
335-77-3	Perfluorodecanesulfonic acid	0.0241	0.0238	99	40-150
79780-39-5	Perfluorododecanesulfonic aci	0.0243	0.0237	98	40-150
757124-72-44:2	Fluorotelomer sulfonate	0.0938	0.0881	94	40-150
27619-97-2	6:2 Fluorotelomer sulfonate	0.095	0.103	108	40-150
39108-34-4	8:2 Fluorotelomer sulfonate	0.096	0.116	121	40-150
754-91-6	PFOSA	0.025	0.0268	107	40-150
31506-32-8	MeFOSA	0.025	0.0264	106	40-150
4151-50-2	EtFOSA	0.025	0.0233	93	40-150
2355-31-9	MeFOSAA	0.025	0.0235	94	40-150
2991-50-6	EtFOSAA	0.025	0.0211	84	40-150
24448-09-7	MeFOSE	0.25	0.226	90	40-150
1691-99-2	EtFOSE	0.25	0.250	100	40-150
13252-13-6	HFPO-DA (GenX)	0.1	0.0922	92	40-150
919005-14-4	ADONA	0.0945	0.0916	97	40-150
377-73-1	PFMPA	0.05	0.0473	95	40-150
863090-89-5	PFMBA	0.05	0.0482	96	40-150
151772-58-6	NFDHA	0.05	0.0497	99	40-150
756426-58-19	Cl-PF3ONS (F-53B Major)	0.0935	0.0871	93	40-150
763051-92-91	Cl-PF3OUdS (F-53B Minor)	0.0945	0.0885	94	40-150

\* = Outside of Control Limits.

# Blank Spike Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-BS	6Q15106.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	Spike ug/l	BSP ug/l	BSP %	Limits
113507-82-7	PFEESA	0.0445	0.0439	99	40-150
356-02-5	3:3 Fluorotelomer carboxylate	0.125	0.116	93	40-150
914637-49-35:3	Fluorotelomer carboxylate	0.625	0.651	104	40-150
812-70-4	7:3 Fluorotelomer carboxylate	0.625	0.652	104	40-150

CAS No.	ID Standard Recoveries	BSP	Limits
	13C4-PFBA	64%	20-150%
	13C5-PFPeA	102%	20-150%
	13C5-PFHxA	103%	20-150%
	13C4-PFHpA	100%	20-150%
	13C8-PFOA	106%	20-150%
	13C9-PFNA	98%	20-150%
	13C6-PFDA	114%	20-150%
	13C7-PFUnDA	109%	20-150%
	13C2-PFDoDA	107%	20-150%
	13C2-PFTeDA	101%	20-150%
	13C3-PFBS	109%	20-150%
	13C3-PFHxS	110%	20-150%
	13C8-PFOS	99%	20-150%
	13C8-FOSA	106%	20-150%
	d3-MeFOSA	94%	20-150%
	d5-EtFOSA	95%	20-150%
	d3-MeFOSAA	107%	20-150%
	d5-EtFOSAA	114%	20-150%
	d7-MeFOSE	107%	20-150%
	d9-EtFOSE	101%	20-150%
	13C2-4:2FTS	123%	20-150%
	13C2-6:2FTS	117%	20-150%
	13C2-8:2FTS	110%	20-150%
	13C3-HFPO-DA	102%	20-150%

\* = Outside of Control Limits.

# Matrix Spike Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-MS	6Q15114.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229
FC3558-2	6Q15113.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	FC3558-2 ug/l	Spike Q	MS ug/l	MS %	Limits
375-22-4	Perfluorobutanoic acid	0.018 U	0.0877	0.0835	95	40-150
2706-90-3	Perfluoropentanoic acid	0.0089 U	0.0439	0.0427	97	40-150
307-24-4	Perfluorohexanoic acid	0.0045 U	0.0219	0.0217	99	40-150
375-85-9	Perfluoroheptanoic acid	0.0045 U	0.0219	0.0214	98	40-150
335-67-1	Perfluorooctanoic acid	0.0045 U	0.0219	0.0225	103	40-150
375-95-1	Perfluorononanoic acid	0.0045 U	0.0219	0.0216	98	40-150
335-76-2	Perfluorodecanoic acid	0.0045 U	0.0219	0.0196	89	40-150
2058-94-8	Perfluoroundecanoic acid	0.0045 U	0.0219	0.0201	92	40-150
307-55-1	Perfluorododecanoic acid	0.0045 U	0.0219	0.0201	92	40-150
72629-94-8	Perfluorotridecanoic acid	0.0045 U	0.0219	0.0189	86	40-150
376-06-7	Perfluorotetradecanoic acid	0.0045 U	0.0219	0.0218	99	40-150
375-73-5	Perfluorobutanesulfonic acid	0.0045 U	0.0195	0.0185	95	40-150
2706-91-4	Perfluoropentanesulfonic acid	0.0045 U	0.0206	0.0214	104	40-150
355-46-4	Perfluorohexanesulfonic acid	0.0045 U	0.02	0.0203	101	40-150
375-92-8	Perfluoroheptanesulfonic acid	0.0045 U	0.0209	0.0229	110	40-150
1763-23-1	Perfluorooctanesulfonic acid	0.0045 U	0.0204	0.0197	97	40-150
68259-12-1	Perfluorononanesulfonic acid	0.0045 U	0.0211	0.0231	109	40-150
335-77-3	Perfluorodecanesulfonic acid	0.0045 U	0.0212	0.0239	113	40-150
79780-39-5	Perfluorododecanesulfonic aci	0.0045 U	0.0213	0.0213	100	40-150
757124-72-44:2	Fluorotelomer sulfonate	0.018 U	0.0822	0.0743	90	40-150
27619-97-2	6:2 Fluorotelomer sulfonate	0.018 U	0.0833	0.0869	104	40-150
39108-34-4	8:2 Fluorotelomer sulfonate	0.018 U	0.0842	0.0987	117	40-150
754-91-6	PFOSA	0.0045 U	0.0219	0.0207	94	40-150
31506-32-8	MeFOSA	0.0045 U	0.0219	0.0226	103	40-150
4151-50-2	EtFOSA	0.0045 U	0.0219	0.0221	101	40-150
2355-31-9	MeFOSAA	0.0045 U	0.0219	0.0220	100	40-150
2991-50-6	EtFOSAA	0.0045 U	0.0219	0.0187	85	40-150
24448-09-7	MeFOSE	0.045 U	0.219	0.208	95	40-150
1691-99-2	EtFOSE	0.045 U	0.219	0.222	101	40-150
13252-13-6	HFPO-DA (GenX)	0.018 U	0.0877	0.0778	89	40-150
919005-14-4	ADONA	0.018 U	0.0829	0.0804	97	40-150
377-73-1	PFMPA	0.0089 U	0.0439	0.0422	96	40-150
863090-89-5	PFMBA	0.0089 U	0.0439	0.0418	95	40-150
151772-58-6	NFDHA	0.0089 U	0.0439	0.0393	90	40-150
756426-58-19	Cl-PF3ONS (F-53B Major)	0.018 U	0.082	0.0813	99	40-150
763051-92-91	Cl-PF3OUdS (F-53B Minor)	0.018 U	0.0829	0.0740	89	40-150

\* = Outside of Control Limits.



# Matrix Spike Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-MS	6Q15114.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229
FC3558-2	6Q15113.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	FC3558-2 ug/l	Spike Q	MS ug/l	MS %	Limits
113507-82-7	PFEESA	0.0089 U	0.039	0.0352	90	40-150
356-02-5	3:3 Fluorotelomer carboxylate	0.022 U	0.11	0.124	113	40-150
914637-49-35:3	Fluorotelomer carboxylate	0.11 U	0.548	0.563	103	40-150
812-70-4	7:3 Fluorotelomer carboxylate	0.11 U	0.548	0.557	102	40-150

CAS No.	ID Standard Recoveries	MS	FC3558-2	Limits
	13C4-PFBA	101%	97%	20-150%
	13C5-PFPeA	98%	95%	20-150%
	13C5-PFHxA	100%	94%	20-150%
	13C4-PFHpA	98%	100%	20-150%
	13C8-PFOA	104%	98%	20-150%
	13C9-PFNA	101%	91%	20-150%
	13C6-PFDA	97%	99%	20-150%
	13C7-PFUnDA	97%	97%	20-150%
	13C2-PFDoDA	90%	91%	20-150%
	13C2-PFTeDA	77%	81%	20-150%
	13C3-PFBS	104%	99%	20-150%
	13C3-PFHxS	94%	95%	20-150%
	13C8-PFOS	87%	87%	20-150%
	13C8-FOSA	100%	101%	20-150%
	d3-MeFOSA	85%	91%	20-150%
	d5-EtFOSA	84%	88%	20-150%
	d3-MeFOSAA	115%	121%	20-150%
	d5-EtFOSAA	124%	120%	20-150%
	d7-MeFOSE	98%	106%	20-150%
	d9-EtFOSE	92%	99%	20-150%
	13C2-4:2FTS	115%	115%	20-150%
	13C2-6:2FTS	97%	100%	20-150%
	13C2-8:2FTS	94%	97%	20-150%
	13C3-HFPO-DA	97%	88%	20-150%

\* = Outside of Control Limits.

# Duplicate Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-DUP	6Q15118.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229
FC3558-3	6Q15115.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	FC3558-3 ug/l	DUP Q ug/l	Q	RPD	Limits
375-22-4	Perfluorobutanoic acid	0.019 U	ND		nc	30
2706-90-3	Perfluoropentanoic acid	0.0094 U	ND		nc	30
307-24-4	Perfluorohexanoic acid	0.0047 U	ND		nc	30
375-85-9	Perfluoroheptanoic acid	0.0047 U	ND		nc	30
335-67-1	Perfluorooctanoic acid	0.0047 U	ND		nc	30
375-95-1	Perfluorononanoic acid	0.0047 U	ND		nc	30
335-76-2	Perfluorodecanoic acid	0.0047 U	ND		nc	30
2058-94-8	Perfluoroundecanoic acid	0.0047 U	ND		nc	30
307-55-1	Perfluorododecanoic acid	0.0047 U	ND		nc	30
72629-94-8	Perfluorotridecanoic acid	0.0047 U	ND		nc	30
376-06-7	Perfluorotetradecanoic acid	0.0047 U	ND		nc	30
375-73-5	Perfluorobutanesulfonic acid	0.0047 U	ND		nc	30
2706-91-4	Perfluoropentanesulfonic acid	0.0047 U	ND		nc	30
355-46-4	Perfluorohexanesulfonic acid	0.0047 U	ND		nc	30
375-92-8	Perfluoroheptanesulfonic acid	0.0047 U	ND		nc	30
1763-23-1	Perfluorooctanesulfonic acid	0.0047 U	ND		nc	30
68259-12-1	Perfluorononanesulfonic acid	0.0047 U	ND		nc	30
335-77-3	Perfluorodecanesulfonic acid	0.0047 U	ND		nc	30
79780-39-5	Perfluorododecanesulfonic aci	0.0047 U	ND		nc	30
757124-72-44:2	Fluorotelomer sulfonate	0.019 U	ND		nc	30
27619-97-2	6:2 Fluorotelomer sulfonate	0.019 U	ND		nc	30
39108-34-4	8:2 Fluorotelomer sulfonate	0.019 U	ND		nc	30
754-91-6	PFOSA	0.0047 U	ND		nc	30
31506-32-8	MeFOSA	0.0047 U	ND		nc	30
4151-50-2	EtFOSA	0.0047 U	ND		nc	30
2355-31-9	MeFOSAA	0.0047 U	ND		nc	30
2991-50-6	EtFOSAA	0.0047 U	ND		nc	30
24448-09-7	MeFOSE	0.047 U	ND		nc	30
1691-99-2	EtFOSE	0.047 U	ND		nc	30
13252-13-6	HFPO-DA (GenX)	0.019 U	ND		nc	30
919005-14-4	ADONA	0.019 U	ND		nc	30
377-73-1	PFMPA	0.0094 U	ND		nc	30
863090-89-5	PFMBA	0.0094 U	ND		nc	30
151772-58-6	NFDHA	0.0094 U	ND		nc	30
756426-58-19	Cl-PF3ONS (F-53B Major)	0.019 U	ND		nc	30
763051-92-91	Cl-PF3OUdS (F-53B Minor)	0.019 U	ND		nc	30

\* = Outside of Control Limits.

# Duplicate Summary

Job Number: FC3558  
 Account: AECOMCOD AECOM, INC.  
 Project: N6274223F0104 RH Fire Suppression System

Sample	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
OP95968-DUP	6Q15118.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229
FC3558-3	6Q15115.D	1	03/21/23	MV	03/20/23	OP95968	S6Q229

The QC reported here applies to the following samples:

Method: EPA DRAFT 1633

FC3558-1, FC3558-2, FC3558-3

CAS No.	Compound	FC3558-3 ug/l	DUP Q	ug/l	Q	RPD	Limits
113507-82-7	PFEESA	0.0094	U	ND		nc	30
356-02-5	3:3 Fluorotelomer carboxylate	0.024	U	ND		nc	30
914637-49-35:3	Fluorotelomer carboxylate	0.12	U	ND		nc	30
812-70-4	7:3 Fluorotelomer carboxylate	0.12	U	ND		nc	30

CAS No.	ID Standard Recoveries	DUP	FC3558-3	Limits
	13C4-PFBA	102%	107%	20-150%
	13C5-PFPeA	99%	107%	20-150%
	13C5-PFHxA	98%	112%	20-150%
	13C4-PFHpA	103%	112%	20-150%
	13C8-PFOA	88%	101%	20-150%
	13C9-PFNA	94%	100%	20-150%
	13C6-PFDA	88%	105%	20-150%
	13C7-PFUnDA	86%	107%	20-150%
	13C2-PFDoDA	83%	100%	20-150%
	13C2-PFTeDA	56%	96%	20-150%
	13C3-PFBS	99%	102%	20-150%
	13C3-PFHxS	106%	102%	20-150%
	13C8-PFOS	83%	93%	20-150%
	13C8-FOSA	86%	100%	20-150%
	d3-MeFOSA	81%	88%	20-150%
	d5-EtFOSA	80%	94%	20-150%
	d3-MeFOSAA	89%	101%	20-150%
	d5-EtFOSAA	92%	103%	20-150%
	d7-MeFOSE	89%	99%	20-150%
	d9-EtFOSE	89%	100%	20-150%
	13C2-4:2FTS	114%	121%	20-150%
	13C2-6:2FTS	113%	117%	20-150%
	13C2-8:2FTS	96%	103%	20-150%
	13C3-HFPO-DA	101%	107%	20-150%

\* = Outside of Control Limits.