



# Sample Analysis Tracking System

**C21-12-0006**

5720 Erne Ave  
SCRS Analyte/Analyte Group : Volatile Organic Compounds

**Sample Receipt Data****Sampler Name:**

David Kawahara

**Sample Date/Time:**

12/2/2021 at 11:35 AM

**Received By:**

Sung Jung, Yean

**Receipt Date/Time:**

12/2/2021 at 1:05 PM

**Collection Remarks:**

CHLORINE RESIDUAL 0.44 FREE

**Lab Comments:**

SAMPLE TEMP 4C

**Disposal Date/Time:**

None

**Volatile Organic Compounds - GCMS (EPA 524.2)****Analyst:**

Oyadomari, Wendy

**Analysis Date/Time:**

12/2/2021 at 4:20 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Vinyl Chloride	Less than 0.5 µg/L		2 µg/L	ND
1,1-Dichloroethylene	Less than 0.5 µg/L		7 µg/L	ND
1,1,1-Trichloroethane	Less than 0.5 µg/L		200 µg/L	ND
Carbon Tetrachloride	Less than 0.5 µg/L		5 µg/L	ND
Benzene	Less than 0.5 µg/L		5 µg/L	ND
1,2-Dichloroethane	Less than 0.5 µg/L		5 µg/L	ND
Trichloroethylene	Less than 0.5 µg/L		5 µg/L	ND
p-Dichlorobenzene	Less than 0.5 µg/L		75 µg/L	ND
trans-1,2-Dichloroethylene	Less than 0.5 µg/L		100 µg/L	ND
cis-1,2-Dichloroethylene	Less than 0.5 µg/L		70 µg/L	ND
1,2-Dichloropropane	Less than 0.5 µg/L		5 µg/L	ND
Toluene	Less than 0.5 µg/L		1000 µg/L	ND

<b>Contaminant</b>	<b>Detection Limit</b>	<b>Non-Quantifiable Limit</b>	<b>MCL</b>	<b>Result</b>
Ethylbenzene	Less than 0.5 µg/L		700 µg/L	ND
Chlorobenzene	Less than 0.5 µg/L		100 µg/L	ND
o-Dichlorobenzene	Less than 0.5 µg/L		600 µg/L	ND
Styrene	Less than 0.5 µg/L		100 µg/L	ND
Total Xylenes	Less than 0.5 µg/L		10000 µg/L	ND
Tetrachloroethylene	Less than 0.5 µg/L		5 µg/L	ND
Dichloromethane	Less than 0.5 µg/L		5 µg/L	ND
1,1,2-Trichloroethane	Less than 0.5 µg/L		5 µg/L	ND
1,2,4-Trichlorobenzene	Less than 0.5 µg/L		70 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.



# Sample Analysis Tracking System

**C21-12-0012**

1713 Blackhawk Place, Honolulu, Hawaii  
SCRS Analyte/Analyte Group : Synthetic Organic Chemicals

## Sample Receipt Data

**Sampler Name:**  
Melvin Tokuda

**Sample Date/Time:**  
12/2/2021 at 12:10 PM

**Received By:**  
Oyadomari, Wendy

**Receipt Date/Time:**  
12/2/2021 at 3:00 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Level of free chlorine residue was 0.59

**Disposal Date/Time:**  
None

## Synthetic Organic Compounds (EPA 508.1)

**Analyst:**  
Sung Jung, Yean

**Analysis Date/Time:**  
12/5/2021 at 12:00 AM

**Extraction Date/Time:**  
12/3/2021 at 12:00 AM

### Sample Results:

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Hexachlorocyclopentadiene	Less than 0.05 µg/L		50 µg/L	ND
Hexachlorobenzene	Less than 0.05 µg/L		1 µg/L	ND
Lindane	Less than 0.02 µg/L		0.2 µg/L	ND
Heptachlor	Less than 0.01 µg/L		0.4 µg/L	ND
Heptachlor Epoxide	Less than 0.01 µg/L		0.2 µg/L	ND
Endrin	Less than 0.01 µg/L		2 µg/L	ND
Methoxychlor	Less than 0.05 µg/L		40 µg/L	ND
Alachlor	Less than 0.05 µg/L		2 µg/L	ND
Chlordane	Less than 0.1 µg/L	Less than 0.3 µg/L	2 µg/L	ND
Toxaphene	Less than 0.5 µg/L	Less than 1.5 µg/L	3 µg/L	ND
Aroclor 1016	Less than 0.26 µg/L			ND
Aroclor 1221	Less than 0.19 µg/L			ND
Aroclor 1232	Less than 0.23 µg/L			ND
Aroclor 1242	Less than 0.26 µg/L			ND
Aroclor 1248	Less than 0.3 µg/L			ND
Aroclor 1254	Less than 0.33 µg/L			ND
Aroclor 1260	Less than 0.36 µg/L			ND

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Simazine	Less than 0.07 µg/L		4 µg/L	ND
Atrazine	Less than 0.05 µg/L		3 µg/L	ND
Metribuzin	Less than 0.2 µg/L			ND
Aldrin	Less than 0.01 µg/L			ND
Butachlor	Less than 0.05 µg/L			ND
Dieldrin	Less than 0.01 µg/L			ND
Metolachlor	Less than 0.05 µg/L			ND
Propachlor	Less than 0.1 µg/L			ND

**Trace Amounts:**

Heptachlor Epoxide, Chlordane and Dieldrin: trace amount less than RDL

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.



# Sample Analysis Tracking System

**C21-12-0007**5720 Erne Ave  
SCRS Analyte/Analyte Group : Synthetic Organic Chemicals**Sample Receipt Data****Sampler Name:**

David Kawahara

**Sample Date/Time:**

12/2/2021 at 11:35 AM

**Received By:**

Sung Jung, Yean

**Receipt Date/Time:**

12/2/2021 at 1:05 PM

**Collection Remarks:**

None

**Lab Comments:**

Level of free chlorine residue was 0.44

**Disposal Date/Time:**

None

**Synthetic Organic Compounds (EPA 508.1)****Analyst:**

Sung Jung, Yean

**Analysis Date/Time:**

12/5/2021 at 12:00 AM

**Extraction Date/Time:**

12/3/2021 at 12:00 AM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Hexachlorocyclopentadiene	Less than 0.05 µg/L		50 µg/L	ND
Hexachlorobenzene	Less than 0.05 µg/L		1 µg/L	ND
Lindane	Less than 0.02 µg/L		0.2 µg/L	ND
Heptachlor	Less than 0.01 µg/L		0.4 µg/L	ND
Heptachlor Epoxide	Less than 0.01 µg/L		0.2 µg/L	ND
Endrin	Less than 0.01 µg/L		2 µg/L	ND
Methoxychlor	Less than 0.05 µg/L		40 µg/L	ND
Alachlor	Less than 0.05 µg/L		2 µg/L	ND
Chlordane	Less than 0.1 µg/L	Less than 0.3 µg/L	2 µg/L	ND
Toxaphene	Less than 0.5 µg/L	Less than 1.5 µg/L	3 µg/L	ND
Aroclor 1016	Less than 0.26 µg/L			ND

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Aroclor 1221	Less than 0.19 µg/L			ND
Aroclor 1232	Less than 0.23 µg/L			ND
Aroclor 1242	Less than 0.26 µg/L			ND
Aroclor 1248	Less than 0.3 µg/L			ND
Aroclor 1254	Less than 0.33 µg/L			ND
Aroclor 1260	Less than 0.36 µg/L			ND
Simazine	Less than 0.07 µg/L		4 µg/L	ND
Atrazine	Less than 0.05 µg/L		3 µg/L	ND
Metribuzin	Less than 0.2 µg/L			ND
Aldrin	Less than 0.01 µg/L			ND
Butachlor	Less than 0.05 µg/L			ND
Dieldrin	Less than 0.01 µg/L			ND
Metolachlor	Less than 0.05 µg/L			ND
Propachlor	Less than 0.1 µg/L			ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.



# Sample Analysis Tracking System

**C21-12-0009**

1610 Cowslip Lane, Honolulu, Hawaii 96819  
SCRS Analyte/Analyte Group : Volatile Organic Compounds

**Sample Receipt Data****Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 11:00 AM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

CHLORINE RESIDUAL 0.19

**Lab Comments:**

SAMPLE TEMP 4C

**Disposal Date/Time:**

None

**Volatile Organic Compounds - GCMS (EPA 524.2)****Analyst:**

Oyadomari, Wendy

**Analysis Date/Time:**

12/2/2021 at 5:16 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Vinyl Chloride	Less than 0.5 µg/L		2 µg/L	ND
1,1-Dichloroethylene	Less than 0.5 µg/L		7 µg/L	ND
1,1,1-Trichloroethane	Less than 0.5 µg/L		200 µg/L	ND
Carbon Tetrachloride	Less than 0.5 µg/L		5 µg/L	ND
Benzene	Less than 0.5 µg/L		5 µg/L	ND
1,2-Dichloroethane	Less than 0.5 µg/L		5 µg/L	ND
Trichloroethylene	Less than 0.5 µg/L		5 µg/L	ND
p-Dichlorobenzene	Less than 0.5 µg/L		75 µg/L	ND
trans-1,2-Dichloroethylene	Less than 0.5 µg/L		100 µg/L	ND
cis-1,2-Dichloroethylene	Less than 0.5 µg/L		70 µg/L	ND
1,2-Dichloropropane	Less than 0.5 µg/L		5 µg/L	ND
Toluene	Less than 0.5 µg/L		1000 µg/L	ND

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Ethylbenzene	Less than 0.5 µg/L		700 µg/L	ND
Chlorobenzene	Less than 0.5 µg/L		100 µg/L	ND
o-Dichlorobenzene	Less than 0.5 µg/L		600 µg/L	ND
Styrene	Less than 0.5 µg/L		100 µg/L	ND
Total Xylenes	Less than 0.5 µg/L		10000 µg/L	1.60 µg/L
Tetrachloroethylene	Less than 0.5 µg/L		5 µg/L	ND
Dichloromethane	Less than 0.5 µg/L		5 µg/L	ND
1,1,2-Trichloroethane	Less than 0.5 µg/L		5 µg/L	ND
1,2,4-Trichlorobenzene	Less than 0.5 µg/L		70 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19. NAPHTHALENE (not-regulated): 1.4 PPB





# Sample Analysis Tracking System

**C21-12-0011**

Holy Family Catholic Academy  
SCRS Analyte/Analyte Group : Volatile Organic Compounds

**Sample Receipt Data****Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 1:50 PM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

CHLORINE RESIDUAL 0.15

**Lab Comments:**

SAMPLE TEMP 4C

**Disposal Date/Time:**

None

**Volatile Organic Compounds - GCMS (EPA 524.2)****Analyst:**

Oyadomari, Wendy

**Analysis Date/Time:**

12/2/2021 at 5:44 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Vinyl Chloride	Less than 0.5 µg/L		2 µg/L	ND
1,1-Dichloroethylene	Less than 0.5 µg/L		7 µg/L	ND
1,1,1-Trichloroethane	Less than 0.5 µg/L		200 µg/L	ND
Carbon Tetrachloride	Less than 0.5 µg/L		5 µg/L	ND
Benzene	Less than 0.5 µg/L		5 µg/L	ND
1,2-Dichloroethane	Less than 0.5 µg/L		5 µg/L	ND
Trichloroethylene	Less than 0.5 µg/L		5 µg/L	ND
p-Dichlorobenzene	Less than 0.5 µg/L		75 µg/L	ND
trans-1,2-Dichloroethylene	Less than 0.5 µg/L		100 µg/L	ND
cis-1,2-Dichloroethylene	Less than 0.5 µg/L		70 µg/L	ND
1,2-Dichloropropane	Less than 0.5 µg/L		5 µg/L	ND
Toluene	Less than 0.5 µg/L		1000 µg/L	ND

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Ethylbenzene	Less than 0.5 µg/L		700 µg/L	ND
Chlorobenzene	Less than 0.5 µg/L		100 µg/L	ND
o-Dichlorobenzene	Less than 0.5 µg/L		600 µg/L	ND
Styrene	Less than 0.5 µg/L		100 µg/L	ND
Total Xylenes	Less than 0.5 µg/L		10000 µg/L	ND
Tetrachloroethylene	Less than 0.5 µg/L		5 µg/L	ND
Dichloromethane	Less than 0.5 µg/L		5 µg/L	ND
1,1,2-Trichloroethane	Less than 0.5 µg/L		5 µg/L	ND
1,2,4-Trichlorobenzene	Less than 0.5 µg/L		70 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.



# Sample Analysis Tracking System

**C21-12-0008**

1713 Blackhawk Place, Honolulu, Hawaii  
SCRS Analyte/Analyte Group : Volatile Organic Compounds

**Sample Receipt Data****Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 12:10 PM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

CHLORINE RESIDUAL 0.59

**Lab Comments:**

SAMPLE TEMP 4C

**Disposal Date/Time:**

None

**Volatile Organic Compounds - GCMS (EPA 524.2)****Analyst:**

Oyadomari, Wendy

**Analysis Date/Time:**

12/2/2021 at 4:48 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Vinyl Chloride	Less than 0.5 µg/L		2 µg/L	ND
1,1-Dichloroethylene	Less than 0.5 µg/L		7 µg/L	ND
1,1,1-Trichloroethane	Less than 0.5 µg/L		200 µg/L	ND
Carbon Tetrachloride	Less than 0.5 µg/L		5 µg/L	ND
Benzene	Less than 0.5 µg/L		5 µg/L	ND
1,2-Dichloroethane	Less than 0.5 µg/L		5 µg/L	ND
Trichloroethylene	Less than 0.5 µg/L		5 µg/L	ND
p-Dichlorobenzene	Less than 0.5 µg/L		75 µg/L	ND
trans-1,2-Dichloroethylene	Less than 0.5 µg/L		100 µg/L	ND
cis-1,2-Dichloroethylene	Less than 0.5 µg/L		70 µg/L	ND
1,2-Dichloropropane	Less than 0.5 µg/L		5 µg/L	ND
Toluene	Less than 0.5 µg/L		1000 µg/L	ND

<b>Contaminant</b>	<b>Detection Limit</b>	<b>Non-Quantifiable Limit</b>	<b>MCL</b>	<b>Result</b>
Ethylbenzene	Less than 0.5 µg/L		700 µg/L	ND
Chlorobenzene	Less than 0.5 µg/L		100 µg/L	ND
o-Dichlorobenzene	Less than 0.5 µg/L		600 µg/L	ND
Styrene	Less than 0.5 µg/L		100 µg/L	ND
Total Xylenes	Less than 0.5 µg/L		10000 µg/L	ND
Tetrachloroethylene	Less than 0.5 µg/L		5 µg/L	ND
Dichloromethane	Less than 0.5 µg/L		5 µg/L	ND
1,1,2-Trichloroethane	Less than 0.5 µg/L		5 µg/L	ND
1,2,4-Trichlorobenzene	Less than 0.5 µg/L		70 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.



# Sample Analysis Tracking System

**C21-12-0010**

4072 Ironwood Loop, Honolulu, Hawaii 96819  
SCRS Analyte/Analyte Group : Volatile Organic Compounds

**Sample Receipt Data****Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 1:00 PM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

CHLORINE RESIDUAL 0.39

**Lab Comments:**

SAMPLE TEMP 4C

**Disposal Date/Time:**

None

**Volatile Organic Compounds - GCMS (EPA 524.2)****Analyst:**

Oyadomari, Wendy

**Analysis Date/Time:**

12/2/2021 at 5:44 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Vinyl Chloride	Less than 0.5 µg/L		2 µg/L	ND
1,1-Dichloroethylene	Less than 0.5 µg/L		7 µg/L	ND
1,1,1-Trichloroethane	Less than 0.5 µg/L		200 µg/L	ND
Carbon Tetrachloride	Less than 0.5 µg/L		5 µg/L	ND
Benzene	Less than 0.5 µg/L		5 µg/L	ND
1,2-Dichloroethane	Less than 0.5 µg/L		5 µg/L	ND
Trichloroethylene	Less than 0.5 µg/L		5 µg/L	ND
p-Dichlorobenzene	Less than 0.5 µg/L		75 µg/L	ND
trans-1,2-Dichloroethylene	Less than 0.5 µg/L		100 µg/L	ND
cis-1,2-Dichloroethylene	Less than 0.5 µg/L		70 µg/L	ND
1,2-Dichloropropane	Less than 0.5 µg/L		5 µg/L	ND
Toluene	Less than 0.5 µg/L		1000 µg/L	ND

<b>Contaminant</b>	<b>Detection Limit</b>	<b>Non-Quantifiable Limit</b>	<b>MCL</b>	<b>Result</b>
Ethylbenzene	Less than 0.5 µg/L		700 µg/L	ND
Chlorobenzene	Less than 0.5 µg/L		100 µg/L	ND
o-Dichlorobenzene	Less than 0.5 µg/L		600 µg/L	ND
Styrene	Less than 0.5 µg/L		100 µg/L	ND
Total Xylenes	Less than 0.5 µg/L		10000 µg/L	ND
Tetrachloroethylene	Less than 0.5 µg/L		5 µg/L	ND
Dichloromethane	Less than 0.5 µg/L		5 µg/L	ND
1,1,2-Trichloroethane	Less than 0.5 µg/L		5 µg/L	ND
1,2,4-Trichlorobenzene	Less than 0.5 µg/L		70 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.



# Sample Analysis Tracking System

## C21-12-0013

1610 Cowslip Lane, Honolulu, Hawaii 96819  
SCRS Analyte/Analyte Group : Synthetic Organic Chemicals

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 11:00 AM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

None

**Lab Comments:**

Level of free chlorine residue was 0.19

**Disposal Date/Time:**

None

### Synthetic Organic Compounds (EPA 508.1)

**Analyst:**

Sung Jung, Yean

**Analysis Date/Time:**

12/5/2021 at 12:00 AM

**Extraction Date/Time:**

12/3/2021 at 12:00 AM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Hexachlorocyclopentadiene	Less than 0.05 µg/L		50 µg/L	ND
Hexachlorobenzene	Less than 0.05 µg/L		1 µg/L	ND
Lindane	Less than 0.02 µg/L		0.2 µg/L	ND
Heptachlor	Less than 0.01 µg/L		0.4 µg/L	ND
Heptachlor Epoxide	Less than 0.01 µg/L		0.2 µg/L	ND
Endrin	Less than 0.01 µg/L		2 µg/L	ND
Methoxychlor	Less than 0.05 µg/L		40 µg/L	ND
Alachlor	Less than 0.05 µg/L		2 µg/L	ND
Chlordane	Less than 0.1 µg/L	Less than 0.3 µg/L	2 µg/L	ND
Toxaphene	Less than 0.5 µg/L	Less than 1.5 µg/L	3 µg/L	ND
Aroclor 1016	Less than 0.26 µg/L			ND

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Aroclor 1221	Less than 0.19 µg/L			ND
Aroclor 1232	Less than 0.23 µg/L			ND
Aroclor 1242	Less than 0.26 µg/L			ND
Aroclor 1248	Less than 0.3 µg/L			ND
Aroclor 1254	Less than 0.33 µg/L			ND
Aroclor 1260	Less than 0.36 µg/L			ND
Simazine	Less than 0.07 µg/L		4 µg/L	ND
Atrazine	Less than 0.05 µg/L		3 µg/L	ND
Metribuzin	Less than 0.2 µg/L			ND
Aldrin	Less than 0.01 µg/L			ND
Butachlor	Less than 0.05 µg/L			ND
Dieldrin	Less than 0.01 µg/L			ND
Metolachlor	Less than 0.05 µg/L			ND
Propachlor	Less than 0.1 µg/L			ND

**Trace Amounts:**

Heptachlor Epoxide and Dieldrin: trace amount less than RDL

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.





# Sample Analysis Tracking System

**C21-12-0014**

4072 Ironwood Loop, Honolulu, Hawaii 96819  
SCRS Analyte/Analyte Group : Synthetic Organic Chemicals

**Sample Receipt Data****Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 1:00 PM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

None

**Lab Comments:**

Level of free chlorine residue was 0.39

**Disposal Date/Time:**

None

**Synthetic Organic Compounds (EPA 508.1)****Analyst:**

Sung Jung, Yean

**Analysis Date/Time:**

12/5/2021 at 12:00 AM

**Extraction Date/Time:**

12/3/2021 at 12:00 AM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Hexachlorocyclopentadiene	Less than 0.05 µg/L		50 µg/L	ND
Hexachlorobenzene	Less than 0.05 µg/L		1 µg/L	ND
Lindane	Less than 0.02 µg/L		0.2 µg/L	ND
Heptachlor	Less than 0.01 µg/L		0.4 µg/L	ND
Heptachlor Epoxide	Less than 0.01 µg/L		0.2 µg/L	ND
Endrin	Less than 0.01 µg/L		2 µg/L	ND
Methoxychlor	Less than 0.05 µg/L		40 µg/L	ND
Alachlor	Less than 0.05 µg/L		2 µg/L	ND
Chlordane	Less than 0.1 µg/L	Less than 0.3 µg/L	2 µg/L	ND
Toxaphene	Less than 0.5 µg/L	Less than 1.5 µg/L	3 µg/L	ND
Aroclor 1016	Less than 0.26 µg/L			ND

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Aroclor 1221	Less than 0.19 µg/L			ND
Aroclor 1232	Less than 0.23 µg/L			ND
Aroclor 1242	Less than 0.26 µg/L			ND
Aroclor 1248	Less than 0.3 µg/L			ND
Aroclor 1254	Less than 0.33 µg/L			ND
Aroclor 1260	Less than 0.36 µg/L			ND
Simazine	Less than 0.07 µg/L		4 µg/L	ND
Atrazine	Less than 0.05 µg/L		3 µg/L	ND
Metribuzin	Less than 0.2 µg/L			ND
Aldrin	Less than 0.01 µg/L			ND
Butachlor	Less than 0.05 µg/L			ND
Dieldrin	Less than 0.01 µg/L			0.02 µg/L
Metolachlor	Less than 0.05 µg/L			ND
Propachlor	Less than 0.1 µg/L			ND

**Trace Amounts:**

Heptachlor Epoxide, Chlordane: Trace amount less than RDL

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.



# Sample Analysis Tracking System

**E21-12-0001**

Red Hill Elementary Cafeteria Kitchen Sink  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

11/30/2021 at 12:30 PM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/1/2021 at 10:13 AM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 10:39 AM

**Read By:**

Kim, June

**Read By Date/Time:**

12/2/2021 at 12:25 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 1:55 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/3/2021 at 10:58 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## C21-12-0019

Holy Family Catholic Academy  
SCRS Analyte/Analyte Group : Metals

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 1:50 PM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

None

**Lab Comments:**

None

**Disposal Date/Time:**

None

### Inorganic Metals - Flame AA (SM3111B)

**Analyst:**

Chun, Elsie

**Analysis Date/Time:**

12/3/2021 at 3:00 PM

**Preservation Date/Time:**

12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	NA
Sodium	Less than 1 mg/L			45.00 mg/L
Iron	Less than 0.1 mg/L		0.3 mg/L	NA
Calcium	Less than 1 mg/L			NA
Zinc	Less than 0.1 mg/L		5 mg/L	NA
Calcium Hardness as CaCO <sub>3</sub>				NA
Magnesium				NA

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

### Inorganic Metals - Graphite Furnace (EPA 200.9)

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	NA
Arsenic	Less than 2 µg/L		10 µg/L	NA
Beryllium	Less than 0.5 µg/L		4 µg/L	NA
Cadmium	Less than 0.2 µg/L		5 µg/L	NA
Chromium	Less than 2 µg/L		100 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	NA
Nickel	Less than 5 µg/L			NA
Selenium	Less than 5 µg/L		50 µg/L	ND
Thallium	Less than 1 µg/L		2 µg/L	NA

**Trace Amounts:**  
None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Inorganic Regular Metals - ICPMS (EPA 200.8)**

---

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	ND
Arsenic	Less than 2 µg/L		10 µg/L	ND
Barium	Less than 10 µg/L		2000 µg/L	ND
Beryllium	Less than 0.5 µg/L		4 µg/L	ND
Cadmium	Less than 0.2 µg/L		5 µg/L	ND
Chromium	Less than 2 µg/L		100 µg/L	NA
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	ND

<b>Contaminant</b>	<b>Detection Limit</b>	<b>Non-Quantifiable Limit</b>	<b>MCL</b>	<b>Result</b>
Mercury	Less than 0.5 µg/L		2 µg/L	ND
Nickel	Less than 5 µg/L			ND
Selenium	Less than 5 µg/L		50 µg/L	NA
Thallium	Less than 1 µg/L		2 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19. Cr & Se analyzed by EPA 200.9 due to matrix interference in EPA 200.8



# Sample Analysis Tracking System

## C21-12-0017

1610 Cowslip Lane, Honolulu, Hawaii 96819  
SCRS Analyte/Analyte Group : Metals

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 11:00 AM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

None

**Lab Comments:**

None

**Disposal Date/Time:**

None

### Inorganic Metals - Flame AA (SM3111B)

**Analyst:**

Chun, Elsie

**Analysis Date/Time:**

12/3/2021 at 3:00 PM

**Preservation Date/Time:**

12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	NA
Sodium	Less than 1 mg/L			58.00 mg/L
Iron	Less than 0.1 mg/L		0.3 mg/L	NA
Calcium	Less than 1 mg/L			NA
Zinc	Less than 0.1 mg/L		5 mg/L	NA
Calcium Hardness as CaCO <sub>3</sub>				NA
Magnesium				NA

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

### Inorganic Metals - Graphite Furnace (EPA 200.9)

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	NA
Arsenic	Less than 2 µg/L		10 µg/L	NA
Beryllium	Less than 0.5 µg/L		4 µg/L	NA
Cadmium	Less than 0.2 µg/L		5 µg/L	NA
Chromium	Less than 2 µg/L		100 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	NA
Nickel	Less than 5 µg/L			NA
Selenium	Less than 5 µg/L		50 µg/L	ND
Thallium	Less than 1 µg/L		2 µg/L	NA

**Trace Amounts:**  
None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Inorganic Regular Metals - ICPMS (EPA 200.8)**

---

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	ND
Arsenic	Less than 2 µg/L		10 µg/L	ND
Barium	Less than 10 µg/L		2000 µg/L	ND
Beryllium	Less than 0.5 µg/L		4 µg/L	ND
Cadmium	Less than 0.2 µg/L		5 µg/L	ND
Chromium	Less than 2 µg/L		100 µg/L	NA
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	ND



<b>Contaminant</b>	<b>Detection Limit</b>	<b>Non-Quantifiable Limit</b>	<b>MCL</b>	<b>Result</b>
Mercury	Less than 0.5 µg/L		2 µg/L	ND
Nickel	Less than 5 µg/L			ND
Selenium	Less than 5 µg/L		50 µg/L	NA
Thallium	Less than 1 µg/L		2 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19. Cr & Se analyzed by EPA 200.9 due to matrix interference in EPA 200.8



# Sample Analysis Tracking System

**E21-12-0003**

Aliamanu Child and Youth Service Kitchen Sink  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Isaiah Kela-Pacheco

**Sample Date/Time:**

11/30/2021 at 1:30 PM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/1/2021 at 10:15 AM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 10:39 AM

**Read By:**

Kim, June

**Read By Date/Time:**

12/2/2021 at 12:25 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 1:55 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/3/2021 at 10:58 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## C21-12-0018

4072 Ironwood Loop, Honolulu, Hawaii 96819  
SCRS Analyte/Analyte Group : Metals

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 1:00 PM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

None

**Lab Comments:**

None

**Disposal Date/Time:**

None

### Inorganic Metals - Flame AA (SM3111B)

**Analyst:**

Chun, Elsie

**Analysis Date/Time:**

12/3/2021 at 3:00 PM

**Preservation Date/Time:**

12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	NA
Sodium	Less than 1 mg/L			60.00 mg/L
Iron	Less than 0.1 mg/L		0.3 mg/L	NA
Calcium	Less than 1 mg/L			NA
Zinc	Less than 0.1 mg/L		5 mg/L	NA
Calcium Hardness as CaCO <sub>3</sub>				NA
Magnesium				NA

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

### Inorganic Metals - Graphite Furnace (EPA 200.9)

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	NA
Arsenic	Less than 2 µg/L		10 µg/L	NA
Beryllium	Less than 0.5 µg/L		4 µg/L	NA
Cadmium	Less than 0.2 µg/L		5 µg/L	NA
Chromium	Less than 2 µg/L		100 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	NA
Nickel	Less than 5 µg/L			NA
Selenium	Less than 5 µg/L		50 µg/L	ND
Thallium	Less than 1 µg/L		2 µg/L	NA

**Trace Amounts:**  
None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Inorganic Regular Metals - ICPMS (EPA 200.8)**

---

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	ND
Arsenic	Less than 2 µg/L		10 µg/L	ND
Barium	Less than 10 µg/L		2000 µg/L	ND
Beryllium	Less than 0.5 µg/L		4 µg/L	ND
Cadmium	Less than 0.2 µg/L		5 µg/L	ND
Chromium	Less than 2 µg/L		100 µg/L	NA
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	ND

<b>Contaminant</b>	<b>Detection Limit</b>	<b>Non-Quantifiable Limit</b>	<b>MCL</b>	<b>Result</b>
Mercury	Less than 0.5 µg/L		2 µg/L	ND
Nickel	Less than 5 µg/L			ND
Selenium	Less than 5 µg/L		50 µg/L	NA
Thallium	Less than 1 µg/L		2 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19. Cr & Se analyzed by EPA 200.9 due to matrix interference in EPA 200.8



# Sample Analysis Tracking System

## C21-12-0016

1713 Blackhawk Place, Honolulu, Hawaii  
SCRS Analyte/Analyte Group : Metals

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 12:10 PM

**Received By:**

Oyadomari, Wendy

**Receipt Date/Time:**

12/2/2021 at 3:00 PM

**Collection Remarks:**

None

**Lab Comments:**

None

**Disposal Date/Time:**

None

### Inorganic Metals - Flame AA (SM3111B)

**Analyst:**

Chun, Elsie

**Analysis Date/Time:**

12/3/2021 at 3:00 PM

**Preservation Date/Time:**

12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	NA
Sodium	Less than 1 mg/L			57.00 mg/L
Iron	Less than 0.1 mg/L		0.3 mg/L	NA
Calcium	Less than 1 mg/L			NA
Zinc	Less than 0.1 mg/L		5 mg/L	NA
Calcium Hardness as CaCO <sub>3</sub>				NA
Magnesium				NA

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

### Inorganic Metals - Graphite Furnace (EPA 200.9)

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	NA
Arsenic	Less than 2 µg/L		10 µg/L	NA
Beryllium	Less than 0.5 µg/L		4 µg/L	NA
Cadmium	Less than 0.2 µg/L		5 µg/L	NA
Chromium	Less than 2 µg/L		100 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	NA
Nickel	Less than 5 µg/L			NA
Selenium	Less than 5 µg/L		50 µg/L	ND
Thallium	Less than 1 µg/L		2 µg/L	NA

**Trace Amounts:**  
None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Inorganic Regular Metals - ICPMS (EPA 200.8)**

---

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	ND
Arsenic	Less than 2 µg/L		10 µg/L	ND
Barium	Less than 10 µg/L		2000 µg/L	ND
Beryllium	Less than 0.5 µg/L		4 µg/L	ND
Cadmium	Less than 0.2 µg/L		5 µg/L	ND
Chromium	Less than 2 µg/L		100 µg/L	NA
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	ND

<b>Contaminant</b>	<b>Detection Limit</b>	<b>Non-Quantifiable Limit</b>	<b>MCL</b>	<b>Result</b>
Mercury	Less than 0.5 µg/L		2 µg/L	ND
Nickel	Less than 5 µg/L			ND
Selenium	Less than 5 µg/L		50 µg/L	NA
Thallium	Less than 1 µg/L		2 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19. Cr & Se analyzed by EPA 200.9 due to matrix interference in EPA 200.8





# Sample Analysis Tracking System

## E21-12-0005

Nimitz Elementary School Cafeteria Sink  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

11/30/2021 at 2:20 PM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/1/2021 at 10:15 AM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 10:41 AM

**Read By:**

Kim, June

**Read By Date/Time:**

12/2/2021 at 12:25 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 1:55 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/3/2021 at 10:58 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0002

Aliamanu Child Development Center  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 11/30/2021 at 1:13 PM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/1/2021 at 10:15 AM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/1/2021 at 10:39 AM

**Read By:** Kim, June  
**Read By Date/Time:** 12/2/2021 at 12:25 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/1/2021 at 1:55 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/3/2021 at 10:58 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0006**

Mokulele Elementary School Cafeteria Sink  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

11/30/2021 at 3:00 PM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/1/2021 at 10:15 AM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 10:39 AM

**Read By:**

Kim, June

**Read By Date/Time:**

12/2/2021 at 12:25 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 1:55 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/3/2021 at 10:58 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0007

Hickam Elementary School Cafeteria Sink  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

11/30/2021 at 3:30 PM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/1/2021 at 10:15 AM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 10:39 AM

**Read By:**

Kim, June

**Read By Date/Time:**

12/2/2021 at 12:25 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 1:55 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/3/2021 at 10:58 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0004

Pearl Harbor Elementary School Cafeteria Sink  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

11/30/2021 at 1:50 PM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/1/2021 at 10:15 AM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 10:39 AM

**Read By:**

Kim, June

**Read By Date/Time:**

12/2/2021 at 12:25 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 1:55 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/3/2021 at 10:58 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## C21-12-0020

5720 Erne Ave  
SCRS Analyte/Analyte Group : Metals

### Sample Receipt Data

**Sampler Name:**  
David Kawahara

**Sample Date/Time:**  
12/2/2021 at 11:35 AM

**Received By:**  
Sung Jung, Yean

**Receipt Date/Time:**  
12/2/2021 at 1:05 PM

**Collection Remarks:**  
None

**Lab Comments:**  
None

**Disposal Date/Time:**  
None

### Inorganic Metals - Flame AA (SM3111B)

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 3:00 PM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

#### Sample Results:

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	NA
Sodium	Less than 1 mg/L			25.00 mg/L
Iron	Less than 0.1 mg/L		0.3 mg/L	NA
Calcium	Less than 1 mg/L			NA
Zinc	Less than 0.1 mg/L		5 mg/L	NA
Calcium Hardness as CaCO <sub>3</sub>				NA
Magnesium				NA

**Trace Amounts:**  
None

#### Lab Comments:

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

### Inorganic Metals - Graphite Furnace (EPA 200.9)

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	NA
Arsenic	Less than 2 µg/L		10 µg/L	NA
Beryllium	Less than 0.5 µg/L		4 µg/L	NA
Cadmium	Less than 0.2 µg/L		5 µg/L	NA
Chromium	Less than 2 µg/L		100 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	NA
Nickel	Less than 5 µg/L			NA
Selenium	Less than 5 µg/L		50 µg/L	ND
Thallium	Less than 1 µg/L		2 µg/L	NA

**Trace Amounts:**  
None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Inorganic Regular Metals - ICPMS (EPA 200.8)**

---

**Analyst:**  
Chun, Elsie

**Analysis Date/Time:**  
12/3/2021 at 9:00 AM

**Preservation Date/Time:**  
12/2/2021 at 4:00 PM

**Sample Results:**

Contaminant	Detection Limit	Non-Quantifiable Limit	MCL	Result
Antimony	Less than 2 µg/L		6 µg/L	ND
Arsenic	Less than 2 µg/L		10 µg/L	ND
Barium	Less than 10 µg/L		2000 µg/L	ND
Beryllium	Less than 0.5 µg/L		4 µg/L	ND
Cadmium	Less than 0.2 µg/L		5 µg/L	ND
Chromium	Less than 2 µg/L		100 µg/L	NA
Copper	Less than 25 µg/L	Less than 50 µg/L	1300 µg/L	ND
Lead	Less than 2.5 µg/L	Less than 5 µg/L	15 µg/L	ND

<b>Contaminant</b>	<b>Detection Limit</b>	<b>Non-Quantifiable Limit</b>	<b>MCL</b>	<b>Result</b>
Mercury	Less than 0.5 µg/L		2 µg/L	ND
Nickel	Less than 5 µg/L			ND
Selenium	Less than 5 µg/L		50 µg/L	NA
Thallium	Less than 1 µg/L		2 µg/L	ND

**Trace Amounts:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19. Cr & Se analyzed by EPA 200.9 due to matrix interference in EPA 200.8





# Sample Analysis Tracking System

**E21-12-0008**

Pearl Kai Elementary Cafeteria Sink  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

11/30/2021 at 4:00 PM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/1/2021 at 10:15 AM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 10:41 AM

**Read By:**

Kim, June

**Read By Date/Time:**

12/3/2021 at 12:25 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/1/2021 at 1:55 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/3/2021 at 10:58 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0009**

Iroquois Point Elementary School Cafeteria  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** David Kawahara  
**Sample Date/Time:** 12/1/2021 at 10:30 AM  
**Received By:** Fox, Paul  
**Receipt Date/Time:** 12/1/2021 at 3:00 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Fox, Paul  
**Analysis Date/Time:** 12/1/2021 at 3:15 PM  
**Read By:** Fox, Paul  
**Read By Date/Time:** 12/2/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Fox, Paul  
**Analysis Date/Time:** 12/1/2021 at 3:50 PM  
**Read By:** Fox, Paul  
**Read By Date/Time:** 12/3/2021 at 3:30 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0011**

5720 Erne Ave  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** David Kawahara  
**Sample Date/Time:** 12/2/2021 at 11:25 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/2/2021 at 1:15 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/2/2021 at 2:52 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/3/2021 at 3:00 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
HPC per SDWB

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/2/2021 at 3:13 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/4/2021 at 3:04 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
HPC per SDWB



# Sample Analysis Tracking System

## E21-12-0010

1829 Fox Boulevard, Honolulu, Hawaii 96818  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
David Kawahara

**Sample Date/Time:**  
12/1/2021 at 12:05 PM

**Received By:**  
Fox, Paul

**Receipt Date/Time:**  
12/1/2021 at 3:00 PM

**Collection Remarks:**  
upstairs masterbath sink on right

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Fox, Paul

**Analysis Date/Time:**  
12/1/2021 at 3:15 PM

**Read By:**  
Fox, Paul

**Read By Date/Time:**  
12/2/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Fox, Paul

**Analysis Date/Time:**  
12/1/2021 at 3:50 PM

**Read By:**  
Fox, Paul

**Read By Date/Time:**  
12/3/2021 at 3:30 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	9 CFU
HPC2 1.0	6 CFU
HPC Result	8 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0012

1713 Blackhawk Place, Honolulu, Hawaii 96819  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 12:10 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/2/2021 at 2:46 PM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/2/2021 at 2:52 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/3/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

HPC per SDWB

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/2/2021 at 3:13 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/4/2021 at 3:04 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	2 CFU
HPC2 1.0	2 CFU
HPC Result	2 CFU/ml

**Lab Comments:**

HPC per SDWB



# Sample Analysis Tracking System

## E21-12-0015

1316 Eagle Circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** David Kawahara  
**Sample Date/Time:** 12/3/2021 at 10:43 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/3/2021 at 2:38 PM

**Collection Remarks:**  
kitchen sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/3/2021 at 4:17 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/4/2021 at 4:32 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/3/2021 at 4:20 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/5/2021 at 2:36 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0014**

Holy Family Catholic Academy  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/2/2021 at 1:50 PM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/2/2021 at 2:46 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/2/2021 at 2:53 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/3/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
HPC per SDWB

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/2/2021 at 3:13 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/4/2021 at 3:04 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	3 CFU
HPC2 1.0	4 CFU
HPC Result	4 CFU/ml

**Lab Comments:**  
HPC per SDWB



# Sample Analysis Tracking System

**E21-12-0017**

6811 Milo Lane  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** David Kawahara  
**Sample Date/Time:** 12/3/2021 at 12:18 PM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/3/2021 at 2:38 PM

**Collection Remarks:**  
laundry sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/3/2021 at 4:17 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/4/2021 at 4:32 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/3/2021 at 4:20 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/5/2021 at 2:36 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None





# Sample Analysis Tracking System

**E21-12-0018**

3158 Snyder Court  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
David Kawahara

**Sample Date/Time:**  
12/3/2021 at 1:05 PM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/3/2021 at 2:38 PM

**Collection Remarks:**  
kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/3/2021 at 4:17 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/4/2021 at 4:32 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/3/2021 at 4:20 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/5/2021 at 2:36 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0016**

6813 Milo Lane  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** David Kawahara  
**Sample Date/Time:** 12/3/2021 at 11:35 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/3/2021 at 2:38 PM

**Collection Remarks:**  
bottom floor bath sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/3/2021 at 4:17 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/5/2021 at 4:32 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/3/2021 at 4:20 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/5/2021 at 2:36 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0013

4072 Ironwood Loop, Honolulu, Hawaii 96818  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/2/2021 at 1:00 PM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/2/2021 at 2:46 PM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/2/2021 at 2:52 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/3/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

HPC per SDWB

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/2/2021 at 3:13 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/4/2021 at 3:04 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	3 CFU
HPC2 1.0	4 CFU
HPC Result	4 CFU/ml

**Lab Comments:**

HPC per SDWB



# Sample Analysis Tracking System

## E21-12-0020

3054 Vaessen Court, Honolulu, Hawaii  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/3/2021 at 12:00 PM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/3/2021 at 3:25 PM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/3/2021 at 4:17 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/4/2021 at 4:32 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/3/2021 at 4:20 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/5/2021 at 2:36 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0019**

2760 Stowell Circle, Honolulu, Hawaii  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/3/2021 at 11:10 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/3/2021 at 3:25 PM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/3/2021 at 4:17 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/4/2021 at 4:32 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/3/2021 at 4:20 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/5/2021 at 2:36 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	8 CFU
HPC2 0.1	19 CFU
HPC1 1.0	1 CFU
HPC2 1.0	0 CFU
HPC Result	14 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0021

3276 Maloelap Street, Honolulu, Hawaii  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/3/2021 at 12:30 PM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/3/2021 at 3:25 PM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/3/2021 at 4:20 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/5/2021 at 4:32 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/3/2021 at 4:20 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/5/2021 at 2:36 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0023

6230 Naupaka Street, Honolulu, Hawaii  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/4/2021 at 9:35 AM

**Received By:**

Fox, Paul

**Receipt Date/Time:**

12/4/2021 at 12:20 PM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/4/2021 at 1:41 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/5/2021 at 1:58 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/4/2021 at 2:14 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/6/2021 at 2:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0022

4685 Kou Lane, Honolulu, Hawaii  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Melvin Tokuda

**Sample Date/Time:**

12/4/2021 at 9:30 AM

**Received By:**

Fox, Paul

**Receipt Date/Time:**

12/4/2021 at 12:20 PM

**Collection Remarks:**

None

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/4/2021 at 1:40 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/5/2021 at 1:58 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/4/2021 at 2:14 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/6/2021 at 2:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

None





# Sample Analysis Tracking System

**E21-12-0027**

Red Hill Upper Storage Tank  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Elizabeth Galvez  
**Sample Date/Time:** 12/6/2021 at 3:28 PM  
**Received By:** Kim, June  
**Receipt Date/Time:** 12/6/2021 at 2:40 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/6/2021 at 3:52 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 8:27 AM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Analysis - 12/06/2021 02:52p

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Fox, Paul  
**Analysis Date/Time:** 12/6/2021 at 4:30 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 1:53 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0026**

Red Hill Shaft  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Elizabeth Galvez  
**Sample Date/Time:** 12/6/2021 at 2:00 PM  
**Received By:** Kim, June  
**Receipt Date/Time:** 12/6/2021 at 2:40 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/6/2021 at 2:52 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 8:27 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
Colisure results emailed to Mel Tokuda, 12/8/21 8:41am TL

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Fox, Paul  
**Analysis Date/Time:** 12/6/2021 at 4:30 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 1:53 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	Est. 670 CFU
HPC2 0.1	Est. 660 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	Est. 6700 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0025

Pearl Harbor Church of Christ  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Lauren Cruz / Adam Teckell  
**Sample Date/Time:** 12/6/2021 at 11:10 AM

**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/6/2021 at 12:14 PM

**Collection Remarks:**  
No odor

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/6/2021 at 12:25 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/7/2021 at 12:30 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/6/2021 at 1:08 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 11:37 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0064**

131 3rd Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/7/2021 at 10:20 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/7/2021 at 12:58 PM

**Collection Remarks:**  
Sample collected from the kitchen sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Lau, Tiffany

**Analysis Date/Time:**  
12/7/2021 at 1:40 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/8/2021 at 3:03 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Lau, Tiffany

**Analysis Date/Time:**  
12/7/2021 at 1:59 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/9/2021 at 12:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	6 CFU
HPC2 1.0	4 CFU
HPC Result	5 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0065

1167 Hekau Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/7/2021 at 10:55 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/7/2021 at 12:58 PM

**Collection Remarks:**  
Sample collected from the laundry room sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Lau, Tiffany

**Analysis Date/Time:**  
12/7/2021 at 1:40 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/8/2021 at 3:03 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Lau, Tiffany

**Analysis Date/Time:**  
12/7/2021 at 1:59 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/9/2021 at 12:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	5 CFU
HPC2 0.1	4 CFU
HPC1 1.0	85 CFU
HPC2 1.0	73 CFU
HPC Result	79 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0066

719 McGrew Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/7/2021 at 11:20 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/7/2021 at 12:58 PM

**Collection Remarks:**  
Sample collected in upstairs bathroom - shower faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Lau, Tiffany

**Analysis Date/Time:**  
12/7/2021 at 1:40 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/8/2021 at 3:03 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Lau, Tiffany

**Analysis Date/Time:**  
12/7/2021 at 2:07 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/9/2021 at 12:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	2 CFU
HPC1 1.0	27 CFU
HPC2 1.0	26 CFU
HPC Result	27 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0067**

539 McGrew Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/7/2021 at 11:55 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/7/2021 at 12:58 PM

**Collection Remarks:**  
Sample collected from kitchen sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Lau, Tiffany

**Analysis Date/Time:**  
12/7/2021 at 1:40 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/8/2021 at 3:03 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Lau, Tiffany

**Analysis Date/Time:**  
12/7/2021 at 2:07 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/9/2021 at 12:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0068**

7397 Birch Circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/7/2021 at 12:00 PM

**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/7/2021 at 1:20 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/7/2021 at 1:40 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 3:03 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/7/2021 at 2:15 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/9/2021 at 12:41 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	0 CFU
HPC1 1.0	19 CFU
HPC2 1.0	18 CFU
HPC Result	19 CFU/ml

**Lab Comments:**  
None





# Sample Analysis Tracking System

**E21-12-0069**

Iroquois Point Elementary School Cafeteria  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/7/2021 at 10:30 AM

**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/7/2021 at 1:20 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/7/2021 at 1:40 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 3:03 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/7/2021 at 2:15 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/9/2021 at 12:41 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0024**

Aliamanu Child Development Center  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Isaiah Kela-Pacheco  
**Sample Date/Time:** 12/6/2021 at 11:00 AM

**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/6/2021 at 12:12 PM

**Collection Remarks:**  
No odor detected in tap. Water shutoff ~ 1 week prior to sampling.

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/6/2021 at 12:25 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/7/2021 at 12:30 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/6/2021 at 1:08 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 11:37 AM

**Sample Results:**

Contaminant	Result
HPC1 0.1	34 CFU
HPC2 0.1	26 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	300 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0072**

1161 Honu Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Michael Cummings

**Sample Date/Time:**

12/8/2021 at 11:10 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/8/2021 at 12:11 PM

**Collection Remarks:**

upstairs bathroom shower faucet

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/8/2021 at 2:22 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/9/2021 at 2:30 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/8/2021 at 2:31 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/10/2021 at 4:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	5 CFU
HPC2 0.1	5 CFU
HPC1 1.0	38 CFU
HPC2 1.0	48 CFU
HPC Result	43 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0071

500-258 - Waiawa Shaft  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** David Kawahara  
**Sample Date/Time:** 12/7/2021 at 12:30 PM  
**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/7/2021 at 1:45 PM

**Collection Remarks:**  
Pre-chlorination

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/7/2021 at 1:48 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 3:03 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/7/2021 at 2:23 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/9/2021 at 12:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0070**

Iroquois Point Pre School  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/7/2021 at 11:15 AM

**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/7/2021 at 1:20 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/7/2021 at 1:40 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/8/2021 at 3:03 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/7/2021 at 2:23 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/9/2021 at 12:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	3 CFU
HPC2 0.1	2 CFU
HPC1 1.0	31 CFU
HPC2 1.0	31 CFU
HPC Result	31 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0076**

7200 Birch Circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

David Wong

**Sample Date/Time:**

12/8/2021 at 1:03 PM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/8/2021 at 2:10 PM

**Collection Remarks:**

no odor detected in kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/8/2021 at 2:22 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/9/2021 at 2:30 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/8/2021 at 2:40 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/10/2021 at 4:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	5 CFU
HPC2 0.1	26 CFU
HPC1 1.0	239 CFU
HPC2 1.0	255 CFU
HPC Result	250 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0074**

565 McGrew Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Michael Cummings  
**Sample Date/Time:** 12/8/2021 at 10:15 AM

**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/8/2021 at 12:11 PM

**Collection Remarks:**  
laundry room sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/8/2021 at 2:22 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/9/2021 at 2:30 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/8/2021 at 2:36 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:20 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	1 CFU
HPC1 1.0	51 CFU
HPC2 1.0	75 CFU
HPC Result	63 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0073

1156 Hekau Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Michael Cummings

**Sample Date/Time:**

12/8/2021 at 10:50 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/8/2021 at 12:11 PM

**Collection Remarks:**

upstairs bathroom shower faucet

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/8/2021 at 2:22 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/9/2021 at 2:30 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/8/2021 at 2:31 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/10/2021 at 4:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	3 CFU
HPC2 1.0	6 CFU
HPC Result	5 CFU/ml

**Lab Comments:**

None





# Sample Analysis Tracking System

**E21-12-0077**

147 Octopus Lane  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** David Wong  
**Sample Date/Time:** 12/8/2021 at 10:15 AM

**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/8/2021 at 2:11 PM

**Collection Remarks:**  
laundry sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/8/2021 at 2:22 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/9/2021 at 2:30 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/8/2021 at 2:40 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	31 CFU
HPC2 1.0	38 CFU
HPC Result	35 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0080**

5424 Edgewater Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Christopher Hakoda  
**Sample Date/Time:** 12/9/2021 at 11:18 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 1:53 PM

**Collection Remarks:**  
Bath tub

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:09 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0078**

Halawa Correctional Facility  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/9/2021 at 11:46 AM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 1:00 PM

**Collection Remarks:**  
Special needs facility hose bib

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:00 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0079**

6666B 106th Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Christopher Hakoda  
**Sample Date/Time:** 12/9/2021 at 11:35 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 1:53 PM

**Collection Remarks:**  
Outside hose bib

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:00 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0081

6181 Ibis Ave  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Christopher Hakoda  
**Sample Date/Time:** 12/9/2021 at 10:55 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 1:53 PM

**Collection Remarks:**  
Bath tub

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:09 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0082**

6660B 106th Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Christopher Hakoda  
**Sample Date/Time:** 12/9/2021 at 11:54 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 1:53 PM

**Collection Remarks:**  
Bath tub

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:20 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0083

5019 Iroquois Pt  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Christopher Hakoda  
**Sample Date/Time:** 12/9/2021 at 12:15 PM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 1:53 PM

**Collection Remarks:**  
Bath tub

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

#### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:20 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

#### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	1 CFU
HPC1 1.0	0 CFU
HPC2 1.0	2 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0085

5534 Bittern Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Shirley Watanabe  
**Sample Date/Time:** 12/9/2021 at 11:41 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:37 PM

**Collection Remarks:**  
Tub faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:35 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	5 CFU
HPC1 1.0	5 CFU
HPC2 1.0	7 CFU
HPC Result	6 CFU/ml

**Lab Comments:**  
None





# Sample Analysis Tracking System

## E21-12-0075

824 McGrew Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Michael Cummings  
**Sample Date/Time:** 12/8/2021 at 10:35 AM

**Received By:** Lau, Tiffany  
**Receipt Date/Time:** 12/8/2021 at 12:11 PM

**Collection Remarks:**  
bathroom shower faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/8/2021 at 2:22 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/9/2021 at 2:30 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/8/2021 at 2:36 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	1 CFU
HPC2 1.0	2 CFU
HPC Result	2 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0084**

4908 Mokupea Place Apt B  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Shirley Watanabe  
**Sample Date/Time:** 12/9/2021 at 11:05 AM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:37 PM

**Collection Remarks:**  
Tub faucet upstairs

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/13/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:35 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	3 CFU
HPC2 0.1	5 CFU
HPC1 1.0	2 CFU
HPC2 1.0	12 CFU
HPC Result	7 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0086**

5673 Dovekie Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Shirley Watanabe  
**Sample Date/Time:** 12/9/2021 at 12:15 PM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:37 PM

**Collection Remarks:**  
Tub faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:43 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	2 CFU
HPC1 1.0	24 CFU
HPC2 1.0	44 CFU
HPC Result	34 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0087**

5669A Dovekie Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Shirley Watanabe  
**Sample Date/Time:** 12/9/2021 at 12:27 PM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:37 PM

**Collection Remarks:**  
Outside spigot

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:43 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0088**

6674 106th Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/9/2021 at 12:59 PM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/9/2021 at 2:37 PM

**Collection Remarks:**  
Outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/9/2021 at 3:42 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/9/2021 at 5:52 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0091**

3763 Elm Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Grace Simmons

**Sample Date/Time:**  
12/10/2021 at 9:37 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/10/2021 at 12:28 PM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/10/2021 at 2:11 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/10/2021 at 2:58 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	14 CFU
HPC2 0.1	22 CFU
HPC1 1.0	163 CFU
HPC2 1.0	157 CFU
HPC Result	160 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0092**

7257 Birch circle

## Sample Receipt Data

**Sampler Name:**  
Grace Simmons

**Sample Date/Time:**  
12/10/2021 at 10:44 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/10/2021 at 12:28 PM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/10/2021 at 2:11 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/10/2021 at 3:05 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	1 CFU
HPC2 1.0	3 CFU
HPC Result	2 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0089**

Halawa Shafter  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/9/2021 at 10:30 AM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:53 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 5:52 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	3 CFU
HPC2 1.0	3 CFU
HPC Result	3 CFU/ml

**Lab Comments:**  
None





# Sample Analysis Tracking System

E21-12-0093

Create Duplicate(s)

7257 Birch circle

## Sample Receipt Data

**Sampler Name:**  
Grace Simmons

**Sample Date/Time:**  
12/10/2021 at 10:44 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/10/2021 at 12:28 PM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
None

**Analysis Date/Time:**  
None

**Read By:**  
None

**Read By Date/Time:**  
None

**Sample Results:**

Contaminant	Result
Total Coliforms	
E. coli	

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
None

**Analysis Date/Time:**  
None

**Read By:**  
None

**Read By Date/Time:**  
None

**Sample Results:**

Contaminant	Result
HPC1 0.1	
HPC2 0.1	
HPC1 1.0	
HPC2 1.0	
HPC Result	

**Lab Comments:**  
None



# Sample Analysis Tracking System

E21-12-0094

Create Duplicate(s)

7257 Birch circle

## Sample Receipt Data

**Sampler Name:**  
Grace Simmons

**Sample Date/Time:**  
12/10/2021 at 10:44 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/10/2021 at 12:28 PM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
None

**Analysis Date/Time:**  
None

**Read By:**  
None

**Read By Date/Time:**  
None

**Sample Results:**

Contaminant	Result
Total Coliforms	
E. coli	

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
None

**Analysis Date/Time:**  
None

**Read By:**  
None

**Read By Date/Time:**  
None

**Sample Results:**

Contaminant	Result
HPC1 0.1	
HPC2 0.1	
HPC1 1.0	
HPC2 1.0	
HPC Result	

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0095**

7273 Elm Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Grace Simmons

**Sample Date/Time:**  
12/10/2021 at 9:06 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/10/2021 at 12:28 PM

**Collection Remarks:**  
Upstairs laundry sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/10/2021 at 2:11 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/10/2021 at 3:05 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	8 CFU
HPC2 0.1	8 CFU
HPC1 1.0	37 CFU
HPC2 1.0	37 CFU
HPC Result	37 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0098**

5856B Fulmar Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/10/2021 at 10:30 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/10/2021 at 12:50 PM

**Collection Remarks:**

Outside spigot, no odor, > 10 min purge

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/10/2021 at 2:11 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/10/2021 at 3:19 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0097**

5012A Iroquois Ave  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/10/2021 at 9:52 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/10/2021 at 12:50 PM

**Collection Remarks:**

Outside spigot no odor

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/10/2021 at 2:11 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/10/2021 at 3:19 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0096**

7236 Birch Circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Grace Simmons

**Sample Date/Time:**  
12/10/2021 at 11:05 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/10/2021 at 12:28 PM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/10/2021 at 2:11 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/10/2021 at 3:12 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	3 CFU
HPC Result	2 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0101

5682 Dovekie Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/10/2021 at 9:30 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/10/2021 at 12:50 PM

**Collection Remarks:**

Outside spigot, no odor, > 10 min

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/10/2021 at 2:11 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/10/2021 at 3:30 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0099**

5869 Fulmar Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/10/2021 at 10:40 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/10/2021 at 12:50 PM

**Collection Remarks:**

Outside spigot, no odor

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/10/2021 at 2:11 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/10/2021 at 3:27 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/13/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	2 CFU
HPC1 1.0	1 CFU
HPC2 1.0	0 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

None





# Sample Analysis Tracking System

## E21-12-0100

5861 Fulmar Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/10/2021 at 10:20 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/10/2021 at 12:50 PM

**Collection Remarks:**

Outdoor spigot, no odor, > 10 min purge

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/10/2021 at 2:11 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/10/2021 at 3:27 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/13/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	63 CFU
HPC2 0.1	60 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	620 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0090

5321 Cedar Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Grace Simmons

**Sample Date/Time:**  
12/10/2021 at 10:02 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/10/2021 at 12:28 PM

**Collection Remarks:**  
Outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/10/2021 at 2:11 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/10/2021 at 2:58 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0102

4976 Kela Place Apt B  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/10/2021 at 11:05 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/10/2021 at 12:50 PM

**Collection Remarks:**

Outside spigot, no odor, > 10 min purge

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/10/2021 at 2:11 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/11/2021 at 2:40 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/10/2021 at 3:12 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/12/2021 at 2:05 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0104

Building 1338 Fitness Center  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Lauren Cruz  
**Sample Date/Time:** 12/12/2021 at 11:40 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/12/2021 at 12:17 PM

**Collection Remarks:**  
spigot near front door

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/12/2021 at 2:37 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	34 CFU
HPC2 0.1	59 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	470 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/12/2021 at 1:57 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.



# Sample Analysis Tracking System

## E21-12-0103

7377 Birch circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/12/2021 at 10:30 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/12/2021 at 12:17 PM

**Collection Remarks:**

no odor

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/12/2021 at 2:37 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/12/2021 at 1:57 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.



# Sample Analysis Tracking System

## E21-12-0105

7370 Birch Circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/12/2021 at 10:45 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/12/2021 at 12:17 PM

**Collection Remarks:**

spigot spurting no odor

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/12/2021 at 2:37 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	0 CFU
HPC1 1.0	10 CFU
HPC2 1.0	19 CFU
HPC Result	15 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/12/2021 at 1:57 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.



# Sample Analysis Tracking System

## E21-12-0107

7384 Birch Circle Bldg  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/12/2021 at 10:55 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/12/2021 at 12:17 PM

**Collection Remarks:**

no odor. outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/12/2021 at 2:37 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	20 CFU
HPC2 1.0	24 CFU
HPC Result	22 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/12/2021 at 1:57 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.



# Sample Analysis Tracking System

## E21-12-0109

Bldg. 303, BEQ  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/12/2021 at 12:04 PM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/12/2021 at 1:40 PM

**Collection Remarks:**  
outside spigot

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/12/2021 at 1:57 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/12/2021 at 2:37 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

## E21-12-0111

4755D East Ekahi Way  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Adam Teekell

**Sample Date/Time:**

12/12/2021 at 10:53 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/12/2021 at 1:40 PM

**Collection Remarks:**

outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/12/2021 at 1:57 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/12/2021 at 2:37 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0110

4973B Kela Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

<b>Sampler Name:</b> Adam Teekell	<b>Sample Date/Time:</b> 12/12/2021 at 11:10 AM
<b>Received By:</b> Kim, June	<b>Receipt Date/Time:</b> 12/12/2021 at 1:40 PM

**Collection Remarks:**  
outside spigot

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

<b>Analyst:</b> Kim, June	<b>Analysis Date/Time:</b> 12/12/2021 at 1:57 PM
<b>Read By:</b> Kim, June	<b>Read By Date/Time:</b> 12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

<b>Analyst:</b> Kim, June	<b>Analysis Date/Time:</b> 12/12/2021 at 2:37 PM
<b>Read By:</b> Kim, June	<b>Read By Date/Time:</b> 12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0112

4974D Kela Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/12/2021 at 11:28 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/12/2021 at 1:40 PM

**Collection Remarks:**  
outside spigot

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/12/2021 at 1:57 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/12/2021 at 2:37 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0113

Bldg. 300 Block-A, BEQ  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

<b>Sampler Name:</b> Adam Teekell	<b>Sample Date/Time:</b> 12/12/2021 at 11:55 AM
<b>Received By:</b> Kim, June	<b>Receipt Date/Time:</b> 12/12/2021 at 1:40 PM

**Collection Remarks:**  
east side. outside spigot

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

<b>Analyst:</b> Kim, June	<b>Analysis Date/Time:</b> 12/12/2021 at 1:57 PM
<b>Read By:</b> Kim, June	<b>Read By Date/Time:</b> 12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

<b>Analyst:</b> Kim, June	<b>Analysis Date/Time:</b> 12/12/2021 at 2:37 PM
<b>Read By:</b> Kim, June	<b>Read By Date/Time:</b> 12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0114

4976D Kela Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/12/2021 at 11:20 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/12/2021 at 1:40 PM

**Collection Remarks:**  
outside spigot

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/12/2021 at 2:00 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/12/2021 at 3:05 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0115

4906 Wasp Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Scott Murakawa  
**Sample Date/Time:** 12/13/2021 at 10:35 AM  
**Received By:** Kim, June  
**Receipt Date/Time:** 12/13/2021 at 1:55 PM

**Collection Remarks:**  
washroom faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:51 PM  
**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 1:11 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:55 PM  
**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 4:04 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0118**

4623 Scott Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/13/2021 at 12:00 PM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/13/2021 at 1:55 PM

**Collection Remarks:**  
laundry room sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/13/2021 at 4:51 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/15/2021 at 1:11 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/13/2021 at 4:55 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/15/2021 at 4:04 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0116**

4682 Oklahoma Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Scott Murakawa  
**Sample Date/Time:** 12/13/2021 at 11:00 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/13/2021 at 1:55 PM

**Collection Remarks:**  
washroom faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:51 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 1:11 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:55 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 4:04 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

## E21-12-0108

3802 Elm Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

<b>Sampler Name:</b> Melvin Tokuda	<b>Sample Date/Time:</b> 12/12/2021 at 10:00 AM
<b>Received By:</b> Kim, June	<b>Receipt Date/Time:</b> 12/12/2021 at 1:32 PM

**Collection Remarks:**  
notice sheen on water surface

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

<b>Analyst:</b> Kim, June	<b>Analysis Date/Time:</b> 12/12/2021 at 1:57 PM
<b>Read By:</b> Kim, June	<b>Read By Date/Time:</b> 12/14/2021 at 10:18 AM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

<b>Analyst:</b> Kim, June	<b>Analysis Date/Time:</b> 12/12/2021 at 2:37 PM
<b>Read By:</b> Kim, June	<b>Read By Date/Time:</b> 12/14/2021 at 3:15 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	258 CFU
HPC2 0.1	282 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	2700 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0117**

2031 Fox Boulevard  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/13/2021 at 11:30 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/13/2021 at 1:55 PM

**Collection Remarks:**  
upstairs bathroom bathtub faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/13/2021 at 4:51 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/15/2021 at 1:11 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/13/2021 at 4:55 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/15/2021 at 4:04 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	10 CFU
HPC2 0.1	8 CFU
HPC1 1.0	107 CFU
HPC2 1.0	110 CFU
HPC Result	110 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0121**

Aiea Halawa Post Chlor  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/9/2021 at 12:00 PM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:53 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 6:00 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0119**

732 Sibley Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/13/2021 at 12:30 PM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/13/2021 at 1:55 PM

**Collection Remarks:**  
1st floor bathroom bathtub faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/13/2021 at 4:51 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/15/2021 at 1:11 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/13/2021 at 4:55 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/15/2021 at 4:04 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	3 CFU
HPC2 0.1	0 CFU
HPC1 1.0	4 CFU
HPC2 1.0	5 CFU
HPC Result	5 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0123**

Halawa Storage Tank 2(S2)  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/9/2021 at 1:10 PM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:53 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:48 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 6:12 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0124**

Camp smith Tanks  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/13/2021 at 10:00 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/13/2021 at 4:40 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:51 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 1:11 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected. Per Mel Tokuda, other samples listed on the COC are on different COCs.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:55 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 4:04 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	17 CFU
HPC2 1.0	10 CFU
HPC Result	14 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0122

Halawa Storage Tank 1(S1)  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/9/2021 at 12:50 PM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:53 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 6:12 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0161

Uluakupu Building  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/14/2021 at 10:00 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/14/2021 at 11:30 AM

**Collection Remarks:**  
QA/QC

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/14/2021 at 2:16 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total coliform and HPC per SDWB. QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/14/2021 at 2:16 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/16/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
Total coliform and HPC per SDWB. Analysis Time: 3:15 PM. QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

## E21-12-0166

6151 A Heron Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Evan Watarida

**Sample Date/Time:**

12/14/2021 at 11:22 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/14/2021 at 1:00 PM

**Collection Remarks:**

Bedroom sink. Residents showing symptoms.

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	4 CFU
HPC2 1.0	6 CFU
HPC Result	5 CFU/ml

**Lab Comments:**

Analysis Time: 3:15 PM. Read By Date 12/16/21. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0167**

6168 Heron Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/14/2021 at 10:55 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/14/2021 at 1:23 PM

**Collection Remarks:**

Outdoor spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

Analysis Time: 3:15 PM. Read By Date 12/16/21. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0125**

Camp Smith Tank S-326  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/13/2021 at 11:20 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/13/2021 at 4:40 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:51 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 1:11 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:55 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 4:04 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	0 CFU
HPC1 1.0	3 CFU
HPC2 1.0	5 CFU
HPC Result	4 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0162

Momilani Elementary School  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/14/2021 at 10:25 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/14/2021 at 11:30 AM

**Collection Remarks:**  
QA/QC

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/14/2021 at 2:16 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total coliform and HPC per SDWB. QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/14/2021 at 2:16 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/16/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	5 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	6 CFU
HPC Result	3 CFU/ml

**Lab Comments:**  
Total coliform and HPC per SDWB. Analysis Time: 3:15 PM. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0165

6089 Heron B Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Evan Watarida

**Sample Date/Time:**

12/14/2021 at 11:04 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/14/2021 at 1:00 PM

**Collection Remarks:**

Bedroom sink. Daughter sent to ER. Pets sick.

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/17/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	1 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

Analysis Time: 3:15 PM. Read By Date 12/16/21. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0126

Camp Smith Tank 684  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/13/2021 at 12:45 PM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/13/2021 at 4:40 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:55 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 1:11 PM

#### Sample Results:

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/13/2021 at 4:55 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/15/2021 at 4:04 PM

#### Sample Results:

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	0 CFU
HPC1 1.0	4 CFU
HPC2 1.0	3 CFU
HPC Result	4 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected. Analysis Date / Time: 12/13/21 5:20 PM.



# Sample Analysis Tracking System

**E21-12-0169**

6365 Ibis Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/14/2021 at 11:14 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/14/2021 at 1:23 PM

**Collection Remarks:**

bath tub

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

Analysis Time: 3:15 PM. Read By Date 12/16/21. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0172**

1406 Lanikai Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/15/2021 at 10:25 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/15/2021 at 12:32 PM

**Collection Remarks:**  
outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/15/2021 at 3:03 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/15/2021 at 3:28 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

**E21-12-0170**

5548 Bittern Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/14/2021 at 11:41 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/14/2021 at 1:23 PM

**Collection Remarks:**

Outdoor spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/17/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	13 CFU
HPC2 1.0	14 CFU
HPC Result	14 CFU/ml

**Lab Comments:**

Analysis Time: 3:15 PM. Read By Date 12/16/21. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0164**

6186 A Ibis Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Evan Watarida

**Sample Date/Time:**

12/14/2021 at 10:45 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/14/2021 at 1:00 PM

**Collection Remarks:**

Bathroom tub

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

Analysis Time: 3:15 PM. Read By Date 12/16/21. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0173

1402 Lanikai Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/15/2021 at 10:41 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/15/2021 at 12:32 PM

**Collection Remarks:**  
outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/15/2021 at 3:03 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/15/2021 at 3:28 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	16 CFU
HPC2 0.1	16 CFU
HPC1 1.0	179 CFU
HPC2 1.0	147 CFU
HPC Result	160 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0168**

6176 Heron Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/14/2021 at 10:50 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/14/2021 at 1:23 PM

**Collection Remarks:**

Outdoor spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

Analysis Time: 3:15 PM. Read By Date 12/16/21. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0174**

1619 Aloha Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/15/2021 at 11:00 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/15/2021 at 12:32 PM

**Collection Remarks:**  
outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/15/2021 at 3:03 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/15/2021 at 3:28 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	13 CFU
HPC2 0.1	13 CFU
HPC1 1.0	104 CFU
HPC2 1.0	113 CFU
HPC Result	110 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0175

1813 Palm Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/15/2021 at 11:15 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/15/2021 at 12:32 PM

**Collection Remarks:**  
outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/15/2021 at 3:03 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/15/2021 at 3:28 PM

**Read By:**  
Kim, June

**Read By Date/Time:**  
12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0178**

500-337 - 2899C Makuu Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/15/2021 at 10:30 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/15/2021 at 12:50 PM

**Collection Remarks:**

outdoor spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:03 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:28 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0176**

2862A Kokio Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/15/2021 at 10:40 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/15/2021 at 12:50 PM

**Collection Remarks:**

outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:03 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:28 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

**E21-12-0179**

2856A Kokio Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/15/2021 at 10:55 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/15/2021 at 12:50 PM

**Collection Remarks:**

bath tub

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:03 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:28 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	0 CFU
HPC1 1.0	2 CFU
HPC2 1.0	13 CFU
HPC Result	8 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0171**

5537 Bittern Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/14/2021 at 11:50 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/14/2021 at 1:23 PM

**Collection Remarks:**

Outdoor spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/15/2021 at 2:31 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/14/2021 at 2:16 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:48 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

Analysis Time: 3:15 PM. Read By Date 12/16/21. QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0177**

2879A Hapue Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/15/2021 at 11:30 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/15/2021 at 12:50 PM

**Collection Remarks:**

outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:03 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:28 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0181**

2850A Kokio Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/15/2021 at 11:15 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/15/2021 at 12:50 PM

**Collection Remarks:**

outdoor spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:03 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:28 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0180**

2891DMakuu Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/15/2021 at 10:55 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/15/2021 at 12:50 PM

**Collection Remarks:**

bath tub

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:03 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Sample Time 10:06 AM. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/15/2021 at 3:28 PM

**Read By:**

Kim, June

**Read By Date/Time:**

12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	0 CFU
HPC1 1.0	4 CFU
HPC2 1.0	0 CFU
HPC Result	2 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0184**

Fire Station 10 Aiea  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/15/2021 at 12:22 PM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/15/2021 at 1:35 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/15/2021 at 3:03 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/15/2021 at 3:28 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0185**

Fire Station 42 Waikele  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/15/2021 at 11:44 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/15/2021 at 1:35 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/15/2021 at 3:08 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/17/2021 at 3:10 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/15/2021 at 4:03 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/17/2021 at 1:14 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0183**

Fire Station 12 Waipahu  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/15/2021 at 11:18 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/15/2021 at 1:35 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/15/2021 at 3:03 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/15/2021 at 3:28 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

**E21-12-0188**

Bldg 1B  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Lauren Cruz  
**Sample Date/Time:** 12/16/2021 at 9:30 AM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/16/2021 at 11:22 AM

**Collection Remarks:**  
Janitor room in Denal lab

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 12:25 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 3:18 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	4 CFU
HPC2 1.0	7 CFU
HPC Result	6 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0189**

2165 Baugh Road  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Lauren Cruz  
**Sample Date/Time:** 12/16/2021 at 10:20 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/16/2021 at 11:22 AM

**Collection Remarks:**  
Outside spigot by garage

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 12:25 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/17/2021 at 12:57 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 3:18 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 5:20 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0186**

2173 Baugh Road  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/16/2021 at 10:35 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/16/2021 at 11:21 AM

**Collection Remarks:**

Outdoor spigot by garage

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/16/2021 at 12:25 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/16/2021 at 3:10 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0190**

739 Anderson Road  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/16/2021 at 10:10 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/16/2021 at 11:22 AM

**Collection Remarks:**

Outdoor spigot by garage

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/16/2021 at 12:25 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/16/2021 at 3:25 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	3 CFU
HPC2 1.0	5 CFU
HPC Result	4 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0187**

Bldg 612, Fire Station  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Lauren Cruz  
**Sample Date/Time:** 12/16/2021 at 9:45 AM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/16/2021 at 11:22 AM

**Collection Remarks:**  
Laundry room sink, no odor

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 12:25 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 3:10 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0194**

Across Bldg 2C  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Sven Lindstrom

**Sample Date/Time:**  
12/16/2021 at 10:40 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/16/2021 at 11:40 AM

**Collection Remarks:**  
Spigot at outdoor gym

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/16/2021 at 12:25 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/16/2021 at 3:42 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	4 CFU
HPC1 1.0	54 CFU
HPC2 1.0	66 CFU
HPC Result	60 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0193**

Bldg 4  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Sven Lindstrom  
**Sample Date/Time:** 12/16/2021 at 9:30 AM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/16/2021 at 11:40 AM

**Collection Remarks:**  
1st floor loading dock men's room

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 12:25 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/17/2021 at 12:57 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 3:34 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 5:20 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	3 CFU
HPC2 1.0	5 CFU
HPC Result	4 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0182

Fire Station 38 Waiiau  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Adam Teekell  
**Sample Date/Time:** 12/15/2021 at 10:33 AM

**Received By:** Kim, June  
**Receipt Date/Time:** 12/15/2021 at 1:35 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/15/2021 at 3:03 PM

**Read By:** Lake, Elaine  
**Read By Date/Time:** 12/17/2021 at 3:10 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total coliform per SDWB. Read Date 12/16/21. QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Kim, June  
**Analysis Date/Time:** 12/15/2021 at 3:28 PM

**Read By:** Kim, June  
**Read By Date/Time:** 12/17/2021 at 1:14 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	2 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

**E21-12-0191**

Bldg 20  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Sven Lindstrom  
**Sample Date/Time:** 12/16/2021 at 10:10 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/16/2021 at 11:40 AM

**Collection Remarks:**  
Men's room at 20E

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 12:25 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 3:25 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0192

Bldg. 601 (PMO) Elrod Road  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Sven Lindstrom  
**Sample Date/Time:** 12/16/2021 at 10:20 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/16/2021 at 11:40 AM

**Collection Remarks:**  
Spigot outside 601

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 12:25 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 3:34 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	2 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0199**

1824 Palm Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/17/2021 at 9:15 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/17/2021 at 11:18 AM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 2:27 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 3:51 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	6 CFU
HPC2 0.1	4 CFU
HPC1 1.0	31 CFU
HPC2 1.0	36 CFU
HPC Result	34 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0196**

1025 Saratoga Boulevard  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/16/2021 at 10:15 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/16/2021 at 12:00 PM

**Collection Remarks:**  
Laundry room sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/16/2021 at 12:25 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/16/2021 at 3:49 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0201

128 Ley Court  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Scott Murakawa  
**Sample Date/Time:** 12/17/2021 at 10:00 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/17/2021 at 11:18 AM

**Collection Remarks:**  
Hose faucet - outside front door

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/17/2021 at 2:27 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/17/2021 at 3:59 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	1 CFU
HPC1 1.0	18 CFU
HPC2 1.0	30 CFU
HPC Result	24 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0197**

4670 Nevada Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Scott Murakawa  
**Sample Date/Time:** 12/16/2021 at 10:40 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/16/2021 at 12:00 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 12:25 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/17/2021 at 12:57 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/16/2021 at 3:49 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 5:20 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	29 CFU
HPC2 0.1	32 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	310 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0195**

767 Sibley Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/16/2021 at 9:30 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/16/2021 at 12:00 PM

**Collection Remarks:**  
Outside hose faucet - left corner

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/16/2021 at 12:25 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/16/2021 at 3:42 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	1 CFU
HPC2 1.0	2 CFU
HPC Result	2 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0202**

134 Ley Court  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/17/2021 at 10:15 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/17/2021 at 11:18 AM

**Collection Remarks:**  
Hose faucet - outside front door

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 2:27 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 3:59 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

## E21-12-0200

1838 Palm Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Scott Murakawa  
**Sample Date/Time:** 12/17/2021 at 9:40 AM  
**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/17/2021 at 11:18 AM

**Collection Remarks:**  
Garage hose faucet

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/17/2021 at 2:27 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/17/2021 at 3:51 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	Est. 1382 CFU
HPC2 0.1	Est. 1696 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	Est. 15000 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0203

148 Ley Court  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/17/2021 at 10:30 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/17/2021 at 11:18 AM

**Collection Remarks:**  
Hose faucet - outside front door

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 2:27 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 4:05 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	16 CFU
HPC2 0.1	20 CFU
HPC1 1.0	164 CFU
HPC2 1.0	154 CFU
HPC Result	160 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0205

5533 Bittern Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Sven Lindstrom

**Sample Date/Time:**  
12/17/2021 at 9:45 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/17/2021 at 11:45 AM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 2:27 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 4:13 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	1 CFU
HPC1 1.0	4 CFU
HPC2 1.0	0 CFU
HPC Result	2 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0206

5713 Erne Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Sven Lindstrom

**Sample Date/Time:**  
12/17/2021 at 10:00 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/17/2021 at 11:45 AM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 2:27 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 4:13 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	2 CFU
HPC2 1.0	3 CFU
HPC Result	3 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0207

6073 A Heron Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Sven Lindstrom  
**Sample Date/Time:** 12/17/2021 at 10:15 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/17/2021 at 11:45 AM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/17/2021 at 2:27 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/17/2021 at 4:20 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0198**

4909 Tomahawk Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Scott Murakawa

**Sample Date/Time:**  
12/16/2021 at 11:00 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/16/2021 at 12:00 PM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/16/2021 at 12:31 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/17/2021 at 12:57 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

Total Coliform per SDWB. QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/16/2021 at 3:54 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 5:20 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	4 CFU
HPC Result	2 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0209**

1167 Hekau Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Michael Cummings

**Sample Date/Time:**

12/17/2021 at 9:35 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/17/2021 at 12:17 PM

**Collection Remarks:**

Laundry sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/17/2021 at 2:27 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/17/2021 at 4:29 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	2 CFU
HPC2 1.0	0 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0211

1207 Honu Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Michael Cummings

**Sample Date/Time:**

12/17/2021 at 10:35 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/17/2021 at 12:17 PM

**Collection Remarks:**

Outside hose bib

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/17/2021 at 2:27 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/17/2021 at 4:37 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

## E21-12-0204

5297 Iroquois Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Sven Lindstrom

**Sample Date/Time:**  
12/17/2021 at 9:30 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/17/2021 at 11:45 AM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 2:27 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 4:05 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0210

1191 Honu Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Michael Cummings

**Sample Date/Time:**

12/17/2021 at 10:10 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/17/2021 at 12:17 PM

**Collection Remarks:**

Bath tub

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/17/2021 at 2:27 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/17/2021 at 4:29 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0213

Radford Terrace Community Center, Murray Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/18/2021 at 9:30 AM

**Received By:**  
Fox, Paul

**Receipt Date/Time:**  
12/18/2021 at 12:00 PM

**Collection Remarks:**  
Fitness center outside spigot

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 2:31 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 3:43 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	18 CFU
HPC2 0.1	24 CFU
HPC1 1.0	228 CFU
HPC2 1.0	243 CFU
HPC Result	240 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0215**

Ohana Navy Communities, Jaluit Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/18/2021 at 10:25 AM

**Received By:**  
Fox, Paul

**Receipt Date/Time:**  
12/18/2021 at 12:00 PM

**Collection Remarks:**  
Outside spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 2:31 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 3:50 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0216

4999 Kidd Court  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Shirley Watanabe  
**Sample Date/Time:** 12/18/2021 at 10:50 AM  
**Received By:** Fox, Paul  
**Receipt Date/Time:** 12/18/2021 at 12:00 PM

**Collection Remarks:**  
Community center women's bathroom sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/18/2021 at 2:31 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/19/2021 at 3:02 PM

#### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/18/2021 at 3:50 PM  
**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/20/2021 at 2:41 PM

#### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	1 CFU
HPC1 1.0	16 CFU
HPC2 1.0	17 CFU
HPC Result	17 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0217**

NEX Commissary, 4725 Bouganville Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Natasha Asinsin

**Sample Date/Time:**  
12/18/2021 at 9:30 AM

**Received By:**  
Fox, Paul

**Receipt Date/Time:**  
12/18/2021 at 12:00 PM

**Collection Remarks:**  
Meat processing deep sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 2:31 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 3:57 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0218**

Bloch Arena, A Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Natasha Asinsin  
**Sample Date/Time:** 12/18/2021 at 10:20 AM

**Received By:** Fox, Paul  
**Receipt Date/Time:** 12/18/2021 at 12:00 PM

**Collection Remarks:**  
Outside faucet right side bldg.

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/18/2021 at 2:31 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/19/2021 at 3:02 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/18/2021 at 3:57 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/20/2021 at 2:41 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	4 CFU
HPC1 1.0	66 CFU
HPC2 1.0	76 CFU
HPC Result	71 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0219**

Makalapa Clinic, 1257 Makalapa Road  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Natasha Asinsin  
**Sample Date/Time:** 12/18/2021 at 10:45 AM

**Received By:** Fox, Paul  
**Receipt Date/Time:** 12/18/2021 at 12:00 PM

**Collection Remarks:**  
Outside far left of building

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/18/2021 at 2:31 PM

**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/19/2021 at 3:02 PM

### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/18/2021 at 4:05 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/20/2021 at 2:41 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

**E21-12-0220**

Navy Gateway Lockwood Hall, Dealey Circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Natasha Asinsin

**Sample Date/Time:**  
12/18/2021 at 11:00 AM

**Received By:**  
Fox, Paul

**Receipt Date/Time:**  
12/18/2021 at 12:00 PM

**Collection Remarks:**  
Women's restroom sink

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 2:31 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 4:05 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	1 CFU
HPC2 1.0	2 CFU
HPC Result	2 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0214

619 Pool Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/18/2021 at 9:59 AM

**Received By:**  
Fox, Paul

**Receipt Date/Time:**  
12/18/2021 at 12:00 PM

**Collection Remarks:**  
620 Pool Street outside spigot community center

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

### Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 2:31 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/18/2021 at 3:43 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	2 CFU
HPC2 1.0	5 CFU
HPC Result	4 CFU/ml

**Lab Comments:**  
QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0221

211 Hickam Communities Bldg  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Adam Teekell

**Sample Date/Time:**

12/18/2021 at 12:08 PM

**Received By:**

Fox, Paul

**Receipt Date/Time:**

12/18/2021 at 12:45 PM

**Collection Remarks:**

Outside spigot right of entrance

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/18/2021 at 2:31 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/18/2021 at 4:13 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	171 CFU
HPC2 0.1	226 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	2000 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0222

1301 McMurtry  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Adam Teekell

**Sample Date/Time:**

12/18/2021 at 9:55 AM

**Received By:**

Fox, Paul

**Receipt Date/Time:**

12/18/2021 at 12:45 PM

**Collection Remarks:**

Taken from outside spigot, front door left of garage

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/18/2021 at 2:31 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/18/2021 at 4:13 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	7 CFU
HPC2 0.1	9 CFU
HPC1 1.0	63 CFU
HPC2 1.0	87 CFU
HPC Result	75 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0212

1177 Honu Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Michael Cummings

**Sample Date/Time:**

12/17/2021 at 10:50 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/17/2021 at 12:17 PM

**Collection Remarks:**

Bath tub

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/17/2021 at 2:33 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/17/2021 at 4:37 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	2 CFU
HPC2 1.0	3 CFU
HPC Result	3 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0225

1540 Tampa Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/19/2021 at 9:25 AM

**Received By:**

Fox, Paul

**Receipt Date/Time:**

12/19/2021 at 11:15 AM

**Collection Remarks:**

No odor inside upstairs bath tub

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:59 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0226

1532 Tampa Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Lauren Cruz  
**Sample Date/Time:** 12/19/2021 at 9:40 AM  
**Received By:** Fox, Paul  
**Receipt Date/Time:** 12/19/2021 at 11:15 AM

**Collection Remarks:**  
Outside spigot with aerator flow rate low

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/19/2021 at 12:09 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/19/2021 at 12:59 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	6 CFU
HPC2 0.1	6 CFU
HPC1 1.0	87 CFU
HPC2 1.0	75 CFU
HPC Result	81 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0208**

4836 West Eha Way Unit B  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Sven Lindstrom

**Sample Date/Time:**  
12/17/2021 at 10:30 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/17/2021 at 11:45 AM

**Collection Remarks:**  
Kitchen sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**  
None

## Colisure

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 2:27 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/18/2021 at 2:42 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/17/2021 at 4:20 PM

**Read By:**  
Lau, Tiffany

**Read By Date/Time:**  
12/19/2021 at 1:52 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	3 CFU
HPC2 0.1	3 CFU
HPC1 1.0	20 CFU
HPC2 1.0	19 CFU
HPC Result	20 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.





# Sample Analysis Tracking System

**E21-12-0224**

187 Honohono  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Adam Teekell

**Sample Date/Time:**

12/18/2021 at 10:50 AM

**Received By:**

Fox, Paul

**Receipt Date/Time:**

12/18/2021 at 12:45 PM

**Collection Remarks:**

Front patio spigot

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. Total Coliform and HPC per SDWB

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/18/2021 at 2:37 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/18/2021 at 4:19 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	6 CFU
HPC2 0.1	9 CFU
HPC1 1.0	91 CFU
HPC2 1.0	104 CFU
HPC Result	98 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

## E21-12-0228

1610 Cowslip Lane  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Lauren Cruz  
**Sample Date/Time:** 12/19/2021 at 10:05 AM  
**Received By:** Fox, Paul  
**Receipt Date/Time:** 12/19/2021 at 11:15 AM

**Collection Remarks:**  
Laundry sink, no odor

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/19/2021 at 12:09 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/19/2021 at 12:59 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	48 CFU
HPC2 0.1	41 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	440 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0223**

137 Honohono Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Adam Teekell

**Sample Date/Time:**

12/18/2021 at 11:30 AM

**Received By:**

Fox, Paul

**Receipt Date/Time:**

12/18/2021 at 12:45 PM

**Collection Remarks:**

Kitchen

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/18/2021 at 2:31 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/19/2021 at 3:02 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

QC passed. Positive control E.coli performed as expected.

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/18/2021 at 4:19 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/20/2021 at 2:41 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	5 CFU
HPC2 0.1	6 CFU
HPC1 1.0	36 CFU
HPC2 1.0	46 CFU
HPC Result	41 CFU/ml

**Lab Comments:**

QC passed. Sterility plate performed as expected.



# Sample Analysis Tracking System

**E21-12-0230**

127 Olive Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Isaiah Kela-Pacheco

**Sample Date/Time:**

12/19/2021 at 9:55 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:35 AM

**Collection Remarks:**

Outside hose

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:59 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0231

4072 Ironwood Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Isaiah Kela-Pacheco

**Sample Date/Time:**

12/19/2021 at 10:15 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:35 AM

**Collection Remarks:**

Outside hose

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:59 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	3 CFU
HPC2 1.0	0 CFU
HPC Result	2 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0234

56669A Dovekie Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Glen Haae

**Sample Date/Time:**

12/19/2021 at 9:35 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:44 AM

**Collection Remarks:**

Covered outside faucet to the left of the front door

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 1:15 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	3 CFU
HPC Result	2 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0232

4126 Begonia Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Isaiah Kela-Pacheco

**Sample Date/Time:**

12/19/2021 at 10:30 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:35 AM

**Collection Remarks:**

Laundry room

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:59 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	2 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0235

5424 Edgewater Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Glen Haae

**Sample Date/Time:**

12/19/2021 at 9:50 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:44 AM

**Collection Remarks:**

Covered outside faucet to the right of the main entrance

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 1:15 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	4 CFU
HPC2 0.1	2 CFU
HPC1 1.0	38 CFU
HPC2 1.0	36 CFU
HPC Result	37 CFU/ml

**Lab Comments:**

None





# Sample Analysis Tracking System

**E21-12-0236**

5111 Iroquois Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Glen Haae

**Sample Date/Time:**

12/19/2021 at 10:03 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:44 AM

**Collection Remarks:**

Covered outside faucet to the left of the office door (preschool)

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 1:15 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	1 CFU
HPC2 0.1	0 CFU
HPC1 1.0	2 CFU
HPC2 1.0	5 CFU
HPC Result	4 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0233

4132 Begonia Loop  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Isaiah Kela-Pacheco

**Sample Date/Time:**

12/19/2021 at 10:50 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:35 AM

**Collection Remarks:**

Outside hose

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 1:15 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	1 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0227**

1605 Cowslip Lane  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:** Lauren Cruz  
**Sample Date/Time:** 12/19/2021 at 10:30 AM  
**Received By:** Fox, Paul  
**Receipt Date/Time:** 12/19/2021 at 11:15 AM

**Collection Remarks:**  
Inside laundry sink no odor

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

## Colisure

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/19/2021 at 12:09 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:** Lau, Tiffany  
**Analysis Date/Time:** 12/19/2021 at 12:59 PM  
**Read By:** Lau, Tiffany  
**Read By Date/Time:** 12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	11 CFU
HPC2 0.1	4 CFU
HPC1 1.0	68 CFU
HPC2 1.0	73 CFU
HPC Result	71 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0229**

2018 Point Welcome Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Isaiah Kela-Pacheco

**Sample Date/Time:**

12/19/2021 at 9:35 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:35 AM

**Collection Remarks:**

Bathtub

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:59 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	2 CFU
HPC1 1.0	4 CFU
HPC2 1.0	3 CFU
HPC Result	4 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0238

5019 Iroquois Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Glen Haae

**Sample Date/Time:**

12/19/2021 at 10:30 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:44 AM

**Collection Remarks:**

Covered outside faucet to the left of the front door

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Positive
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 1:15 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	0 CFU
HPC1 1.0	7 CFU
HPC2 1.0	3 CFU
HPC Result	5 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0237

6660B 106th Street  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Glen Haae

**Sample Date/Time:**

12/19/2021 at 10:17 AM

**Received By:**

Lau, Tiffany

**Receipt Date/Time:**

12/19/2021 at 11:44 AM

**Collection Remarks:**

Covered outside faucet to the left of the front door

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Colisure

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 12:09 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/20/2021 at 1:12 PM

**Sample Results:**

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Lau, Tiffany

**Analysis Date/Time:**

12/19/2021 at 1:15 PM

**Read By:**

Lau, Tiffany

**Read By Date/Time:**

12/21/2021 at 12:50 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	1 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0239**

Red Hill Elementary School  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Natasha Asinsin

**Sample Date/Time:**  
12/20/2021 at 9:20 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/20/2021 at 11:30 AM

**Collection Remarks:**  
outside sink cafeteria

**Lab Comments:**  
None

**Disposal Date/Time:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/20/2021 at 1:33 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/22/2021 at 3:00 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	17 CFU
HPC2 0.1	20 CFU
HPC1 1.0	207 CFU
HPC2 1.0	215 CFU
HPC Result	211 CFU/ml

**Lab Comments:**  
Violation of holding conditions: Samples received >10 deg C, >2 h since collection.



# Sample Analysis Tracking System

**E21-12-0240**

Aliamanu CDC  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Natasha Asinsin

**Sample Date/Time:**  
12/20/2021 at 9:45 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/20/2021 at 11:30 AM

**Collection Remarks:**  
Mokihana classroom no. A101

**Lab Comments:**  
None

**Disposal Date/Time:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/20/2021 at 1:33 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/22/2021 at 3:00 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	2 CFU
HPC2 0.1	4 CFU
HPC1 1.0	70 CFU
HPC2 1.0	72 CFU
HPC Result	71 CFU/ml

**Lab Comments:**  
None





# Sample Analysis Tracking System

## E21-12-0243

Pearl Kai Elementary School  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Tom Brand

**Sample Date/Time:**

12/20/2021 at 9:47 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/20/2021 at 11:56 AM

**Collection Remarks:**

kitchen sink

**Lab Comments:**

None

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/20/2021 at 1:33 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/22/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	2 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

Violation of holding conditions: Samples received >10 deg C, >2 h since collection.



# Sample Analysis Tracking System

## E21-12-0245

Nimitz Elementary  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Tom Brand

**Sample Date/Time:**

12/20/2021 at 9:15 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/20/2021 at 11:56 AM

**Collection Remarks:**

custodian room outside men's restroom

**Lab Comments:**

None

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/20/2021 at 1:33 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/22/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	4 CFU
HPC2 1.0	16 CFU
HPC Result	10 CFU/ml

**Lab Comments:**

Violation of holding conditions: Samples received >10 deg C, >2 h since collection.



# Sample Analysis Tracking System

---

## E21-12-0244

Hickam Elementary  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

---

### Sample Receipt Data

**Sampler Name:**  
Tom Brand

**Sample Date/Time:**  
12/20/2021 at 11:15 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/20/2021 at 11:56 AM

**Collection Remarks:**  
cafeteria

**Lab Comments:**  
None

**Disposal Date/Time:**  
None

---

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/20/2021 at 1:33 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/22/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	40 CFU
HPC2 1.0	55 CFU
HPC Result	48 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0247**

Iroquois Point Elementary School  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/20/2021 at 10:27 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/20/2021 at 12:25 PM

**Collection Remarks:**

sink in classroom

**Lab Comments:**

None

**Disposal Date/Time:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/20/2021 at 1:33 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/22/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0242**

Pearl Harbor Elementary  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Natasha Asinsin

**Sample Date/Time:**  
12/20/2021 at 10:40 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/20/2021 at 11:30 AM

**Collection Remarks:**  
kitchen sink cafeteria

**Lab Comments:**  
None

**Disposal Date/Time:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/20/2021 at 1:33 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/22/2021 at 3:00 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0249**

Iroquois Point Pre School  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/20/2021 at 11:00 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/20/2021 at 12:25 PM

**Collection Remarks:**

outdoor spigot

**Lab Comments:**

None

**Disposal Date/Time:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/20/2021 at 1:33 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/22/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	1 CFU
HPC1 1.0	3 CFU
HPC2 1.0	5 CFU
HPC Result	4 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0248**

Iroquois Point Navy Exchange Mini mart, Cormorant Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/20/2021 at 10:44 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/20/2021 at 12:25 PM

**Collection Remarks:**

utility sink

**Lab Comments:**

None

**Disposal Date/Time:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/20/2021 at 1:33 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/22/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0241**

Aliamanu CYS  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**  
Natasha Asinsin

**Sample Date/Time:**  
12/20/2021 at 10:00 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/20/2021 at 11:30 AM

**Collection Remarks:**  
None

**Lab Comments:**  
None

**Disposal Date/Time:**  
None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/20/2021 at 1:33 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/22/2021 at 3:00 PM

### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
None





# Sample Analysis Tracking System

**E21-12-0250**

Kapilina Gym  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Christopher Hakoda

**Sample Date/Time:**

12/20/2021 at 11:00 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/20/2021 at 12:25 PM

**Collection Remarks:**

utility sink

**Lab Comments:**

None

**Disposal Date/Time:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Kim, June

**Analysis Date/Time:**

12/20/2021 at 2:00 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/22/2021 at 3:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0246

Mokulele Elementary School  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Tom Brand

**Sample Date/Time:**  
12/20/2021 at 10:42 AM

**Received By:**  
Kim, June

**Receipt Date/Time:**  
12/20/2021 at 11:56 AM

**Collection Remarks:**  
cafeteria

**Lab Comments:**  
None

**Disposal Date/Time:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Kim, June

**Analysis Date/Time:**  
12/20/2021 at 1:33 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/22/2021 at 3:00 PM

#### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	2 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

---

**E21-12-0253**

7370 Birch Circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

---

**Sample Receipt Data**

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/21/2021 at 10:45 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/21/2021 at 11:43 AM

**Collection Remarks:**  
Outdoor spigot, no sheen, no odor

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

---

**Heterotrophic Plate Count Pour Plate Method**

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/21/2021 at 4:07 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	1 CFU
HPC1 1.0	11 CFU
HPC2 1.0	13 CFU
HPC Result	12 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0259**

4755D East Ekahi Way  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Jammie Aroni

**Sample Date/Time:**

12/21/2021 at 9:55 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/21/2021 at 12:43 PM

**Collection Remarks:**

Outside faucet

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:29 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

Holding conditions violated: Samples received at >10 deg C, >2 h since collection.



# Sample Analysis Tracking System

## E21-12-0258

Pearl Harbor Aviation Museum, 319 Lexington Blvd  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/21/2021 at 11:00 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/21/2021 at 11:50 AM

**Collection Remarks:**

Janitor's closet sink, no odor

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:22 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	14 CFU
HPC2 1.0	16 CFU
HPC Result	15 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

## E21-12-0252

7377 Birch Circle  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/21/2021 at 10:28 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/21/2021 at 11:43 AM

**Collection Remarks:**  
Outdoor spigot, no sheen, no odor

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/21/2021 at 4:00 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	1 CFU
HPC2 1.0	1 CFU
HPC Result	1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0257

Ford Island Landing Park, 4800 Dauntless Drive  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/21/2021 at 10:40 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/21/2021 at 11:50 AM

**Collection Remarks:**

Women's bathroom sink w/ aerator

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:22 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	40 CFU
HPC2 0.1	43 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	420 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

**E21-12-0260**

4973BKela Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Jammie Aroni

**Sample Date/Time:**

12/21/2021 at 10:14 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/21/2021 at 12:43 PM

**Collection Remarks:**

Outside faucet

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:29 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

Holding conditions violated: Samples received at >10 deg C, >2 h since collection.





# Sample Analysis Tracking System

## E21-12-0255

Ford Island CDC, corner of O'Kane Blvd and Saratoga Blvd  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/21/2021 at 9:40 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/21/2021 at 11:50 AM

**Collection Remarks:**

No odor, laundry room sink

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:14 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	71 CFU
HPC2 0.1	81 CFU
HPC1 1.0	TNTC
HPC2 1.0	TNTC
HPC Result	760 CFU/ml

**Lab Comments:**

Holding conditions violated: Samples received at >10 deg C, >2 h since collection.



# Sample Analysis Tracking System

## E21-12-0251

444 Kuahua Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/21/2021 at 9:53 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/21/2021 at 11:43 AM

**Collection Remarks:**  
Female bathroom sink 2nd floor far left, no sheen, no odor

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/21/2021 at 4:00 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

**E21-12-0256**

Navy Lodge Hawaii, 1275 Saratoga Blvd  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

## Sample Receipt Data

**Sampler Name:**

Lauren Cruz

**Sample Date/Time:**

12/21/2021 at 10:00 AM

**Received By:**

Ruiz, Mandelle

**Receipt Date/Time:**

12/21/2021 at 11:50 AM

**Collection Remarks:**

Laundry room sink, no odor

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed. HPC per SDWB

**Disposal Date/Time:**

None

## Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:14 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



# Sample Analysis Tracking System

---

**E21-12-0261**

4974D Kela Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

---

**Sample Receipt Data****Sampler Name:**

Jammie Aroni

**Sample Date/Time:**

12/21/2021 at 10:28 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/21/2021 at 12:43 PM

**Collection Remarks:**

Outside faucet

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

---

**Heterotrophic Plate Count Pour Plate Method****Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:37 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

Holding conditions violated: Samples received at >10 deg C, >2 h since collection.



# Sample Analysis Tracking System

## E21-12-0254

7384 Birch Circle Bldg  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**  
Shirley Watanabe

**Sample Date/Time:**  
12/21/2021 at 10:58 AM

**Received By:**  
Ruiz, Mandelle

**Receipt Date/Time:**  
12/21/2021 at 11:43 AM

**Collection Remarks:**  
Outside faucet, no sheen, no odor

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**  
Ruiz, Mandelle

**Analysis Date/Time:**  
12/21/2021 at 4:07 PM

**Read By:**  
Ruiz, Mandelle

**Read By Date/Time:**  
12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	5 CFU
HPC2 0.1	12 CFU
HPC1 1.0	55 CFU
HPC2 1.0	73 CFU
HPC Result	64 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

## E21-12-0120

Aiea Halawa Shaft Pump Room Pre Chlor  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:** Melvin Tokuda  
**Sample Date/Time:** 12/9/2021 at 11:30 AM

**Received By:** Ruiz, Mandelle  
**Receipt Date/Time:** 12/9/2021 at 2:53 PM

**Collection Remarks:**  
None

**Lab Comments:**  
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**  
None

### Colisure

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 3:42 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/10/2021 at 4:02 PM

#### Sample Results:

Contaminant	Result
Total Coliforms	Negative
E. coli	Negative

**Lab Comments:**  
None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:** Ruiz, Mandelle  
**Analysis Date/Time:** 12/9/2021 at 6:00 PM

**Read By:** Ruiz, Mandelle  
**Read By Date/Time:** 12/11/2021 at 4:45 PM

#### Sample Results:

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**  
None



# Sample Analysis Tracking System

---

**E21-12-0262**

4976D Kela Place  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

---

**Sample Receipt Data****Sampler Name:**

Jammie Aroni

**Sample Date/Time:**

12/21/2021 at 10:39 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/21/2021 at 12:43 PM

**Collection Remarks:**

Outside faucet

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

---

**Heterotrophic Plate Count Pour Plate Method****Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:37 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	3 CFU
HPC Result	2 CFU/ml

**Lab Comments:**

Holding conditions violated: Samples received at >10 deg C, >2 h since collection.



# Sample Analysis Tracking System

## E21-12-0263

5085B Iroquois Avenue  
SCRS Analyte/Analyte Group : Total Coliform Bacteria

### Sample Receipt Data

**Sampler Name:**

Jammie Aroni

**Sample Date/Time:**

12/21/2021 at 11:05 AM

**Received By:**

Kim, June

**Receipt Date/Time:**

12/21/2021 at 12:43 PM

**Collection Remarks:**

Outside faucet with aerator

**Lab Comments:**

Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.

**Disposal Date/Time:**

None

### Heterotrophic Plate Count Pour Plate Method

**Analyst:**

Ruiz, Mandelle

**Analysis Date/Time:**

12/21/2021 at 4:41 PM

**Read By:**

Ruiz, Mandelle

**Read By Date/Time:**

12/23/2021 at 2:00 PM

**Sample Results:**

Contaminant	Result
HPC1 0.1	0 CFU
HPC2 0.1	0 CFU
HPC1 1.0	0 CFU
HPC2 1.0	0 CFU
HPC Result	< 1 CFU/ml

**Lab Comments:**

None



1713 Blackhaw Place	C21-12-0012	C21-12-0008	C21-12-0016	E21-12-0012		
1610 Cowslip Lane	C21-12-0009	C21-12-0013	C21-12-0017	E21-12-0228		
4072 Ironwood Loop	C21-12-0010	C21-12-0014	C21-12-0018	E21-12-0013	E21-12-0231	
Holy Family Academy	C21-12-0011		C21-12-0019	E21-12-0014		
5720 Erne Avenue	C12-21-0006	C21-12-0007	C21-12-0020			
1025 Saratoga Boulevard				E21-12-0196		
Red Hill Elementary School				E21-12-0001	E21-12-0239	
Aliamanu CDC				E21-12-0002	E21-12-0024	
Aliamanu CYS				E21-12-0003		
Pearl Harbor ES				E21-12-0004		
Nimitz ES				E21-12-0005	E21-12-0245	
Mokulele ES				E21-12-0006	E21-12-0246	
Pearl Harbor Kai ES				E21-12-0008	E21-12-0243	
Hickam ES				E21-12-0007	E21-12-0244	
Iroquois Point ES				E21-12-0009	E21-12-0069	E21-12-0247
1829 Fox Blvd				E21-12-0010		
5720 Erne Avenue				E21-12-0011		
3276 Maloelap St				E21-12-0021		
6813 Milo Lane				E21-12-0016		
1316 Eagle Circle				E21-12-0015		
3054 Vaessen Court				E21-12-0020		
2760 Stowell Circle				E21-12-0019		
6811 Milo Lane				E21-12-0017		
3158 Snyder Court				E21-12-0018		
6230 Naupaka St				E21-12-0023		
4685 Kou Lane				E21-12-0022		
PH Church of Christ				E21-12-0025		
Red Hill Shaft				E21-12-0026		
Red Hill Upper Storage Tank				E21-12-0027		
Waiawa Shaft				E21-12-0071		
539 McGrew Loop				E21-12-0067		
719 McGrew Loop				E21-12-0066		
1167 Hekau St				E21-12-0065	E21-12-0209	

131 3rd St				E21-12-0064		
Iroquois Point Pre School				E21-12-0070	E21-12-0249	
7397 Birch Circle				E21-12-0068		
565 McGrew Loop				E21-12-0074		
824 McGrew Loop				E21-12-0075		
1156 Hekau St				E21-12-0073		
1161 Honu Loop				E21-12-0072		
7200 Birch Circle				E21-12-0076		
767 Sibley St				E21-12-0195		
147 Octopus Lane				E21-12-0077		
6181 Ibis Ave				E21-12-0081		
5019 Iroquois Ave				E21-12-0083	E21-12-0238	
6666B 106th St				E21-12-0079		
6660B 106th Str				E21-12-0082	E21-12-0237	
5424 Edgewater Drive				E21-12-0080	E21-12-0235	
6674 106th St				E21-12-0088		
5534 Bittern Ave				E21-12-0085		
5673 Dovekie Ave				E21-12-0086		
5669A Dovekie Avenue				E21-12-0087		
4908 Mokupea Pl				E21-12-0084		
Halawa Correctional Facility				E21-12-0078		
Halawa Shaft				E21-12-0089		
5682 Dovekie Ave				E21-12-0101		
5012A Iroquois Ave				E21-12-0097		
5861 Fulmar Ave				E21-12-0100		
5856B Fulmar Ave				E21-12-0098		
5869 Fulmar Ave				E21-12-0099		
4976 Kela Pl				E21-12-0102		
7273 Elm Pl				E21-12-0095		
3763 Elm Dr				E21-12-0091		
Aiea Halawa Shaft Pump room				E21-12-0120		
5321 Cedar Dr				E21-12-0090		
Aiea Halawa Post Chlor				E21-12-0121		

7257 Birch Circle				E21-12-0092	E21-12-0093	E21-12-0094
7236 Birch Circle				E21-12-0096		
Halawa Storage Tank 1				E21-12-0122		
Halawa Storage Tank 2				E21-12-0123		
6176 Heron Ave				E21-12-0168		
6168 Heron Ave				E21-12-0167		
6365 Ibis Ave				E21-12-0169		
5537 Bittern Ave				E21-12-0171		
5548 Bittern Ave				E21-12-0170		
4682 Oklahoma Ave				E21-12-0116		
2031 Fox Blvd				E21-12-0117		
4623 Scott Loop				E21-12-0118		
732 Sibley St				E21-12-0119		
Bldg 300				E21-12-0113		
Bldg 303				E21-12-0109		
4755D East Ekahi Way				E21-12-0111	E21-12-0259	
4973B Kela Pl				E21-12-0110	E21-12-0260	
4976D Kela Pl				E21-12-0114	E21-12-0262	
4974D Kela Pl				E21-12-0112	E21-12-0261	
7377 Birch Circle				E21-12-0103	E21-12-0252	
7370 Birch Circle				E21-12-0105	E21-12-0253	
7384 Birch Circle				E21-12-0107	E21-21-0254	
Bldg 1338				E21-12-0104		
Pearl City Shaft				E21-12-0163		
4906 Wasp Blvd				E21-12-0115		
3802 Elm Dr				E21-12-0108		
Camp Smith Tanks				E21-12-0124		
6168A Ibis Ave				E21-12-0164		
6151A Heron Ave				E21-12-0166		
6089 Heron Avenue				E21-12-0165		
1402 Lanikai Ave				E21-12-0173		
1610 Aloha Ave				E21-12-0174		
1406 Lanikai Ave				E21-12-0172		

1813 Palm Ave				E21-12-0175		
2891D Makuu Lp				E21-12-0180		
2899C Makuu Lp				E21-12-0178		
2879A Hapue Lp				E21-12-0177		
2856A Kokio Lp				E21-12-0179		
2862A Kokio Lp				E21-12-0176		
2850A Kokio Lp				E21-12-0181		
2165 Baugh Rd				E21-12-0189		
739 Anderson Rd				E21-12-0190		
2173 Baugh Rd				E21-12-0186		
Bldg 1B				E21-12-0188		
Bldg 612				E21-12-0187		
Bldg 4				E21-12-0193		
Bldg 20				E21-12-0191		
Bldg 601				E21-12-0192		
Across Bldg 2C				E21-12-0194		
1838 Palm Ave				E21-12-0200		
134 Ley Court				E21-12-0202		
148 Ley Ct				E21-12-0203		
1832 Palm Ave				E21-12-0199		
5297 Iroquois Ave				E21-12-0204		
4670 Nevada St				E21-12-197		
Camp Smith Tank S326				E21-12-0125		
Camp Smith Tank 684				E21-12-0126		
Momilani ES				E21-12-0162		
Uluakupu Bldg				E21-12-0161		
Fire Station 38 Waiau				E21-12-0182		
Fire Station 12 Waipahu				E21-12-0183		
Fire Station 10 Aiea				E21-12-0184		
Fire Station 42 Waikele				E21-12-0185		
128 Ley Ct				E21-12-0201		
4909 Tomahawk St				E21-12-0198		
6073A Heron Ave				E21-12-0207		

4836 West Eha Way				E21-12-0208		
5533 Bittern Ave				E21-12-0205		
5713 Erne Ave				E21-12-0206		
5111 Iroquois Ave				E21-12-0236		
1191 Honu Wy				E21-12-0210		
1207 Honu Wy				E21-12-0211		
1177 Honu Way				E21-12-0212		
619 Pool St				E21-12-0214		
4999 Kidd Ct				E21-12-0216		
Radfford Terrance CC				E21-12-0213		
Ohana Navy Communities				E21-12-0215		
1301 McMurtry				E21-12-0222		
187 Honohono				E21-12-0224		
137 Honhono St				E21-12-0223		
211 Hickam Communities Bldg				E21-12-0221		
Bloch Arena				E21-12-0218		
Navy Gateway Lockwood Hall				E21-12-0220		
Ford Island CDC				E21-12-0255		
Makalapa Clinic				E21-12-0219		
NEX Commissary				E21-12-0217		
1605 Cowslip Lane				E21-12-0227		
1540 Tampa Dr				E21-12-0225		
1532 Tampa Dr				E21-12-0226		
4126 Begonia Lp				E21-12-0232		
4132 Begonia Lp				E21-12-0233		
127 Olive Pl				E21-12-0230		
2018 Welcome Point Pl				E21-12-0229		
56669A Dovekie Ave				E21-12-0234		
Aliamanu CDC				E21-12-0240		
Aliamanu CYS				E21-12-0241		
Pearl Harbor ES				E21-12-0242		
Kapilina Gym				E21-12-0250		
Iroquois Point NEX Mini Mart				E21-12-0248		

Navy Lodge Hawaii				E21-12-0256		
Ford Island Landing Park				E21-12-0257		
Pearl Harbor Aviation Museum				E21-12-0258		
444 Kuahua Ave				E21-12-0251		
5085B Iroquois Ave				E21-12-0263		

	Log Number	P12-21-001	P12-21-002	P12-21-003	P12-21-004	P12-21-005	P12-21-006	P12-21-007	P12-21-008	P12-21-009	P12-21-010
	Description	Allamanu Child Development Center Classroom Sink	Allamanu Child and Youth Svcs Kitchen Sink	Hickam Elem School Cafeteria Sink	Mokulele Elem School Cafeteria Sink	Nimitz Elem School Cafeteria Sink	Pearl Harbor Elem School Cafeteria Sink	Pearl Kai Elem School Cafeteria Sink	Redhill Elem School Cafeteria Sink	Iroquois Pt. Elem School Cafeteria Sink	1929 Fox Blvd-Upstars Master Bath Sink on right
	Sample Date	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	12/1/2021	12/1/2021
	Sample Time	1313	1330	1530	1500	1420	1350	1600	1230	1035	1205
	Analysis Date	12/4/2021	12/4/2021	12/4/2021	12/4/2021	12/4/2021	12/4/2021	12/4/2021	12/4/2021	12/4/2021	12/5/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected)								
	ug/L										
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	Less than 0.1 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	Less than 0.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		0.02	ND	ND	ND	0.01	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	<i>Yean-Sung Jung</i>	Yean-Sung Jung, 12/5/21									
QA Check / Date:	<i>B. Bando</i>	12/6/21									
Forwarded by:	<i>J. Bando</i>	12-6-21									
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.										
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.											

		Log Number	P12-21-011	P12-21-012	P12-21-013	P12-21-014	P12-21-015	P12-21-016	P12-21-017	P12-21-018	P12-21-019	P12-21-020
		Description	1316 Eagle Circle, Kitchen Sink	3158 Snyder Court, Kitchen Sink	6811 Milo Lane, Laundry Sink	6813 Milo Lane, Bottom Floor Bath Sink	2760 Stowell Circle, Kitchen Sink	3054 Vaessen court, Kitchen Sink	3276 Maloelap Street Laundry Room Sink	6230 Naupoka Street, Laundry Room Faucet	4685 Kou Lane, Bath Tub Faucet	3039 Arizona Road, Kitchen Faucet
		Sample Date	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/4/2021	12/4/2021	12/4/2021
		Sample Time	1047	1309	1219	1140	1110	1200	1230	920	935	1020
		Analysis Date	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected)									
	ug/L											
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	0.07	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	Less than 0.1 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	Less than 0.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	0.01	0.02	0.02	0.01	0.01	0.02	0.01	0.01	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		<i>Wendy Orr</i>	12/9/2021									
QA Check / Date:		<i>A. Pender</i>	12/9/21									
Forwarded by:		<i>Richard K. ...</i>	12-9-21									
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field.											
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers,											
	preserved as specified in the method, then analyzed.											
	SLD is provisionally certified by EPA for this analysis.											



		Log Number	P12-21-021	P12-21-022	P12-21-025	P12-21-026	P12-21-027	P12-21-028	P12-21-029	P12-21-030	P12-21-031	P12-21-032
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	Allamano Child Development Center	PH Church of Christ	131 3rd Street, Kitchen Sink	1167 Hekau Street, Laundry Room Sink	719 McGrew Loop, Upstairs Bathroom Shower Faucet	593 McGrew Loop, Kitchen Sink	5553 Comarant Avenue, Cafeteria Sink	5111 Iroquois Avenue	7397 Birch Circle, Kitchen Faucet Sink	Waiawa Shaft, Pre-chlorination
		Sample Date	12/6/2021	12/6/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021
		Sample Time	1100	1110	1020	1055	1120	1155	1030	1115	1200	1230
		Analysis Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected)									
		ug/L										
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	Less than 0.1 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	Less than 0.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	<i>Heath</i>	12/10/2021										
QA Check / Date:	<i>A. Smith</i>	12/10/21										
Forwarded by:	<i>R. Smith</i>	12-10-21										
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.											

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-033	P12-21-034	P12-21-035	P12-21-036	P12-21-037	P12-21-038	P12-21-039	P12-21-040	P12-21-041	P12-21-042
Description			1161 Honu Loop, Upstars Bathroom Shower Faucet	1156 Hekau Street, Upstars Bathroom Shower Faucet	565 McGrew Loop, Laundry Room Sink	824 McGrew Loop, Bathroom Shower Faucet	147 Octopus Lane, Laundry Sink	7200 Birxh Circle, Kitchen Sink	Halawa Correctional Facility	5019 Iroquois Ave, Bath Tub	6666B 106th Street, Outside Hose Bib	6181 Ibis Ave, Bath Tub
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/8/2021	12/8/2021	12/8/2021	12/8/2021	12/8/2021	12/8/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021
		Sample Time	1110	1050	1015	1035	1015	1303	1146	1215	1135	1055
		Analysis Date	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified		Maximum Contaminant Level										
Detection Limit		ug/L										
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	0.02	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	<i>Yeaman Jr</i> 12/14/21											
QA Check / Date:	<i>B. Pineda</i> 12/14/21											
Forwarded by:	<i>R. Smith</i> 12-14-21											
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field.											
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers,											
	preserved as specified in the method, then analyzed.											

	Log Number	P12-21-043	P12-21-044	P12-21-045	P12-21-046	P12-21-047	P12-21-048	P12-21-049	P12-21-050	P12-21-051
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory	Description	5424 Edgewater Drive, Bath Tub	6660B 106th Street, Bath Tub **	Aiea Halawa Shaft	Aiea Halawa Pump, Room Pre-Chlor	Aiea Halawa Shaft, Post Chlor.	Halawa Storage Tank1 (S1)	Halawa Storage Tank2 (S2)	5669A Dovekie Ave, Outside Spigot	4908 Mokapea Place, Tub Fixture Upstairs
Results (ND = Not Detected, NQ = Not Quantifiable)	Sample Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021
	Sample Time	1118	1154	1030	1130	1200	1250	1310	1227	1105
	Analysis Date	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified	Detection Limit	Maximum Contaminant Level	**Elevated Baseline, not able to analyze sample.							
		ug/L								
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	0.01	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	NQ	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	0.03	0.05	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	Leonard 12/14/21									
QA Check / Date:	R. Smith 12/14/21									
Forwarded by:	Richard Sals 12-14-21									
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field.									
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers,									
	preserved as specified in the method, then analyzed.									

		Log Number	P12-21-052	P12-21-053	P12-21-054	P12-21-055	P12-21-056	P12-21-057	P12-21-058	P12-21-059	P12-21-060	P12-21-061	P12-21-062	P12-21-063	P12-21-064
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	5673 Dovekie Ave	5534 Bittern Avenue, Tub Faucet	6674 106th Street, Outside Spigot	7273 Elm Place, Upstairs Laundry Sink	3763 Elm Drive, Kitchen Sink	7257 Birch Circle, Kitchen Sink	7236 Birch Circle, Kitchen Sink	5321 Cedar Dr., Outside Spigot	5012A Iroquois Ave, Outside Spigot	5861 Fulmar, Outside Spigot	4976B Kela Place, Outside Spigot	5682 Dovekie, Outside Spigot	5856B Furmar, Outdoor Spigot
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/9/2021	12/9/2021	12/9/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021
		Sample Time	1215	1141	1259	906	937	1044	1105	1002	952	1020	1105	930	1030
		Analysis Date	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified		Detection Limit	Maximum Contaminant Level												
		ug/L													
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:			<i>Heandry</i>	12/16/21											
QA Check / Date:			<i>P. Sandoz</i>	12/16/21											
Forwarded by:			<i>R. Sandoz</i>	12-16-21											
Note:		Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field.													
		Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers,													
		preserved as specified in the method, then analyzed.													
		SLD is provisionally certified by EPA for this method.													

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-065	P12-21-066	P12-21-067	P12-21-068	P12-21-069	P12-21-070	P12-21-072	P12-21-073	P12-21-074	P12-21-075	P12-21-076	P12-21-077
Description		5869 Fulmar, Outside Spigot	7377 Birch Circle, Outside Spigot	444 Kahua Avenue, Side Back Spigot	Building 1338 Fitness Center, Front Door Spigot	7370 Birch Circle, Spf Spiriting Spigot	7384 Birch Circle, Front Outside Spigot	Bldg 303, BEQ, Outside Spigot	Bldg 300 Block-A, BEQ, East Side Outside Spigot	4976D Kela Place, Outside Spigot	4755D East Ekahi Way, Outside Spigot	4974D Kela Place, Outside Spigot	4973B Kela Place, Outside Spigot	
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/10/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021
		Sample Time	1040	1030	1130	1140	1045	1055	1204	1155	1120	1053	1128	1110
		Analysis Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified		Detection Limit	Maximum Contaminant Level											
		ug/L												
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	C. Anderson 12/20/21													
QA Check / Date:	R. P. [Signature] 12/20/21													
Forwarded by:	J. [Signature] 12-20-21													
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field.													
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers,													
	preserved as specified in the method, then analyzed.													
	SLD is provisionally certified by EPA for this method.													
	Log number P12-21-071, 3802 Elm Drive water sample, sampled on 12/12/21 @ 10:00 am, not analyzed due to visible sheen on surface.													

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-078	P12-21-079	P12-21-080	P12-21-081	P12-21-082	P12-21-083	P12-21-084	P12-21-085	P12-21-086	P12-21-087	P12-21-088	P12-21-089
Description		4906 Wasp Blvd, Wash Room Faucet	4682 Oklahoma Ave, Wash Room Faucet	2031 Fox Blvd, Upstairs Bathroom Bathtub Faucet	4623 Scott Loop, Laundry Room Sink	732 Sibley St, 1st flr Bathroom bathtub Faucet	Camp Smith Tank S 325, Top Access Hatch	Camp Smith Tank S 326, Top Access Hatch	Camp Smith Tank 684, Top Access Hatch	Pearl City Shaft, EPD	6186 A Ibis Ave, Bathroom Tub Spout	6089 Heron B Ave, Bedroom Sink	6151 A Heron Ave, Bedroom Sink	
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021
		Sample Time	1035	1100	1130	1200	1230	1000	1120	1245	1050	1045	1104	1122
		Analysis Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified		Detection Limit	Maximum Contaminant Level											
		ug/L												
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	<i>Heather D</i> 12/23/2021													
QA Check / Date:	<i>R. P. ...</i> 12/23/21													
Forwarded by:	<i>R. ...</i> 12-23-21													
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field.													
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.													
	SLD is provisionally certified by EPA for this analysis.													

		Log Number	P12-21-090	P12-21-091	P12-21-092	P12-21-093	P12-21-094	P12-21-095	P12-21-096	P12-21-097	P12-21-098	P12-21-099	P12-21-100	P12-21-101	P12-21-102
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	6176 Heron Avenue, Outdoor Spigot	6168 Heron Avenue, Outdoor Spigot	5548 Bittern Avenue, Outdoor Spigot	6365 Ibis Ave, Bath Tub	5537 Bittern Avenue, Outdoor Spigot	1406 Laniwai Avenue, Outside Spigot	1402 Laniwai Avenue, Outside Spigot	1619 Aloha Avenue, Outside Spigot	1813 Palm Avenue, Outside Spigot	2891 D Makuu Loop, Bath Tub	500 337-2899C Makuu Loop, Outdoor Spigot	2862 A Kokio Loop, Outside Spigot	500 339 '2856A Kokio Loop, Bath Tub
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021
		Sample Time	1050	1055	1141	1114	1150	1025	1041	1100	1115	1006	1030	1040	1055
		Analysis Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Synthetic Organic Compounds - EPA Method 508.1 Modified		Detection Limit													
		Maximum Contaminant Level													
		ug/L													
Hexachlorocyclopentadiene		Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene		Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane		Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor		Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide		Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin		Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor		Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor		Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane		ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene		ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016		Less than 0.26 ug/L		ND	NQ	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221		Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232		Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242		Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248		Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254		Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260		Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine		Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine		Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin		Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin		Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor		Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin		Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor		Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor		Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		Leonard J. 12/23/2021													
QA Check / Date:		B. Ruff 12/23/21													
Forwarded by:		Julius S. 12-23-21													
Note:		Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.													
		SLD is provisionally certified by EPA for this analysis.													

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-103	P12-21-104	P12-21-105	P12-21-106	P12-21-107	P12-21-108	P12-21-109	P12-21-110	P12-21-111	P12-21-112	P12-21-113**	P12-21-114
Description			2850A kokio loop, outdoor spigot	2879A hapue loop, outdoor spigot	500 Bldg 1B, janitor room	500 Bldg 612 fire station, laundry room	500-739 anderson rd, outdoor spigot	500-2165 baugh rd outdoor spigot	500-2173 baugh rd outdoor spigot	Bldg 4 1st floor loading dock men's room	Bldg 20 men's room adjacent 20E	Bldg 601 elrod road outside spigot	Across Bldg 2C outdoor spigot	767 sibley st outside hose faucet
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/15/2021	12/15/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021
		Sample Time	1115	1130	930	945	1010	1020	1035	930	1010	1020	1040	930
		Analysis Date	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022
Synthetic Organic Compounds - EPA Method 508.1 Modified		Detection Limit	Maximum Contaminant Level											
		ug/L												
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
** Sample P12-21-113: quantation is not possible due to poor surrogate recovery because of excessively high internal standard recovery														
Analyst / Date:		L. Anderson 1/14/22												
QA Check / Date:		B. Smith 1/14/22												
Forwarded by:		P. Smith 1-14-22												
Note:		Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.												
		SLD is provisionally certified by EPA for this analysis.												



State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-115	P12-21-116	P12-21-117	P12-21-118	P12-21-119	P12-21-120	P12-21-121	P12-21-122	P12-21-123	P12-21-124	P12-21-125	P12-21-126
		Description	1025 saratoga blvd laundry room sink	4670 nevada st outside hose faucet	4909 tomahawk st kitchen sink	1824 palm ave kitchen sink	1838 palm ave garage hose faucet	128 ley court hose faucet	134 ley court hose faucet	148 ley court hose faucet	4836 west eha way unit B kitchen sink	6073A heron ave kitchen sink	5713 erne ave kitchen sink	5533 bittern ave kitchen sink
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/16/2021	12/16/2021	12/16/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021
		Sample Time	1015	1040	1100	915	940	1000	1015	1030	1030	1035	1000	945
		Analysis Date	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022
Synthetic Organic Compounds - EPA Method 508.1 Modified		Detection Limit	Maximum Contaminant Level											
		ug/L												
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		iscander 1/19/22												
QA Check / Date:		B. B. 1/14/22												
Forwarded by:		L. D. 1-14-22												
Note:		Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed. SLD is provisionally certified by EPA for this analysis.												

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-127	P12-21-128	P12-21-129	P12-21-130	P12-21-131	P12-21-132	P12-21-133	P12-21-134	P12-21-135	P12-21-136	P12-21-137	P12-21-138
		Description	5297 Iroquois ave kitchen sink	1167 hekau st laundry wash basin	1191 honu loop bath tub	1207 honu outside hose bib	1177 honu loop bathtub	radford terrace community center murray street outside spigot	619 pool street	ohana navy communities jalut street outside spigot	4999 kidd court community center women's sink	nex commissary 4725 bouganville drive meat processing deep sink	bloch arena A avenue	makalapa clinic 1257 makalapa road outside
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021
		Sample Time	930	935	1010	1035	1050	930	959	1025	1050	930	1020	1045
		Analysis Date	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022
Synthetic Organic Compounds - EPA Method 508.1 Modified		Maximum Contaminant Level												
		Detection Limit												
		ug/L												
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		<i>U. Anderson</i>	1/14/22											
QA Check / Date:		<i>R. Pines</i>	1/14/22											
Forwarded by:		<i>Rebecca S. ...</i>	1-14-22											
Note:		Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.												
		SLD is provisionally certified by EPA for this analysis.												

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-139	P12-21-140	P12-21-141	P12-21-142	P12-21-143	P12-21-144	P12-21-145	P12-21-146	P12-21-147	P12-21-148
		Description	lockwood hall dealey circle women's restroom sink	211 mercury street hickam communities bldg outside spigot	137 honohono street	1301 memurtay outside spigot	187 honohono street front patio spigot	1532 tampa drive outside spigot	1605 cowslip lane laundry sink	1610 cowslip lane laundry sink	1540 tampa drive inside bathroom tub	2018 point welcome place bathtub
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021
		Sample Time	1100	1208	1130	1000	1100	940	1030	1005	925	935
		Analysis Date	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022	1/3/2022
Synthetic Organic Compounds - EPA Method 508.1 Modified		Detection Limit	Maximum Contaminant Level									
		ug/L										
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	0.01	0.01	0.01	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		Heard 1/14/22										
QA Check / Date:		A. Price 1/14/22										
Forwarded by:		K. S. 1-14-22										
Note:		Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed. SLD is provisionally certified by EPA for this analysis.										

	Log Number	P12-21-149	P12-21-150	P12-21-151	P12-21-152	P12-21-153	P12-21-154	P12-21-155	P12-21-156	P12-21-157	P12-21-158	P12-21-159	P12-21-160
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory	Description	127 Olive Place	4072 Ironwood Loop	4126 Begonia Loop	4132 Begonia Loop	56669 A Doekie Ave	5424 Edgewater Drive	5111 Iroquois Avenue	6660B 106th Street	5019 Iroquois Avenue	Red Hill Elementary School	Allamano CDC	Allamano CYS
Results (ND = Not Detected, NQ = Not Quantifiable)	Sample Date	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/20/2021	12/20/2021	12/20/2021
	Sample Time	955	1015	1030	1050	935	950	1003	1017	1030	920	945	1000
	Analysis Date	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022
Synthetic Organic Compounds - EPA Method 508.1 Modified	Detection Limit	Maximum Contaminant Level											
		ug/L											
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	0.01	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	G. Miller 1/18/22												
QA Check / Date:	B. Rindley 1-18-22												
Forwarded by:	C. H. Sal 1-18-22												
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.												
	SLD is provisionally certified by EPA for this analysis.												

		Log Number	P12-21-161	P12-21-162	P12-21-163	P12-21-164	P12-21-165	P12-21-166	P12-21-167	P12-21-168	P12-21-169	P12-21-170	P12-21-171	P12-21-172
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	Pearl Harbor Elementary	Nimitz Elementary	Pearl Kai Elementary	Mokulele Elementary	Hickam Elementary	Iroquois Point Elementary School	Iroquois Point Navy Exchange	Iroquois Point Preschool	Kapilina Gym	444 Kuahua Avenue	7377 Birch Circle	7370 Birch Circle
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/21/2021	12/21/2021	12/21/2021
		Sample Time	1040	915	947	1042	1115	1027	1044	1100	1110	953	1028	1045
		Analysis Date	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022
Synthetic Organic Compounds - EPA Method 508.1 Modified		Maximum Contaminant Level												
		Detection Limit												
		ug/L												
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	John 1/18/2022													
QA Check / Date:	S. B. 1-18-22													
Forwarded by:	Richard Sals 1-18-22													
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field.													
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers,													
	preserved as specified in the method, then analyzed.													
	SLD is provisionally certified by EPA for this analysis.													

		Log Number	P12-21-173	P12-21-174	P12-21-175	P12-21-176	P12-21-177	P12-21-178	P12-21-179	P12-21-180	P12-21-181	P12-21-182
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	7384 Birch Circle Bldg	Ford Island CDC Corner of O'Kane & Saratoga Blvd	Navy Lodge Hawaii, 1275 Saratoga Blvd	Ford Island Landing Park, 4800 Dauntless	Pearl Harbor Aviation Museum, 319 Lexington Blvd	4755 D East Ekahi Way	4973 B Kela Place	4974 D Kela Place	4976 D Kela Place	5085 B Iroquois Ave
Results (ND = Not Detected, NQ = Not Quantifiable)		Sample Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021
		Sample Time	1058	940	1000	1040	1100	955	1014	1028	1039	1105
		Analysis Date	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022	1/11/2022
Synthetic Organic Compounds - EPA Method 508.1 Modified	Detection Limit	Maximum Contaminant Level										
		ug/L										
Hexachlorocyclopentadiene	Less than 0.05 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hexachlorobenzene	Less than 0.05 ug/L	1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Lindane	Less than 0.02 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor	Less than 0.01 ug/L	0.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Heptachlor Epoxide	Less than 0.01 ug/L	0.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Endrin	Less than 0.01 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methoxychlor	Less than 0.05 ug/L	40	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Alachlor	Less than 0.05 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlordane	ND Less than 0.1 ug/L, NQ Less than 0.3 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toxaphene	ND Less than 0.5 ug/L, NQ Less than 1.5 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1016	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1221	Less than 0.19 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1232	Less than 0.23 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1242	Less than 0.26 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1248	Less than 0.3 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1254	Less than 0.33 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aroclor 1260	Less than 0.36 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Simazine	Less than 0.07 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Atrazine	Less than 0.05 ug/L	3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metribuzin	Less than 0.2 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Aldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Butachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Dieldrin	Less than 0.01 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Metolachlor	Less than 0.05 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Propachlor	Less than 0.1 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i> 1/18/2022											
QA Check / Date:	<i>[Signature]</i> 1-18-22											
Forwarded by:	<i>[Signature]</i> 1-18-22											
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.											
	SLD is provisionally certified by EPA for this analysis.											

			Log Number	P12-21-001	P12-21-002	P12-21-003	P12-21-004	P12-21-005	P12-21-006	P12-21-007	P12-21-008	P12-21-009	P12-21-010
			Description	Allamano Child Development Center Classroom Sink	Allamano Child and Youth Svcs Kitchen Sink	Hickam Elem School Cafeteria Sink	Mokulele Elem School Cafeteria Sink	Nimitz Elem School Cafeteria Sink	Pearl Harbor Elem School Cafeteria Sink	Pearl Kai Elem School Cafeteria Sink	Red Hill Elem School Cafeteria Sink	Iroquois Pt Elem School Cafeteria Sink	1829 Fox Blvd - Upstairs Master Bath Sink on right
			Sample Date	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	12/1/2021	12/1/2021
			Sample Time	1313	1330	1530	1500	1420	1350	1600	1230	1035	1205
			Analysis Date	12/2/2021	12/2/2021	12/2/2021	12/2/2021	12/2/2021	12/2/2021	12/2/2021	12/2/2021	12/2/2021	12/2/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected, NQ = Not Quantifiable) (Sodium units in mg/L, other Metals in ug/L)									
			ug/L										
Antimony	EPA Method 200.8 Modified	Less than 2 ug/L	6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Arsenic	EPA Method 200.8 Modified	Less than 2 ug/L	10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Barium	EPA Method 200.8 Modified	Less than 10 ug/L	2000	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Beryllium	EPA Method 200.8 Modified	Less than 0.5 ug/L	4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Cadmium	EPA Method 200.8 Modified	Less than 0.2 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chromium	EPA Method 200.9 Modified	Less than 2 ug/L	100	ND	2.61	ND	ND	ND	ND	ND	2.24	ND	ND
Copper	EPA Method 200.8 Modified	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	ND	NQ	116	ND	ND	80	ND	ND	NQ
Lead	EPA Method 200.8 Modified	Less than 0.5 ug/L	15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Mercury	EPA Method 200.8 Modified	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Nickel	EPA Method 200.8 Modified	Less than 5 ug/L		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Selenium	EPA Method 200.9 Modified	Less than 5 ug/L	50	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Thallium	EPA Method 200.8 Modified	Less than 1 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Sodium	SM 3111B Modified	Less than 1 mg/L		68	53	32	49	50	58	48	55	27	37
	Analyst / Date:	<i>m</i>	12/3/21										
	QA Check / Date:	<i>ABM</i>	12/3/21										
	Forwarded by:	<i>Rubend Salas</i>	12-3-21										
	Note: Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field.												
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.												

			Log Number	P12-21-011	P12-21-012	P12-21-013	P12-21-014	P12-21-015
			Description	1316 Eagle Circle Kitchen sink	3158 Snyder Court Kitchen sink	6811 Milo Lane Laundry sink	6813 Milo Lane Bottom Floor Bath sink	2760 Stowell Circle Kitchen sink
			Sample Date	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021
			Sample Time	1047	1309	1219	1140	1110
			Analysis Date	12/6/2021	12/6/2021	12/6/2021	12/6/2021	12/6/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected, NQ=Not Quantifiable) (Sodium units in mg/L, other Metals in ug/L)				
			ug/L					
Antimony	EPA Method 200.8 Modified	Less than 2 ug/L	6	ND	ND	ND	ND	ND
Arsenic	EPA Method 200.8 Modified	Less than 2 ug/L	10	ND	ND	ND	ND	ND
Barium	EPA Method 200.8 Modified	Less than 10 ug/L	2000	ND	ND	ND	ND	ND
Beryllium	EPA Method 200.8 Modified	Less than 0.5 ug/L	4	ND	ND	ND	ND	ND
Cadmium	EPA Method 200.8 Modified	Less than 0.2 ug/L	5	ND	ND	ND	ND	ND
Chromium	EPA Method 200.9 Modified	Less than 2 ug/L	100	ND	ND	ND	ND	ND
Copper	EPA Method 200.8 Modified	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND	ND	ND
Lead	EPA Method 200.8 Modified	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND	ND
Mercury	EPA Method 200.8 Modified	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND
Nickel	EPA Method 200.8 Modified	Less than 5 ug/L		ND	ND	ND	ND	ND
Selenium	EPA Method 200.8 Modified	Less than 5 ug/L	50	ND	ND	ND	ND	ND
Thallium	EPA Method 200.8 Modified	Less than 1 ug/L	2	ND	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i> 12/6/21							
QA Check / Date:	<i>[Signature]</i> 12/6/21							
Forwarded by:	<i>[Signature]</i> 12-6-21							
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field.							
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers,							
	preserved as specified in the method, then analyzed.							
	SLD is provisionally certified by EPA for these methods.							



			Log Number	P12-21-016	P12-21-017	P12-21-018	P12-21-019	P12-21-020
			Description	3054 Vaessen Court Kitchen sink	3276 Maloelap St Laundry Rm Sink	6230 Naupaka St. Laundry Sink Faucet	4685 Kou Lane Bathtub Faucet	3039 Arizona Rd. Kitchen Faucet
			Sample Date	12/3/2021	12/3/2021	12/4/2021	12/4/2021	12/4/2021
			Sample Time	1200	1230	920	935	1020
			Analysis Date	12/6/2021	12/6/2021	12/6/2021	12/6/2021	12/6/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level					
			ug/L					
Antimony	EPA Method 200.8 Modified	Less than 2 ug/L	6	ND	ND	ND	ND	ND
Arsenic	EPA Method 200.8 Modified	Less than 2 ug/L	10	ND	ND	ND	ND	ND
Barium	EPA Method 200.8 Modified	Less than 10 ug/L	2000	ND	ND	ND	ND	ND
Beryllium	EPA Method 200.8 Modified	Less than 0.5 ug/L	4	ND	ND	ND	ND	ND
Cadmium	EPA Method 200.8 Modified	Less than 0.2 ug/L	5	ND	ND	ND	ND	ND
Chromium	EPA Method 200.9 Modified	Less than 2 ug/L	100	ND	ND	ND	ND	ND
Copper	EPA Method 200.8 Modified	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND	ND	ND
Lead	EPA Method 200.8 Modified	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND	ND
Mercury	EPA Method 200.8 Modified	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND
Nickel	EPA Method 200.8 Modified	Less than 5 ug/L		ND	ND	ND	ND	ND
Selenium	EPA Method 200.8 Modified	Less than 5 ug/L	50	ND	ND	ND	ND	ND
Thallium	EPA Method 200.8 Modified	Less than 1 ug/L	2	ND	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i> 12/6/21							
QA Check / Date:	<i>[Signature]</i> 12/6/21							
Forwarded by:	<i>[Signature]</i> 12-6-21							
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bc							
	Once samples were received in the lab, the analyst transferred water sample							
	preserved as specified in the method, then analyzed.							
	SLD is provisionally certified by EPA for these methods.							

			Log Number	P12-21-021	P12-21-022
			Description	Aliamanu Child Dev Ctr	PH Church of Christ
			Sample Date	12/6/2021	12/6/2021
			Sample Time	1100	1110
			Analysis Date	12/7/2021	12/7/2021
<b>Inorganic Metals</b>	<b>Method</b>	<b>Detection Limit</b>	<b>Maximum Contaminant Level</b>	Results (ND = Not Detected, NQ=Not Quantifiable) (Sodium units in mg/L, other Metals in ug/L)	
			ug/L		
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND
Chromium*	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>62.84</b>	<b>NQ</b>
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND
*Note:	Chromium analysis on 12/8/21				
Analyst / Date:	<i>m</i> 12/8/21				
QA Check / Date:	<i>B. Pungis</i> 12/8/21				
Forwarded by:	<i>Robert S. O.</i> 12-8-21				
Note:	SLD is provisionally certified by EPA for these methods.				

			Log Number	P12-21-025	P12-21-026	P12-21-027	P12-21-028
			Description	131 3rd St.	1167 Hekau St.	719 McGrew Lp	593 McGrew Lp
			Sample Date	12/7/2021	12/7/2021	12/7/2021	12/7/2021
			Sample Time	1020	1055	1120	1155
			Analysis Date	12/8/2021	12/8/2021	12/8/2021	12/8/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected, NQ=Not Quantifiable) (Sodium units in mg/L, other Metals in ug/L)			
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>71.91</b>	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:	<i>Am</i> 12/8/21						
QA Check / Date:	<i>R. P. Smith</i> 12/8/21						
Forwarded by:	<i>Central State</i> 12/8/21						
Note:	SLD is provisionally certified by EPA for these methods.						

			Log Number	P12-21-029	P12-21-030	P12-21-031	P12-21-032
			Description	5553 Comarant Ave	5111 Iroquois Ave	7397 Birch Circle	Waiawa Shaft pre- chlorination
			Sample Date	12/7/2021	12/7/2021	12/7/2021	12/7/2021
			Sample Time	1030	1115	1200	1230
			Analysis Date	12/8/2021	12/8/2021	12/8/2021	12/8/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>63.87</b>	<b>66.73</b>	<b>NQ</b>	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i> 12/8/21						
QA Check / Date:	<i>[Signature]</i> 12/8/21						
Forwarded by:	<i>[Signature]</i> 12/8/21						
Note:	SLD is provisionally certified by EPA for these methods.						

			Log Number	P12-21-033	P12-21-034	P12-21-035	P12-21-036
			Description	1161 Honu Lp	1156 Hekau St	565 McGrew Lp	824 McGrew Lp
			Sample Date	12/8/2021	12/8/2021	12/8/2021	12/8/2021
			Sample Time	1110	1050	1015	1035
			Analysis Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected, NQ=Not Quantifiable) (Sodium units in mg/L, other Metals in ug/L)			
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	NQ	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i> 12/9/21						
QA Check / Date:	<i>[Signature]</i> 12/9/21						
Forwarded by:	<i>[Signature]</i> 12-9-21						
Note:	SLD is provisionally certified by EPA for these methods.						

			<b>Log Number</b>	<b>P12-21-037</b>	<b>P12-21-038</b>
			<b>Description</b>	<b>147 Octopus Ln</b>	<b>7200 Birch Cir</b>
			<b>Sample Date</b>	12/8/2021	12/8/2021
			<b>Sample Time</b>	1015	1303
			<b>Analysis Date</b>	12/9/2021	12/9/2021
<b>Inorganic Metals</b>	<b>Method</b>	<b>Detection Limit</b>	<b>Maximum Contaminant Level</b>		
			ug/L		
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>NQ</b>	<b>302.12</b>
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND
Analyst / Date:	<i>Em</i> 12/9/21				
QA Check / Date:	<i>R. P. P.</i> 12/9/21				
Forwarded by:	<i>Richard S. ...</i> 12-9-21				
Note:	SLD is provisionally certified by EPA for these methods.				

State of Hawaii Department of Health			Log Number	P12-21-039	P12-21-040	P12-21-041	P12-21-042
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Halawa Correctional Facility	5019 Iroquois Ave	6666B 106th St	6181 Ibis Ave
			Sample Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021
			Sample Time	1146	1215	1135	1055
			Analysis Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected, NQ=Not Quantifiable) (Sodium units in mg/L, other Metals in ug/L)			
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8 & 200.9*	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i> 12/11/21						
QA Check / Date:	<i>B. Pineda</i> 12/11/21						
Forwarded by:	<i>[Signature]</i> 12-11-21						
Note:	SLD is provisionally certified by EPA for these methods.						
	*Se EPA200.9 for P12-21-046 & P12-21-048 due to matrix interference in EPA 200.8						

State of Hawaii Department of Health		Log Number	P12-21-043	P12-21-044	P12-21-045	P12-21-046
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	5424 Edgewater Dr	6660B 106th St	Aiea Halawa Shaft	Aiea Halawa Pump Rm Pre-Chlor
		Sample Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021
		Sample Time	1118	1154	1030	1130
		Analysis Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level			
			ug/L			
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	13.70
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND
Selenium	EPA Method 200.8 & 200.9*	Less than 5 ug/L	50	ND	ND	ND*
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND
Analyst / Date:	Sul 12/11/21					
QA Check / Date:	R. Pineda 12/11/21					
Forwarded by:	Richard Suli 12-11-21					
Note:	SLD is provisionally certified by EPA for these methods.					
	*Se EPA200.9 for P12-21-046 & P12-21-048 due to matrix interference in EPA 200.8					



State of Hawaii Department of Health			Log Number	P12-21-047	P12-21-048	P12-21-049	P12-21-050
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Aiea Halawa Shaft Post Chlor	Halawa Storage Tank 1 (S1)	Halawa Storage Tank 2 (S2)	5669A Dovekie Ave
			Sample Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021
			Sample Time	1200	1250	1310	1227
			Analysis Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8 & 200.9*	Less than 5 ug/L	50	ND	ND*	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>[Signature]</i> 12/10/21							
QA Check / Date: <i>[Signature]</i> 12/11/21							
Forwarded by: <i>[Signature]</i> 12-11-21							
Note: SLD is provisionally certified by EPA for these methods.							
*See EPA200.9 for P12-21-046 & P12-21-048 due to matrix interference in EPA							

State of Hawaii Department of Health			Log Number	P12-21-051	P12-21-052	P12-21-053	P12-21-054
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	4908 Mokupea Pl	5673 Dovekie Ave	5534 Bittern Ave	6674 106th St
			Sample Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021
			Sample Time	1105	1215	1141	1259
			Analysis Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	<b>NQ</b>	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8 & 200.9*	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>h</i> 12/10/21							
QA Check / Date: <i>P. Bernard</i> 12/14/21							
Forwarded by: <i>P. Bernard</i> 12-11-21							
Note: SLD is provisionally certified by EPA for these methods.							
*Se EPA200.9 for P12-21-046 & P12-21-048 due to matrix interference in EPA							

State of Hawaii Department of Health			Log Number	P12-21-055	P12-21-056	P12-21-057	P12-21-058
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	7273 Elm Pl	3763 Elm Dr	7257 Birch Circle	7236 Birch Circle
			Sample Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021
			Sample Time	906	937	1044	1105
			Analysis Date	12/11/2021	12/11/2021	12/11/2021	12/11/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level	Results (ND = Not Detected, NQ=Not Quantifiable) (Sodium units in mg/L, other Metals in ug/L)			
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	161.87	78.77	204.95	110.43
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:	<i>im 12/11/21</i>						
QA Check / Date:	<i>B. Binia 12/11/21</i>						
Forwarded by:	<i>Richard 12-12-21</i>						
Note:	SLD is provisionally certified by EPA for these methods.						

State of Hawaii Department of Health			Log Number	P12-21-059	P12-21-060	P12-21-061	P12-21-062
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	5321 Cedar Dr	5012 A Iroquois Ave	5861 Fulmar	4976 B Kela PI
			Sample Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021
			Sample Time	1002	952	1020	1105
			Analysis Date	12/11/2021	12/11/2021	12/11/2021	12/11/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:	m 12/11/21						
QA Check / Date:	B. Pineda 12/11/21						
Forwarded by:	Richard Silva 12-12-21						
Note:	SLD is provisionally certified by EPA for these methods.						

State of Hawaii Department of Health			Log Number	P12-21-063	P12-21-064	P12-21-065
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	5682 Dovekie	5856 B Fulmar	5869 Fulmar
			Sample Date	12/10/2021	12/10/2021	12/10/2021
			Sample Time	930	1030	1040
			Analysis Date	12/11/2021	12/11/2021	12/11/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level			
			ug/L			
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>75.64</b>	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND
Analyst / Date:	<i>[Signature]</i> 12/11/21					
QA Check / Date:	<i>B. Penick</i> 12/11/21					
Forwarded by:	<i>R. Sald...</i> 12-12-21					
Note:	SLD is provisionally certified by EPA for these methods.					

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Log Number	P12-21-066	P12-21-067	P12-21-068	P12-21-069	P12-21-070	P12-21-071
			Description	7377 Birch Circle	444 Kahua Ave	Bldg 1338 Fitness Ctr	7370 Birch Circle	7384 Birch Circle	3802 Elm Dr
Results (ND = Not Detected, NQ=Not Quantifiable) Units in ug/L			Sample Date	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021
			Sample Time	1030	1130	1140	1045	1055	1000
			Analysis Date	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level						
			ug/L						
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	ND	316.17	515.37	520.91	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND	ND	ND
Analyst / Date:			<i>[Signature]</i> 12/13/21						
QA Check / Date:			<i>R. P. [Signature]</i> 12/13/21						
Forwarded by:			<i>[Signature]</i> 12-13-21						
**Note:			Modifications: P12-21-073 Drinking water samples were sampled in 1 liter amber glass bottles x 2, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.						
			SLD is provisionally certified by EPA for these methods.						

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Log Number	P12-21-072	P12-21-073	P12-21-074	P12-21-075	P12-21-076	P12-21-077
			Description	Bldg 303 BEQ	Bldg 300 Block-A BEQ **	4976D Kela Pl	4755D East Ekahi Way	4974D Kela Pl	4973B Kela Pl
Results (ND = Not Detected, NQ=Not Quantifiable) Units in ug/L			Sample Date	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021
			Sample Time	1204	1155	1120	1053	1128	1110
			Analysis Date	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level						
			ug/L						
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	114.31	60.65	ND	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	NQ	ND	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND	ND	ND
Analyst / Date: <i>[Signature]</i> 12/13/21									
QA Check / Date: <i>[Signature]</i> 12/13/21									
Forwarded by: <i>[Signature]</i> 12-13-21									
**Note:									
Modifications: P12-21-073 Drinking water samples were sampled in 1 liter amber glass bottles x 2, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.									
SLD is provisionally certified by EPA for these methods.									

State of Hawaii Department of Health			Log Number	P12-21-078	P12-21-079	P12-21-080	P12-21-081	P12-21-082
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	4906 Wasp Blvd	4682 Oklahoma Ave	2031 Fox Blvd	4623 Scott Loop	732 Sibley St
			Sample Date	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1035	1100	1130	1200	1230
Units in ug/L								
			Analysis Date	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level					
			ug/L					
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>61.45</b>	ND	<b>98.46</b>	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND	ND
Analyst / Date: <i>[Signature]</i> 12/14/21								
QA Check / Date: <i>R. P. [Signature]</i> 12/14/21								
Forwarded by: <i>[Signature]</i> 12-14-21								
Note: SLD is provisionally certified by EPA for these methods.								



State of Hawaii Department of Health			Log Number	P12-21-083	P12-21-084	P12-21-085
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Camp Smith Tank S-325	Camp Smith Tank S-326	Camp Smith Tank 684
			Sample Date	12/13/2021	12/13/2021	12/13/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1000	1120	1245
Units in ug/L						
			Analysis Date	12/14/2021	12/14/2021	12/14/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level			
			ug/L			
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND
Analyst / Date:						
QA Check / Date:						
Forwarded by:						
Note: SLD is provisionally certified by EPA for these methods.						

State of Hawaii Department of Health			Log Number	P12-21-086	P12-21-087	P12-21-088	P12-21-089
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Pearl City Shaft	6186 A Ibis Ave	6089 Heron B Ave	6151 A Heron Ave
			Sample Date	12/14/2021	12/14/2021	12/14/2021	12/14/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1050	1045	1104	1122
Units in ug/L							
			Analysis Date	12/15/2021	12/15/2021	12/15/2021	12/15/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>71.13</b>	ND	NQ	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-090	P12-21-091	P12-21-092	P12-21-093
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	6176 Heron Ave	6168 Heron Ave	5548 Bittern Ave	6365 Ibis Ave
			Sample Date	12/14/2021	12/14/2021	12/14/2021	12/14/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1050	1055	1141	1114
Units in ug/L							
			Analysis Date	12/15/2021	12/15/2021	12/15/2021	12/15/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	128.64	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health		Log Number	P12-21-094	
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	5537 Bittern Ave	
		Sample Date	12/14/2021	
Results (ND = Not Detected, NQ=Not Quantifiable)		Sample Time	1150	
Units in ug/L		Analysis Date	12/15/2021	
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level	
			ug/L	
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>106.87</b>
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND
Analyst / Date:	<i>[Signature]</i> 12/15/21			
QA Check / Date:	<i>R. Puno</i> 12/15/21			
Forwarded by:	<i>R. K. S. Subi</i> 12-15-21			
Note:	SLD is provisionally certified by EPA for these methods.			

State of Hawaii Department of Health			Log Number	P12-21-095	P12-21-096	P12-21-097	P12-21-098
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	1406 Laniwai Ave	1402 Laniwai Ave	1619 Aloha Ave	1813 Palm Ave
			Sample Date	12/15/2021	12/15/2021	12/15/2021	12/15/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1025	1041	1100	1115
Units in ug/L			Analysis Date	12/16/2021	12/16/2021	12/16/2021	12/16/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	<b>2.57</b>	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	NQ	NQ	<b>64.25</b>
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>[Signature]</i> 12/16/21							
QA Check / Date: <i>[Signature]</i> 12/16/21							
Forwarded by: <i>[Signature]</i> 12-16-21							
Note: SLD is provisionally certified by EPA for these methods.							

<b>State of Hawaii Department of Health</b>			<b>Log Number</b>	<b>P12-21-099</b>	<b>P12-21-100</b>	<b>P12-21-101</b>	<b>P12-21-102</b>
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			<b>Description</b>	2891D Makuu Lp	500-337 2899C Makuu Lp	2862A Kokio Lp	500-339 2856A Kokio Lp
			<b>Sample Date</b>	12/15/2021	12/15/2021	12/15/2021	12/15/2021
<b>Results (ND = Not Detected, NQ=Not Quantifiable)</b>			<b>Sample Time</b>	1006	1030	1040	1055
<b>Units in ug/L</b>							
			<b>Analysis Date</b>	12/16/2021	12/16/2021	12/16/2021	12/16/2021
<b>Inorganic Metals</b>	<b>Method</b>	<b>Detection Limit</b>	<b>Maximum Contaminant Level</b>				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	NQ	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>h</i> 12/16/21							
QA Check / Date: <i>R Pined</i> 12/16/21							
Forwarded by: <i>Richard Salo</i> 12-16-21							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-103	P12-21-104
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	500-341 2850A Kokio Lp	2879A Hapue Lp
			Sample Date	12/15/2021	12/15/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1115	1130
Units in ug/L					
			Analysis Date	12/16/2021	12/16/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level		
			ug/L		
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND
Analyst / Date: <i>in</i> 12/16/21					
QA Check / Date: <i>B.P. Smith</i> 12/16/21					
Forwarded by: <i>Robert Sale</i> 12-16-21					
Note: SLD is provisionally certified by EPA for these methods.					

State of Hawaii Department of Health			Log Number	P12-21-105	P12-21-106	P12-21-107	P12-21-108	P12-21-109
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	500-Bldg 1B	500-Bldg 612, Fire Station	500-739 Anderson Rd	500-2165 Baugh Rd	500-2173 Baugh Rd
			Sample Date	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	930	945	1010	1020	1035
Units in ug/L			Analysis Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level					
			ug/L					
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	<b>87.29</b>	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		<b>11.40</b>	ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND	ND
Analyst / Date:			<i>in</i> 12/17/21					
QA Check / Date:			<i>B. Perez</i> 12/17/21					
Forwarded by:			<i>Ronald Gale</i> 12-17-21					
Note:			SLD is provisionally certified by EPA for these methods.					



State of Hawaii Department of Health			Log Number	P12-21-110	P12-21-111	P12-21-112	P12-21-113
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Bldg 4 1st Fl Loading Dock Men's Rm	Bldg 20 Men's Rm Adjacent 20E	Bldg 601 (PMO) Elrod Rd	Across Bldg 2C
			Sample Date	12/16/2021	12/16/2021	12/16/2021	12/16/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	930	1010	1020	1040
Units in ug/L							
			Analysis Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	3.63
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-114	P12-21-115	P12-21-116	P12-21-117
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	767 Sibley St	1025 Saratoga Blvd	4670 Nevada St	4909 Tomahawk St.
			Sample Date	12/16/2021	12/16/2021	12/16/2021	12/16/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	930	1015	1040	1100
Units in ug/L							
			Analysis Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND	<b>72.94</b>
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-118	P12-21-119	P12-21-120	P12-21-121
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	1824 Palm Ave	1838 Palm Ave	128 Ley Court	134 Ley Court
			Sample Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	915	940	1000	1015
Units in ug/L							
			Analysis Date	12/18/2021	12/18/2021	12/18/2021	12/18/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	<b>6.77</b>	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i> 12/18/21						
QA Check / Date:	<i>[Signature]</i> 12/19/21						
Forwarded by:	<i>[Signature]</i> 12-19-21						
Note:	SLD is provisionally certified by EPA for these methods.						

State of Hawaii Department of Health			Log Number	P12-21-122	P12-21-123	P12-21-124	P12-21-125
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	148 Ley Court	4836 West Eha Way Unit B	6073 A Heron Ave	5713 Erne Ave
			Sample Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1030	1030	1015	1000
Units in ug/L							
			Analysis Date	12/18/2021	12/18/2021	12/18/2021	12/18/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	NQ	64.30
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-126	P12-21-127	P12-21-128	P12-21-129
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	5533 Bittern Ave	5297 Iroquois Ave	1167 Hekau St.	1191 Honu Lp
			Sample Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	945	930	935	1010
Units in ug/L							
			Analysis Date	12/18/2021	12/18/2021	12/18/2021	12/18/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	NQ	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-130	P12-21-131
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	1207 Honu Lp	1177 Honu Lp
			Sample Date	12/17/2021	12/17/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1035	1050
Units in ug/L					
			Analysis Date	12/18/2021	12/18/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level		
			ug/L		
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND
Analyst / Date:					
QA Check / Date:					
Forwarded by:					
Note: SLD is provisionally certified by EPA for these methods.					

State of Hawaii Department of Health			Log Number	P12-21-132	P12-21-133	P12-21-134	P12-21-135
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Radford Terrace Com Ctr Murray St	619 Pool St.	Ohana Navy Communities Jalut St	4999 Kidd Court
			Sample Date	12/18/2021	12/18/2021	12/18/2021	12/18/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	930	959	1025	1050
Units in ug/L							
			Analysis Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	<b>87.13</b>	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>[Signature]</i> 12/21/21							
QA Check / Date: <i>B. Pineda</i> 12/22/21							
Forwarded by: <i>Richard Sal.</i> 12-22-21							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-136	P12-21-137	P12-21-138	P12-21-139
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	NEX Commissary 4725 Bouganville Dr	Bloch Arena, A Ave	Makalapa Clinic, 1257 Makalapa Rd	Lockwood Hall, Dealey Circle
			Sample Date	12/18/2021	12/18/2021	12/18/2021	12/18/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	930	1020	1045	1100
Units in ug/L							
			Analysis Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>116.28</b>	<b>311.21</b>	<b>102.32</b>	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	<b>14.25</b>	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	<b>6.49</b>	<b>15.99</b>	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							



State of Hawaii Department of Health			Log Number	P12-21-140	P12-21-141	P12-21-142	P12-21-143
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	211 Mercury St, Hickam Communities Bldg	137 Honohono St	1301 McMurtry	187 Honohono St
			Sample Date	12/18/2021	12/18/2021	12/18/2021	12/18/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1208	1130	1000	1100
Units in ug/L							
			Analysis Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>276.20</b>	<b>62.95</b>	<b>322.02</b>	<b>77.65</b>
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>[Signature]</i> 12/21/21							
QA Check / Date: <i>[Signature]</i> 12/22/21							
Forwarded by: <i>[Signature]</i> 12-22-21							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-144	P12-21-145	P12-21-146	P12-21-147
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	1532 Tampa Dr	1605 Cowslip Ln	1610 Cowslip Ln	1540 Tampa Dr
			Sample Date	12/19/2021	12/19/2021	12/19/2021	12/19/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	940	1030	1005	925
Units in ug/L							
			Analysis Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	NQ	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>sm</i> 12/21/21							
QA Check / Date: <i>B. Pineda</i> 12/22/21							
Forwarded by: <i>Ribal Sal</i> 12-22-21							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-148	P12-21-149	P12-21-150	P12-21-151
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	2018 Point Welcome PI	127 Olive PI	4072 Ironwood Lp	4126 Begonia Lp
			Sample Date	12/19/2021	12/19/2021	12/19/2021	12/19/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	935	955	1015	1030
Units in ug/L							
			Analysis Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	NQ	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-152	P12-21-153	P12-21-154	P12-21-155
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	4132 Begonia Lp	56669A Dovekie Ave	5424 Edgewater Dr	5111 Iroquois Ave
			Sample Date	12/19/2021	12/19/2021	12/19/2021	12/19/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1050	935	950	1003
Units in ug/L							
			Analysis Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	NQ	<b>108.93</b>	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-156	P12-21-157
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	6660B 106th St	5019 Iroquois Ave
			Sample Date	12/19/2021	12/19/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1017	1030
Units in ug/L					
			Analysis Date	12/20/2021	12/20/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level		
			ug/L		
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND
Analyst / Date:					
QA Check / Date:					
Forwarded by:					
Note: SLD is provisionally certified by EPA for these methods.					

State of Hawaii Department of Health			Log Number	P12-21-158	P12-21-159	P12-21-160	P12-21-161
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Red Hill Elementary School	Aliamanu CDC	Aliamanu CYS	Pearl Harbor Elementary
			Sample Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	920	945	1000	1040
Units in ug/L							
			Analysis Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	58.01	100.24	81.83	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-162	P12-21-163	P12-21-164	P12-21-165
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Nimitz Elementary School	Pearl Kai Elementary School	Mokulele Elementary School	Hickam Elementary School
			Sample Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	915	947	1042	1115
Units in ug/L							
			Analysis Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	<b>106.92</b>	<b>165.48</b>	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-166	P12-21-167	P12-21-168	P12-21-169
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Iroquois Point Elem School	Iroquois Pt Navy Exchange	Iroquois Pt Pre School	Kapilina Gym
			Sample Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1027	1044	1100	1110
Units in ug/L							
			Analysis Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ	NQ	<b>233.20</b>	<b>124.60</b>
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							



State of Hawaii Department of Health			Log Number	P12-21-170	P12-21-171	P12-21-172	P12-21-173
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	444 Kuahua Ave	7377 Birch Circle	7370 Birch Circle	7384 Birch Circle Bldg
			Sample Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	953	1028	1045	1058
Units in ug/L							
			Analysis Date	12/22/2021	12/22/2021	12/22/2021	12/22/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	486.15	713.10
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>R</i> 12/22/21							
QA Check / Date: <i>B.P. 12/22/21</i>							
Forwarded by: <i>Richard Smith 12-22-21</i>							
Note: SLD is provisionally certified by EPA for these methods.							




State of Hawaii Department of Health			Log Number	P12-21-174	P12-21-175	P12-21-176	P12-21-177
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Ford Island CDC	Navy Lodge HI 1275 Saratoga Blvd	Ford Island Landing Park 4800 Dauntless	Pearl Harbor Aviation Museum
			Sample Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	940	1000	1040	1100
Units in ug/L							
			Analysis Date	12/22/2021	12/22/2021	12/22/2021	12/22/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level				
			ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	<b>75.31</b>	ND	NQ	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date: <i>[Signature]</i> 12/22/21							
QA Check / Date: <i>[Signature]</i> 12/22/21							
Forwarded by: <i>[Signature]</i> 12-22-21							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-178	P12-21-179	P12-21-180	P12-21-181
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	4755D East Ekahi Way	4973B Kela Pl	4974D Kela Pl	4976D Kela Pl
			Sample Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	955	1014	1028	1039
Units in ug/L							
			Analysis Date	12/22/2021	12/22/2021	12/22/2021	12/22/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level ug/L				
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND	ND
Analyst / Date:							
QA Check / Date:							
Forwarded by:							
Note: SLD is provisionally certified by EPA for these methods.							

State of Hawaii Department of Health			Log Number	P12-21-182
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	5085B Iroquois Ave
			Sample Date	12/21/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1105
Units in ug/L				
			Analysis Date	12/22/2021
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level	
			ug/L	
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND
Chromium	EPA Method 200.9	Less than 2 ug/L	100	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	NQ
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND
Analyst / Date: <i>[Signature]</i> 12/22/21				
QA Check / Date: <i>[Signature]</i> 12/22/21				
Forwarded by: <i>[Signature]</i> 12-22-21				
Note: SLD is provisionally certified by EPA for these methods.				

State of Hawaii Department of Health			Log Number	P12-21-183	P12-21-184	P12-21-185
State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory			Description	Zone-D-1	237 Austin Ct	108 Ley Ct
			Sample Date	12/29/2021	12/30/2021	12/30/2021
Results (ND = Not Detected, NQ=Not Quantifiable)			Sample Time	1030	1220	1100
Units in ug/L						
			Analysis Date	1/4/2022	1/4/2022	1/4/2022
Inorganic Metals	Method	Detection Limit	Maximum Contaminant Level			
			ug/L			
Antimony	EPA Method 200.8	Less than 2 ug/L	6	ND	ND	ND
Arsenic	EPA Method 200.8	Less than 2 ug/L	10	ND	ND	ND
Barium	EPA Method 200.8	Less than 10 ug/L	2000	ND	ND	ND
Beryllium	EPA Method 200.8	Less than 0.5 ug/L	4	ND	ND	ND
Cadmium	EPA Method 200.8	Less than 0.2 ug/L	5	ND	ND	ND
Chromium	<b>EPA Method 200.9</b>	Less than 2 ug/L	100	ND	ND	ND
Copper	EPA Method 200.8	ND Less than 25 ug/L NQ Less than 50 ug/L	1300	ND	ND	ND
Lead	EPA Method 200.8	ND Less than 2.5 ug/L NQ Less than 5 ug/L	15	ND	ND	ND
Mercury	EPA Method 200.8	Less than 0.5 ug/L	2	ND	ND	ND
Nickel	EPA Method 200.8	Less than 5 ug/L		ND	ND	ND
Selenium	EPA Method 200.8	Less than 5 ug/L	50	ND	ND	ND
Thallium	EPA Method 200.8	Less than 1 ug/L	2	ND	ND	ND
Analyst / Date: <i>h 1/5/22</i>						
QA Check / Date: <i>Yeards 1/5/22</i>						
Forwarded by: <i>Patricia Smith 1-5-22</i>						
Note: SLD is provisionally certified by EPA for these methods.						

	Log Number	P12-21-001	P12-21-002	P12-21-003	P12-21-004	P12-21-005	P12-21-006	P12-21-007	P12-21-008	P12-21-009	P12-21-010
	Description	Alliamanu Child Development Center Classroom Sink	Alliamanu Child and Youth Svcs Kitchen Sink	Hickam Elem School Cafeteria Sink	Mokulele Elem School Cafeteria Sink	Nimitz Elem School Cafeterja Sink	Pearl Harbor Elem School Cafeteria Sink	Pearl Kai Elem School Cafeteria Sink	Red Hill Elem School Cafeteria Sink	Iroquois Pt Elem School Cafeteria Sink	1829 Fox Blvd - Upstairs Master Bath Sink on right
	Sample Date	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	11/30/2021	12/1/2021	12/1/2021
	Sample Time	1313	1330	1530	1500	1420	1350	1600	1230	1035	1205
	Analysis Date	12/1/2021	12/1/2021	12/1/2021	12/1/2021	12/1/2021	12/1/2021	12/1/2021	12/1/2021	12/1/2021	12/1/2021
Volatile Organic Compounds - EPA Method 524.2 Modified	Maximum Contaminant Level										
	Detection Limit	ug/L	Results (ND = Not Detected)								
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	[Signature] 12/2/21										
QA Check / Date:	[Signature] 12/3/21										
Forwarded by:	[Signature] 12-3-21										
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field.										
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers,										
	preserved as specified in the method, then analyzed.										

		Log Number	P12-21-011	P12-21-012	P12-21-013	P12-21-014	P12-21-015	P12-21-016	P12-21-017			
		Description	1316 Eagle Circle Kitchen Sink	3158 Snyder Court Kitchen Sink	6811 Milo Lane Laundry Sink	6813 Milo Lane Bottom Floor Bath Sink	2760 Stowell Circle Honolulu Hawaii Kitchen Sink	3054 Vaessen Court Honolulu Hawaii Kitchen Sink	3276 Maloelap Street Honolulu Hawaii Laundry Room Sink			
		Sample Date	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021			
		Sample Time	1047	1309	1219	1140	1110	1200	1230			
		Analysis Date	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021	12/3/2021			
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level										
		ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND			
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND			
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND			
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND			
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND			
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND			
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND			
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND			
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND			
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND			
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND			
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND			
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND			
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND			
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND			
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND			
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND			
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND			
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND			
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND			
Xylenes, total	Less than 0.5 ug/L	10000	0.6	ND	ND	ND	ND	ND	ND			
Analyst / Date:		12/5/21										
QA Check / Date:		12/6/21										
Forwarded by:		12-6-21										
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.											
Notice:	SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.											



		Log Number	P12-21-018	P12-21-019	P12-21-020					
		Description	6230 Naupaka St Honolulu Hawaii Laundry Sink Faucet	4685 Kou Lane Honolulu Hawaii Bath Tub Faucet	3039 Arizona Road Honolulu Hawaii Kitchen Faucet					
		Sample Date	12/4/2021	12/4/2021	12/4/2021					
		Sample Time	920	935	1020					
		Analysis Date	12/4/2021	12/4/2021	12/4/2021					
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level								
		ug/L								
Benzene	Less than 0.5 ug/L	5	ND	ND	ND					
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND					
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND					
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND					
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND					
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND					
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND					
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND					
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND					
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND					
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND					
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND					
Styrene	Less than 0.5 ug/L	100	ND	ND	ND					
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND					
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND					
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND					
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND					
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND					
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND					
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND					
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND					
Analyst / Date:	F. P. 12/6/21									
QA Check / Date:	B. P. 12/6/21									
Forwarded by:	Richard S. 12-6-21									
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field.									
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.									
	Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.									






		Log Number	P12-21-021	P12-21-022						
		Description	Aliamanu Child Development Center	PH Church of Christ						
		Sample Date	12/6/2021	12/6/2021						
		Sample Time	1100	1110						
		Analysis Date	12/6/2021	12/6/2021						
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level								
		ug/L								
Benzene	Less than 0.5 ug/L	5	ND	ND						
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND						
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND						
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND						
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND						
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND						
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND						
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND						
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND						
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND						
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND						
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND						
Styrene	Less than 0.5 ug/L	100	ND	ND						
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND						
Toluene	Less than 0.5 ug/L	1000	ND	ND						
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND						
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND						
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND						
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND						
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND						
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND						
Analyst / Date:	[Signature] 12/7/21									
QA Check / Date:	[Signature] 12/7/21									
Forwarded by:	[Signature] 12-7-21									
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles x 4, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.									
Notice:	SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.									




		Log Number	P12-21-025	P12-21-026	P12-21-027	P12-21-028	P12-21-029	P12-21-030	P12-21-031	P12-21-032
		Description	131 3rd Street Kitchen Sink	1167 Hekau Street Laundry Room Sink	719 McGrew Loop Upstairs Bathroom Shower Faucet	593 McGrew Loop Kitchen Sink	5553 Comarant Avenue Cafeteria Sink	5111 Iroquois Avenue	7397 Birch Circle Kitchen Faucet Sink	Waiawa Shaft Pre-Chlorination
		Sample Date	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021
		Sample Time	1020	1055	1120	1155	1030	1115	1200	1230
		Analysis Date	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021	12/7/2021
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level	Results (ND=Not Detected)							
		ug/L								
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND
	Analyst / Date:	<i>[Signature]</i> 12/8/21								
	QA Check / Date:	<i>[Signature]</i> 12/8/21								
	Forwarded by:	<i>[Signature]</i> 12-8-21								
	Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.								
	Notice:	SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.								

		Log Number	P12-21-033	P12-21-034	P12-21-035	P12-21-036	P12-21-037	P12-21-038	
		Description	1161 Honu Loop Upstairs Bathroom Shower Faucet	1156 Hekau Street Upstairs Bathroom Shower Faucet	565 McGrew Loop Laundry Room Sink	824 McGrew Loop Bathroom Shower Faucet	147 Octopus Lane Laundry Sink	7200 Birch Cir Kitchen Sink	
		Sample Date	12/8/2021	12/8/2021	12/8/2021	12/8/2021	12/8/2021	12/8/2021	
		Sample Time	1110	1050	1015	1035	1015	1303	
		Analysis Date	12/8/2021	12/8/2021	12/8/2021	12/8/2021	12/8/2021	12/8/2021	
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level							
		ug/L							
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	J.P. 12/9/21								
QA Check / Date:	G.P. 12/9/21								
Forwarded by:	E. Hand 12-9-21								
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.								
Notice:	SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.								

		Log Number	P12-21-039	P12-21-040	P12-21-041	P12-21-042	P12-21-043	P12-21-044	P12-21-045	P12-21-046	P12-21-047
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	Halawa Correctional Facility	5019 Iroquois Ave Bathtub	6666B 106th Street Outside Hose Bib	6181 Ibis Ave Bathtub	5424 Edgewater Drive Bathtub	6660B 106th Street Bathtub	Aiea Halawa Shaft	Aiea Halawa Pump Room Pre-Chlor	Aiea Halawa Shaft Post Chlor
Laboratory Results ND = Not Detected		Sample Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021
		Sample Time	1146	1215	1135	1055	1118	1154	1030	1130	1200
		Analysis Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level									
		ug/L									
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		12/11/21									
QA Check / Date:	R. Pineda	12/11/21									
Forwarded by:		12-12-21									
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field.										
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.										
	Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.										

		Log Number	P12-21-048	P12-21-049	P12-21-050	P12-21-051	P12-21-052	P12-21-053	P12-21-054
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	Halawa Storage Tank 1 (S1)	Halawa Storage Tank 2 (S2)	5669A Dovekie Avenue Outside Spigot	4908 Mokupea Place Tub Fixture Upstairs	5673 Dovekie Ave	5534 Bittern Avenue Tub Faucet	6674 106th St Outside Spigot
Laboratory Results ND = Not Detected		Sample Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021
		Sample Time	1250	1310	1227	1105	1215	1141	1259
		Analysis Date	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021	12/9/2021
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level							
		ug/L							
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		12/11/21							
QA Check / Date:		12/11/21							
Forwarded by:		12-12-21							
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field.								
	Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.								
	Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.								

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-055	P12-21-056	P12-21-057	P12-21-058	P12-21-059	P12-21-060	P12-21-061	P12-21-062	P12-21-063	
		Description	7273 Elm Place Upstairs Laundry Sink	3763 Elm Drive Kitchen Sink	7257 Birch Circle Kitchen Sink	7236 Birch Circle Kitchen Sink	5321 Cedar Dr Outside Spigot	5012A Iroquois Ave Outside Spigot	5861 Fulmar Outside Spigot	4976B Kela Place Outside Spigot	5682 Dovekie Outside Spigot	
Laboratory Results ND = Not Detected		Sample Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	
		Sample Time	906	937	1044	1105	1002	952	1020	1105	930	
		Analysis Date	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	12/10/2021	
Volatile Organic Compounds - EPA Method 524.2 Modified		Detection Limit	Maximum Contaminant Level									
		ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND	
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND	
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Analyst / Date:			12/11/21									
QA Check / Date:			12/11/21									
Forwarded by:			12-12-21									
<p>Note: Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.</p> <p>Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.</p>												

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-064	P12-21-065						
		Description	5856B Fulmar Outdoor Spigot	5869 Fulmar Outside Spigot						
	Laboratory Results ND = Not Detected	Sample Date	12/10/2021	12/10/2021						
		Sample Time	1030	1040						
		Analysis Date	12/10/2021	12/10/2021						
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level								
		ug/L								
Benzene	Less than 0.5 ug/L	5	ND	ND						
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND						
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND						
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND						
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND						
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND						
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND						
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND						
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND						
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND						
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND						
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND						
Styrene	Less than 0.5 ug/L	100	ND	ND						
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND						
Toluene	Less than 0.5 ug/L	1000	ND	ND						
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND						
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND						
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND						
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND						
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND						
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND						
Analyst / Date:		12/11/21								
QA Check / Date:		12/12/21								
Forwarded by:		12/12/21								
Note:	Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.									
Notice:	SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.									

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-066	P12-21-067	P12-21-068	P12-21-069	P12-21-070	P12-21-071	P12-21-072	P12-21-073	P12-21-074	
		Description	7377 Birch Circle Outside Spigot By Garage	444 Kahua Avenue Side Back Spigot	Building 1338 Fitness Center Front Door Spigot	7370 Birch Circle Spirting Spigot	7384 Birch Circle Front Outside Spigot	3802 Elm Drive *Sheen Visible On Water Surface*	Bldg 303 BEQ Outside Spigot	Block A BEQ East Side Outside Spigot	4976D Kela Place Outside Spigot	
Laboratory Results ND = Not Detected		Sample Date	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	
		Sample Time	1030	1130	1140	1045	1055	1000	1204	1155	1120	
		Analysis Date	12/12/2021	12/12/2021	12/12/2021	12/12/2021	12/12/2021	---	12/12/2021	12/12/2021	12/12/2021	
Volatile Organic Compounds - EPA Method 524.2 Modified		Detection Limit	Maximum Contaminant Level									
		ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	---	ND	ND	ND	
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	---	ND	ND	ND	
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	---	ND	ND	ND	
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	---	ND	ND	ND	
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	---	ND	ND	ND	
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	---	ND	ND	ND	
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	---	ND	ND	ND	
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	---	ND	ND	ND	
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	---	ND	ND	ND	
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	---	ND	ND	ND	
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	---	ND	ND	ND	
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	---	ND	ND	ND	
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	---	ND	ND	ND	
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	---	ND	ND	ND	
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	---	ND	ND	ND	
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	---	ND	ND	ND	
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	---	ND	ND	ND	
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	---	ND	ND	ND	
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	---	ND	ND	ND	
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	---	ND	ND	ND	
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	---	ND	ND	ND	
Analyst / Date:			12/13/21									
QA Check / Date:			12/13/21									
Forwarded by:			12-13-21									
Note:		Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed. VOC sample P12-21-071 was not analyzed to protect the instrumentation from damage due to the "sheen visible on water surface". Richard Sald 12-13-21										
		Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.										






State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-075	P12-21-076	P12-21-077
		Description	4755D East Ekahi Way Outside Spigot	4974D Kela Place Outside Spigot	4973B Kela Place Outside Spigot
Laboratory Results ND = Not Detected		Sample Date	12/12/2021	12/12/2021	12/12/2021
		Sample Time	1053	1128	1110
		Analysis Date	12/12/2021	12/12/2021	12/12/2021
Method 524.2 Modified	Detection Limit	Maximum Contaminant Level			
		ug/L			
Benzene	Less than 0.5 ug/L	5	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND
Analyst / Date:		12/13/21			
QA Check / Date:		12/13/21			
Forwarded by:		12-13-21			
Note: Modifications: Drinking water samples were sampled in 1 liter amber glass bottles, no preservatives were added in the field. Once samples were received in the lab, the analyst transferred water sample into separate method-specific containers, preserved as specified in the method, then analyzed.					
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.					




	Log Number	P12-21-078	P12-21-079	P12-21-080	P12-21-081	P12-21-082	P12-21-083	P12-21-084	P12-21-085	
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory	Description	4906 Wasp Blvd Wash Room Faucet	4682 Oklahoma Ave Wash Room Faucet	2031 Fox Blvd Upstairs Bathroom Bathtub Faucet	4623 Scott Loop Laundry Room Sink	732 Sibley St 1st Floor Bathroom Bathtub Faucet	Camp Smith Tank S325 From Top Access Hatch Using Bailers	Camp Smith Tank S326 From Top Access Hatch Using Bailers	Camp Smith Tank 684 From Top Access Hatch Using Bailers	
Laboratory Results ND = Not Detected	Sample Date	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	
	Sample Time	1035	1100	1130	1200	1230	1000	1120	1245	
	Analysis Date	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	12/13/2021	
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level								
		ug/L								
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	
Analyst / Date:	J. J. [Signature] 12/14/21									
QA Check / Date:	B. [Signature] 12/14/21									
Forwarded by:	[Signature] 12-14-21									
Note:	Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab. Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.									
Notice:	SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.									




	Log Number	P12-21-086	P12-21-087	P12-21-088	P12-21-089	P12-21-090	P12-21-091	P12-21-092	P12-21-093	P12-21-094
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory	Description	Pearl City Shaft Collected At EPD	6186A Ibis Ave Bathroom Tub Spout	6089 Heron B Ave Bedroom Sink	6151A Heron Ave Bathroom Sink	6176 Heron Avenue Outdoor Spigot	6168 Heron Ave Outdoor Spigot	5548 Bittern Avenue Outdoor Spigot	6365 Ibis Ave Bathtub	5537 Bittern Ave Outdoor Spigot
Laboratory Results ND = Not Detected	Sample Date	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021
	Sample Time	1050	1045	1104	1122	1050	1055	1141	1114	1150
	Analysis Date	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021	12/14/2021
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level								
		ug/L								
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:										
QA Check / Date:										
Forwarded by:										
Note:	Modifications: Drinking water samples were collected in 40-ml amber vials containing 25 mg ascorbic acid and delivered to the lab.									
	Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.									
	Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.									

	Log Number	P12-21-095	P12-21-096	P12-21-097	P12-21-098	P12-21-099	P12-21-100	P12-21-101	P12-21-102	P12-21-103
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory	Description	1406 Lanikai Avenue Outside Spigot	1402 Lanikai Avenue Outside Spigot	1619 Aloha Avenue Outside Spigot	1813 Palm Avenue Outside Spigot	2891D Makuu Loop Bath tub	2899C Makuu Loop Outdoor Spigot	2862A Kokio Loop Outdoor Spigot	2856A Kokio Loop Bath tub	2850A Kokio Loop Outdoor Spigot
Laboratory Results ND = Not Detected	Sample Date	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021
	Sample Time	1025	1041	1100	1115	1006	1030	1040	1055	1115
	Analysis Date	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021	12/15/2021
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level								
		ug/L								
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i>	2/16/21								
QA Check / Date:	<i>[Signature]</i>	12/16/21								
Forwarded by:	<i>[Signature]</i>	12-16-21								
Note:	Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.									
	Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.									
	Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.									

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-104										
		Description	2879A Hapue Loop Outdoor Spigot										
Laboratory Results ND = Not Detected		Sample Date	12/15/2021										
		Sample Time	1130										
		Analysis Date	12/15/2021										
Volatile Organic Compounds - EPA Method 524.2 Modified		Detection Limit	Maximum Contaminant Level										
			ug/L										
Benzene	Less than 0.5 ug/L	5	ND										
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND										
Chlorobenzene	Less than 0.5 ug/L	100	ND										
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND										
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND										
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND										
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND										
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND										
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND										
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND										
Ethylbenzene	Less than 0.5 ug/L	700	ND										
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND										
Styrene	Less than 0.5 ug/L	100	ND										
Tetrachloroethylene	Less than 0.5 ug/L	5	ND										
Toluene	Less than 0.5 ug/L	1000	ND										
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND										
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND										
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND										
Trichloroethylene	Less than 0.5 ug/L	5	ND										
Vinyl chloride	Less than 0.5 ug/L	2	ND										
Xylenes, total	Less than 0.5 ug/L	10000	ND										
Analyst / Date:		 12/16/21											
QA Check / Date:		 12/16/21											
Forwarded by:		 12-16-21											
Note: Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.													
Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.													
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.													

		Log Number	P12-21-105	P12-21-106	P12-21-107	P12-21-108	P12-21-109	P12-21-110	P12-21-111	P12-21-112	P12-21-113
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	500 Bldg 1B Janitor Room In Dental Closet	500 Bldg 612 Fire Station Laundry Room Sink	500 739 Anderson Rd Outdoor Spigot By Garage	500 2165 Baugh Rd Outdoor Spigot By Garage	500 2173 Baugh Rd Outdoor Spigot By Garage	Bldg 4 1st Floor Loading Dock Mens Room	Bldg 20 Mens Adjacent 20E	Bldg 601 (PMO) Elrod Road Spigot Outside 601	Across Bldg 2C Spigot At Outdoor Crossfit Gym Behind Bldg
Laboratory Results ND = Not Detected		Sample Date	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021
		Sample Time	930	945	1010	1020	1035	930	1010	1020	1040
		Analysis Date	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021	12/16/2021
Volatile Organic Compounds - EPA Method 524.2 Modified		Detection Limit	Maximum Contaminant Level								
		ug/L									
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		<i>[Signature]</i>	12/17/21								
QA Check / Date:		<i>[Signature]</i>	12/17/21								
Forwarded by:		<i>[Signature]</i>	12-17-21								
Note: Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.											
Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.											
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.											

		Log Number	P12-21-114	P12-21-115	P12-21-116	P12-21-117							
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	767 Sibley St Outside Hose Faucet Left Corner Of House	1025 Saratoga Blvd Laundry Room Sink	4670 Nevada St Outside Hose Faucet Right Side Of House	4909 Tomahawk St Kitchen Sink							
Laboratory Results ND = Not Detected		Sample Date	12/16/2021	12/16/2021	12/16/2021	12/16/2021							
		Sample Time	930	1015	1040	1100							
		Analysis Date	12/16/2021	12/16/2021	12/16/2021	12/16/2021							
Volatile Organic Compounds - EPA Method 524.2 Modified		Detection Limit											
		Maximum Contaminant Level											
		ug/L											
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND							
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND							
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND							
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND							
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND							
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND							
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND							
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND							
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND							
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND							
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND							
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND							
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND							
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND							
Analyst / Date:			12/17/21										
QA Check / Date:			12/17/21										
Forwarded by:			12-17-21										
Note: Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.													
Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.													
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.													

		Log Number	P12-21-118	P12-21-119	P12-21-120	P12-21-121	P12-21-122	P12-21-123	P12-21-124	P12-21-125	P12-21-126	
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	1824 Palm Ave Kitchen Sink	1838 Palm Ave Garage Hose Faucet	128 Ley Court Hose Faucet Outside Front Door	134 Ley Court Hose Faucet Outside Front Door	148 Ley Court Hose Faucet Outside Front Door	4836 West Eha Way Unit B Kitchen Sink	6073A Heron Ave Kitchen Sink	5713 Erne Ave Kitchen Sink	5533 Bittern Ave Kitchen Sink	
Laboratory Results ND = Not Detected		Sample Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	
		Sample Time	915	940	1000	1015	1030	1030	1015	1000	945	
		Analysis Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021	
Volatile Organic Compounds - EPA Method 524.2 Modified		Maximum Contaminant Level	Detection Limit									
		ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND	
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND	
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Analyst / Date:		 12/15/21										
QA Check / Date:		 12/19/21										
Forwarded by:		 12-19-21										
Note:		Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.										
		Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.										
		Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building										
		which are currently being addressed.										






		Log Number	P12-21-127	P12-21-128	P12-21-129	P12-21-130	P12-21-131					
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	5297 Iroquois Ave Kitchen Sink	1167 Hekau St Laundry Wash Basin	1191 Honu Loop Bathtub	1207 Honu Outside Hose Bib	1177 Honu Loop Bathtub					
Laboratory Results ND = Not Detected		Sample Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021					
		Sample Time	930	935	1010	1035	1050					
		Analysis Date	12/17/2021	12/17/2021	12/17/2021	12/17/2021	12/17/2021					
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level										
		ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND					
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND					
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND					
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND					
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND					
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND					
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND					
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND					
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND					
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND					
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND					
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND					
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND					
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND					
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND					
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND					
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND					
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND					
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND					
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND					
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND					
Analyst / Date:	<i>[Signature]</i>	12/19/21										
QA Check / Date:	<i>[Signature]</i>	12/19/21										
Forwarded by:	<i>[Signature]</i>	12-19-21										
Note: Modifications: Drinking water samples were collected in 40-ml amber vials containing 25 mg ascorbic acid and delivered to the lab.												
Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.												
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.												

		Log Number	P12-21-132	P12-21-133	P12-21-134	P12-21-135	P12-21-136	P12-21-137	P12-21-138	P12-21-139	P12-21-140	P12-21-141
State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Description	Radford Terrace Community Center Murray Street Fitness Center Outside Spigot	619 Pool Street 620 Pool Street Community Center	Ohana Navy Communities Jalut Street Outside Spigot	4999 Kidd Court Community Center Womens Bathroom Sink	NEX Commissary 4725 Bouganville Drive Meat Processing Deep Sink	Bloch Arena A Avenue	Makalapa Clinic 1257 Makalapa Road Outside Far Left Of Building	Lockwood Hall Dealey Circle Womens Restroom Sink	211 Mercury Street Hickam Communities Bldg Outside Spigot Right Of Entrance	137 Honohono Street
Laboratory Results ND = Not Detected		Sample Date	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021	12/18/2021
		Sample Time	930	959	1025	1050	930	1020	1045	1100	1208	1130
		Analysis Date	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021
Volatil Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level										
		ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:												
QA Check / Date:												
Forwarded by:												
Note:	Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.											
	Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.											
	Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.											

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-142	P12-21-143																	
		Description	1301 McMurtry Outside Spigot Front Door Left Of Garage	187 Honohono St Front Patio Spigot																	
	Laboratory Results ND = Not Detected	Sample Date	12/18/2021	12/18/2021																	
		Sample Time	1000	1100																	
		Analysis Date	12/19/2021	12/19/2021																	
Volatil Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level																			
		ug/L																			
Benzene	Less than 0.5 ug/L	5	ND	ND																	
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND																	
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND																	
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND																	
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND																	
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND																	
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND																	
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND																	
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND																	
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND																	
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND																	
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND																	
Styrene	Less than 0.5 ug/L	100	ND	ND																	
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND																	
Toluene	Less than 0.5 ug/L	1000	ND	ND																	
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND																	
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND																	
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND																	
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND																	
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND																	
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND																	
Analyst / Date:		12/20/21																			
QA Check / Date:		12/20/21																			
Forwarded by:		12-20-21																			
Note:	Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.																				
	Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.																				
	Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.																				

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-144	P12-21-145	P12-21-146	P12-21-147	P12-21-148	P12-21-149	P12-21-150	P12-21-151	P12-21-152	P12-21-153
		Description	1532 Tampa Drive Outside Spigot	1605 Cowslip Lane Laundry Sink	1610 Cowslip Lane Laundry Sink	1540 Tampa Drive Inside Bathroom Tub	2018 Point Welcome Place Bathtub	127 Olive Place Outside Hose	4072 Ironwood Loop Outside Hose	4126 Begonia Loop Laundry Room	4132 Begonia Loop Outside Hose	5666A Dovekie Ave Covered Outside Faucet Left Of Front Door
Laboratory Results ND = Not Detected		Sample Date	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021	12/19/2021
		Sample Time	940	1030	1005	925	935	955	1015	1030	1050	935
		Analysis Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021
Volatile Organic Compounds - EPA Method 524.2 Modified		Detection Limit	Maximum Contaminant Level									
		ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		12/21/21										
QA Check / Date:		12/21/21										
Forwarded by:		12-21-21										
Note:		Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab. Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.										
		Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.										

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-154	P12-21-155	P12-21-156	P12-21-157							
		Description	5424 Edgewater Drive Covered Outside Faucet Right Of Main Entrance	5111 Iroquois Avenue Covered Outside Faucet Left Of Preschool Office Door	6660B 106th Street Covered Outside Faucet Left Of Front Door	5019 Iroquois Ave Covered Outside Faucet Left Of Front Door							
	Laboratory Results ND = Not Detected	Sample Date	12/19/2021	12/19/2021	12/19/2021	12/19/2021							
		Sample Time	950	1003	1017	1030							
		Analysis Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021							
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level											
		ug/L											
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND							
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND							
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND							
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND							
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND							
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND							
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND							
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND							
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND							
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND							
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND							
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND							
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND							
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND							
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND							
	Analyst / Date:	 12/21/21											
	QA Check / Date:	 12/21/21											
	Forwarded by:	 12-21-21											
	Note:	Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab. Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.											
		Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.											

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-158	P12-21-159	P12-21-160	P12-21-161	P12-21-162	P12-21-163	P12-21-164	P12-21-165	P12-21-166	P12-21-167
		Description	Red Hill Elementary School Outside Sink Cafeteria	Aliamanu CDC Classroom No A101 Mokihana	Aliamanu CYS Kitchen Sink	Pearl Harbor Elementary Kitchen Sink Cafeteria	Nimitz Elementary School Custodian Room Outside Mens Restroom	Pearl Kai Elementary School Kitchen Sink	Mokulele Elementary School Cafeteria	Hickam Elementary School Cafeteria	Iroquois Point Elementary School Sink In Classroom	Iroquois Point Navy Exchange Utility Sink
Laboratory Results ND = Not Detected		Sample Date	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021	12/20/2021
		Sample Time	920	945	1000	1040	915	947	1042	1115	1027	1044
		Analysis Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021
Volatile Organic Compounds - EPA Method 524.2 Modified		Detection Limit	Maximum Contaminant Level									
		ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:		<i>[Signature]</i> 12/22/21										
QA Check / Date:		<i>[Signature]</i> 12/22/21										
Forwarded by:		<i>[Signature]</i> 12-22-21										
Note: Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.												
Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.												
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.												

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-168	P12-21-169										
		Description	Iroquois Point Preschool Outdoor Spigot	Kapilina Gym Utility Sink										
Laboratory Results ND = Not Detected		Sample Date	12/20/2021	12/20/2021										
		Sample Time	1100	1110										
		Analysis Date	12/21/2021	12/21/2021										
Volatile Organic Compounds - EPA Method 524.2 Modified		Detection Limit	Maximum Contaminant Level											
			ug/L											
Benzene	Less than 0.5 ug/L	5	ND	ND										
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND										
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND										
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND										
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND										
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND										
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND										
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND										
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND										
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND										
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND										
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND										
Styrene	Less than 0.5 ug/L	100	ND	ND										
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND										
Toluene	Less than 0.5 ug/L	1000	ND	ND										
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND										
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND										
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND										
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND										
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND										
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND										
Analyst / Date:		<i>[Signature]</i>	12/22/21											
QA Check / Date:		<i>[Signature]</i>	12/22/21											
Forwarded by:		<i>[Signature]</i>	12-22-21											
Note:		Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab.												
		Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.												
		Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.												

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory	Log Number	P12-21-180	P12-21-181	P12-21-182																
	Description	4974D Kela Place Outside Faucet	4976D Kela Place Outside Faucet	5085B Iroquois Ave Outside Faucet With Aerator																
	Laboratory Results ND = Not Detected	Sample Date	12/21/2021	12/21/2021	12/21/2021															
	Sample Time	1028	1039	1105																
	Analysis Date	12/22/2021	12/22/2021	12/22/2021																
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level																		
		ug/L																		
Benzene	Less than 0.5 ug/L	5	ND	ND	ND															
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND															
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND															
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND															
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND															
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND															
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND															
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND															
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND															
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND															
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND															
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND															
Styrene	Less than 0.5 ug/L	100	ND	ND	ND															
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND															
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND															
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND															
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND															
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND															
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND															
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND															
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND															
Analyst / Date:	<i>[Signature]</i>	12/27/21																		
QA Check / Date:	<i>P. Pineda</i>	12/27/21																		
Forwarded by:	<i>R. Stuber</i>	12-30-21																		
Note:	Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab. Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.																			
Notice:	SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.																			



State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory	Log Number	P12-21-170	P12-21-171	P12-21-172	P12-21-173	P12-21-174	P12-21-175	P12-21-176	P12-21-177	P12-21-178	P12-21-179
		Description	444 Kuahua Avenue Female Bathroom Sink 2nd Floor Far Left	7377 Birch Circle Outdoor Spigot	7370 Birch Circle Outdoor Spigot	7384 Birch Circle Bldg Outside Faucet	Ford Island CDC Corner Of Okane Blvd And Saratoga Blvd Laundry Room Sink	Navy Lodge Hawaii 1275 Saratoga Blvd	Ford Island Landing Park 4800 Dauntless Womens Bathroom With Aerator	Pearl Harbor Aviation Museum 319 Lexington Blvd Janitors Closet Sink	4755D East Okahi Way Outside Faucet
Laboratory Results ND = Not Detected	Sample Date	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021	12/21/2021
	Sample Time	953	1028	1045	1058	940	1000	1040	1100	955	1014
	Analysis Date	12/22/2021	12/22/2021	12/22/2021	12/22/2021	12/22/2021	12/22/2021	12/22/2021	12/22/2021	12/22/2021	12/22/2021
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level									
	ug/L										
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	<i>[Signature]</i>	12/27/21									
QA Check / Date:	<i>[Signature]</i>	12/27/21									
Forwarded by:	<i>[Signature]</i>	12-30-21									
Note:	Modifications: Drinking water samples were collected in 40-mL amber vials containing 25 mg ascorbic acid and delivered to the lab. Samples were then preserved in the lab on the day of arrival by adding 2 drops of 1:1 HCl to each vial as specified in the method, then analyzed.										
Notice:	SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.										

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory		Log Number	P12-21-183																			
		Description	Zone D-1 Fire Hydrant 768 Spigot																			
	Laboratory Results ND = Not Detected		Sample Date	12/29/2021																		
			Sample Time	1030																		
			Analysis Date	12/29/2021																		
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level																				
		ug/L																				
Benzene	Less than 0.5 ug/L	5	ND																			
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND																			
Chlorobenzene	Less than 0.5 ug/L	100	ND																			
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND																			
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND																			
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND																			
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND																			
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND																			
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND																			
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND																			
Ethylbenzene	Less than 0.5 ug/L	700	ND																			
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND																			
Styrene	Less than 0.5 ug/L	100	ND																			
Tetrachloroethylene	Less than 0.5 ug/L	5	ND																			
Toluene	Less than 0.5 ug/L	1000	ND																			
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND																			
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND																			
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND																			
Trichloroethylene	Less than 0.5 ug/L	5	ND																			
Vinyl chloride	Less than 0.5 ug/L	2	ND																			
Xylenes, total	Less than 0.5 ug/L	10000	ND																			
	Analyst / Date:		12/30/21																			
	QA Check / Date:		12/30/21																			
	Forwarded by:		12/30/21																			
	Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.																					

State of Hawaii Department of Health State Laboratories Division Environmental Health Analytical Services Branch Drinking Water Section Laboratory	Log Number Description	P12-21-184	P12-21-185	C22-01-0001	C22-01-0002	C22-01-0003	C22-01-0011	C22-01-0012	C22-01-0013	C22-01-0014
		237 Austin Ct Kitchen Sink	108 Lex Ct Upstairs Bathroom Tub	224 Parker Court Downstairs Kitchen Sink	1203 Robinson Avenue Taken From Upstairs Bathroom Tub Faucet	1001 Lowella Avenue Downstairs Kitchen Sink	225 Austin Ct	1836 Palm Ave	1705 Coral Ave	2262 Waikaha Ct
Laboratory Results ND = Not Detected	Sample Date	12/30/2021	12/30/2021	1/2/2022	1/2/2022	1/2/2022	1/2/2022	1/2/2022	1/2/2022	1/2/2022
	Sample Time	1220	1100	1035	836	1108	840	1015	1110	300
	Analysis Date	1/3/2021	1/3/2021	1/3/2021	1/3/2021	1/3/2021	1/3/2021	1/3/2021	1/3/2021	1/3/2021
Volatile Organic Compounds - EPA Method 524.2 Modified	Detection Limit	Maximum Contaminant Level								
	ug/L									
Benzene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Carbon Tetrachloride	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Chlorobenzene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
o-Dichlorobenzene	Less than 0.5 ug/L	600	ND	ND	ND	ND	ND	ND	ND	ND
p-Dichlorobenzene	Less than 0.5 ug/L	75	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
1,1-Dichloroethylene	Less than 0.5 ug/L	7	ND	ND	ND	ND	ND	ND	ND	ND
cis-1,2-Dichloroethylene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND
trans-1,2-Dichloroethylene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
1,2-Dichloropropane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Ethylbenzene	Less than 0.5 ug/L	700	ND	ND	ND	ND	ND	ND	ND	ND
Methylene Chloride (Dichloromethane)	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Styrene	Less than 0.5 ug/L	100	ND	ND	ND	ND	ND	ND	ND	ND
Tetrachloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Toluene	Less than 0.5 ug/L	1000	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-Trichlorobenzene	Less than 0.5 ug/L	70	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-Trichloroethane	Less than 0.5 ug/L	200	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-Trichloroethane	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Trichloroethylene	Less than 0.5 ug/L	5	ND	ND	ND	ND	ND	ND	ND	ND
Vinyl chloride	Less than 0.5 ug/L	2	ND	ND	ND	ND	ND	ND	ND	ND
Xylenes, total	Less than 0.5 ug/L	10000	ND	ND	ND	ND	ND	ND	ND	ND
Analyst / Date:	[Signature] 1/4/22									
QA Check / Date:	[Signature] 1/4/22									
Forwarded by:	[Signature] 1-5-22									
Notice: SLD is provisionally certified by EPA for this drinking water analysis effective 8/9/19 due to deficiencies in the building which are currently being addressed.										