

**Appendix E: Regional Haze Four-Factor Analysis  
Hawaiian Electric Company, Inc.  
Kahe Generating Station  
August 12, 2022 RH-SIP Submittal**

## **Initial Four – Factor Analysis**



REGIONAL HAZE FOUR-FACTOR ANALYSIS  
Kahe Generating Station



Hawaiian  
Electric

**TRINITY CONSULTANTS**  
12700 Park Central Drive  
Suite 2100  
Dallas, TX 75251  
972-661-8100

April 2020

Project 194401.0297

Trinity  
Consultants

*Environmental solutions delivered uncommonly well*

## TABLE OF CONTENTS

---

<b>1. EXECUTIVE SUMMARY</b>	<b>1-1</b>
<b>2. BACKGROUND AND ADDITIONAL FACTORS</b>	<b>2-1</b>
2.1. Regional Haze Rule Background.....	2-1
2.2. Additional Factors.....	2-3
<b>3. SULFUR DIOXIDE FOUR-FACTOR ANALYSIS</b>	<b>3-1</b>
3.1. Sulfur Dioxide Control Options .....	3-1
3.2. Four-Factor Analysis.....	3-3
3.3. Sulfur Dioxide Conclusion.....	3-4
<b>4. NITROGEN OXIDES FOUR-FACTOR ANALYSIS</b>	<b>4-1</b>
4.1. Nitrogen Oxides Control Options.....	4-1
4.2. Four-Factor Analysis.....	4-4
4.3. Nitrogen Oxides Conclusion .....	4-6
<b>5. PARTICULATE MATTER FOUR-FACTOR ANALYSIS</b>	<b>5-1</b>
5.1. Particulate Matter Control Options .....	5-1
5.2. Four-Factor Analysis and Conclusion .....	5-1
<b>APPENDIX A: DETAILED COSTING</b>	<b>A-I</b>
<b>APPENDIX B: HAWAIIAN ELECTRIC REGIONAL HAZE VISIBILITY CONSIDERATIONS</b>	<b>B-I</b>
<b>APPENDIX C: HAWAII'S RENEWABLE PORTFOLIO STANDARDS CONTRIBUTION TO REGIONAL HAZE PROGRESS</b>	<b>C-I</b>

## LIST OF TABLES

---

Table 3-1. Baseline SO <sub>2</sub> Emissions	3-1
Table 3-2. SO <sub>2</sub> Cost effectiveness of CDS	3-5
Table 3-3. SO <sub>2</sub> Cost effectiveness of Switching to a Residual/ULSD Blend	3-5
Table 3-4. SO <sub>2</sub> Cost effectiveness of Switching to ULSD	3-6
Table 4-1. Baseline NO <sub>x</sub> Emissions	4-1
Table 4-2. Control Effectiveness of Technically Feasible NO <sub>x</sub> Control Technologies	4-4
Table 4-3. NO <sub>x</sub> Cost effectiveness of LNB with OFA and SCR	4-5
Table 5-1. Baseline PM <sub>10</sub> Emissions	5-1

## 1. EXECUTIVE SUMMARY

---

This report is submitted to comply with the second implementation period of the Regional Haze Rule (RHR). In the first implementation period, the EPA excluded sources, such as the Kahe Generating Station (Kahe), which is located on the Island of Oahu, from its analysis because of the distance and downwind location of the sources in relation to the Class I areas in Hawai'i.

The State of Hawai'i has two Class I areas (National Parks) that trigger compliance with the RHR: Hawai'i's Mandatory Federal Class I Areas are Haleakalā National Park on Maui and Hawai'i Volcanoes National Park on Hawai'i Island. This report documents the results of a four-factor analysis conducted by Trinity Consultants (Trinity) on behalf of Hawaiian Electric<sup>1</sup> for the six boilers (K1, K2, K3, K4, K5, and K6) at Kahe. K1, K2, K5, and K6 are wall-fired boilers with nominal ratings of 92 megawatts (MW), 90 MW, 142 MW, and 142 MW, respectively. K3 and K4 are tangentially-fired boilers with nominal ratings of 92 MW and 93 MW, respectively. The boilers currently burn residual oil. Also, Appendix B and Appendix C contain analyses performed by AECOM Technical Services, Inc. (AECOM) of a fifth factor that includes a review of visibility impacts.

This report addresses the options that could be considered that have the potential to lower emissions and show reasonable progress toward the RHR goals. The results of the four-factor analysis herein are consistent with the conclusions reached for the first planning period for Kahe. Other long-term emission reduction strategies, such as those included as part of Hawai'i's Renewable Portfolio Standards (RPS), are viable alternatives to emissions reductions from add-on controls and changes in the method of operations.

Hawaiian Electric and AECOM met with the Department of Health (DOH) on February 12, 2020 to present special circumstances applicable in Hawai'i that should be given consideration in the development of the Hawai'i Regional Haze State Implementation Plan (SIP). Significant among those circumstances is Hawai'i's Statutory RPS which have put the state on a timetable to accomplish the same goals as the RHR twenty (20) years before the Regional Haze 2064 target date and that this facility is a considerable distance and mostly downwind of the Class I areas. These same issues were addressed by the EPA in the Federal Implementation Plan (FIP) and the DOH in its Progress Report<sup>2</sup> that was approved by the EPA effective on September 11, 2019. These special considerations are discussed further in Appendix B and Appendix C to this report.

Based on the four-factor analysis and the materials set forth in the appendices, Hawaiian Electric does not propose any emissions reduction measures in addition to its RPS program to meet the RHR requirements.

<sup>1</sup> Hawaiian Electric" or the "Company" refers to Hawaiian Electric Company, Inc. (or "HE"), Hawai'i Electric Light Company, Inc. (or "HL") and/or Maui Electric Company, Limited (or "ME"). On December 20, 2019, the State of Hawai'i Department of Commerce and Consumer Affairs ("DCCA") approved Hawaiian Electric Company, Inc., Hawai'i Electric Light Company, Inc. and Maui Electric Company, Limited's application to do business under the trade name "Hawaiian Electric" for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.

<sup>2</sup> 5-Year Regional Haze Progress Report for Federal Implementation Plan, Hawai'i State Department of Health, October 2017, EPA-R09-OAR-2018-0744-0004.

## 2. BACKGROUND AND ADDITIONAL FACTORS

### 2.1. REGIONAL HAZE RULE BACKGROUND

In the 1977 amendments to the federal Clean Air Act (CAA), Congress set a nation-wide goal to restore national parks and wilderness areas to natural visibility conditions by remedying existing, anthropogenic visibility impairment and preventing future impairments. On July 1, 1999, the EPA published the final RHR (40 CFR Part 51, Subpart P). The objective of the RHR is to restore visibility to natural conditions in 156 specific areas across the United States, known as Federal Class I areas. The CAA defines Class I areas as certain national parks (over 6,000 acres), wilderness areas (over 5,000 acres), national memorial parks (over 5,000 acres)<sup>3</sup>, and international parks that were in existence on August 7, 1977.

The RHR requires states to set goals that provide for reasonable progress towards achieving natural visibility conditions for each Class I area in their jurisdiction. In establishing a reasonable progress goal for a Class I area, each state must:

- (A) *Consider the costs of compliance, the time necessary for compliance, the energy and non-air quality environmental impacts of compliance, and the remaining useful life of any potentially affected sources, and include a demonstration showing how these factors were taken into consideration in selecting the goal. 40 CFR 51.308(d)(1)(i)(A).* This is known as a four-factor analysis.
- (B) *Analyze and determine the rate of progress needed to attain natural visibility conditions by the year 2064. To calculate this rate of progress, the State must compare baseline visibility conditions to natural visibility conditions in the mandatory Federal Class I area and determine the uniform rate of visibility improvement (measured in deciviews) that would need to be maintained during each implementation period in order to attain natural visibility conditions by 2064. In establishing the reasonable progress goal, the State must consider the uniform rate of improvement in visibility and the emission reduction. 40 CFR 51.308(d)(1)(i)(B).* The uniform rate of progress or improvement is sometimes referred to as the glidepath and is part of the state's Long Term Strategy (LTS).

During the first implementation period the EPA issued a FIP (77 FR 61478, October 9, 2012; see also *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawaii Air Division* U.S. EPA Region 9, May 14, 2012) which determined for the first planning period that nitrogen oxides (NO<sub>x</sub>) was not contributing to regional haze significantly as to require control measures, and that the Oahu sources were not significantly contributing to regional haze. Additionally, as part of the EPA's decision with respect to BART controls, the EPA took into account that controls would result in "unduly increasing electricity rates in Hawai'i." (see 77 FR 31707, May 29, 2012).

The control measures that were imposed during the first RHR implementation period established an emissions cap of 3,550 tons of sulfur dioxide (SO<sub>2</sub>) per year from the fuel oil-fired boilers at Hawai'i Electric Light's Hill, Shipman and Puna generating stations, beginning in January 1, 2018, at an estimated cost of 7.9 million dollars per year. According to the FIP, this represents a reduction of 1,400 tons per year from the total projected 2018 annual emissions of SO<sub>2</sub> from these facilities. This control measure, in conjunction with SO<sub>2</sub> and NO<sub>x</sub> emissions control requirements that are already in place, was found to

<sup>3</sup> The Class I areas in the state of Hawai'i include the Hawai'i Volcanoes National Park on the Hawai'i Island, and Haleakalā National Park on Maui.

ensure that reasonable progress is made during this first planning period toward the national goal of no anthropogenic visibility impairment by 2064 at Hawai'i's two Class I areas.

The second implementation planning period (2019-2028) for the national regional haze efforts is currently underway. The EPA's *Guidance on Regional Haze State Implementation Plans for the Second Implementation Period* (SIP Guidance)<sup>4</sup> provides guidance to states for the development of the implementation plans. There are a few key distinctions from the processes that took place during the first planning period (2004-2018). Most notably, the second planning period analysis distinguishes between natural (or "biogenic") and manmade (or "anthropogenic") sources of emissions. The EPA's *Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program* (Visibility Guidance)<sup>5</sup> provides guidance to states on methods for selecting the twenty (20) percent most impaired days to track visibility and determining natural visibility conditions. The approach described in this guidance document does not attempt to account for haze formed from natural volcanic emissions; however, the 2017 RHR defines visibility impairment or anthropogenic visibility impairment as:

*any humanly perceptible difference due to air pollution from anthropogenic sources between actual visibility and natural visibility on one or more days. Because natural visibility can only be estimated or inferred, visibility impairment also is estimated or inferred rather than directly measured.*

Specifically, the EPA's Visibility Guidance states that although they did not attempt to account for haze formed by natural volcanic emissions:

*We encourage states with Class I areas affected by volcanic emissions to work with their EPA Regional office to determine an appropriate approach for determining which days are the 20 percent most anthropogenically impaired days.*

In the *5-Year Regional Haze Progress Report for Federal Implementation Plan*<sup>6</sup>, the DOH acknowledges the impact of SO<sub>2</sub> from the Kilauea volcano with the following statement:

*A majority of the visibility degradation is due to the ongoing release of SO<sub>2</sub> from Kilauea volcano with emissions that vary by hundreds of thousands of tons from one year to another. Visibility improvement from significant reductions in Maui and Hawaii Island point source SO<sub>2</sub> is obscured by sulfate from natural volcanic SO<sub>2</sub> that overwhelms sulfate from anthropogenic SO<sub>2</sub> sources.*

Step 1 of the EPA's SIP Guidance is to identify the twenty (20) percent most anthropogenically impaired days and the twenty (20) percent clearest days and determine baseline, current, and natural visibility conditions for each Class I area within the state (40 CFR 51.308(f)(1)). Hawaiian Electric has concerns that this key step may not be accounted for during the second implementation planning period and the development of Hawai'i's RHR SIP. The identification of the twenty (20) percent most impaired days sets the foundation for identifying any needed emission reductions.

Pursuant to 40 CFR 51.308(d)(3)(iv), the states are responsible for identifying the sources that contribute to the most impaired days in the Class I areas. To accomplish this the Western Regional Air Partnership (WRAP), with Ramboll US Corporation, reviewed the 2014 National Emissions Inventory (NEI) and assessed each facility's impact on visibility in Class I areas with a "Q/d" analysis, where "Q" is the magnitude of emissions that impact ambient visibility and "d" is the distance of a facility to a Class I

<sup>4</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, August 2019, EPA-457/B-19-003.

<sup>5</sup> Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program, December 2018, EPA-454/R-18-010.

<sup>6</sup> 5-Year Regional Haze Progress Report for Federal Implementation Plan, Hawai'i State Department of Health, October 2017, EPA-R09-OAR-2018-0744-0004.



area. The WRAP Guidance states that the EPA has concerns over only relying on the Q/d method for screening sources. The EPA points out that the Q/d metric is only a rough indicator of actual visibility impact because it does not consider transport direction/pathway and dispersion and photochemical processes. To address the EPA's concern, the WRAP subcommittee recommends a second step, application of the weighted emissions potential analysis (WEP).<sup>7</sup> On September 11, 2019, the DOH informed Hawaiian Electric, that Kahe Generating Station (Kahe) was identified as one of the sources potentially contributing to regional haze at the Haleakalā National Park and Volcanoes National Park. This report responds to the DOH September 2019 request to Hawaiian Electric to submit a four-factor analysis for Kahe.

The "Q/d" approach does not take into consideration the frequency or actual visibility impact on the Class I area. In support of the SIP for the first planning period, modeling was conducted for several facilities<sup>8</sup> located on the island of Oahu. Regional haze modeling shows these facilities had an insignificant impact on visibility at Haleakalā and Volcanoes National Parks. Therefore, Hawaiian Electric encourages the DOH to consider actual visibility impacts in the SIP development process.

The SIP Guidance requires that the selection of sources and controls necessary to make reasonable progress must, in addition to the statutory four factors (cost, remaining useful life, etc.), also consider the five required factors listed in 40 CFR section 51.308(f)(2)(iv), and other factors that are reasonable to consider.<sup>9</sup> These additional factors include consideration of emissions reductions due to ongoing air pollution control programs and the anticipated net effect on visibility due to projected changes in source emissions. The Hawaiian Electric and AECOM prepared summary, included in Section 2.2, describes special circumstances applicable in Hawai'i that should be considered during the development of the Hawai'i Regional Haze SIP.

## 2.2. ADDITIONAL FACTORS

Hawaiian Electric and AECOM met with the DOH on February 12, 2020 to present special circumstances applicable in Hawai'i that should be considered during the development of the Hawai'i Regional Haze SIP. Significant among those circumstances is Hawai'i's Statutory RPS which have put the state on a timetable to accomplish the same goals as the RHR twenty years before the Regional Haze 2064 target date. These same issues were addressed by the EPA in the FIP and the DOH in their Progress Report that as approved by the EPA, effective on September 11, 2019. These special considerations are discussed further in Appendix B and Appendix C to this report and summarized in the following sections.

### 2.2.1. Lack of Contribution to Visibility Impairment Due to Prevailing Winds

As noted above, the DOH did not consider actual contribution to visibility impairment when selecting sources for the Four-Factor Analysis, but this is a critical factor in establishing realistic reasonable progress goals for Class I areas. The EPA's FIP for Hawai'i for the First Decadal Review (77 FR 61478, October 9, 2012) has already acknowledged the predominant trade winds in Hawai'i and thus, did not require controls on upwind sources (i.e., sources on Oahu and Maui).


<sup>7</sup> WRAP Reasonable Progress Source Identification and Analysis Protocol For Second 10-year Regional Haze State Implementation Plans, dated February 27, 2019 (<https://www.wrapair2.org/pdf/final%20WRAP%20Reasonable%20Progress%20Source%20Identification%20and%20Analysis%20Protocol-Feb27-2019.pdf>).

<sup>8</sup> Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawaii, U.S. EPA Region 9, May 14, 2012. Table VI-3 provides visibility modeling results for the following Oahu facilities: Chevron Refinery, Tesoro Refinery, and Hawaiian Electric's Kahe and Waiau power plants.

<sup>9</sup> US EPA Memorandum, "Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program", Dec. 20, 2018, Pages 9, 21, C-1.

The wind rose plot for the Honolulu airport on Oahu shows that the wind is almost always from the northeast and rarely blows from the west or northwest, directions necessary for emissions from Kahe to blow toward either of Hawai'i's Class I areas. The Honolulu airport wind rose plot is provided as Figure 2-1 and shows the persistence of the northeasterly trade winds. Based on the infrequent amount of time the wind blows from Kahe toward either of Hawai'i's Class I areas, it is unlikely that the facility's potential emissions impact visibility at Haleakalā National Park and Volcanoes National Park. Therefore, when balancing retrofit costs and visibility improvements, the DOH should remain mindful that emissions from this facility are unlikely to contribute to regional haze at Haleakalā National Park and Volcanoes National Park and as such will have no impact on a showing of further reasonable progress.

**Figure 2-1. Honolulu Wind Rose (2015 - 2019) Predominant Wind from the Northeast**



### 2.2.2. Lack of Contribution to Visibility Impairment Due to Warm Weather Conditions

The potential for the formation of haze due to  $\text{NO}_x$  emissions is very low in Hawai'i because of the warm weather conditions year-round. Nitrate haze composition analyses for the Haleakalā and Hawai'i Volcanoes National Parks from the IMPROVE web site are included in Appendix B to this report. The data for both national parks show that the contribution of nitrates to haze is very low. It is low as a percentage of the total haze composition, but it is also low as an absolute value for light extinction (visibility impairment). The minimal impact of nitrate haze is clearly illustrated in the Hawai'i National Park monitoring data and is much lower than found at many monitors in other Class I areas around the country. This is in large part due to the unique chemistry of nitrate haze which is discussed further in Appendix B to this report.

Due to the low haze impact of  $\text{NO}_x$ , the DOH should not consider  $\text{NO}_x$  controls for the Second Decadal Review for Kahe. A similar conclusion was reached during the First Decadal Review, for which the EPA did not consider  $\text{NO}_x$  controls to be material.

### 2.2.3. Contribution to Visibility Impairment from Volcanic Activity

Volcanic activity on the Hawai'i Island represents a unique challenge to understanding haze in Hawai'i Class I areas. The Kilauea volcano on Hawai'i Island has been active for several years, and the levels of SO<sub>2</sub> emissions are being monitored by the United States Geological Survey. In addition to volcanoes being large sources of SO<sub>2</sub>, they also emit significant amounts of NO<sub>x</sub>. Volcanic activity on Hawai'i Island is by far the largest source of both SO<sub>2</sub> and NO<sub>x</sub> in the state and so dominates visibility impairment to Class I areas as to completely obscure any small impact from anthropogenic sources. Significant portions of direct Particulate Matter (PM) emissions are due to volcanic activity. Whatever small impact of SO<sub>2</sub>, NO<sub>x</sub>, and PM emissions come from power plants are projected to be phased out well before the end point of the Regional Haze Rule (i.e., 2064) by Hawai'i's State Law: Renewable Portfolio Standards (RPS). Thus, the DOH should not consider SO<sub>2</sub>, NO<sub>x</sub>, or PM controls for the Second Decadal Period Review for Kahe.

### 2.2.4. Renewable Portfolio Standards

For the reasons stated above and based on AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, SO<sub>2</sub>, NO<sub>x</sub>, and particulate matter, 10 microns or less in diameter (PM<sub>10</sub>) emissions from Kahe do not significantly contribute to regional haze at the Class I areas. The low impact that Kahe may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the Hawai'i Clean Energy Initiative (HCEI). Both past and projected future decreases in fossil-fueled electric generating unit (EGU) usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls at Kahe would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1), it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

### 3. SULFUR DIOXIDE FOUR-FACTOR ANALYSIS

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that SO<sub>2</sub> emissions from Kahe do not significantly contribute to regional haze. Additionally, as also mentioned in *Appendix B: Hawaiian Electric Regional Haze Visibility Considerations*, Kahe is not upwind of either of Hawai'i's Class I areas. The first step in the analysis is to establish a baseline for emissions. Per DOH's letter dated September 11, 2019, calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 3-1 lists the baseline SO<sub>2</sub> emissions for Kahe.

Table 3-1. Baseline SO<sub>2</sub> Emissions

Unit	Fuel Sulfur <sup>A</sup>	SO <sub>2</sub> Emissions	
		(lb/MMBtu) <sup>B</sup>	(TPY) <sup>C</sup>
K1	0.42%	0.446	841.8
K2	0.42%	0.446	659.5
K3	0.42%	0.446	836.3
K4	0.42%	0.446	859.8
K5	0.42%	0.446	1,136.2
K6	0.42%	0.446	1,431.5
<b>Total</b>			<b>5,765.1</b>

<sup>A</sup> Calendar year 2017 annual average LSFO sulfur content.

<sup>B</sup> The SO<sub>2</sub> emission factor is based on 100% conversion of fuel sulfur to SO<sub>2</sub> and the calendar year 2017 annual average LSFO fuel density (7.93 lb/gal) and higher heating value (149,479 Btu/gal).

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

#### 3.1. SULFUR DIOXIDE CONTROL OPTIONS

The characterization of emission controls available and applicable to the source is a necessary step before the four factors can be analyzed. SO<sub>2</sub> emissions are generated during fuel oil combustion from the oxidation of sulfur contained in the fuel. Available SO<sub>2</sub> control technologies for the Kahe boilers are:

- Flue Gas Desulfurization (FGD)
  - Dry Sorbent Injection (DSI)
  - Spray Dryer Absorber (SDA)
  - Wet Scrubber
  - Circulating Dry Scrubber (CDS)
- Fuel Switching
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.


##### 3.1.1. Post-Combustion Controls

###### 3.1.1.1. Boilers

An internal engineering study in 2012 identified CDS as the best option, if required, for the Kahe Boilers. The CDS process uses a circulating fluidized bed of dry hydrated lime reagent to remove SO<sub>2</sub>. The

process starts when flue gas enters multiple venturi nozzles at the base of a vertical reactor tower, where it is humidified by a water mist before entering the circulating bed of powdered hydrated lime, fly ash, and recycled byproducts. Figure 3-1 shows a typical process flow diagram of a CDS system. The addition of CDS is expected to reduce SO<sub>2</sub> emissions by ninety percent.

Figure 3-1. Typical CDS system



### 3.1.2. Fuel Switching

The Kahe boilers currently burn residual low sulfur fuel oil with a maximum sulfur content of 0.5 percent by weight. The average sulfur content of the low sulfur fuel oil burned in 2017 was approximately 0.42 percent by weight. Switching to a lower sulfur fuel will reduce SO<sub>2</sub> emissions in proportion to the reduction in fuel sulfur content.<sup>10</sup> However, a lower sulfur residual oil is not currently available in Hawai'i. Lower sulfur content distillate fuels are available and could be burned in the boilers or could be blended with the existing residual low sulfur fuel oil to lower the sulfur content. Technically feasible options include blending the current residual low sulfur fuel oil with a lower sulfur distillate fuel or switching to a lower sulfur distillate fuel. The SO<sub>2</sub> four-factor analysis will evaluate both options.

### 3.1.3. Renewable Portfolio Standards

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that SO<sub>2</sub> emissions from Kahe do not significantly contribute to regional haze. The low impact that Kahe may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the HCEI. Both past and projected future decreases in fossil-fueled EGU usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress

<sup>10</sup> Natural gas has less sulfur than the existing residual fuel oil. However, natural gas is not a technically feasible option because there is no utility-scale natural gas supply in Hawai'i.

goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls at Kahe would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1) it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

### 3.2. FOUR-FACTOR ANALYSIS

As discussed above, the technically feasible options to reduce SO<sub>2</sub> emissions are:

- CDS;
- Fuel switching to a residual/distillate blended fuel; or
- Fuel switching to a lower sulfur distillate fuel.

For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors are discussed in the following sections.

#### 3.2.1. Cost of Compliance

The cost effectiveness of CDS was based on the annualized cost of the CDS divided by the reduction in SO<sub>2</sub> emissions. The cost effectiveness of the fuel switching was determined by calculating the annual incremental cost of switching to a lower sulfur fuel divided by the reduction in SO<sub>2</sub> emissions. Switching fuel would require changes to the injectors and the fuel system; however, these expenses were not included in the analysis.

Kahe currently purchases low sulfur fuel oil from Par Hawaii Refining, LLC; current fuel costs are based on 2019 fuel purchases. The current residual low sulfur fuel oil is refined on Oahu and changes in quantities of residual low sulfur fuel oil and ULSD would require new contracts with fuel suppliers. This adds a level of uncertainty to the cost of compliance.

Table 3-2 presents the cost effectiveness of adding CDS to the boilers. The cost effectiveness is determined by dividing the annualized cost by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of adding CDS systems ranges from \$15,261 to \$21,115 per ton of SO<sub>2</sub> in the different units and the total cost equals 92 million dollars (\$92,000,000) annually and 1.4 billion dollars (\$1,400,000,000) over fifteen (15) years.

Table 3-3 presents the cost effectiveness of switching the boilers from residual low sulfur fuel oil to a residual low sulfur fuel oil/ULSD blend with a maximum sulfur content of 0.25 percent by weight. The cost effectiveness is determined by dividing the annual cost increase in fuel by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of switching to a residual low sulfur fuel oil /ULSD blend with a maximum sulfur content of 0.25 percent by weight is \$11,357 per ton of SO<sub>2</sub> and would increase fuel cost by 27 million dollars (\$27,000,000) annually and 405 million dollars (\$405,000,000) over fifteen (15) years.

Table 3-4 presents the cost effectiveness of switching the boilers from residual low sulfur fuel oil to ULSD with a maximum sulfur content of 0.0015 percent by weight. The cost effectiveness is determined by dividing the annual cost increase in fuel by the annual reduction in SO<sub>2</sub> emissions. The cost

effectiveness of switching the boilers to ULSD with a maximum sulfur content of 0.0015 percent by weight is \$9,897 per ton of SO<sub>2</sub> and would increase fuel cost by 57 million dollars (\$57,000,000) annually and 855 million dollars (\$855,000,000) over fifteen (15) years.

### 3.2.2. Time Necessary to Achieve Compliance

If the DOH determines that switching fuel is needed to achieve reasonable progress, it is anticipated that this change could be implemented within two to three years. If the DOH determines that CDS systems are needed to achieve reasonable progress goals, it is anticipated that this change could be implemented in three to five years.

### 3.2.3. Energy and Non-Air Quality Environmental Impacts

There are no energy and non-air quality environmental impact of compliance for fuel switching. The cost increase associated with fuel switching to a lower sulfur fuel will increase the cost of the electricity produced by Kahe and directly impact the price of electricity for Hawaiian Electric customers.

CDS systems require electricity to operate the ancillary equipment. The need for electricity to help power some of the ancillary equipment creates a demand for energy that currently does not exist. In addition, solid waste streams are created that will require disposal.

### 3.2.4. Remaining Useful Life

The cost of compliance for fuel switching does not contain any capital cost. The remaining useful lives of the boilers do not impact the annualized capital costs of potential controls because the useful lives of the boilers are assumed to be at least as long as the capital cost recovery period, which is fifteen (15) years. However, Hawaiian Electric intends to retire the Kahe 5 and 6 boilers in 2028, Kahe 1 and 2 boilers in 2035, and Kahe 3 and 4 boilers in 2039.<sup>11</sup> The retirements of Kahe 1, 2, 5 and 6 may significantly shorten the estimated time the control equipment is used, as calculated in the analysis, and would serve to further increase the removal cost per ton for SO<sub>2</sub>.

## 3.3. SULFUR DIOXIDE CONCLUSION

The cost effectiveness of switching the boilers to a residual low sulfur fuel oil/ULSD blend with a maximum sulfur content of 0.25 percent by weight is \$11,400 per ton of SO<sub>2</sub> and would increase fuel cost by 27 million dollars (\$27,000,000) annually and 405 million dollars (\$405,000,000) over fifteen (15) years. The cost effectiveness of switching the boilers to ULSD with a maximum sulfur content of 0.0015 percent by weight will reduce SO<sub>2</sub> emissions at a cost of \$9,900 per ton of SO<sub>2</sub> and would increase fuel cost by 57 million dollars (\$57,000,000) annually and 855 million dollars (\$855,000,000) over fifteen (15) years. The cost effectiveness of adding CDS systems to boilers exceeds \$15,000 per ton of SO<sub>2</sub> and the total cost equals 92 million dollars (\$92,000,000) annually and 1.4 billion dollars (\$1,400,000,000) over fifteen (15) years. These costs are greater than the BART and reasonable progress thresholds established in the first planning period of \$5,600 per ton and \$5,500 per ton, respectively.<sup>12</sup>

While there are no fuel changes or add-on controls proposed, other long-term emission reduction strategies, such as those included as part of the Hawai'i RPS, are viable alternatives that would create greater benefits.

<sup>11</sup> *Hawaiian Electric Companies' PSIP Update Report*, PUC Docket 2014-0183, December 23, 2016.

<sup>12</sup> *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawai'i*, U.S. EPA Region 9, May 14, 2012.

Table 3-2. SO<sub>2</sub> Cost effectiveness of CDS

Unit	Control Option	2017 SO <sub>2</sub> Emissions (tpy)	Controlled Emission Level <sup>A</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (ton/yr)	Total Annual Cost <sup>B</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	CDS	841.8	0.045	3,778,041	84.2	757.6	\$12,347,786	\$16,298
K2	CDS	659.5	0.045	2,959,869	66.0	593.6	\$12,532,786	\$21,115
K3	CDS	836.3	0.045	3,753,356	83.6	752.7	\$13,291,786	\$17,660
K4	CDS	859.8	0.045	3,858,826	86.0	773.8	\$12,747,786	\$16,474
K5	CDS	1,136.2	0.045	5,099,323	113.6	1,022.6	\$21,291,819	\$20,822
K6	CDS	1,431.5	0.045	6,424,644	143.2	1,288.4	\$19,661,819	\$15,261

<sup>A</sup> Controlled emission levels based on 90% control.

<sup>B</sup> See Appendix A for total annual cost calculations.

Table 3-3. SO<sub>2</sub> Cost effectiveness of Switching to a Residual/ULSD Blend

Unit	Current Residual Oil (0.50% maximum Sulfur) <sup>A</sup>					Residual/ULSD Blend (0.25% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content (%)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup> (\$/Gal) (\$/yr)		SO <sub>2</sub> Cost Effectiveness (\$/ton)
K1	0.42%	149,479	25,274,725	3,778,041	841.8	143,071	26,406,754	493.0	348.8	0.15	\$3,961,013	11,357
K2	0.42%	149,479	19,801,237	2,959,869	659.5	143,071	20,688,114	386.3	273.2	0.15	\$3,103,217	11,357
K3	0.42%	149,479	25,109,590	3,753,356	836.3	143,071	26,234,222	489.8	346.5	0.15	\$3,935,133	11,357
K4	0.42%	149,479	25,815,168	3,858,826	859.8	143,071	26,971,403	503.6	356.2	0.15	\$4,045,710	11,357
K5	0.42%	149,479	34,113,973	5,099,323	1,136.2	143,071	35,641,903	665.5	470.7	0.15	\$5,346,285	11,357
K6	0.42%	149,479	42,980,244	6,424,644	1,431.5	143,071	44,905,284	838.4	593.1	0.15	\$6,735,793	11,357

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on a blend of 50.0% residual oil and 50.0% ULSD and the weighted average of the 2017 fuel HHV and density for residual oil and ULSD, and contract fuel sulfur limits.

<sup>C</sup> Based on actual fuel purchases by Hawaiian Electric.



**Table 3-4. SO<sub>2</sub> Cost effectiveness of Switching to ULSD**

Unit	Current Residual Oil (0.50% maximum Sulfur) <sup>A</sup>					ULSD (0.0015% maximum Sulfur) <sup>B</sup>						
	2017 Fuel		Annual Fuel Usage (gal/yr)	2017 SO <sub>2</sub>		Fuel		Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost		SO <sub>2</sub> Cost Effectiveness (\$/ton)
	Average Sulfur Content (%)	Heating Value (HHV) (Btu/gal)		Annual Heat Input (MMBtu/yr)	SO <sub>2</sub> Emissions (tpy)	Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)			(\$/Gal)	(\$/yr)	
K1	0.42%	149,479	25,274,725	3,778,041	841.8	136,662	27,645,144	3.8	838.0	0.30	\$8,293,543	9,897
K2	0.42%	149,479	19,801,237	2,959,869	659.5	136,662	21,658,318	3.0	656.5	0.30	\$6,497,496	9,897
K3	0.42%	149,479	25,109,590	3,753,356	836.3	136,662	27,464,521	3.8	832.5	0.30	\$8,239,356	9,897
K4	0.42%	149,479	25,815,168	3,858,826	859.8	136,662	28,236,273	3.9	855.9	0.30	\$8,470,882	9,897
K5	0.42%	149,479	34,113,973	5,099,323	1,136.2	136,662	37,313,391	5.1	1,131.1	0.30	\$11,194,017	9,897
K6	0.42%	149,479	42,980,244	6,424,644	1,431.5	136,662	47,011,195	6.4	1,425.1	0.30	\$14,103,358	9,897

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on 2017 average HHV and density for residual oil, AP-42 HHV and density for diesel, and contract fuel sulfur limits.

<sup>C</sup> Based on actual fuel purchases by Hawaiian Electric.

## 4. NITROGEN OXIDES FOUR-FACTOR ANALYSIS

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that NO<sub>x</sub> emissions from Kahe do not significantly contribute to regional haze. Additionally, as also mentioned in *Appendix B: Hawaiian Electric Regional Haze Visibility Considerations*, Kahe is not upwind of either of Hawai'i's Class I areas. The first step in the analysis is to establish a baseline for emissions. Per DOH's letter dated September 11, 2019, calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 4-1 lists the baseline NO<sub>x</sub> emissions for Kahe.

**Table 4-1. Baseline NO<sub>x</sub> Emissions**

Unit	NO <sub>x</sub> Emissions		(TPY) <sup>C</sup>
	LSFO Emission Factor (lb/MMBtu) <sup>A</sup>	Adjusted Emission Factor (lb/MMBtu) <sup>B</sup>	
K1	0.491	0.494	932.7
K2	0.647	0.651	963.0
K3	0.350	0.353	661.7
K4	0.337	0.379	732.2
K5	0.797	0.802	2,044.2
K6	0.195	0.196	630.1
<b>Total</b>			<b>5,963.9</b>

<sup>A</sup> Calendar year 2017 emission factors from the 2018 Emissions Fee Report.

<sup>B</sup> The adjusted emission factors include emissions from the ignition fuels and used oil.

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

### 4.1. NITROGEN OXIDES CONTROL OPTIONS

The characterization of emission controls available and applicable to the source is a necessary step before the four factors can be analyzed. NO<sub>x</sub> is produced during fuel combustion when nitrogen contained in the fuel and combustion air is exposed to high temperatures. The origin of the nitrogen (i.e., fuel versus combustion air) has led to the use of the terms "thermal NO<sub>x</sub>" and "fuel NO<sub>x</sub>" when describing NO<sub>x</sub> emissions from the combustion of fuel. Thermal NO<sub>x</sub> emissions are produced when elemental nitrogen in the combustion air is oxidized by high combustion temperatures. Fuel NO<sub>x</sub> emissions are created by the oxidation of nitrogen contained in the fuel. Fuel NO<sub>x</sub> emissions from firing residual oil are greater than fuel NO<sub>x</sub> from firing diesel. NO<sub>x</sub> emissions from residual oil can be up to fifty percent fuel NO<sub>x</sub>.<sup>13</sup>

The formation of NO<sub>x</sub> compounds in utility boilers is sensitive to the method of firing and combustion controls utilized. Nitrogen oxide (NO) is typically the predominant form of NO<sub>x</sub> emissions from fossil fuel combustion, with the remaining NO<sub>x</sub> being in the form of nitrogen dioxide (NO<sub>2</sub>). The NO<sub>2</sub>/NO<sub>x</sub> in-stack ratio for boilers is typically less than ten percent.

Available NO<sub>x</sub> control technologies for the boilers are categorized as combustion or post-combustion controls. Combustion controls reduce the peak flame temperature and excess air in the furnace, which minimizes NO<sub>x</sub> formation. K6 is currently equipped with combustion controls to reduce NO<sub>x</sub> emissions.

<sup>13</sup> AP-42, Fifth Edition, Volume I, Chapter 1, Section 1.3.3.

Post-combustion controls convert NO<sub>x</sub> in the flue gas to molecular nitrogen and water. Available NO<sub>x</sub> control technologies for the boilers are:

- Combustion Controls (K1 – K5)
  - Flue Gas Recirculation (FGR)
  - Overfire Air (OFA)
  - Low NO<sub>x</sub> Burners (LNB)
- Post-Combustion Controls (K1 – K6)
  - Selective Catalytic Reduction (SCR)
  - Selective Non-Catalytic Reduction (SNCR)
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.

#### 4.1.1. Combustion Controls

##### 4.1.1.1. Flue Gas Recirculation (FGR)

FGR uses flue gas as an inert material to reduce flame temperatures. In a typical FGR system, flue gas is collected from the combustion chamber or stack and returned to the burner via a duct and blower. The addition of flue gas reduces the oxygen content of the “combustion air” (air + flue gas) in the burner. The lower oxygen level in the combustion zone reduces flame temperatures, which in turn reduces thermal NO<sub>x</sub> formation. When FGR is operated without additional controls, the NO<sub>x</sub> control range for wall-fired boilers (K1, K2, and K5) with FGR is approximately 0.25-0.30 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.15-0.20 lb/MMBtu.<sup>14</sup> This control is a technically feasible option for the Kahe boilers.

##### 4.1.1.2. Overfire Air (OFA)

OFA diverts a portion of the total combustion air from the burners and injects it through separate air ports above the top level of burners. Staging of the combustion air creates an initial fuel-rich combustion zone with a lower peak flame temperature. This reduces the formation of thermal NO<sub>x</sub> by lowering combustion temperature and limiting the availability of oxygen in the combustion zone where NO<sub>x</sub> is most likely to be formed. When OFA is operated without additional controls, the NO<sub>x</sub> control range for wall-fired boilers (K1, K2, and K5) is approximately 0.30-0.45 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.20-0.30 lb/MMBtu.<sup>15</sup> This control is a technically feasible option for the Kahe boilers.

##### 4.1.1.3. Low NO<sub>x</sub> Burners (LNB)

LNB technology utilizes advanced burner design to reduce NO<sub>x</sub> formation through the restriction of oxygen, lowering of flame temperature, and/or reduced residence time. In the primary zone, NO<sub>x</sub> formation is limited by either one of two methods. Under staged fuel-rich conditions, low oxygen levels limit flame temperatures resulting in less NO<sub>x</sub> formation. The primary zone is then followed by a secondary zone in which the incomplete combustion products formed in the primary zone act as reducing agents. Alternatively, under staged fuel-lean conditions, excess air will reduce flame

<sup>14</sup> *Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler*, EPA, 1994.

<sup>15</sup> *Ibid.*



temperature to reduce NO<sub>x</sub> formation. In the secondary zone, combustion products formed in the primary zone act to lower the local oxygen concentration, resulting in a decrease in NO<sub>x</sub> formation.

The estimated NO<sub>x</sub> control range for LNBs on wall-fired boilers (K1, K2, and K5) is approximately 0.25-0.35 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.15-0.20 lb/MMBtu.<sup>16</sup> When combined with OFA, the estimated NO<sub>x</sub> control range on wall-fired boilers (K1, K2, and K5) is approximately 0.25-0.30 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.15-0.20 lb/MMBtu.<sup>17</sup> LNB systems and LNB systems with OFA are technically feasible for the Kahe boilers.

#### 4.1.2. Post Combustion Controls

##### 4.1.2.1. Selective Catalytic Reduction (SCR)

SCR refers to the process in which NO<sub>x</sub> is reduced by ammonia over a heterogeneous catalyst in the presence of oxygen. The process is termed selective because the ammonia preferentially reacts with NO<sub>x</sub> rather than oxygen, although the oxygen enhances the reaction and is a necessary component of the process. The overall reactions are:



The SCR process requires a reactor, catalyst, ammonia storage, and an ammonia injection system. The effectiveness of an SCR system is dependent on a variety of factors, including the inlet NO<sub>x</sub> concentration, the exhaust temperature, the ammonia injection rate, and the type of catalyst. The estimated NO<sub>x</sub> control range for SCR is approximately 0.05-0.10 lb/MMBtu for a wall-fired boiler (K1, K2, and K5), and for tangentially-fired boilers (K3 and K4) is approximately 0.03-0.10 lb/MMBtu.<sup>18</sup> This control is a technically feasible option for the Kahe boilers.

##### 4.1.2.2. Selective Non-Catalytic Reduction (SNCR)

In SNCR systems, a reagent (ammonia or urea) is injected into the flue gas in the furnace within an appropriate temperature window. The NO<sub>x</sub> and reagent react to form nitrogen and water. A typical SNCR system consists of reagent storage, multi-level reagent-injection equipment, and associated control instrumentation. The SNCR reagent storage and handling systems are similar to those for SCR systems. However, both ammonia- and urea-based SNCR processes require three or four times as much reagent as SCR systems to achieve similar NO<sub>x</sub> reductions. The estimated NO<sub>x</sub> control range for SNCR for wall-fired boilers (K1, K2, and K5) is approximately 0.30-0.40 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.20-0.25 lb/MMBtu.<sup>19</sup> This control is a technically feasible option for the Kahe boilers.

#### 4.1.3. Rank of Technically Feasible NO<sub>x</sub> Boiler Control Options by Effectiveness

The next step is to rank the technically feasible options according to effectiveness. Table 4-2 provides a ranking of the control levels for the controls listed in the previous section.

<sup>16</sup> Ibid.

<sup>17</sup> Ibid.

<sup>18</sup> Ibid.

<sup>19</sup> Ibid.

**Table 4-2. Control Effectiveness of Technically Feasible NO<sub>x</sub> Control Technologies**

Control Technology	Estimated Controlled Level	
	Wall-Fired Boilers	Tangentially-Fired Boilers
	(lb/MMBtu)	(lb/MMBtu)
SCR	0.05 - 0.10	0.03 - 0.10
LNB & OFA	0.25 - 0.30	0.15 - 0.20
FGR	0.25 - 0.30	0.15 - 0.20
LNB	0.25 - 0.35	0.15 - 0.20
SNCR	0.30 - 0.40	0.20 - 0.25
OFA	0.30 - 0.45	0.20 - 0.30

The control levels in Table 4-2 are presented as a range. This is due to the specific level of control that is achievable for the Kahe boilers based on the application of the controls listed in Table 4-2 is unknown. It is anticipated that combustion controls such as LNB with OFA and possibly LNB alone can achieve NO<sub>x</sub> emission levels of approximately 0.30 lb/MMBtu for K1, K2, and K5 and 0.20 lb/MMBtu for K3 and K4. As noted in Table 4-1, the Kahe boilers are currently emitting in the range of 0.196 lb/MMBtu to 0.802 lb/MMBtu. Further, it is believed that SCR can achieve a NO<sub>x</sub> emissions level of approximately 0.10 lb/MMBtu.

## 4.2. FOUR-FACTOR ANALYSIS

As discussed above, LNB with OFA and SCR are the best feasible options to reduce NO<sub>x</sub> emissions from the boilers. For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors for adding NO<sub>x</sub> controls are discussed in the following sections.

### 4.2.1. Cost of Compliance

For purposes of this four-factor analysis, the capital costs, operating costs, and cost effectiveness of LNB with OFA and SCR have been estimated for the boilers. The cost effectiveness of LNB with OFA is based on a controlled NO<sub>x</sub> emissions level of 0.30 lb/MMBtu for K1, K2, and K5 and 0.20 lb/MMBtu for K3 and K4. At this time, it is unknown if LNBs alone can achieve this level of emissions or if LNB combined with OFA would be required to meet this level. Therefore, the costing is based on LNB with OFA, it is assumed that a NO<sub>x</sub> emissions level of 0.30 lb/MMBtu for K1, K2, and K5 and 0.20 lb/MMBtu for K3 and K4 can be achieved with LNB with OFA. This level of NO<sub>x</sub> emissions is comparable to SNCR; the only other control expected to result in lower achievable NO<sub>x</sub> emissions is SCR. The cost effectiveness of SCR is based on a controlled NO<sub>x</sub> emissions level of 0.10 lb/MMBtu.

Table 4-3 presents a summary of the cost effectiveness of adding LNB with OFA and SCR to the boiler. The cost effectiveness is determined by dividing the annual cost by the annual reduction in NO<sub>x</sub> emissions. The cost effectiveness of LNB with OFA ranges from \$634 per ton to over \$1,675 per ton of NO<sub>x</sub> emissions in the different units and the total cost equals 3 million dollars (\$3,000,000) annually and 45 million dollars (\$45,000,000) over fifteen (15) years. The cost effectiveness of SCR ranges from \$2,078 per ton to \$11,840 per ton of NO<sub>x</sub> emissions in the different units and the total cost equals 18 million dollars (\$18,000,000) annually and 270 million dollars (\$270,000,000) over fifteen (15) years.

Table 4-3. NO<sub>x</sub> Cost effectiveness of LNB with OFA and SCR

Unit	Control Option	2017 NO <sub>x</sub> Emissions (tpy)	Controlled Emission Level <sup>A</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled NO <sub>x</sub> Emissions (tpy)	NO <sub>x</sub> Reduced (ton/yr)	Total Annual Cost <sup>B</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	LNB w/OFA	932.7	0.30	3,778,041	566.7	366.0	\$612,900	\$1,675
	SCR	932.7	0.10	3,778,041	188.9	743.8	\$2,708,372	\$3,641
K2	LNB w/OFA	963.0	0.30	2,959,869	444.0	519.0	\$596,013	\$1,148
	SCR	963.0	0.10	2,959,869	148.0	815.0	\$2,574,564	\$3,159
K3	LNB w/OFA	661.7	0.20	3,753,356	375.3	286.4	\$444,186	\$1,551
	SCR	661.7	0.10	3,753,356	187.7	474.0	\$2,669,012	\$5,630
K4	LNB w/OFA	732.2	0.20	3,858,826	385.9	346.3	\$447,598	\$1,292
	SCR	732.2	0.10	3,858,826	192.9	539.3	\$2,704,056	\$5,014
K5	LNB w/OFA	2,044.2	0.30	5,099,323	764.9	1,279.3	\$810,691	\$634
	SCR	2,044.2	0.10	5,099,323	255.0	1,789.2	\$3,718,061	\$2,078
K6	SCR	630.1	0.10	6,424,644	321.2	308.9	\$3,656,850	\$11,840

<sup>A</sup> Controlled emission levels based on "Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler" EPA, 1994.

<sup>B</sup> See Appendix A for total annual cost calculations.

#### 4.2.2. Time Necessary to Achieve Compliance

If the DOH determines that controls are needed to achieve reasonable progress, it is anticipated that these changes could be implemented within three to five years.

#### 4.2.3. Energy and Non-Air Quality Environmental Impacts

SCR systems require electricity to operate the ancillary equipment. The need for electricity to help power some of the ancillary equipment creates a demand for energy that currently does not exist.

SCR can potentially cause significant environmental impacts related to the storage of ammonia, and the storage of aqueous ammonia above 10,000 pounds is regulated by the EPA's Risk Management Program (RMP) because the accidental release of ammonia has the potential to cause serious injury and death to persons in the vicinity of the release. SCR will likely also cause the release of unreacted ammonia to the atmosphere. This is referred to as ammonia slip. Ammonia slip from SCR systems occurs either from ammonia injection at temperatures too low for effective reaction with NO<sub>x</sub>, leading to an excess of unreacted ammonia, or from over-injection of reagent leading to uneven distribution, which also leads to an excess of unreacted ammonia. Ammonia released from SCR systems will react with sulfates and nitrates in the atmosphere to form ammonium sulfate and ammonium nitrate. Together, ammonium sulfate and ammonium nitrate are the predominant sources of regional haze.

#### 4.2.4. Remaining Useful Life

The remaining useful lives of the boilers do not impact the annualized capital costs of potential controls because the useful lives of the boilers are assumed to be at least as long as the capital cost recovery period, which is fifteen (15) years. However, Hawaiian Electric intends to retire the Kahe 5 and 6 boilers in 2028, Kahe 1 and 2 boilers in 2035, and Kahe 3 and 4 boilers in 2039.<sup>20</sup> Although the plan is not binding with respect to specific dates, this is a necessary step to meet Hawai'i's statutory requirement to discontinue the use of fossil fuels for electric generation by 2045. The retirements of Kahe 1, 2, 5 and 6 may significantly shorten the estimated time the control equipment is used, as calculated in the analysis, and would serve to further increase the removal cost per ton for NO<sub>x</sub>.

### 4.3. NITROGEN OXIDES CONCLUSION

The cost effectiveness of adding LNB with OFA to the Kahe boilers ranges from \$600 per ton to \$1,700 per ton of NO<sub>x</sub> in the different units and the total cost equals 3 million dollars (\$3,000,000) annually and 45 million dollars (\$45,000,000) over fifteen (15) years. These costs are similar to the BART analyses conducted for the first planning period. For the first planning period, the EPA concluded the emission reductions provided by LNB are unlikely to provide a measurable visibility benefit at Hawai'i Volcanoes National Park or Haleakalā National Park.<sup>21</sup>

The cost effectiveness of SCR to the Kahe boilers ranges from \$2,100 per ton to \$11,800 per ton of NO<sub>x</sub> in the different units and the total cost equals 18 million dollars (\$18,000,000) annually and 270 million dollars (\$270,000,000) over fifteen (15) years. These costs are similar to the BART analyses conducted for the first planning period. For the first planning period, the EPA concluded that SCR was not cost effective.<sup>22</sup>

<sup>20</sup> *Hawaiian Electric Companies' PSIP Update Report, PUC Docket 2014-0183, December 23, 2016.*

<sup>21</sup> *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawai'i, U.S. EPA Region 9, May 14, 2012.*

<sup>22</sup> *Ibid.*

The results of the four-factor analysis are consistent with the conclusions, that NO<sub>x</sub> controls are not required, reached for the first planning period. Therefore, Hawaiian Electric does not propose any NO<sub>x</sub> emissions reduction measures in addition to its RPS program to meet the RHR requirements.



## 5. PARTICULATE MATTER FOUR-FACTOR ANALYSIS

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that PM<sub>10</sub> emissions from Kahe do not significantly contribute to regional haze. Additionally, as also mentioned in *Appendix B: Hawaiian Electric Regional Haze Visibility Considerations*, Kahe is not upwind of either of Hawai'i's Class I areas. The first step in the analysis is to establish a baseline for emissions. Per DOH's letter dated September 11, 2019 calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 5-1 lists the baseline PM<sub>10</sub> emissions for Kahe.

**Table 5-1. Baseline PM<sub>10</sub> Emissions**

Unit	PM <sub>10</sub> Emissions		(TPY) <sup>c</sup>
	LSFO Emission Factor (lb/MMBtu) <sup>A</sup>	Adjusted Emission Factor (lb/MMBtu) <sup>B</sup>	
K1	0.0293	0.0295	55.7
K2	0.0264	0.0266	39.3
K3	0.0274	0.0275	51.7
K4	0.0260	0.0262	50.5
K5	0.0307	0.0309	78.7
K6	0.0336	0.0338	108.6
<b>Total</b>			<b>384.5</b>

<sup>A</sup> Calendar year 2017 emission factors from the 2018 Emissions Fee Report.

<sup>B</sup> The adjusted emission factors include emissions from the ignition fuels and used oil.

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

### 5.1. PARTICULATE MATTER CONTROL OPTIONS

The Kahe boilers are subject to the Electric Utility Steam Generating Units Maximum Achievable Control Technology (EGU MACT) standards (40 CFR Part 63, Subpart UUUUU). Under the EGU MACT standards, the Kahe boilers are subject to the filterable PM emission limit of 0.030 lb/MMBtu on a thirty-boiler operating day rolling average for non-continental liquid oil-fired units. Currently, the Kahe boilers are meeting the filterable PM emission limit. Due to these low levels of PM emissions, additional post-combustion controls are not expected to be cost effective. Therefore, the four-factor analysis was not conducted for the Kahe boilers.

### 5.2. FOUR-FACTOR ANALYSIS AND CONCLUSION

PM<sub>10</sub> baseline emissions are fifteen times lower than SO<sub>2</sub> and NO<sub>x</sub> baseline emissions. Due to these low levels of PM emissions, additional post-combustion controls are not expected to be cost effective and any reductions are expected to have a negligible impact on regional haze. Therefore, the four-factor analysis was not conducted for the Kahe Boilers. Therefore, Hawaiian Electric does not propose any PM<sub>10</sub> emissions reduction measures in addition to its RPS program to meet the RHR requirements.

## APPENDIX A: DETAILED COSTING

---

**Appendix Table A-1. CDS Capital and O&M Cost Estimate**

Unit MW Rating (Nominal) Classification	K1 92 Fuel Oil	K2 90 Fuel Oil	K3 92 Fuel Oil	K4 93 Fuel Oil	K5 142 Fuel Oil	K6 142 Fuel Oil
<b>Capital Cost</b>						
<b>Direct Costs</b>						
Total Direct Costs (DC)	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 61,988,000	\$ 61,988,000
<b>Indirect Costs</b>						
Summary of Indirect Costs not including Contingency	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 19,142,000	\$ 19,142,000
Contingencies	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 21,468,000	\$ 21,468,000
Total Indirect Costs (IC)	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 40,610,000	\$ 40,610,000
<b>Allowance for Funds Used During Construction (AFDC)</b>	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 10,466,000	\$ 10,466,000
<b>Total Capital Investment (TCI)</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 113,064,000</b>	<b>\$ 113,064,000</b>
<b>Annual Cost</b>						
<b>Direct Annual Costs</b>						
Fixed Annual Costs						
Maintenance labor and materials	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Total Fixed Annual Costs	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Variable Annual Costs						
Byproduct disposal	\$ 273,000	\$ 294,000	\$ 377,000	\$ 314,000	\$ 478,000	\$ 352,000
Reagent Cost (lime)	\$ 632,000	\$ 679,000	\$ 864,000	\$ 740,000	\$ 1,582,000	\$ 1,204,000
Water Cost	\$ 51,000	\$ 54,000	\$ 69,000	\$ 58,000	\$ 116,000	\$ 88,000
Power (ID and Aux) Cost	\$ 1,561,000	\$ 1,675,000	\$ 2,151,000	\$ 1,805,000	\$ 4,259,000	\$ 3,161,000
Total Variable Annual Costs	\$ 2,517,000	\$ 2,702,000	\$ 3,461,000	\$ 2,917,000	\$ 6,435,000	\$ 4,805,000
Total Direct Annual Costs (DAC)	\$ 4,305,000	\$ 4,490,000	\$ 5,249,000	\$ 4,705,000	\$ 8,878,000	\$ 7,248,000
<b>Indirect Annual Costs</b>						
Cost for capital recovery <sup>2</sup>	\$ 8,042,786	\$ 8,042,786	\$ 8,042,786	\$ 8,042,786	\$ 12,413,819	\$ 12,413,819
Total Indirect Annual Costs (IDAC)	\$ 8,042,786	\$ 8,042,786	\$ 8,042,786	\$ 8,042,786	\$ 12,413,819	\$ 12,413,819
<b>Total Annual Cost (TAC)</b>	<b>\$ 12,347,786</b>	<b>\$ 12,532,786</b>	<b>\$ 13,291,786</b>	<b>\$ 12,747,786</b>	<b>\$ 21,291,819</b>	<b>\$ 19,661,819</b>

<sup>1</sup> Costing from an Hawaiian Electric internal study dated July 2012.

<sup>2</sup> Capital Recovery Factor (CRF) =  $[I \times (1+i)^a] / [(1+i)^a - 1]$  CRF = 0.11

Where:

- I = Interest Rate (7% interest)
- a = Equipment life (15 yrs)

**Appendix Table A-2. LNB with OFA Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4	K5
Boiler design capacity, mmBtu/hr (C)		903	900	892	918	1468
Boiler Type		Normal	Normal	Tangential	Tangential	Normal
2017 Annual Heat Input, MMBtu/yr (H)		3,778,041	2,959,869	3,753,356	3,858,826	5,099,323
Unit Size, kW (kW)		92,000	90,000	92,000	93,000	142,000
Unit Size, MW (MW)		92.0	90.0	92.0	93.0	142.0
Capital recovery factor a. Equipment CRF, 15-yr life, 7% interest	$= [ I \times (1+i)^a ] / [ (1+i)^a - 1 ]$ where I = interest rate, a = equipment life	0.11	0.11	0.11	0.11	0.11
Cost Index (CI) <sup>A</sup> a. 2018 b. 2004	603.1 444.2					
Total Capital Investment <sup>B,C</sup> TCI (\$)	$= \$24/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004})$ - Wall $= \$18/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004})$ - Tangential	\$4,582,437	\$4,518,331	\$3,436,828	\$3,460,727	\$6,052,369
Direct Annual Operating Costs \$/yr Variable O&M Costs <sup>D</sup>	$= (\$0.08 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times \text{H} \times 10^6$ Btu/mmBtu $\times (\text{CI}_{2018}/\text{CI}_{2004})$ - Wall $= (\$0.03 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times \text{H} \times 10^6$ Btu/mmBtu $\times (\text{CI}_{2018}/\text{CI}_{2004})$ - Tangential	\$41,036	\$32,149	\$15,288	\$15,718	\$55,388
Indirect Annual Costs, \$/yr 1. Fixed O&M Costs <sup>E</sup> 2. Capital recovery	$= \$0.36/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times (300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004})$ - Wall $= \$0.27/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times (300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004})$ - Tangential $= \text{Equipment CRF} \times \text{TCI}$	\$68,737 \$503,127	\$67,775 \$496,088	\$51,552 \$377,345	\$51,911 \$379,969	\$90,786 \$664,518
<b>Total Annual Cost \$/yr</b>	$= \text{Direct Annual Costs} + \text{Indirect Annual Costs}$	<b>\$612,900</b>	<b>\$596,013</b>	<b>\$444,186</b>	<b>\$447,598</b>	<b>\$810,691</b>

**Source:** All costs were estimated using Section 4.3 and Appendix D of the WRAP guidance document, *Analysis of Combustion Controls for Reducing NOx Emissions from Coal-fired EGUs in the WRAP Region*, dated September 6, 2005. The cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). As published in Chemical Engineering Magazine - Revision: 18, Apr 16, 2019.

<sup>B</sup> TCI for LNB and LNB w/over fire air ranges from \$6/kW to \$24/kW for wall boilers and \$10/kW to \$18/kW for tangential boilers, the high end of the range was used due to Hawai'i's remote location.

<sup>C</sup> Scaling factor =  $(300/\text{Nameplate capacity})^{0.359}$

<sup>D</sup> The variable O&M costs for LNB and LNB w/over fire air ranges from 0.05 mills/kW-hr to 0.08 mills/kW-hr for wall boilers and 0.027 mills/kW-hr to 0.03 mills/kW-hr for tangential boilers, the high end of the range was used due to Hawai'i's remote location.

<sup>E</sup> The fixed O&M costs for LNB and LNB w/over fire air ranges from \$0.09/kW to \$0.36/kW for wall boilers and \$0.15/kW to \$0.27/kW for tangential boilers, the high end of the range was used due to Hawai'i's remote location.

## Attachment Table A-3a. Kahe K1 - SCR Costing

### Data Inputs

**Enter the following data for your combustion unit:**

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWhs output?  MWhs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,688

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Attachment Table A-3a. Kahe K1 - SCR Costing

**Enter the following design parameters for the proposed SCR:**

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.494 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	15 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>			
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*	<u>Densities of typical SCR reagents:</u> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/ft<sup>3</sup> are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used	<input type="text" value="Ammonia"/>		

**Enter the cost data for the proposed SCR:**

Desired dollar-year	2018	CEPCI for 2018	603.1	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*			
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh			* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.
Catalyst cost (CC <sub>replace</sub> )	227.00	Catalyst cost (CC <sub>replace</sub> )	\$227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)			* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Labor Rate	60.00 \$/hour (including benefits)*			* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.
Operator Hours/Day	4.00 hours/day*	Operator Hours/Day	4.00 hours/day*			
<small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small>						

## Attachment Table A-3a. Kahe K1 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Default bank prime rate	

## Attachment Table A-3a. Kahe K1 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	Bmw x NPHR =	903	MMBtu/hour
Maximum Annual MW Output (Bmw) =	Bmw x 8760 =	805,920	MW/hrs
Estimated Actual Annual MW/hrs Output (Boutput) =		384,917	MW/hrs
Heat Rate Factor (HRF) =	NPHR/10 =	0.98	
Total System Capacity Factor ( $CF_{total}$ ) =	(Boutput/Bmw)*(tscr/tpplant) =	0.478	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4184	hours
NOx Removal Efficiency (EF) =	$(NO_{x,in} - NO_{x,out})/NO_{x,in} =$	79.7	percent
NOx removed per hour =	$NO_{x,in} \times EF \times Q_b =$	355.55	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x,in} \times EF \times Q_b \times t_{op})/2000 =$	743.80	tons/year
NO <sub>x</sub> removal factor (NRF) =	EF/80 =	1.00	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{flue} \times QB \times (460 + T)/(460 + 700)n_{scr} =$	418,214	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	111.61	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (Coalf) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / ((1 + interest\ rate)^Y - 1))$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x,adj} \times S_{adj} \times (T_{adj}/N_{scr})$	3,746.95	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	436	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet



### Attachment Table A-3a. Kahe K1 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	501	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.4	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	52	feet

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft <sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_g \times EF \times SRF \times MW_g) / MW_{NO_x} =$	138	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	476	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	64	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	45,900	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate	0.1098

Other parameters	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	511.08	kw

### Attachment Table A-3a. Kahe K1 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,416,366</b>	<b>in 2018 dollars</b>

## Attachment Table A-3a. Kahe K1 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$792,382 in 2018 dollars
Indirect Annual Costs (IDAC) =		\$1,915,990 in 2018 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$2,708,372 in 2018 dollars</b>
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$87,082 in 2018 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$78,028 in 2018 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$539,069 in 2018 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$88,203 in 2018 dollars
<b>Direct Annual Cost =</b>		<b>\$792,382 in 2018 dollars</b>
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,673 in 2018 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,912,317 in 2018 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$1,915,990 in 2018 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,708,372 per year in 2018 dollars
NOx Removed =		744 tons/year
<b>Cost Effectiveness =</b>		<b>\$3,641 per ton of NOx removed in 2018 dollars</b>

## Appendix Table A-3b. Kahe K2 - SCR Costing

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWhs output?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,688

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Appendix Table A-3b. Kahe K2 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.651 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	15 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>			
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*	<u>Densities of typical SCR reagents:</u> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/ft<sup>3</sup> are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used	<input type="text" value="Ammonia"/>		

Enter the cost data for the proposed SCR:

Desired dollar-year	2018	CEPCI for 2018	603.1	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*			
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh			<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Catalyst cost (CC <sub>replace</sub> )	227.00	Catalyst cost (CC <sub>replace</sub> )	\$227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Labor Rate	60.00 \$/hour (including benefits)*			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
Operator Hours/Day	4.00 hours/day*	Operator Hours/Day	4.00 hours/day*			<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>
<small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small>						

## Appendix Table A-3b. Kahe K2 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Default bank prime rate	

## Appendix Table A-3b. Kahe K2 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	900	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	788,400	MW/hrs
Estimated Actual Annual MWhs Output (Boutput) =		295,987	MW/hrs
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.00	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tpplant) =$	0.375	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	3289	hours
NOx Removal Efficiency (EF) =	$(NO_{x,in} - NO_{x,out})/NO_{x,in} =$	84.6	percent
NOx removed per hour =	$NO_{x,in} \times EF \times Q_b =$	495.63	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x,in} \times EF \times Q_b \times t_{op})/2000 =$	815.01	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	1.06	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700)n_{scr} =$	416,824	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	101.67	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (Coalf) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / ((1 + interest\ rate)^Y - 1))$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x,adj} \times S_{adj} \times (T_{adj}/N_{scr})$	4,099.76	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	434	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Appendix Table A-3b. Kahe K2 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	499	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.3	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	54	feet

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft <sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_g \times EF \times SRF \times MW_g) / MW_{NO_x} =$	193	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	664	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	89	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	63,900	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate	0.1098

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	504.00	kw



## Appendix Table A-3b. Kahe K2 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,169,319</b>	<b>in 2018 dollars</b>

## Appendix Table A-3b. Kahe K2 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$685,715 in 2018 dollars
Indirect Annual Costs (IDAC) =		\$1,888,849 in 2018 dollars
Total annual costs (TAC) = DAC + IDAC		\$2,574,564 in 2018 dollars
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$85,847 in 2018 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$85,498 in 2018 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$417,862 in 2018 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$96,508 in 2018 dollars
Direct Annual Cost =		\$685,715 in 2018 dollars
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,658 in 2018 dollars
Capital Recovery Costs (CR) =	$CRF \times TCI =$	\$1,885,191 in 2018 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$1,888,849 in 2018 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,574,564 per year in 2018 dollars
NOx Removed =		815 tons/year
Cost Effectiveness =		\$3,159 per ton of NOx removed in 2018 dollars

## Appendix Table A-3c. Kahe K3 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWhs output?  MWhs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,688

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Appendix Table A-3c. Kahe K3 - SCR Costing

**Enter the following design parameters for the proposed SCR:**

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.353 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	15 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>			
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*	<u>Densities of typical SCR reagents:</u> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/ft<sup>3</sup> are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used	<input type="text" value="Ammonia"/>		

**Enter the cost data for the proposed SCR:**

Desired dollar-year	2018	CEPCI for 2018	603.1	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*			
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh			
Catalyst cost (CC <sub>replace</sub> )	227.00	Catalyst cost (CC <sub>replace</sub> )	\$227/cf (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)			
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Labor Rate	60.00 \$/hour (including benefits)*			
Operator Hours/Day	4.00 hours/day*	Operator Hours/Day	4.00 hours/day*			
<small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small>						

## Appendix Table A-3c. Kahe K3 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Default bank prime rate	

## Appendix Table A-3c. Kahe K3 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	892	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	805,920	MW/hrs
Estimated Actual Annual MW/hrs Output (Boutput) =		387,117	MW/hrs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.97	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.480	Fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4208	hours
NOx Removal Efficiency (EF) =	$(NO_{x,in} - NO_{x,out})/NO_{x,in} =$	71.6	percent
NOx removed per hour =	$NO_{x,in} \times EF \times Q_b =$	225.31	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x,in} \times EF \times Q_b \times t_{op})/2000 =$	474.03	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.90	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{flue} \times QB \times (460 + T)/(460 + 700)n_{scr} =$	413,119	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	126.44	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (Coalf) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%/100) \times (64/32) \times 1 \times 10^3 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / ((1 + interest\ rate)^Y - 1))$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x,adj} \times S_{adj} \times (T_{adj}/N_{scr})$	3,267.24	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	430	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Appendix Table A-3c. Kahe K3 - SCR Costing

### SCR Reactor Data:

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	495	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.2	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

### Reagent Data:

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft <sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_g \times EF \times SRF \times MW_g) / MW_{NO_x} =$	88	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	302	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	40	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	29,100	gallons (storage needed to store a 30 day reagent supply rounded to t

### Capital Recovery Factor:

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate	0.1098

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	508.40	kw

## Appendix Table A-3c. Kahe K3 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,416,366</b>	<b>in 2018 dollars</b>



## Appendix Table A-3c. Kahe K3 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$753,022 in 2018 dollars
Indirect Annual Costs (IDAC) =		\$1,915,990 in 2018 dollars
Total annual costs (TAC) = DAC + IDAC		\$2,669,012 in 2018 dollars
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$87,082 in 2018 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$49,728 in 2018 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$539,302 in 2018 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$76,910 in 2018 dollars
Direct Annual Cost =		\$753,022 in 2018 dollars
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,673 in 2018 dollars
Capital Recovery Costs (CR) =	$CRF \times TCI =$	\$1,912,317 in 2018 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$1,915,990 in 2018 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,669,012 per year in 2018 dollars
NOx Removed =		474 tons/year
Cost Effectiveness =		\$5,630 per ton of NOx removed in 2018 dollars

## Appendix Table A-3d. Kahe K4 - SCR Costing

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?  What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWhs output?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,688

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Appendix Table A-3d. Kahe K4 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.379 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	15 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>			
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*	<u>Densities of typical SCR reagents:</u> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/ft<sup>3</sup> are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used	<input type="text" value="Ammonia"/>		

Enter the cost data for the proposed SCR:

Desired dollar-year	2018	CEPCI for 2018	603.1	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*			
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh			<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Catalyst cost (CC <sub>replace</sub> )	227.00	Catalyst cost (CC <sub>replace</sub> )	\$227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Labor Rate	60.00 \$/hour (including benefits)*			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
Operator Hours/Day	4.00 hours/day*	Operator Hours/Day	4.00 hours/day*			<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>
<small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small>						

## Appendix Table A-3d. Kahe K4 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Default bank prime rate	

## Appendix Table A-3d. Kahe K4 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	918	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	814,680	MW/hrs
Estimated Actual Annual MW/hrs Output (Boutput) =		390,927	MW/hrs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.99	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tpplant) =$	0.480	Fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4204	hours
NOx Removal Efficiency (EF) =	$(NO_{x,in} - NO_{x,out})/NO_{x,in} =$	73.6	percent
NOx removed per hour =	$NO_{x,in} \times EF \times Q_b =$	256.58	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x,in} \times EF \times Q_b \times t_{op})/2000 =$	539.26	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.92	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700)n_{scr} =$	425,161	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	122.82	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (Coalf) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / ((1 + interest\ rate)^Y - 1))$ , where $Y = H_{catalyst} / (t_{SCR} \times 24\ hours)$ rounded to the nearest integer	0.3111	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x,adj} \times S_{adj} \times (T_{adj}/N_{scr})$	3,461.60	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	443	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Appendix Table A-3d. Kahe K4 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	509	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.6	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft <sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_g \times EF \times SRF \times MW_g) / MW_{NO_x} =$	100	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	344	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	46	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	33,100	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate	0.1098

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	517.90	kw

### Appendix Table A-3d. Kahe K4 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,539,183</b>	<b>in 2018 dollars</b>

## Appendix Table A-3d. Kahe K4 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$774,574 in 2018 dollars
Indirect Annual Costs (IDAC) =		\$1,929,483 in 2018 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$2,704,056 in 2018 dollars</b>
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$87,696 in 2018 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$56,571 in 2018 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$548,821 in 2018 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$81,486 in 2018 dollars
<b>Direct Annual Cost =</b>		<b>\$774,574 in 2018 dollars</b>
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,680 in 2018 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,925,802 in 2018 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$1,929,483 in 2018 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,704,056 per year in 2018 dollars
NOx Removed =		539 tons/year
<b>Cost Effectiveness =</b>		<b>\$5,014 per ton of NOx removed in 2018 dollars</b>



## Appendix Table A-3e. Kahe K5 - SCR Costing

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWhs output?  MWhs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units buring fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,688

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Appendix Table A-3e. Kahe K5 - SCR Costing

**Enter the following design parameters for the proposed SCR:**

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.802 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	15 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>			
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*	<u>Densities of typical SCR reagents:</u> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/ft<sup>3</sup> are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used	<input type="text" value="Ammonia"/>		

**Enter the cost data for the proposed SCR:**

Desired dollar-year	2018	CEPCI for 2018	603.1	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*			
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh			<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Catalyst cost (CC <sub>replace</sub> )	227.00	Catalyst cost (CC <sub>replace</sub> )	\$227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Labor Rate	60.00 \$/hour (including benefits)*			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
Operator Hours/Day	4.00 hours/day*	Operator Hours/Day	4.00 hours/day*			<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>
<small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small>						

## Appendix Table A-3e. Kahe K5 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Default bank prime rate	

## Appendix Table A-3e. Kahe K5 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	1,468	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	1,243,920	MW/hrs
Estimated Actual Annual MW/hrs Output (Boutput) =		493,259	MW/hrs
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.03	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tpplant) =$	0.397	Fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	3474	hours
NOx Removal Efficiency (EF) =	$(NO_{x,in} - NO_{x,out})/NO_{x,in} =$	87.5	percent
NOx removed per hour =	$NO_{x,in} \times EF \times Q_b =$	1030.17	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x,in} \times EF \times Q_b \times t_{op})/2000 =$	1,789.23	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	1.09	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{flue} \times QB \times (460 + T)/(460 + 700)n_{scr} =$	679,886	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	94.77	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (Coalf) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate)/(1/(1 + interest\ rate)^Y - 1)$ , where $Y = H_{catalyst}/(t_{SCR} \times 24\ hours)$ rounded to the nearest integer	0.3111	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x,adj} \times S_{adj} \times (T_{adj}/N_{scr})$	7,173.70	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas}/(16\ ft/sec \times 60\ sec/min)$	708	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst}/(R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Appendix Table A-3e. Kahe K5 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	814	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	28.5	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	55	feet

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft <sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_g \times EF \times SRF \times MW_g) / MW_{NO_x} =$	400	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	1,381	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	184	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	132,800	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate	0.1098

Other parameters	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	806.65	kw

## Appendix Table A-3e. Kahe K5 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$23,093,134</b>	<b>in 2018 dollars</b>

## Appendix Table A-3e. Kahe K5 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$1,178,421 in 2018 dollars
Indirect Annual Costs (IDAC) =		\$2,539,640 in 2018 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$3,718,061 in 2018 dollars</b>
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$115,466 in 2018 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$187,699 in 2018 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$706,389 in 2018 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$168,868 in 2018 dollars
<b>Direct Annual Cost =</b>		<b>\$1,178,421 in 2018 dollars</b>
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$4,014 in 2018 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$2,535,626 in 2018 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$2,539,640 in 2018 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$3,718,061 per year in 2018 dollars
NOx Removed =		1,789 tons/year
<b>Cost Effectiveness =</b>		<b>\$2,078 per ton of NOx removed in 2018 dollars</b>

## Appendix Table A-3f. Kahe K6 - SCR Costing

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWhs output?  MWhs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,688

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable



## Appendix Table A-3f. Kahe K6 - SCR Costing

**Enter the following design parameters for the proposed SCR:**

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.196 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	15 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>			
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*	<u>Densities of typical SCR reagents:</u> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/ft<sup>3</sup> are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used	Ammonia		

**Enter the cost data for the proposed SCR:**

Desired dollar-year	2018	CEPCI for 2018	603.1	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*			
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh			<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Catalyst cost (CC <sub>replace</sub> )	227.00	Catalyst cost (CC <sub>replace</sub> )	\$ /cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Labor Rate	60.00 \$/hour (including benefits)*			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
Operator Hours/Day	4.00 hours/day*	Operator Hours/Day	4.00 hours/day*			<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

## Appendix Table A-3f. Kahe K6 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Default bank prime rate	

## Appendix Table A-3f. Kahe K6 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	1,516	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	1,243,920	MW/hrs
Estimated Actual Annual MW/hrs Output (Boutput) =		601,781	MW/hrs
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.07	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tpplant) =$	0.484	Fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4238	hours
NOx Removal Efficiency (EF) =	$(NO_{x,in} - NO_{x,out})/NO_{x,in} =$	49.0	percent
NOx removed per hour =	$NO_{x,in} \times EF \times Q_b =$	145.76	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x,in} \times EF \times Q_b \times t_{op})/2000 =$	308.87	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.61	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700)n_{scr} =$	702,117	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	173.00	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (Coalf) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7]/518.6]^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate)/(1/(1 + interest\ rate)^Y - 1)$ , where $Y = H_{catalyst}/(t_{SCR} \times 24\ hours)$ rounded to the nearest integer	0.3111	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x,adj} \times S_{eq} \times (T_{adj}/N_{scr})$	4,058.46	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas}/(16ft/sec \times 60\ sec/min)$	731	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst}/(R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	3	feet

## Appendix Table A-3f. Kahe K6 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	841	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	29.0	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	48	feet

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft <sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_g \times EF \times SRF \times MW_g) / MW_{NO_x} =$	57	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	195	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	26	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	18,800	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate	0.1098

Other parameters	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	817.89	kw

## Appendix Table A-3f. Kahe K6 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$23,093,134</b>	<b>in 2018 dollars</b>

## Appendix Table A-3f. Kahe K6 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$1,117,210 in 2018 dollars
Indirect Annual Costs (IDAC) =		\$2,539,640 in 2018 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$3,656,850 in 2018 dollars</b>
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$115,466 in 2018 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$32,402 in 2018 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$873,807 in 2018 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$95,536 in 2018 dollars
<b>Direct Annual Cost =</b>		<b>\$1,117,210 in 2018 dollars</b>
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$4,014 in 2018 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$2,535,626 in 2018 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$2,539,640 in 2018 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$3,656,850 per year in 2018 dollars
NOx Removed =		309 tons/year
<b>Cost Effectiveness =</b>		<b>\$11,840 per ton of NOx removed in 2018 dollars</b>

**Appendix B:**  
**Hawaiian Electric Regional Haze Visibility Considerations**

**Fifth Factor Considerations for SO<sub>2</sub>, NO<sub>x</sub>, and PM Controls**

AECOM Project Number: 60626547

Prepared for:



PO Box 2750  
Honolulu, HI 96840

Prepared by:



AECOM Technical Services, Inc.  
250 Apollo Drive  
Chelmsford, MA 01824-3627

March 31, 2020

haze precursors for Hawai'i due to the unique NOx haze chemistry and climate, leaving SO<sub>2</sub> as the primary precursor pollutant for haze. Hawaiian Electric requests that the DOH make this proposal to the EPA.

- 5) In the recent past, volcanic activity on Hawai'i Island has produced as much as 2 million tons of SO<sub>2</sub> emissions per year<sup>2,3</sup> (emissions vary yearly), as well as roughly 125,000 tons of NOx emissions per year<sup>4</sup>. These volcanic SO<sub>2</sub> emissions are about three orders of magnitude (approximately 1,000 times) greater than anthropogenic SO<sub>2</sub> emissions. Although the IMPROVE monitors indicate that sulfate haze is the most important haze species, it is evident from monthly haze trends and the likelihood of winds from the volcanic activity reaching the IMPROVE monitors that the overwhelming sulfate haze influence comes from natural sources (i.e., volcanic activity).

The locations of the affected Hawaiian Electric sources and the two national parks are shown in Figure B-1. The remainder of this appendix presents details of the above issues and recommendations for how this information should be considered in selection of facilities for Four-Factor analyses and for evaluating potential pollutant control options.

<sup>2</sup> Information on the volcanic SO<sub>2</sub> emissions in 2014 was provided by the EPA in their SO<sub>2</sub> National Ambient Air Quality Technical Support Document at EPA's 2016 SO<sub>2</sub> NAAQS TSD, at <https://www.epa.gov/sites/production/files/2016-03/documents/hi-epa-tds-r2.pdf>.


<sup>3</sup> Information on 2014-2017 volcanic SO<sub>2</sub> emissions is available in this journal article: Elias T, Kern C, Horton KA, Sutton AJ and Garbeil H. (2018) Measuring SO<sub>2</sub> Emission Rates at Kīlauea Volcano, Hawaii, Using an Array of Upward-Looking UV Spectrometers, 2014–2017. *Front. Earth Sci.* 6:214. doi: 10.3389/feart.2018.00214. <https://www.frontiersin.org/articles/10.3389/feart.2018.00214/full>.

<sup>4</sup> The 125,000 tons per year of NOx assumes NOx emissions rate equals 6% of SO<sub>2</sub> emissions rate. The 6% is derived from worldwide volcanic NOx emissions estimate of 1.0 Teragram ("Tg" – trillion grams)/year ("yr") nitric oxide ("NO") (or 1.5 Tg/yr NO<sub>2</sub>) from <https://www.chemistryworld.com/features/a-volcanic-breath-of-life/3004482.article> and worldwide volcanic SO<sub>2</sub> estimate of 23 Tg/yr from <https://www.nature.com/articles/srep44095>.



Figure B-1:

Location of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas



## 2. EPA Guidance Regarding Considerations of Visibility Impacts

The EPA issued “Guidance on Regional Haze State Implementation Plans for the Second Implementation Period”<sup>5</sup> in August 2019. This guidance allows states to consider, as part of its consideration of emission controls to include for the Second Decadal Review a “5<sup>th</sup> factor” which involves consideration of visibility impacts of candidate control options. A companion document<sup>6</sup> issued in September 2019 that involves the EPA’s visibility modeling results for 2028 is entitled, “Availability of Modeling Data and Associated Technical Support Document for the EPA’s Updated 2028 Visibility Air Quality Modeling”.

On Page 11 of the August 2019 guidance, the EPA states:

*“When selecting sources for analysis of control measures, a state may focus on the PM species that dominate visibility impairment at the Class I areas affected by emissions from the state and then select only sources with emissions of those dominant pollutants and their precursors.” . . .*

<sup>5</sup> Available at [https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019\\_-\\_regional\\_haze\\_guidance\\_final\\_guidance.pdf](https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019_-_regional_haze_guidance_final_guidance.pdf).

<sup>6</sup> Available at [https://www3.epa.gov/ttn/scram/reports/2028\\_Regional\\_Haze\\_Modeling-Transmittal\\_Memo.pdf](https://www3.epa.gov/ttn/scram/reports/2028_Regional_Haze_Modeling-Transmittal_Memo.pdf).

*“Also, it may be reasonable for a state to not consider measures for control of the remaining pollutants from sources that have been selected on the basis of their emissions of the dominant pollutants”*

Further, on Page 36 and 37, the EPA states:

*“Because the goal of the regional haze program is to improve visibility, it is reasonable for a state to consider whether and by how much an emission control measure would help achieve that goal.” . . .*

*“. . . EPA interprets the CAA and the Regional Haze Rule to allow a state reasonable discretion to consider the anticipated visibility benefits of an emission control measure along with the other factors when determining whether a measure is necessary to make reasonable progress.”*

Consequently, the extremely low likelihood for impact to Class I visibility impairment from control of certain facility pollutants and the plant locations relative to the Class I areas is appropriate for consideration when evaluating the need for further control of these emissions for Regional Haze Reasonable Progress.

### **3. Nitrate Haze Composition Analysis**



Nitrate haze composition analyses for the Haleakalā and Hawai‘i Volcanoes National Parks are available at the IMPROVE web site at <http://vista.cira.colostate.edu/Improve/pm-and-haze-composition/>. Figure B-2 provides various charts for the haze species composition at the Haleakalā Crater IMPROVE site, and Figure B-3 provides a time series of stacked bars by species for a recent year at that site. Figures B-4 and B-5 provide similar information for the Hawai‘i Volcanoes IMPROVE site. Note that these figures show information for the worst 20 percent (“%”) impaired days, which is the focus of the RHR for reducing haze. The goal for each decadal review is to track the progress of haze reduction for the worst 20% impaired days; reviewing the composition of haze on these days is a key element in understanding what precursor pollutants to control to achieve the goal.

The data for both National Parks shows that the contribution of nitrates to haze is very low as a percentage of the total, but it is also low as an absolute value for extinction (visibility impairment). The total nitrate haze impairment is approximately 1 inverse megameter (“Mm<sup>-1</sup>”), equivalent to approximately 0.25 deciview (“dv”), or less. This is the impairment at these monitors due to ALL sources, natural and anthropogenic, and as noted below, the volcanic emissions are much greater than the entire state’s anthropogenic NO<sub>x</sub> emissions for recent years with SO<sub>2</sub> volcanic emissions of roughly 2 million tons per year (“TPY”).


The minimal impact of nitrate haze is clearly illustrated in the Hawai‘i National Park monitoring data and is much smaller than found at many monitors in other Class I areas around the country. This is in large part due to the unique chemistry of nitrate haze, as discussed below.

Figure B-2: Charts Showing the Worst 20% Haze Days Multiple-Year Species Composition for the Haleakalā Crater IMPROVE Site

Light Extinction Summary - Most Impaired Days



Most Impaired Days 2007-2018  
Haleakala Crater



Haleakala Crater IMPROVE monitor

Data source for Figures B-2 through B-5: [http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF\\_VisSum](http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF_VisSum).

Figure B-3: Time Series of 2018 Daily Haze Extinction Composition Plots for the Haleakalā Crater IMPROVE Site






Figure B-4: Charts Showing the Worst 20% Haze Days Multiple-Year Species Composition for the Hawai'i Volcanoes IMPROVE Site



**Hawaii Volcanoes NP IMPROVE monitor**

Figure B-5: Time Series of 2018 Daily Haze Extinction Composition Plots for the Hawai'i Volcanoes IMPROVE Site



The nitrate contribution to visibility impairment in the above bar charts is shown as a narrow “red” segment. The small size relative to other constituents clearly shows that nitrate is only a small contributor. Additionally, the Figures B-6 and B-7 below which presents only the ammonium nitrate visibility impairment also shows that nitrates, already small contribution, is trending downward.






Figure B-8: CALPUFF Example Plot of Aerosol Percentage of Total NO<sub>x</sub> Equilibrium





The potential for the formation of haze due to NO<sub>x</sub> emissions is very low in Hawai'i because of the warm weather conditions year-round. This strong dependency of the equilibrium relationship between invisible gaseous HNO<sub>3</sub> and visible NO<sub>3</sub> haze particles as a function of ambient temperature is illustrated in Figure B-8. In Figure B-8, it is evident that for most conditions, the percentage of total nitrate in the form of particulate (NO<sub>3</sub>) is less than 20% for temperatures above approximately 286 degrees Kelvin (approximately 55 degrees Fahrenheit). Temperatures at most locations in Hawai'i rarely get that low and are not that low at any of the Hawaiian Electric plant locations.

This dependency of nitrate haze formation as a function of temperature (and season) for more seasonally-varying locations in the United States is shown in the September 2019 EPA modeling report<sup>2</sup> in Figure B-9 (from Appendix A of that report). This figure shows that the thermodynamics of the nitrate haze equilibrium result in much greater particulate formation in winter versus other seasons for more temperate climates, while NO<sub>x</sub> emissions are expected to be relatively constant over the entire year. This implies that NO<sub>x</sub> emission reductions would only be effective for haze reduction during cold winter months, while consideration of NO<sub>x</sub> emission reductions in other months is relatively ineffective.



Figure B-9: Monthly Variation of Nitrate Particulate Concentrations for Selected IMPROVE Sites from EPA 2019 Modeling Report



additional pollution controls at Hawaiian Electric facilities for Regional Haze progress should be limited to SO<sub>2</sub> for sources on Hawai'i Island.

## 6. Natural Sources of SO<sub>2</sub> From Volcanic Activity

Volcanic activity on the Hawai'i Island represents a unique and challenging complication to understating haze in Hawai'i Class I areas. The Kilauea volcano on Hawai'i Island has been active for several years, and the levels of SO<sub>2</sub> emissions are being monitored by the United States Geological Survey. As shown in Figure B-11<sup>12</sup> (related to the SO<sub>2</sub> National Ambient Air Quality Standards implementation and monitoring), there were over 2 million tons of SO<sub>2</sub> emissions from volcanic activity on Hawai'i Island in the year 2014, compared to roughly 2,000 tons of power plant SO<sub>2</sub> emissions for that year. As noted in a *Frontiers in Earth Science* 2018 article<sup>13</sup>, the volcanic SO<sub>2</sub> emissions have been relatively steady at levels close to 2 million TPY for the period of 2014 to 2017.

The extremely high levels of natural SO<sub>2</sub> emissions present a significant challenge for defining "impaired" haze days because the same pollutant (i.e., SO<sub>2</sub>) is emitted by volcanic activity and the power plants and other combustion sources. Therefore, the RHR glidepath for the two Class I areas in Hawai'i is difficult to establish if naturally-caused haze is to be excluded from the analysis.

There appears to be very little anthropogenic haze impairment remaining at Haleakalā National Park because there are very few sources on Maui upwind of the park and there are no land masses upwind of Maui for thousands of kilometers. For Hawai'i Island, the natural sources of SO<sub>2</sub> are part of (or adjacent to) the park, so they are likely to be a large and continuous source of naturally-caused haze.

Even the anthropogenic sources (from power plants) are projected to be phased out well before the end point of the RHR (i.e., 2064) by Hawai'i's State Renewable Portfolio Standards Law ("RPS") implementing requirements to convert 100% of the state's electrical generation to renewable energy sources. This RPS law (Hawai'i Revised Statute §269-92) will substantially reduce emissions of haze precursors by 2045. Further details of the past and future benefits of the RPS requirements are detailed in separate Appendix C.

<sup>12</sup> <https://www.epa.gov/sites/production/files/2016-03/documents/hi-epa-tds-r2.pdf>.

<sup>13</sup> Elias, T., C. Kern, K. Horton, A. Sutton, and H. Garbeil, 2018. Measuring SO<sub>2</sub> Emission Rates at Kilauea Volcano, Hawai'i, Using an Array of Upward-Looking UV Spectrometers, 2014–2017. *Front. Earth Sci.* 6:214. doi: 10.3389/feart.2018.00214. <https://www.frontiersin.org/articles/10.3389/feart.2018.00214/full>.

Figure B-10: Geography of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas, with Wind Roses





Figure B-11: Geography of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas, with Wind Roses



## 7. Conclusions

The state of Hawai'i is isolated from all other states and has very unique regional haze issues due, in part, to its tropical climate, the prevalent trade winds, very large natural emissions of haze precursors, and statewide commitment to renewable energy.

- Emission sources on Oahu and Maui are downwind of Hawai'i's Class I areas and do not contribute to haze issues, such that additional emission controls would not contribute to further reasonable progress at either of Hawai'i's Class I area National Parks. This is consistent with the EPA's First Decadal Review findings.
- Additionally, NOx emissions do not significantly contribute to haze in Hawai'i due the nitrate chemistry and Hawai'i's warm climate, and additional NOx controls would likewise not contribute to further reasonable progress. Therefore, NOx should not be regulated as a contributing precursor to haze in Hawai'i; especially from Oahu and Maui sources that are downwind of the parks. If they are reviewed as precursors, consideration should be given to their insignificant contribution when evaluating possible controls.
- Direct PM emissions constitute a very small portion of the haze associated with the worst 20% haze days in the Hawai'i Class I areas. Furthermore, significant portions of the observed haze in the categories of elemental carbon, soil, and coarse mass are due to volcanic emissions. Therefore, further PM controls on power plant sources would not have a significant benefit for visibility at these Class I areas.
- For the above reasons, the only pollutant that should be considered for possible haze controls in the state of Hawai'i is SO<sub>2</sub> which is consistent with the findings of the First Decadal Review. Furthermore, the only Hawaiian Electric sources to be considered for a four factor analysis for SO<sub>2</sub> should be those that are predominantly upwind of a Class I area which include only the Puna and Kanoiehua-Hill Generating Stations on Hawai'i Island.
- Hawai'i's Class I area haze impacts are principally due to natural sources. Volcanic emissions of precursor SO<sub>2</sub> during the 2014-2017 period of analysis were three orders of magnitude greater than the anthropogenic emissions on Hawai'i Island. Volcanic NOx emissions were about three times greater than all the state's NOx emissions. Since these natural emissions are the principal cause of haze at the two Class I areas in the state and are difficult to distinguish from the relatively small amount of anthropogenically-caused haze, photochemical grid modeling is not practical or even needed. The definition of "impaired days" for Hawai'i Volcanoes National Park as referenced in some of the figures in this report is uncertain due to the overwhelming influence of natural emissions of SO<sub>2</sub>.
- For Haleakalā National Park, with the lack of upwind anthropogenic sources, it could be reasonably concluded that natural conditions are already attained, and no further Reasonable Progress modeling (or controls) is needed. For Hawai'i Volcanoes National Park, the only United

States anthropogenic potential sources are those upwind of the park on Hawai'i Island; all other sources in the state are not contributing to haze at the Class I areas.

- Implementation of Hawai'i's RPS (discussed in detail in Appendix C) will provide a dramatic reduction of virtually all power plant haze-causing emissions in the state of Hawai'i well before the year 2064. This Hawai'i state law established enforceable requirements that a certain percentage of electricity must be generated from renewable energy sources by the end of identified benchmark years leading to 100% renewable energy by 2045. The interim targets are 30 percent by 2020, 40 percent by 2030, and 70 percent by 2040 which provide an RPS "glide path" for EGUs that mirrors the RHR visibility improvement glide path for the next few decades. No separate new regional haze measures for EGUs are needed to assure reasonable progress for this decadal period.

Plans for renewable energy sources, the likely reduction in utilization of fossil-fueled electric generation in this interim period, the unique climate and wind patterns, and the difficulty of addressing the high volcanic emissions should be considered in the current planning for the Second Decadal Review process for the state of Hawai'i.

**Appendix C:  
Hawai'i's Renewable Portfolio Standards ("RPS")  
Contribution to Regional Haze Progress**

AECOM Project Number: 60626547

Prepared for:



**Hawaiian  
Electric**

PO Box 2750  
Honolulu, HI 96840

Prepared by:

**AECOM**

AECOM Technical Services, Inc.  
500 West Jefferson, Suite 1600  
Louisville, KY 40202

March 30, 020

## **Hawai'i's Renewable Portfolio Standards ("RPS") Contribution to Regional Haze Progress**

### **1. Executive Summary**

Hawai'i's ongoing conversion of fossil-fueled electric generation to renewable energy sources as mandated by the Hawai'i Revised Statute ("HRS") §269-92 Renewable Portfolio Standards ("RPS") is significantly decreasing emissions from Hawai'i's electric generating stations. Past actual and expected future decreases in usage of fossil-fueled electric generating units ("EGUs") are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the Regional Haze Rule ("RHR"). Emissions from the majority of Hawai'i's electric generating plants are not a significant contributor to haze at Class I areas (for reasons explained in Appendix B). Further, their very low impact is being mitigated under the RPS state law. This rate of progress from the RPS law can be relied upon for further emissions reductions from EGUs in the coming years and thus separate further requirements for EGU controls under the RHR are not needed at this time. The following sections of this appendix provide a background on the RPS requirements and progress to date, and high confidence of continued progress consistent with the goals of the RHR.

### **2. Renewable Portfolio Standards**

In 2002 the Hawai'i RPS legislation set voluntary goals for converting the islands' electrical generation from fossil fuels to renewable energy. In 2005, the RPS was set into law as binding requirements for Hawai'i electric utility companies. The law requires that electric utilities in Hawai'i achieve 100% of their electric generation from renewable energy sources by 2045 and meet a series of interim limits for the percentages of their electricity sales that must be provided by renewables (e.g., 30% renewable by 2020, and 40% by 2030, etc.). Renewable energy sources such as solar, hydro and wind energy have no direct emissions. Others such as biomass combustion have significantly lower emissions (especially sulfur dioxide ("SO<sub>2</sub>")) than fossil fuels. Consequently, the RPS law results in steady progress in emissions reductions from electric utilities creating, in effect, an "RPS glidepath" providing dramatic reduction of electric generating unit emissions by mid-century.

The RPS program, although not directly related to the Regional Haze Rule, is providing emissions reductions and improvements to air quality consistent with the goals of the RHR.

Table C-1 shows the interim and final RPS for EGUs along with the Regional Haze adjusted glidepath emissions reductions goals<sup>1</sup>.

<sup>1</sup> Regional Haze Adjusted Glidepath assumes consistent reductions in haze precursor emissions impacts from all U.S. anthropogenic sources from the baseline average of 2000-2004 to zero impacts in 2064, i.e. natural background.



**Table C-1 Comparison of RPS and Regional Haze Glidepaths**

Year	RPS Renewable Requirement % of Electricity Sales	Regional Haze Glidepath % Visibility Improvement
2010	10%	8%
2015	15%	17%
2020	30%	25%
2030	40%	42%
2040	70%	58%
2045	100%	67%
2065		100%

This table illustrates that the emissions reductions from EGUs under the RPS are similar to the visibility goals of the Regional Haze Program in the intermediate years and become much more stringent in later years. The RPS seeks to achieve 100% renewable electrical supply by 2045, which is twenty years earlier than the RHR target of 2065 to achieve natural background visibility in Class I areas.

**3. Historical RPS Achievement**


Hawaiian Electric<sup>2</sup>, and other electric utility providers in Hawai‘i, have made excellent progress in developing and supporting renewable energy sources. Figure C-1 below shows the percentage of all electrical sales statewide provided by renewable sources since the RPS inception (green columns).<sup>3</sup> It also shows as a line illustrating the RPS interim standards (with proportional progress assumed between RPS milestone years). This figure illustrates that Hawai‘i EGUs have made significant progress to date and have been ahead of the RPS interim targets.

Hawaiian Electric represents majority of Hawai‘i’s electric generation. Figure C-2 shows the renewable energy source percentages for this same period specifically for Hawaiian Electric. The data follows the same trend as the statewide figures and this figure also shows a breakdown of the type of renewable energy technology used.

<sup>2</sup> “Hawaiian Electric” or the “Company” refers to Hawaiian Electric Company, Inc. (or “HE”), Hawai‘i Electric Light Company, Inc. (or “HL”) and/or Maui Electric Company, Limited (or “ME”). On December 20, 2019, the State of Hawai‘i Department of Commerce and Consumer Affairs (“DCCA”) approved Hawaiian Electric Company, Inc., Hawai‘i Electric Light Company, Inc. and Maui Electric Company, Limited’s application to do business under the trade name “Hawaiian Electric” for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.


<sup>3</sup> Hawai‘i Public Utility Commission (PUC), “Report to the 2019 Legislature on Hawai‘i’s Renewable Portfolio Standards”, Dec. 2018 [https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report\\_FINAL.pdf](https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report_FINAL.pdf).

**Figure C-1 Statewide Renewable Portfolio Progress**



Source: [https://puc.Hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report\\_FINAL.pdf](https://puc.Hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report_FINAL.pdf)

**Figure C-2 Hawaiian Electric Companies RPS Achievement by Generation Technology<sup>4</sup>**



<sup>4</sup> PUC Dec. 2018 Report, Figure 2, page 7.

#### 4. Future RPS Achievability

To date, Hawai'i's electric utilities have generally met or exceeded the RPS requirements. Continued progress consistent with RPS is expected to continue. Projects and plans are already in place to continue this rapid RPS shift to renewable energy sources for the period of interest of the next decadal period of the RHR. In its December 2018 report to the state legislature, the Hawai'i Public Utility Commission ("PUC") indicated that *"future renewable projects under construction or planned for the HECO Companies and KIUC should ensure that the state remains on track for meeting the 2020 and 2030 RPS targets."*<sup>5</sup>

Figure C-3 below shows Hawaiian Electric's projection of percent renewables through 2030 presented in the December 2018 PUC report. This projected progress remains well ahead of the RPS requirements which also is ahead of the requirements of the Regional Haze glidepath goals.

**Figure C-3 Hawaiian Electric Companies RPS Expectation by 2030 Technology<sup>6</sup>**




Table C-2 below shows the past actual and future forecast for Hawaiian Electric from the previous two figures (from PUC's 2018 report) together with the requirements of RPS and the goals of the RHR. Hawaiian Electric's renewable energy progress and forecast is ahead of both programs. Additionally, Hawaiian Electric has an internal target to achieve 100% renewables by 2040, five years ahead of the RPS requirement and 25 years ahead of the RHR goals.

<sup>5</sup> PUC Dec. 2018 Report, page 2.


<sup>6</sup> PUC Dec. 2018 Report, Figure 2, page 16.

**Table C-2 Comparison of RPS and Regional Haze Glidepaths**

Year	RPS Renewable Requirement % of Electricity Sales	Regional Haze Glidepath % Visibility Improvement	Hawaiian Electric % Renewables
2010	10%	8%	9.5% (actual)
2015	15%	17%	23.2% (actual)
2020	30%	25%	31.9% (projection)
2030	40%	42%	47.3% (projection)
2040	70%	58%	100% (goal)
2045	100%	67%	100% (goal)

Hawaiian Electric’s latest projections show an even more rapid shift to renewable energy sources than forecasted in 2018. This will continue to decrease Hawaiian Electric facility emissions. For example, Figure C-4 illustrates Hawaiian Electric’s latest forecast emissions trends for total nitrogen oxides (“NOx”), sulfur dioxide (“SO<sub>2</sub>”) and Particulate Matter (“PM<sub>10</sub>”) emissions (in tons per year “TPY”) from the six power plants (Waiau and Kahe Generating Stations on Oahu, Kahului and Maalaea on Maui, and Kanoiehua-Hill and Puna on Hawai’i) requested to conduct Four-Factor Analyses by the Hawai’i Department of Health (“DOH”). These dramatic emissions decreases illustrate the expected progress from RPS alone – without any additional RHR measures. The forecast emissions shown in Figure C-4 was derived from recent fuel consumption projections based on the resource plans and planning assumptions submitted to the PUC as part of Hawaiian Electric’s 2016 Power Supply Improvement Plan (“PSIP”) which was accepted by the PUC and recent renewable project applications.

**Figure C-4 Hawaiian Electric NOx Forecast Emissions**



The emissions reduction is quite rapid and most of the projected reduction by Hawaiian Electric are expected to be in place prior to 2028, the next Regional Haze planning milestone.

Although this projection is based on reasonable assumptions, plans are subject to change as there is some uncertainty regarding future projections and forecast assumptions. For this reason and due to energy security issues, Hawaiian Electric cannot commit to specific dates for particular emissions reductions or final retirements of any specific generating station. Nevertheless, Hawaiian Electric is on an aggressive path to end fossil-fueled generation and replace it with renewable energy sources – especially during this next decadal period. This progress should be sufficient for Hawaiian Electric’s contribution to the state’s efforts regarding reasonable progress of the RHR for the current Regional Haze decadal review.

## **5. Reliance on RPS for this Regional Haze Decadal Review**

The RPS requirements are part of Hawai’i state law. An electric utility failing to meet the RPS requirements is subject to enforcement action and penalties by the PUC unless the PUC determines the electric utility is unable to meet the RPS due to factors beyond its reasonable control. However, given the progress to date of the Hawai’i electric utilities acquiring renewable generation and expectations for planned renewable projects in the near future, it is reasonable to expect that RPS will result in continued steady progress, at least through 2030.

The DOH can rely on the RPS for regional haze progress without having to impose separate RHR requirements in facility permits. This is supported by EPA guidance which states that “Enforceable requirements are one reasonable basis for projecting a change in operating parameters and thus emissions; energy efficiency, renewable energy, or other such programs where there is a documented commitment to participate and verifiable basis for quantifying any change in future emissions due to operational changes may be another.”<sup>7</sup>

Even if progress were slower than currently expected, it would not prevent the RPS from being relied upon as the major EGU contribution to meeting Hawai’i’s regional haze goals. The time perspective of the Regional Haze Program is long. Making wise decisions that help achieve the long-term goals is important. Hawai’i electric utilities are currently focusing resources on advancing renewable energy projects that will permanently displace fossil-fueled unit generation and fossil-fueled combustion emissions. These ongoing RPS efforts help achieve the long-term goals of the RHR and provide permanent emissions reductions and other societal benefits. In contrast, new investments in conventional emissions controls on aging fossil-fueled units provide only modest short-term benefits impose additional costs on rate payers and will have no lasting value when those units are deactivated or retired.

<sup>7</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period – August 2019 at page 17. [https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019\\_-\\_regional\\_haze\\_guidance\\_final\\_guidance.pdf](https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019_-_regional_haze_guidance_final_guidance.pdf).

## **Comments on Four – Factor Analysis**

DAVID Y. IGE  
GOVERNOR OF HAWAII



STATE OF HAWAII  
DEPARTMENT OF HEALTH  
P.O. Box 3378  
HONOLULU, HAWAII 96801-3378

July 8, 2020

BRUCE S. ANDERSON, Ph.D.  
DIRECTOR OF HEALTH

In reply, please refer to:  
File:

20-317E CAB  
File No. 0240

Ms. Karen Kimura  
Director, Environmental Division  
Hawaiian Electric  
P.O. Box 2750  
Honolulu, Hawaii 96840-0001

Dear Ms. Kimura:

**Subject: Four-Factor Analysis for Regional Haze  
Covered Source Permit No. 0240-01-C  
Hawaii Electric Company, Inc. (HECO)  
Kahe Generating Station  
Located At: 92-200 Farrington Highway, Waianae, Oahu**

The Department of Health, Clean Air Branch (CAB) acknowledges receipt of the subject four-factor analysis on April 6, 2020 and has determined the analysis to be incomplete. Please refer to the attached comments for completing the four-factor analysis. Pursuant to 40 Code of Federal Regulations (CFR) §51.308 (d)(1) of the Regional Haze Rule (RHR), the four-factor analysis will be used to establish control measures and reasonable progress goals for Hawaii's Regional Haze State Implementation Plan (RH-SIP).

The CAB requests that you address the comments and resubmit the subject four-factor analysis with the appropriate revisions by **August 10, 2020**.

If there are any questions regarding this matter, please contact Mr. Mike Madsen of my staff at (808) 586-4200.

Sincerely,

MARIANNE ROSSIO, P.E.  
Manager, Clean Air Branch

MM:rkb

Attachment

c: Debra Miller, National Park Service, Air Resources Division  
Don Shepherd, National Park Service, Air Resources Division  
Melanie Peters, National Park Service, NPS-Air

## Attachment I

After our review and feedback from the National Park Service (NPS) and Environmental Protection Agency (EPA), Region 9, we have the following comments on the four-factor analysis for Boilers K-1 through K-6:

- a. The cost per ton of sulfur dioxide (SO<sub>2</sub>) removed was provided for switching fuel from residual low sulfur fuel oil No. 6 to ultralow sulfur diesel (ULSD); however, there was no cost analysis provided for nitrogen oxide NO<sub>x</sub> or particulate matter less than ten (10) microns in diameter (PM<sub>10</sub>). Please provide the cost per ton of NO<sub>x</sub> and PM<sub>10</sub> reduced for switching from residual low sulfur fuel oil No. 6 to ULSD. Also, provide the cost per total combined tons of SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> reduced for the fuel switch.
- b. Section 3.2.2 of the analysis states that fuel switching could be implemented within two (2) to three (3) years. Other facilities have reported that a fuel switch could be accomplished within as short as one (1) year. The amount of time specified for switching fuels at the Kahe Generating Station seems excessive. Please explain the reason for the long compliance time and whether there are ways to reduce the time for implementing this control measure.
- c. Section 3.2.3 states that fuel switching to a lower sulfur fuel will increase the cost of electricity. Although the topic was discussed in the technical support document for the Regional Haze Federal Implementation Plan, it is not something we can generally take into consideration for the regional haze four-factor analysis in this second planning period.
- d. Provide documentation of the internal engineering study in 2012 identifying a circulating dry scrubber (CDS) as the best option for controlling SO<sub>2</sub> emissions from the boilers.
- e. Section 3.2.4 states that the remaining useful life of the boilers do not impact the annualized cost of controls because the useful lives of the boilers are assumed to be at least as long as the capital cost recovery period, which is fifteen (15) years. This section of the analysis also indicates that, in HECO's Power Supply Improvement Plan (PSIP), HECO intends to retire Kahe Boilers 5 and 6 in 2028, Kahe Boilers 1 and 2 in 2035, and Kahe Boilers 3 and 4 in 2039. Please note that the PSIP is not federally enforceable. In the situation of an enforceable requirement for the source to cease operation before the end of the useful life of the controls under consideration, EPA guidance for the second planning period allows the use of the enforceable shutdown date as the end of the remaining useful life. This measure would need to be included in the RH-SIP and/or be federally enforceable. Please see 40 CFR 51.308(f)(2). If HECO agrees to make a commitment to the shutdowns through federally enforceable permit limits, the remaining useful life assumed for the control measure is acceptable. The federally enforceable shutdowns could also be used as control measures for showing reasonable progress if the shutdowns occur in the second regional haze planning period (2018-2028). In the situation where an enforceable shutdown date does not exist, the remaining useful life of a control under consideration should be the full period of the useful life of that control as recommended by EPA's Control Cost Manual (CCM). The current (2019) CCM specifies a remaining useful life for SCR of thirty (30) years at power plants and twenty (20) years for other sources.
- f. The current prime interest rate (currently at 3.25%) should be used to estimate the costs of additional emission controls, rather than seven percent seven (7%) used in the analysis. Please see the following site for the current bank prime rate: <https://www.federalreserve.gov/releases/h15/>. The prime interest rate has not been seven percent (7%) or higher in the past twelve (12) years. A three (3%) interest rate may also be considered.



## Attachment I

- g. Fuel costs are provided in 2019 dollars and the control costs are in 2018 dollars. Please provide control costs in 2019 dollars.
- h. Flue gas recirculation (FGR) is listed as a technically feasible control option; however, the cost effectiveness of FGR was not evaluated. Please evaluate the cost effectiveness of FGR for reducing NO<sub>x</sub> emissions from the boilers and provide the results in Table 4-3.
- i. Please add the combination of FGR plus low NO<sub>x</sub> burner (LNB) and overfire air (OFA) to Table 4.2, evaluate the cost effectiveness of this combined NO<sub>x</sub> control measure for the boilers, and provide the results in Table 4-3.
- j. Selective non-catalytic reduction (SNCR) is listed as a technically feasible control option; however, the cost effectiveness of SNCR was not evaluated. Please evaluate the cost effectiveness of SNCR for reducing NO<sub>x</sub> emissions from the boilers and provide the results in Table 4-3.
- k. Please add the combination of SNCR plus LNB and OFA to Table 4.2, evaluate the cost effectiveness of this combined NO<sub>x</sub> control measure for the boilers, and provide the results in Table 4-3.
- l. Please add the combination of selective catalytic reduction (SCR) plus LNB and OFA to Table 4.2, evaluate the cost effectiveness of this combined NO<sub>x</sub> control measure for the boilers, and provide the results in Table 4-3.
- m. The NO<sub>x</sub> output rate of 0.1 pound per million British thermal unit (lb/MMBtu) was assumed for SCR. It is generally assumed that new SCR can achieve 0.05 lb/MMBtu (or lower) on an annual basis. The current (2019) CCM states that a 0.05 lb/MMBtu outlet NO<sub>x</sub> rate based on a 30-day (boiler operating) average should be obtainable by a power plant boiler with an SCR system.
- n. In the control cost worksheets, a retrofit factor of 1.5 was selected from a recommended range between 0.8 and 1.5 for retrofitting the boilers with SCR. Please note that the CCM for SCR allows a retrofit factor of greater than one (1) provided the reasons for using the higher retrofit factor are appropriate and fully documented. A note in the control cost spreadsheet indicated that a retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location. For selecting a retrofit factor of greater than one (1), please provide additional detail on the complexities involved for retrofitting the boilers with SCR at the Kahe Generating Station.
- o. Appendix B of the four-factor analysis indicated that, in the recent past, Hawaii's volcanic SO<sub>2</sub> emissions are about 1,000 times greater than anthropogenic SO<sub>2</sub> emissions and volcanic activity in Hawaii produced as much as two (2) million tons of SO<sub>2</sub> per year. Please note that SO<sub>2</sub> emissions have significantly decreased after the Kilauea eruption ended in September 2018. The United States Geological Survey (USGS) stated, that in 2019, the summit is the only source releasing enough SO<sub>2</sub> emissions to be quantified using ultra-violet spectroscopy. Preliminary USGS results for 2019 indicate an average summit daily SO<sub>2</sub> emission rate of about 43 tons and an annual total SO<sub>2</sub> emission rate of about 17,119 tons which is far lower than the two (2) million tons of SO<sub>2</sub> reported to be emitted by the volcano in Appendix B. Note that the total combined SO<sub>2</sub> emissions from point sources screened for four-factor analyses were about 18,058 tons per year in 2017 which is 939 tons higher than preliminary USGS estimates of volcanic SO<sub>2</sub> for 2019. Since Kilauea eruption activity ended in September 2018, point sources screened for four-factor analysis now play a more significant part in SO<sub>2</sub> visibility impacts.

Attachment I

- p. Appendix B of the four-factor analysis also noted that volcanic activity on Hawaii Island is the largest source of NO<sub>x</sub> in the state based on a NO<sub>x</sub> emission estimate for the Kilauea Volcano of roughly 125,000 tons per year. Data, indicating worldwide volcano NO<sub>x</sub> and SO<sub>2</sub> emissions of 1.5 and 23 teragrams, respectively, was used for the estimate. It was stated that the NO<sub>x</sub> was likely caused by thermal contact of air with lava. Based on the NO<sub>x</sub>/SO<sub>2</sub> ratio using the worldwide numbers, it was then assumed that NO<sub>x</sub> emissions from Kilauea Volcano are about 6% of the volcano's total SO<sub>2</sub> emissions. It was also assumed that Hawaii volcanic activity emits approximately two (2) million tons per year of SO<sub>2</sub>. Please note that the global ratio of NO<sub>x</sub>/SO<sub>2</sub> is likely not appropriate to use for estimating NO<sub>x</sub> emissions from the Kilauea Volcano. Interagency Monitoring of Protected Visual Environments data shows that annual light extinction from ammonium nitrates for the most impaired days at Haleakala National Park over the current visibility period (2014-2018 when the volcano was erupting) are higher than those at Hawaii Volcanoes National park where the volcano is located. Also, while volcanic SO<sub>2</sub> emissions were reported to be as high as two (2) million tons per year when the Kilauea Volcano was erupting, SO<sub>2</sub> emissions have significantly decreased after the Kilauea eruption ended in September 2018. There currently is no lava in the Kilauea summit crater. Instead, a lake of water has formed in the Kilauea crater after the volcano stopped erupting towards the end of 2018. Please refer to: <https://earthobservatory.nasa.gov/images/146687/a-new-lakewater-not-lavaon-kilauea>.
- q. In the four-factor analysis, HECO states that no reduction measures in addition to Hawaii's Renewable Portfolio Standards (RPS) are proposed to meet the RHR requirements. While provisions mandated by the RPS are subject to enforcement action by the Hawaii Public Utilities Commission, these are state only enforceable requirements which are not federally enforceable under the federal Clean Air Act. The RHR requires federally enforceable emission limits and/or RH-SIP approved rule provisions in establishing the long-term strategy for regional Haze. As an option, HECO may propose caps for the emissions of visibility impairing pollutants (SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub>) based on anticipated emission reductions from the RPS as a reasonable progress measure that could be incorporated into permits. These emission caps would need to occur in the second planning period (2018-2028) in order to be credited as a control measure for reasonable progress. Additional measures for showing reasonable progress include federally enforceable plant shutdowns as described in comment e above. In essence, HECO could propose: 1) federally enforceable conditions for retiring units during the second implementation planning period (2018-2028) and include those units and retirement dates in the four factor analyses along with a four factor analysis of the remaining equipment; 2) propose federally enforceable emission control measures such as fuel switching or add-on controls with the associated pollutant reductions, or 3) propose federally enforceable permit limits such as emission caps, for operational flexibility, or hour restrictions with the associated compliance dates or any combination of 1, 2, or 3 above.

## **Responses to Comments**

# Attachment 1

## Responses to the DOH's July 8, 2020 Comments

### Regional Haze Four-Factor Analysis, Dated April 6, 2020

#### Kahe Generating Station

#### Hawaiian Electric Company, Inc.

- a. The cost per ton of sulfur dioxide (SO<sub>2</sub>) removed was provided for switching fuel from residual low sulfur fuel oil No. 6 to ultralow sulfur diesel (ULSD); however, there was no cost analysis provided for nitrogen oxide (NO<sub>x</sub>) or particulate matter less than ten (10) microns in diameter (PM<sub>10</sub>). Please provide the cost per ton of NO<sub>x</sub> and PM<sub>10</sub> reduced for switching from residual low sulfur fuel oil No. 6 to ULSD. Also, provide the cost per total combined tons of SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> reduced for the fuel switch.

**Response** – The requested costs will be provided within the updated four-factor analysis report.

- b. Section 3.2.2 of the analysis states that fuel switching could be implemented within two (2) to three (3) years. Other facilities have reported that a fuel switch could be accomplished within as short as one (1) year. The amount of time specified for switching fuels at the Kahe Generating Station seems excessive. Please explain the reason for the long compliance time and whether there are ways to reduce the time for implementing this control measure.

**Response** - Two to three years is a realistic estimate of the timeframe for fuel switching because of several factors: 1) Hawaiian Electric generally requests that the State of Hawai'i Public Utilities Commission (Commission) approve fuel contracts and issue its Decision and Order within one year following the filing of the application to the Commission; 2) Hawaiian Electric needs to go through a formal process to request bids from fuel suppliers; 3) Negotiations with the fuel supplier can take up to four months; 4) The schedule for any required infrastructure modifications are dependent on the extent on the required changes; 5) If fuel switching is required at other Hawaiian Electric facilities, the type of fuel to be switched and used, the effect on the fuel supply, and ability of the local refinery to accommodate the change may significantly be impacted; and 6) Imported fuel may be required if there is a lack of local supply.

- c. Section 3.2.3 states that fuel switching to a lower sulfur fuel will increase the cost of electricity. Although the topic was discussed in the technical support document for the Regional Haze Federal Implementation Plan, it is not something we can generally take into consideration for the regional haze four-factor analysis in this second planning period.

**Response** – Fuel costs are directly reflected in customer electricity rates on all islands Hawaiian Electric provides electricity; this is an important cost to the community that must be considered. Hawaiian Electric encourages the DOH to use the flexibility in the EPA's SIP guidance<sup>1</sup> in the selection of control measures necessary to make reasonable progress and to consider additional factors when developing the long-term strategy to improve visibility at Class I areas. Also, note that given the fragile condition of the state's fuel supply and because of Hawaiian Electric's position as a major customer in the market, a fuel supply change could have sweeping effects on the island's market that may not be apparent from the cost estimates associated with Hawaiian

<sup>1</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, August 2019, EPA-457/B-19-003.

Electric such as the ability of the local refinery to accommodate the change and potential need for imported fuel.. Hawaiian Electric suggests that the DOH needs to take these factors into account in its decision-making process.

- d. Provide documentation of the internal engineering study in 2012 identifying a circulating dry scrubber (CDS) as the best option for controlling SO<sub>2</sub> emissions from the boilers.

**Response** – Key excerpts from the July 10, 2012 Mercury and Air Toxics Standards (MATS)/National Ambient Air Quality Standards (NAAQS) Environmental Controls Study for Kahe Generating Station Units 1-6 prepared by Black & Veatch are included with this Response to Comments attachment as Attachment 5.

- e. Section 3.2.4 states that the remaining useful life of the boilers do not impact the annualized cost of controls because the useful lives of the boilers are assumed to be at least as long as the capital cost recovery period, which is fifteen (15) years. This section of the analysis also indicates that, in HECO's Power Supply Improvement Plan (PSIP), HECO intends to retire Kahe Boilers 5 and 6 in 2028, Kahe Boilers 1 and 2 in 2035, and Kahe Boilers 3 and 4 in 2039. Please note that the PSIP is not federally enforceable. In the situation of an enforceable requirement for the source to cease operation before the end of the useful life of the controls under consideration, EPA guidance for the second planning period allows the use of the enforceable shutdown date as the end of the remaining useful life. This measure would need to be included in the RH-SIP and/or be federally enforceable. Please see 40 CFR 51.308(f)(2). If HECO agrees to make a commitment to the shutdowns through federally enforceable permit limits, the remaining useful life assumed for the control measure is acceptable. The federally enforceable shutdowns could also be used as control measures for showing reasonable progress if the shutdowns occur in the second regional haze planning period (2018-2028). In the situation where an enforceable shutdown date does not exist, the remaining useful life of a control under consideration should be the full period of the useful life of that control as recommended by EPA's Control Cost Manual (CCM). The current (2019) CCM specifies a remaining useful life for SCR of thirty (30) years at power plants and twenty (20) years for other sources.

**Response** - The capital recovery period will be increased to the CCM recommended value of 30-years for boiler controls (combustion controls, SCR, SO<sub>2</sub> post-combustion controls, and PM post-combustion controls). The capital cost recovery period updates will be included in the updated four-factor analysis report. Hawaiian Electric is still evaluating the retirement of its sources as part of the Regional Haze program, but due to the complexity of retirement factors Hawaiian Electric may provide additional information in the updated four-factor analysis report.

- f. The current prime interest rate (currently at 3.25%) should be used to estimate the costs of additional emission controls, rather than seven percent seven (7%) used in the analysis. Please see the following site for the current bank prime rate: <https://www.federalreserve.gov/releases/h15/>. The prime interest rate has not been seven percent (7%) or higher in the past twelve (12) years. A three (3%) interest rate may also be considered.

**Response** – Hawaiian Electric will continue to use an interest rate of 7% because it is more appropriate than the prime interest rate for the four-factor analyses. The cost analyses follow the Office of Management and Budget (OMB) and EPA Air Pollution Cost Control Manual (CCM) guidance by using an interest rate of 7% for evaluating the cost of capital recovery. The EPA cost manual states that:

*"when performing cost analysis, it is important to ensure that the correct interest rate is being used. Because this Manual is concerned with estimating private costs, the correct interest rate to use is the nominal interest rate, which is the rate firms actually face." <sup>2</sup>*

For these analyses, which evaluates equipment costs that may take place more than five (5) years into the future, it is important to ensure that the selected interest rate represents a longer-term view of corporate borrowing rates. The CCM cites the bank prime rate as one indicator of the cost of borrowing as an option for use when the specific nominal interest rate is not available. Over the past 20 years, the annual average prime rate has varied from 3.25% to 9.23%, with an overall average of 4.86% over the 20-year period.<sup>3</sup> However, the EPA CCM cautions the use of bank prime rates and states:

*"Analysts should use the bank prime rate with caution as these base rates used by banks do not reflect entity and project specific characteristics and risks including the length of the project, and credit risks of the borrowers." <sup>4</sup>*

For this reason, the prime rate should be considered the low end of the range for estimating capital cost recovery. Actual borrowing costs experienced by firms are typically higher.

For economic evaluations of the impact of federal regulations, the OMB uses an interest rate of 7%. OMB Circular A-4 states:

*"As a default position, OMB Circular A-94 states that a real discount rate of 7 percent should be used as a base-case for regulatory analysis. The 7 percent rate is an estimate of the average before-tax rate of return to private capital in the U.S. economy. It is a broad measure that reflects the returns to real estate and small business capital as well as corporate capital. It approximates the opportunity cost of capital, and it is the appropriate discount rate whenever the main effect of a regulation is to displace or alter the use of capital in the private sector." <sup>5</sup>*

The above statement is confirmed in the EPA CCM with the following statement:

*"When assessing the societal effect of regulations, such as for EPA rulemakings that are economically significant according to Executive Order 12866, analysts should use the 3% and 7% real discount rates as specified in the U.S. Office of Management and Budget (OMB) 's Circular A-4. The 3% discount rate represents the social discount rate when*

<sup>2</sup> Sorrels, J. and Walton, T. "Cost Estimation: Concepts and Methodology," *EPA Air Pollution Control Cost Manual*, Section 1, Chapter 2, p. 15. U.S. EPA Air Economics Group, November 2017.

[https://www.epa.gov/sites/production/files/2017-12/documents/epaccmcostestimationmethodchapter\\_7thedition\\_2017.pdf](https://www.epa.gov/sites/production/files/2017-12/documents/epaccmcostestimationmethodchapter_7thedition_2017.pdf)

<sup>3</sup> Board of Governors of the Federal Reserve System Data Download Program, "H.15 Selected Interest Rates," accessed April 16, 2020.

<https://www.federalreserve.gov/datadownload/Download.aspx?rel=H15&series=8193c94824192497563a23e3787878ec&filetype=sheet&label=include&layout=seriescolumn&from=01/01/2000&to=12/31/2020>

<sup>4</sup> Sorrels, J. and Walton, T. "Cost Estimation: Concepts and Methodology," *EPA Air Pollution Control Cost Manual*, Section 1, Chapter 2, p. 16. U.S. EPA Air Economics Group, November 2017.

[https://www.epa.gov/sites/production/files/2017-12/documents/epaccmcostestimationmethodchapter\\_7thedition\\_2017.pdf](https://www.epa.gov/sites/production/files/2017-12/documents/epaccmcostestimationmethodchapter_7thedition_2017.pdf)

<sup>5</sup> OMB Circular A-4, <https://www.whitehouse.gov/sites/whitehouse.gov/files/omb/circulars/A4/a-4.pdf> - "

consumption is displaced by regulation and the 7% rate represents the social discount rate when capital investment is displaced." <sup>6</sup>

- g. Fuel costs are provided in 2019 dollars and the control costs are in 2018 dollars. Please provide control costs in 2019 dollars.

**Response** – The Chemical Engineering Plant Cost Index (CEPCI) for 2019 equals 607.5 which represents a 0.7% increase in cost from 2018. The control costs will be adjusted to 2019 dollars. The requested updates will be provided in the updated four-factor analysis report.

- h. Flue gas recirculation (FGR) is listed as a technically feasible control option; however, the cost effectiveness of FGR was not evaluated. Please evaluate the cost effectiveness of FGR for reducing NO<sub>x</sub> emissions from the boilers and provide the results in Table 4-3.

**Response** – The combustion controls in the four-factor analysis includes various air pollution reduction technologies and combinations of these technologies. FGR can be combined with LNB, if needed. The LNB with overfire air (OFA) costing provided in Appendix Table A-2 of the four-factor analysis was based on costing provided for LNB and LNB with OFA. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control. Therefore, the costing provided in Appendix Table A-2 is applicable to range of various combustion controls and combinations of these controls.

For clarification, the provided costing for “LNB w/overfire” air will be renamed to “Combustion Controls” in the updated four-factor analysis report and the discussion in the four-factor analysis will also be updated accordingly.

- i. Please add the combination of FGR plus low NO<sub>x</sub> burner (LNB) and overfire air (OFA) to Table 4.2, evaluate the cost effectiveness of this combined NO<sub>x</sub> control measure for the boilers, and provide the results in Table 4-3.

**Response** – See the response to item h.

- j. Selective non-catalytic reduction (SNCR) is listed as a technically feasible control option; however, the cost effectiveness of SNCR was not evaluated. Please evaluate the cost effectiveness of SNCR for reducing NO<sub>x</sub> emissions from the boilers and provide the results in Table 4-3.

**Response** – As stated in Section 4.1.2.2 of the four-factor analysis report, the estimated NO<sub>x</sub> control range for SNCR for wall-fired boilers (K1, K2, and K5) is approximately 0.30-0.40 lb/MMBtu, for a wall-fired boiler equipped with LNB (K6) the estimated control level is approximately 25%<sup>7</sup>, and for tangentially-fired boilers (K3 and K4) is approximately 0.20-0.25 lb/MMBtu. These estimated control ranges for uncontrolled boilers are in the same range as combustion controls.<sup>8</sup> SNCR is only effective in a relatively high and narrow temperature range and therefore, is not suitable for all applications. Several factors determine whether SNCR is an appropriate control for a source, including temperature, residence time, the feasibility of

<sup>6</sup> Sorrels, J. and Walton, T. "Cost Estimation: Concepts and Methodology," *EPA Air Pollution Control Cost Manual*, Section 1, Chapter 2, pp. 16-17. U.S. EPA Air Economics Group, November 2017.

[https://www.epa.gov/sites/production/files/2017-12/documents/epaccmcostestimationmethodchapter\\_7thedition\\_2017.pdf](https://www.epa.gov/sites/production/files/2017-12/documents/epaccmcostestimationmethodchapter_7thedition_2017.pdf)

<sup>7</sup> Cost Control Manual, Selective Noncatalytic Reduction, EPA, 2019.

<sup>8</sup> *Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler*, EPA, 1994.

installing reagent injection ports, and the NO<sub>x</sub> concentration.<sup>9</sup> These site-specific operating and design characteristics of the emission unit must be evaluated on a case-by-case basis to determine whether SNCR is feasible. For these reasons, the effectiveness of SNCR will be based on the upper range of the estimated controlled emissions level.

EPA's SNCR costing spreadsheet was used to calculate the SNCR cost effectiveness for K1 and K5 (wall-fired boilers), K6 (wall-fired boiler with LNB), and K3 (tangentially-fired boiler). The SNCR cost effectiveness calculations for K1, K3, K5, and K6 are provided as representative costing for wall-fired and tangentially-fired boilers. Hawaiian Electric proposes to use this SNCR costing as a representative analysis for the boilers at the Kahe, Waiau, Kahului, Kanoiehua-Hill, and Puna Generating Stations instead of providing SNCR costing for each boiler. Due to the uncertainty in the level of control offered by SNCR, the upper control range was used (0.40 lb/MMBtu for wall-fired boilers (K1 and K5) and 0.25 lb/MMBtu for tangentially-fired boilers) was used in the cost effectiveness calculations. For K6 a control level of 25% (0.15 lb/MMBtu) was used in the cost effectiveness calculation.

The expanded cost effectiveness results for units K1, K3, K5, and K6 are provided in Attachment 3 included with this Response to Comments attachment. The cost effectiveness of SNCR added to uncontrolled boilers is greater than combustion controls and offers less control. SNCR has a lower cost effectiveness than SCR and SCR plus combustion controls. However, SNCR results in a lower level of control than SCR alone and SCR plus combustion controls. Based on the provided SNCR results, SNCR does not offer a significantly better control option than combustion controls, SCR, or SCR plus combustion controls.

The SNCR upper control range for Kahe units K1 and K2, wall-fired boilers, is 0.4 lb/MMBtu based on the evaluation performed for Kahe unit K1. The SNCR upper control range for Kahe units K3 and K4, tangentially-fired boilers, is 0.25 lb/MMBtu based on the evaluation performed for Kahe unit K3.

The SNCR costing spreadsheet and the cost effectiveness results are provided in Attachment 4 included with this Response to Comments attachment.

- k. Please add the combination of SNCR plus LNB and OFA to Table 4.2, evaluate the cost effectiveness of this combined NO<sub>x</sub> control measure for the boilers, and provide the results in Table 4-3.

**Response** – Due to the uncertainty in the level of control offered by SNCR, the combination of combustion controls and SNCR has the same level of expected control range as SNCR alone, approximately 0.20-0.40 lb/MMBtu for wall-fired boilers (K1, K2, and K5) and approximately 0.15-0.25 lb/MMBtu for tangentially-fired boilers (K3 and K4).<sup>10</sup> The SNCR plus combustion controls cost effectiveness calculations for Kahe K1 and K5, and K3 are provided as representative costing for wall-fired and tangentially-fired boilers, respectively. The cost effectiveness calculation is based on controlled emission levels of 0.20 lb/MMBtu for Kahe K1 and K5 (wall-fired boilers) and 0.15 lb/MMBtu for K3 (tangentially-fired boiler).

The expanded cost effectiveness results for K1, K3, K5, and K6 are provided in Attachment 3 included with this Response to Comments attachment and will be also be included in the updated four-factor analysis report. SNCR plus combustion controls has a lower cost effectiveness than SCR and SCR plus combustion controls. However, SNCR plus combustion

<sup>9</sup> Cost Control Manual, Selective Noncatalytic Reduction, EPA, 2019.

<sup>10</sup> *Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler*, EPA, 1994.



controls results in a lower level of control than SCR and SCR plus combustion controls. Based on the provided SNCR plus combustion controls results, SNCR plus combustion controls does not offer a significantly better control option than SCR or SCR plus combustion controls. Hawaiian Electric proposes to use this SNCR plus combustion controls costing as a representative analysis for the boilers at the Kahe, Waiau, Kahului, Kanoiehua-Hill, and Puna Generating Stations instead of providing SNCR costing for each boiler.

- l. Please add the combination of selective catalytic reduction (SCR) plus LNB and OFA to Table 4.2, evaluate the cost effectiveness of this combined NO<sub>x</sub> control measure for the boilers, and provide the results in Table 4-3.

**Response** – The combination of SCR plus combustion controls is expected to reduce NO<sub>x</sub> emissions to 0.05 lb/MMBtu and will be added to Table 4-2 in the updated four-factor analysis report. The cost effectiveness of SCR plus combustion controls will also be added to Table 4-3 in the updated four-factor analysis report.

- m. The NO<sub>x</sub> output rate of 0.1 pound per million British thermal unit (lb/MMBtu) was assumed for SCR. It is generally assumed that new SCR can achieve 0.05 lb/MMBtu (or lower) on an annual basis. The current (2019) CCM states that a 0.05 lb/MMBtu outlet NO<sub>x</sub> rate based on a 30-day (boiler operating) average should be obtainable by a power plant boiler with an SCR system.

**Response** – The 0.05 lb/MMBtu referenced in the CCM generally applies to boilers equipped with combustion controls. As stated in the above response, the combination of SCR plus combustion controls is expected to reduce NO<sub>x</sub> emissions to 0.05 lb/MMBtu. Several factors contribute to the level of control that SCR can provide. For these reasons, the level of SCR control for K1 – K5 was set to 0.1lb/MMBtu. Since K6 is equipped with combustion controls, the level of SCR control was reduced to 0.05 lb/MMBtu. The requested updates will be provided in the updated four-factor analysis report.

- n. In the control cost worksheets, a retrofit factor of 1.5 was selected from a recommended range between 0.8 and 1.5 for retrofitting the boilers with SCR. Please note that the CCM for SCR allows a retrofit factor of greater than one (1) provided the reasons for using the higher retrofit factor are appropriate and fully documented. A note in the control cost spreadsheet indicated that a retrofit factor of 1.5 is appropriate for the proposed project due to Hawai'i's remote location. For selecting a retrofit factor of greater than one (1), please provide additional detail on the complexities involved for retrofitting the boilers with SCR at the Kahe Generating Station.

**Response** –The EPA Air Pollution Control Cost Manual (CCM) recommends a retrofit factor of 0.8 should be used for new construction and a retrofit factor of 1 should be used for average retrofits. The CCM lists the following specific factors that impact retrofit costs:

- The amount of available space between and around the economizer and air heater;
- Congestion downstream of the air heater (i.e., buildings, ID fan, or stack);
- The age/vintage and manufacturer of the boiler;
- The design margin of the existing ID fan (i.e., the need to upgrade or replace fan impellers, replace ID fans, or add booster fans);
- The capacity, condition, and design margins of the electrical distribution system;
- The design margins of the existing structural steel support systems;
- The positive and negative design pressure of the furnace; and
- The number, nature, and type of existing items that must be relocated to accommodate the SCR and associated systems.

Although all of the factors listed above will impact the retrofit costs for the Kahe boilers, to determine the specific degree of impact for each individual factor would require a more detailed engineering study to evaluate, provide, and itemize the cost impact of the above factors. It is estimated that such an engineering study could take an up to ten (10) months to complete at a cost of approximately \$532,500 for the Kahe Generating Station. In addition, Hawai'i's higher construction cost impacts the cost to address the required equipment upgrades and space constraints which require relocation of existing equipment. Based on these factors, rather than engage in additional time consuming and costly studies, the more conservative upper range of the retrofit factor was selected.

- o. Appendix B of the four-factor analysis indicated that, in the recent past, Hawai'i's volcanic SO<sub>2</sub> emissions are about 1,000 times greater than anthropogenic SO<sub>2</sub> emissions and volcanic activity in Hawai'i produced as much as two (2) million tons of SO<sub>2</sub> per year. Please note that SO<sub>2</sub> emissions have significantly decreased after the Kilauea eruption ended in September 2018. The United States Geological Survey (USGS) stated, that in 2019, the summit is the only source releasing enough SO<sub>2</sub> emissions to be quantified using ultra-violet spectroscopy. Preliminary USGS results for 2019 indicate an average summit daily SO<sub>2</sub> emission rate of about 43 tons and an annual total SO<sub>2</sub> emission rate of about 17,119 tons which is far lower than the two (2) million tons of SO<sub>2</sub> reported to be emitted by the volcano in Appendix B. Note that the total combined SO<sub>2</sub> emissions from point sources screened for four-factor analyses were about 18,058 tons per year in 2017 which is 939 tons higher than preliminary USGS estimates of volcanic SO<sub>2</sub> for 2019. Since Kilauea eruption activity ended in September 2018, point sources screened for four-factor analysis now play a more significant part in SO<sub>2</sub> visibility impacts.

**Response** – Hawaiian Electric agrees that the volcanic SO<sub>2</sub> emissions have significantly decreased since September 2018. The four-factor analysis report Appendix B will be updated to acknowledge this change in the volcanic emissions. However, Hawaiian Electric does not believe that this changes the overall conclusion of the analysis which indicated that the Hawaiian Electric power plants are not significant contributors to visibility impairment at Hawai'i's Class I areas. Although the percent impact of point sources will increase with less volcanic emissions, the absolute value of the point source impacts remains unchanged. Given the negligible impact, the cost of control measures cannot be justified.

Hawaiian Electric sources on O'ahu are not upwind of either Class I area and do not have any significant impact on the visibility at either area. As mentioned in the four-factor analysis report, EPA CALPUFF modeling conducted for the First Decadal Review confirms the expected low impacts from these Hawaiian Electric sources.

As discussed in Section 2.1 of the four-factor analysis report, Step 1 of the EPA SIP guidance is to identify the 20 percent most anthropogenically impaired days, which requires factoring out volcanic impacts. Hawaiian Electric understands that volcanic activity has decreased since the September 2018. The reduction in volcanic activity should be visible in the 2019 IMPROVE monitoring data. The DOH should review the 2019 IMPROVE monitoring data to assist with defining the level of anthropogenic impaired.

Additionally, Hawaiian Electric, as a key affected company, should be allowed to participate as a major stakeholder in discussing and reviewing the EPA's photochemical modeling and the Western Regional Air Partnership's Hybrid-Single Particle Lagrangian Integrated Trajectory (HYSPLIT) modeling mentioned during the conference call with Hawaiian Electric and the DOH on July 30, 2020.

- p. Appendix B of the four-factor analysis also noted that volcanic activity on Hawai'i Island is the largest source of NO<sub>x</sub> in the state based on a NO<sub>x</sub> emission estimate for the Kilauea Volcano of roughly 125,000 tons per year. Data, indicating worldwide volcano NO<sub>x</sub> and SO<sub>2</sub> emissions of 1.5 and 23 teragrams, respectively, was used for the estimate. It was stated that the NO<sub>x</sub> was likely caused by thermal contact of air with lava. Based on the NO<sub>x</sub>/SO<sub>2</sub> ratio using the worldwide numbers, it was then assumed that NO<sub>x</sub> emissions from Kilauea Volcano are about 6% of the volcano's total SO<sub>2</sub> emissions. It was also assumed that Hawai'i volcanic activity emits approximately two (2) million tons per year of SO<sub>2</sub>. Please note that the global ratio of NO<sub>x</sub>/SO<sub>2</sub> is likely not appropriate to use for estimating NO<sub>x</sub> emissions from the Kilauea Volcano. Interagency Monitoring of Protected Visual Environments data shows that annual light extinction from ammonium nitrates for the most impaired days at Haleakala National Park over the current visibility period (2014-2018 when the volcano was erupting) are higher than those at Hawai'i Volcanoes National park where the volcano is located. Also, while volcanic SO<sub>2</sub> emissions were reported to be as high as two (2) million tons per year when the Kilauea Volcano was erupting, SO<sub>2</sub> emissions have significantly decreased after the Kilauea eruption ended in September 2018. There currently is no lava in the Kilauea summit crater. Instead, a lake of water has formed in the Kilauea crater after the volcano stopped erupting towards the end of 2018. Please refer to: <https://earthobservatory.nasa.gov/images/146687/a-new-lakewater-not-lavaon-kilauea>.

**Response** – Hawaiian Electric recognizes that estimates of NO<sub>x</sub> emissions from the volcano are uncertain as are the significance of its impact to nitrate haze. Appendix B of the four-factor analysis report will be updated to recognize this and acknowledge that monitoring data does not suggest a large impact from the volcanos. However, more importantly, as discussed in the four-factor analysis report, monitoring data for both National Parks shows that the total contribution of nitrates from all sources to haze is very low as both a percentage of the total impairment, and is also low as an absolute value for extinction (visibility impairment). The total nitrate haze impairment is approximately 1 inverse megameter ("Mm<sup>-1</sup>"), an extremely small value which is the total due to ALL sources, natural and anthropogenic. The small impact of NO<sub>x</sub> emissions to haze formation is due to the unique chemistry of nitrate haze and Hawai'i's generally warm weather year-round as explained in the four-factor analysis report.

Regarding the noted significant decrease in volcanic SO<sub>2</sub> emissions, see the previous response to item o.

- q. In the four-factor analysis, HECO states that no reduction measures in addition to Hawai'i's Renewable Portfolio Standards (RPS) are proposed to meet the RHR requirements. While provisions mandated by the RPS are subject to enforcement action by the Hawai'i Public Utilities Commission, these are state only enforceable requirements which are not federally enforceable under the federal Clean Air Act. The RHR requires federally enforceable emission limits and/or RH-SIP approved rule provisions in establishing the long-term strategy for regional Haze. As an option, HECO may propose caps for the emissions of visibility impairing pollutants (SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub>) based on anticipated emission reductions from the RPS as a reasonable progress measure that could be incorporated into permits. These emission caps would need to occur in the second planning period (2018-2028) in order to be credited as a control measure for reasonable progress. Additional measures for showing reasonable progress include federally enforceable plant shutdowns as described in comment e above. In essence, HECO could propose: 1) federally enforceable conditions for retiring units during the second implementation planning period (2018-2028) and include those units and retirement dates in the four factor analyses along with a four factor analysis of the remaining equipment; 2) propose federally enforceable emission control measures such as fuel switching or add-on controls with the associated pollutant reductions, or 3) propose federally enforceable permit limits such as emission caps, for operational flexibility, or hour restrictions with the associated compliance dates or any combination of 1, 2, or 3 above.

**Response** As Hawaiian Electric set forth in the four-factor analysis report (see in particular Appendix C) continues to assert that several of its programs can in fact be used to show that their emissions are being reduced in a manner that shows reasonable progress.

EPA's *Guidance on Regional Haze State Implementation Plans for the Second Implementation Period* (SIP Guidance) allows for the use of renewable energy programs as an alternative to permit limits. Also, the SIP Guidance encourages the use of projected 2028 emissions in selecting emission controls required to show reasonable progress and allows for energy efficiency, renewable energy, or other such programs where there is a documented commitment to participate and a verifiable basis for quantifying any change in future emissions due to operational changes. Hawaiian Electric's progress towards meeting the RPS is documented in annual reports to the Public Utility Commission (PUC) see also Appendix C to the Four Factor Reports. In addition, the status of future renewable projects are listed on the *Renewable Project Status Board* on the Hawaiian Electric website.<sup>11</sup> The addition of renewable energy is an operational change that reduces fossil fuel consumption, which results in reductions in emissions of visibility impairing pollutants.

The EPA's Regional Haze SIP Guidance supports the use of the State's RPS as an alternative to permit limits as it states:

**" Step 3: Selection of sources for analysis**

...

***Selection of emissions information when estimating visibility impacts (or surrogates) for source selection purposes***

\*\*\*\*

*All of the techniques described above require estimates of source emissions. Generally, we recommend that states use estimates of 2028 emissions (resolved by day and hour, as appropriate) to estimate visibility impacts (or related surrogates) when selecting sources, rather than values of recent year emissions. By doing so, sources that are projected on a reasonable basis to cease or greatly reduce their operations or to install much more effective emissions controls by 2028 may be removed from further consideration early in the SIP development process, which can reduce analytical costs. Generally, the estimate of a source's 2028 emissions is based at least in part on information on the source's operation and emissions in a representative historical period. However, there may be circumstances under which it is reasonable to project that 2028 operations will differ significantly from historical emissions. Enforceable requirements are one reasonable basis for projecting a change in operating parameters and thus emissions; energy efficiency, renewable energy, or other such programs where there is a documented commitment to participate and a verifiable basis for quantifying any change in future emissions due to operational changes may be another. A state considering using assumptions about future operating parameters that are significantly different than historical operating parameters should consult with its EPA Regional office.*

*If a state uses a value for emissions in an earlier year, we recommend the state consider whether emissions have appreciably changed (or will change) between the earlier year, the current period, and the projected future year (2028). It is especially important to consider whether source emissions have increased or are likely to increase in the future compared to earlier emissions values.*

<sup>11</sup> Renewable Project Status Board (<https://www.hawaiianelectric.com/clean-energy-hawaii/our-clean-energy-portfolio/renewable-project-status-board>)

***Use of actual emissions versus allowable emissions***

*Generally, we recommend that a reasonably projected actual level of source operation in 2028 be used to estimate 2028 actual emissions for purposes of selecting sources for control measure analysis. Source operation during a historical period can inform this projection, but temporary factors that suppressed or bolstered the level of operation in the historical period should be considered, along with factors that indicate a likely increase or decrease in operation.*

...

***Step 4: Characterization of factors for emission control measures***

...

*Examples of types of emission control measures states may consider States have the flexibility to reasonably determine which control measures to evaluate, and the following is a list of example types of control measures that states may consider:*

...

*Energy efficiency and renewable energy measures that could be applied elsewhere in a state to reduce emissions from EGUs.*

...

*EPA understands that some states may be interested in exploring such measures for their second implementation period SIPs, which is generally appropriate. We suggest such states discuss the measures and programs and their incorporation into the SIP with their EPA Regional office..."<sup>12</sup>*

Based on the above EPA guidance, the selection of controls for the long-term strategy (LTS) can include alternatives to permit limits and rely on projected emissions based on the planned transition to 100% renewable energy. For example, various RPS goals across the 48 contiguous states were used as inputs in the EPA's Integrated Planning Model (IPM)<sup>13,14</sup> to project EGU emissions. The CAM<sub>x</sub> modeling used these projected emissions to support the LTS for 2028 (SIP Guidance Steps 5 and 6).

Hawaiian Electric is willing to work with the DOH and EPA Region IX on an alternative to permit limits that relies on the State's RPS goals. The State of Hawai'i apparently contemplated that both the RPS and GHG emissions cap could be used to show reasonable progress in the 2018 Western States Planning Readiness Survey For Regional Haze State Implementation Plans For The Second Implementation Period Survey Results And Discussion (Readiness Survey)<sup>15</sup>.

The Readiness Survey that was conducted by the Western Regional Air Partnership (WRAP) states:

*Hawaiian Electric plans to use Hawai'i's existing Renewable Portfolio Standard (RPS) as a measure to make reasonable progress. The RPS ultimately requires the Hawaiian Electric Company to establish 100% renewable energy sales by 2045 to reduce fossil fuel consumption for mitigating GHGs. Mitigating GHGs will also reduce pollutants that impair visibility as a co-benefit. Hawaiian Electric Companies' Power Supply Improvement Plan (PSIP) provides future plans for the utility*

<sup>12</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, page 17, August 2019, EPA-457/B-19-003. <https://www.epa.gov/visibility/guidance-regional-haze-state-implementation-plans-second-implementation-period>

<sup>13</sup> Technical Support Document for EPA's Updated 2028 Regional Haze Modeling, pages 11-12, September 2019. [https://www.epa.gov/sites/production/files/2019-10/documents/updated\\_2028\\_regional\\_haze\\_modeling-tsd-2019\\_0.pdf](https://www.epa.gov/sites/production/files/2019-10/documents/updated_2028_regional_haze_modeling-tsd-2019_0.pdf)

<sup>14</sup> Power Sector Modeling Platform v6 November 2018. <https://www.epa.gov/airmarkets/power-sector-modeling-platform-v6-november-2018>

<sup>15</sup> 2018 (final 1/2019) Western States Planning Readiness Survey For Regional Haze State Implementation Plans For The Second Implementation Period Survey Results And Discussion. [https://www.wrapair2.org/pdf/WRAP%202018%20RH%20Planning%20Readiness%20Survey%20-%20Synthesis%20Report%20FINAL%20\(including%20figures%20and%20attachments\).PDF](https://www.wrapair2.org/pdf/WRAP%202018%20RH%20Planning%20Readiness%20Survey%20-%20Synthesis%20Report%20FINAL%20(including%20figures%20and%20attachments).PDF)

*and independent power producers to achieve 100% RPS by 2045. The PSIP may be used to establish permit conditions to limit the emissions of pollutants that impair visibility for meeting reasonable progress goals. In accordance with our Hawai'i Administrative Rules (HAR), point sources are subject to a GHG emission cap to ensure emissions from stationary sources (both minor and major) return to 1990 GHG levels by 2020. The GHG emissions cap must be at least 16% below the baseline level unless the affected facility demonstrates that a 16% reduction is unattainable.*

Although based on the analysis herein, we do not believe that permit conditions are required to use the RPS to show progress, nor is it practical to do so given the difficulty in predicting the specifics of the RPS progress. However, Hawaiian Electric intends to provide a further analysis that may include additional strategies to include these two programs in its updated four-factor analysis report.

## **Revised Four – Factor Analysis**



**REGIONAL HAZE FOUR-FACTOR ANALYSIS**  
**Kahe Generating Station**



**TRINITY CONSULTANTS**  
12700 Park Central Drive  
Suite 2100  
Dallas, TX 75251  
972-661-8100

April 2020  
Revised September 14, 2020  
Revised September 25, 2020

Project 194401.0297



*Environmental solutions delivered uncommonly well*



TABLE OF CONTENTS

1. EXECUTIVE SUMMARY 1-1

2. BACKGROUND AND ADDITIONAL FACTORS 2-1

    2.1. Regional Haze Rule Background .....2-1

    2.2. Additional Factors.....2-3

3. SULFUR DIOXIDE FOUR-FACTOR ANALYSIS 3-1

    3.1. Sulfur Dioxide Control Options.....3-1

    3.2. Four-Factor Analysis.....3-3

    3.3. Sulfur Dioxide Conclusion .....3-5

4. NITROGEN OXIDES FOUR-FACTOR ANALYSIS 4-1

    4.1. Nitrogen Oxides Control Options .....4-1

    4.2. Four-Factor Analysis.....4-5

    4.3. Nitrogen Oxides Conclusion.....4-8

5. PARTICULATE MATTER FOUR-FACTOR ANALYSIS 5-1

    5.1. Particulate Matter Control Options.....5-1

    5.2. Four-Factor Analysis and Conclusion .....5-2

6. TOTAL COST EFFECTIVENESS OF FUEL SWITCHING 6-1

APPENDIX A: DETAILED COSTING A-I

APPENDIX B: HAWAIIAN ELECTRIC REGIONAL HAZE VISIBILITY CONSIDERATIONS B-I

APPENDIX C: HAWAII'S RENEWABLE PORTFOLIO STANDARDS CONTRIBUTION TO REGIONAL HAZE PROGRESS C-I

APPENDIX D: FUEL COST D-I

## LIST OF TABLES

---

Table 3-1. 2017 Fuel Property Data and Usage and Baseline SO <sub>2</sub> Emissions	3-1
Table 3-2. SO <sub>2</sub> Cost effectiveness of CDS	3-6
Table 3-3. SO <sub>2</sub> Cost effectiveness of Fuel Switching to a Residual Oil/ULSD Blend	3-6
Table 3-4. SO <sub>2</sub> Cost effectiveness of Fuel Switching to ULSD	3-7
Table 4-1. Baseline NO <sub>x</sub> Emissions	4-1
Table 4-2. NO <sub>x</sub> Reduction from Fuel Switching	4-2
Table 4-3. Control Effectiveness of Technically Feasible NO <sub>x</sub> Control Technologies	4-5
Table 4-4. NO <sub>x</sub> Cost effectiveness of Controls Summary	4-7
Table 5-1. Baseline PM <sub>10</sub> Emissions	5-1
Table 5-2. PM <sub>10</sub> Reduction from Fuel Switching	5-1
Table 5-3. PM <sub>10</sub> Cost Effectiveness Summary	5-3
Table 6-1. Total Cost Effectiveness of Fuel Switching	6-1

## 1. EXECUTIVE SUMMARY

This report is submitted to comply with the second implementation period of the Regional Haze Rule (RHR). In the first implementation period, the EPA excluded sources, such as the Kahe Generating Station (Kahe), which is located on the Island of Oahu, from its analysis because of the distance and downwind location of the sources in relation to the Class I areas in Hawai'i.

The State of Hawai'i has two Class I areas (National Parks) that trigger compliance with the RHR: Hawai'i's Mandatory Federal Class I Areas are Haleakalā National Park on Maui and Hawai'i Volcanoes National Park on Hawai'i Island. This report documents the results of a four-factor analysis conducted by Trinity Consultants (Trinity) on behalf of Hawaiian Electric<sup>1</sup> for the six boilers (K1, K2, K3, K4, K5, and K6) at Kahe. K1, K2, K5, and K6 are wall-fired boilers with nominal ratings of 92 megawatts (MW), 90 MW, 142 MW, and 142 MW, respectively. K3 and K4 are tangentially-fired boilers with nominal ratings of 92 MW and 93 MW, respectively. The boilers currently burn residual oil (residual oil, residual low sulfur fuel oil, or LSFO). Also, Appendix B and Appendix C contain analyses performed by AECOM Technical Services, Inc. (AECOM) of a fifth factor that includes a review of visibility impacts.

This report addresses the options that could be considered that have the potential to lower emissions and show reasonable progress toward the RHR goals. The results of the four-factor analysis herein are consistent with the conclusions reached for the first planning period for Kahe. Other long-term emissions reduction strategies, such as those included as part of Hawai'i's Renewable Portfolio Standards (RPS), the Hawaiian Electric Partnership Greenhouse Gas Emissions Reduction Plan (GHG ERP) required by Act 234 and the associated DOH GHG Emissions Regulations (Hawaii Administrative Rules Title 11, Chapter 60.1, Subchapter 11) which require State enforceable GHG emissions limits, and Hawai'i's Energy Efficiency Portfolio Standard (EEPS) are viable alternatives to emissions reductions from add-on controls and changes in the method of operations.

Hawaiian Electric and AECOM met with the Department of Health (DOH) on February 12, 2020 to present special circumstances applicable in Hawai'i that should be given consideration in the development of the Hawai'i Regional Haze State Implementation Plan (SIP). Significant among those circumstances is Hawai'i's Statutory RPS which have put the state on a timetable to accomplish the same goals as the RHR twenty (20) years before the Regional Haze 2064 target date and that this facility is a considerable distance and mostly downwind of the Class I areas. These same issues were addressed by the EPA in the Federal Implementation Plan (FIP) and the DOH in its Progress Report<sup>2</sup> that was approved by the EPA effective on September 11, 2019. These special considerations are discussed further in Appendix B and Appendix C to this report.

Based on the four-factor analysis and the materials set forth in the appendices, Hawaiian Electric does not propose any emissions reduction measures in addition to the Hawai'i RPS, EEPS, and the GHG ERP to meet the RHR requirements.

<sup>1</sup> Hawaiian Electric" or the "Company" refers to Hawaiian Electric Company, Inc. (or "HE"), Hawai'i Electric Light Company, Inc. (or "HL") and/or Maui Electric Company, Limited (or "ME"). On December 20, 2019, the State of Hawai'i Department of Commerce and Consumer Affairs ("DCCA") approved Hawaiian Electric Company, Inc., Hawai'i Electric Light Company, Inc. and Maui Electric Company, Limited's application to do business under the trade name "Hawaiian Electric" for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.

<sup>2</sup> 5-Year Regional Haze Progress Report for Federal Implementation Plan, Hawai'i State Department of Health, October 2017, EPA-R09-OAR-2018-0744-0004.

ensure that reasonable progress is made during this first planning period toward the national goal of no anthropogenic visibility impairment by 2064 at Hawai'i's two Class I areas.

The second implementation planning period (2019-2028) for the national regional haze efforts is currently underway. The EPA's *Guidance on Regional Haze State Implementation Plans for the Second Implementation Period* (SIP Guidance)<sup>4</sup> provides guidance to states for the development of the implementation plans. There are a few key distinctions from the processes that took place during the first planning period (2004-2018). Most notably, the second planning period analysis distinguishes between natural (or "biogenic") and manmade (or "anthropogenic") sources of emissions. The EPA's *Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program* (Visibility Guidance)<sup>5</sup> provides guidance to states on methods for selecting the twenty (20) percent most impaired days to track visibility and determining natural visibility conditions. The approach described in this guidance document does not attempt to account for haze formed from natural volcanic emissions; however, the 2017 RHR defines visibility impairment or anthropogenic visibility impairment as:

*any humanly perceptible difference due to air pollution from anthropogenic sources between actual visibility and natural visibility on one or more days. Because natural visibility can only be estimated or inferred, visibility impairment also is estimated or inferred rather than directly measured.*

Specifically, the EPA's Visibility Guidance states that although they did not attempt to account for haze formed by natural volcanic emissions:

*We encourage states with Class I areas affected by volcanic emissions to work with their EPA Regional office to determine an appropriate approach for determining which days are the 20 percent most anthropogenically impaired days.*

In the *5-Year Regional Haze Progress Report for Federal Implementation Plan*<sup>6</sup>, the DOH acknowledges the impact of SO<sub>2</sub> from the Kilauea volcano with the following statement:

*A majority of the visibility degradation is due to the ongoing release of SO<sub>2</sub> from Kilauea volcano with emissions that vary by hundreds of thousands of tons from one year to another. Visibility improvement from significant reductions in Maui and Hawaii Island point source SO<sub>2</sub> is obscured by sulfate from natural volcanic SO<sub>2</sub> that overwhelms sulfate from anthropogenic SO<sub>2</sub> sources.*

Step 1 of the EPA's SIP Guidance is to identify the twenty (20) percent most anthropogenically impaired days and the twenty (20) percent clearest days and determine baseline, current, and natural visibility conditions for each Class I area within the state (40 CFR 51.308(f)(1)). Hawaiian Electric has concerns that this key step may not be accounted for during the second implementation planning period and the development of Hawai'i's RHR SIP. The identification of the twenty (20) percent most impaired days sets the foundation for identifying any needed emissions reductions.

Pursuant to 40 CFR 51.308(d)(3)(iv), the states are responsible for identifying the sources that contribute to the most impaired days in the Class I areas. To accomplish this the Western Regional Air Partnership (WRAP), with Ramboll US Corporation, reviewed the 2014 National Emissions Inventory (NEI) and assessed each facility's impact on visibility in Class I areas with a "Q/d" analysis, where "Q" is the magnitude of emissions that impact ambient visibility and "d" is the distance of a facility to a Class I area. The WRAP Guidance states that the EPA has concerns over only relying on the Q/d method for

<sup>4</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, August 2019, EPA-457/B-19-003.

<sup>5</sup> Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program, December 2018, EPA-454/R-18-010.

<sup>6</sup> 5-Year Regional Haze Progress Report for Federal Implementation Plan, Hawai'i State Department of Health, October 2017, EPA-R09-OAR-2018-0744-0004.

screening sources. The EPA points out that the Q/d metric is only a rough indicator of actual visibility impact because it does not consider transport direction/pathway and dispersion and photochemical processes. To address the EPA's concern, the WRAP subcommittee recommends a second step, application of the weighted emissions potential analysis (WEP).<sup>7</sup> On September 11, 2019, the DOH informed Hawaiian Electric, that Kahe Generating Station (Kahe) was identified as one of the sources potentially contributing to regional haze at the Haleakalā National Park and Volcanoes National Park. This report responds to the DOH September 2019 request to Hawaiian Electric to submit a four-factor analysis for Kahe.

The "Q/d" approach does not take into consideration the frequency or actual visibility impact on the Class I area. In support of the SIP for the first planning period, modeling was conducted for several facilities<sup>8</sup> located on the island of Oahu. Regional haze modeling shows these facilities had an insignificant impact on visibility at Haleakalā and Volcanoes National Parks. Therefore, Hawaiian Electric encourages the DOH to consider actual visibility impacts in the SIP development process.

The SIP Guidance requires that the selection of sources and controls necessary to make reasonable progress must, in addition to the statutory four factors (cost, remaining useful life, etc.), also consider the five required factors listed in 40 CFR section 51.308(f)(2)(iv), and other factors that are reasonable to consider.<sup>9</sup> These additional factors include consideration of emissions reductions due to ongoing air pollution control programs and the anticipated net effect on visibility due to projected changes in source emissions. The Hawaiian Electric and AECOM prepared summary, included in Section 2.2, describes special circumstances applicable in Hawai'i that should be considered during the development of the Hawai'i Regional Haze SIP.

## 2.2. ADDITIONAL FACTORS

Hawaiian Electric and AECOM met with the DOH on February 12, 2020 to present special circumstances applicable in Hawai'i that should be considered during the development of the Hawai'i Regional Haze SIP. Significant among those circumstances is Hawai'i's Statutory RPS which have put the state on a timetable to accomplish the same goals as the RHR twenty years before the Regional Haze 2064 target date. These same issues were addressed by the EPA in the FIP and the DOH in their Progress Report that as approved by the EPA, effective on September 11, 2019. These special considerations are discussed further in Appendix B and Appendix C to this report and summarized in the following sections.

Additionally, Kahe is subject to the DOH's GHG ERP and the associated State enforceable Covered Source Permit limit and thereby, also reduces emissions relevant to the RHR.

### 2.2.1. Lack of Contribution to Visibility Impairment Due to Prevailing Winds

As noted above, the DOH did not consider actual contribution to visibility impairment when selecting sources for the Four-Factor Analysis, but this is a critical factor in establishing realistic reasonable progress goals for Class I areas. The EPA's FIP for Hawai'i for the First Decadal Review (77 FR 61478,

<sup>7</sup> WRAP Reasonable Progress Source Identification and Analysis Protocol For Second 10-year Regional Haze State Implementation Plans, dated February 27, 2019 (<https://www.wrapair2.org/pdf/final%20WRAP%20Reasonable%20Progress%20Source%20Identification%20and%20Analysis%20Protocol-Feb27-2019.pdf>).


<sup>8</sup> Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawaii, U.S. EPA Region 9, May 14, 2012. Table VI-3 provides visibility modeling results for the following Oahu facilities: Chevron Refinery, Tesoro Refinery, and Hawaiian Electric's Kahe and Waiiau power plants.

<sup>9</sup> US EPA Memorandum, "Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program", Dec. 20, 2018, Pages 9, 21, C-1.

October 9, 2012) has already acknowledged the predominant trade winds in Hawai'i and thus, did not require controls on upwind sources (i.e., sources on Oahu and Maui).

The wind rose plot for the Honolulu airport on Oahu shows that the wind is almost always from the northeast and rarely blows from the west or northwest, directions necessary for emissions from Kahe to blow toward either of Hawai'i's Class I areas. The Honolulu airport wind rose plot is provided as Figure 2-1 and shows the persistence of the northeasterly trade winds. Based on the infrequent amount of time the wind blows from Kahe toward either of Hawai'i's Class I areas, it is unlikely that the facility's potential emissions impact visibility at Haleakalā National Park and Volcanoes National Park. Therefore, when balancing retrofit costs and visibility improvements, the DOH should remain mindful that emissions from this facility are unlikely to contribute to regional haze at Haleakalā National Park and Volcanoes National Park and as such will have no impact on a showing of further reasonable progress.

**Figure 2-1. Honolulu Wind Rose (2015 – 2019) Predominant Wind from the Northeast**



### 2.2.2. Lack of Contribution to Visibility Impairment Due to Warm Weather Conditions

The potential for the formation of haze due to  $\text{NO}_x$  emissions is very low in Hawai'i because of the warm weather conditions year-round. Nitrate haze composition analyses for the Haleakalā and Hawai'i Volcanoes National Parks from the IMPROVE web site are included in Appendix B to this report. The data for both national parks show that the contribution of nitrates to haze is very low. It is low as a percentage of the total haze composition, but it is also low as an absolute value for light extinction (visibility impairment). The minimal impact of nitrate haze is clearly illustrated in the Hawai'i National Park monitoring data and is much lower than found at many monitors in other Class I areas around the country. This is in large part due to the unique chemistry of nitrate haze which is discussed further in Appendix B to this report.

Due to the low haze impact of  $\text{NO}_x$ , the DOH should not consider  $\text{NO}_x$  controls for the Second Decadal Review for Kahe. A similar conclusion was reached during the First Decadal Review, for which the EPA did not consider  $\text{NO}_x$  controls to be material.

### 2.2.3. Contribution to Visibility Impairment from Volcanic Activity

Volcanic activity on the Hawai'i Island represents a unique challenge to understanding haze in Hawai'i Class I areas. The Kilauea volcano on Hawai'i Island has been active for several years, and the levels of SO<sub>2</sub> emissions are being monitored by the United States Geological Survey. In addition to volcanoes being large sources of SO<sub>2</sub>, they also emit significant amounts of NO<sub>x</sub>. Volcanic activity on Hawai'i Island is by far the largest source of both SO<sub>2</sub> and NO<sub>x</sub> in the state and so dominates visibility impairment to Class I areas as to completely obscure any small impact from anthropogenic sources. Significant portions of direct Particulate Matter (PM) emissions are due to volcanic activity. Whatever small impact of SO<sub>2</sub>, NO<sub>x</sub>, and PM emissions from power plants are projected to be eliminated well before the end point of the Regional Haze Rule (i.e., 2064) by Hawai'i's Statutory Renewable Portfolio Standards (RPS). Thus, the DOH should not consider SO<sub>2</sub>, NO<sub>x</sub>, or PM controls for the Second Decadal Period Review for Kahe.

### 2.2.4. Renewable Portfolio Standards

For the reasons stated above and based on AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, SO<sub>2</sub>, NO<sub>x</sub>, and particulate matter, 10 microns or less in diameter (PM<sub>10</sub>) emissions from Kahe do not significantly contribute to regional haze at the Class I areas. The low impact that Kahe may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the Hawai'i Clean Energy Initiative (HCEI). Both past and projected future decreases in fossil-fueled electric generating unit (EGU) usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls at Kahe would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1), it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.


### 3.1.1. Post-Combustion Controls

#### 3.1.1.1. Boilers

FGD applications have not been used historically for SO<sub>2</sub> control on oil-fired boilers. As there are no known FGD applications for oil-fired boilers, the performance of FGDs on oil-fired boilers is unknown. An internal engineering study in 2012 identified CDS as the best option, if required, for the Kahe Boilers. Since there are no applications of FGD on oil-fired boilers in the U.S., FGDs, including CDS, are considered unproven technology for the control of SO<sub>2</sub> from the Kahe boilers due to lack of similar applications. However, the cost effectiveness of CDS is evaluated for completeness. The SO<sub>2</sub> cost-effectiveness calculations show that CDS is the least cost-effective option to reduce SO<sub>2</sub>.

The CDS process uses a circulating fluidized bed of dry hydrated lime reagent to remove SO<sub>2</sub>. The process starts when flue gas enters multiple venturi nozzles at the base of a vertical reactor tower, where it is humidified by a water mist before entering the circulating bed of powdered hydrated lime, fly ash, and recycled byproducts. Figure 3-1 shows a typical process flow diagram of a CDS system. The addition of CDS is expected to reduce SO<sub>2</sub> emissions by ninety percent.

Figure 3-1. Typical CDS system



#### 3.1.2. Fuel Switching

The Kahe boilers currently burn residual low sulfur fuel oil with a maximum sulfur content of 0.5 percent by weight. The average sulfur content of the residual low sulfur fuel oil burned in 2017 was approximately 0.42 percent by weight. Switching to a lower sulfur fuel will reduce SO<sub>2</sub> emissions in proportion to the reduction in fuel sulfur content.<sup>10</sup> However, a lower sulfur residual oil is not currently available in Hawai'i. Lower sulfur content distillate fuels are available and could be burned in the boilers or could be blended with the existing residual low sulfur fuel oil to lower the sulfur content. Technically feasible options include blending the current residual low sulfur fuel oil with a lower sulfur distillate fuel or switching to a lower sulfur distillate fuel. The SO<sub>2</sub> four-factor analysis evaluates both options.

<sup>10</sup> Natural gas has less sulfur than the existing residual oil. However, natural gas is not a technically feasible option because there is no utility-scale natural gas supply in Hawai'i.



### 3.1.3. Renewable Portfolio Standards

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that SO<sub>2</sub> emissions from Kahe do not significantly contribute to regional haze. The low impact that Kahe may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the HCEI. Both past and projected future decreases in fossil-fueled EGU usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls at Kahe would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1) it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

## 3.2. FOUR-FACTOR ANALYSIS

As discussed above, the technically feasible options to reduce SO<sub>2</sub> emissions are:

- CDS;
- Fuel switching to a residual/distillate blended fuel; or
- Fuel switching to a lower sulfur distillate fuel.

For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors are discussed in the following sections.

### 3.2.1. Cost of Compliance

The cost effectiveness of CDS was based on the annualized cost of the CDS divided by the reduction in SO<sub>2</sub> emissions. The cost effectiveness of the fuel switching was determined by calculating the annual incremental cost of switching to a lower sulfur fuel divided by the reduction in SO<sub>2</sub> emissions. Switching fuel would require changes to the injectors and the fuel system; however, these expenses were not included in the analysis.

Kahe currently purchases residual low sulfur fuel oil from Par Hawaii Refining, LLC (Par Hawaii); current fuel costs are provided in Appendix D. The current residual low sulfur fuel oil is refined on Oahu and changes in quantities of residual low sulfur fuel oil and ULSD would require new contracts with fuel suppliers. This adds a level of uncertainty to the cost of compliance. Par Hawaii is the only refinery in Hawai'i and is near production capacity of ULSD. Therefore, increases in ULSD will require importing ULSD to Hawai'i and Appendix D contains the estimated cost of importing ULSD to Hawai'i.

Table 3-2 presents the cost effectiveness of adding CDS to the boilers. The cost effectiveness is determined by dividing the annualized cost by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of adding CDS systems ranges from \$13,195 to \$18,281 per ton of SO<sub>2</sub> in the different units and the total cost equals 80 million dollars (\$80,000,000) annually and 2.4 billion dollars (\$2,400,000,000) over thirty (30) years.

Table 3-2. SO<sub>2</sub> Cost effectiveness of CDS

Unit	Control Option	2017 SO <sub>2</sub> Emissions <sup>A</sup> (tpy)	Controlled Emission Level <sup>B</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (ton/yr)	Total Annual Cost <sup>C</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	CDS	841.8	0.045	3,778,041	84.2	757.6	\$10,608,072	\$14,002
K2	CDS	659.5	0.045	2,959,869	66.0	593.6	\$10,800,319	\$18,196
K3	CDS	836.3	0.045	3,753,356	83.6	752.7	\$11,589,051	\$15,397
K4	CDS	859.8	0.045	3,858,826	86.0	773.8	\$11,023,741	\$14,246
K5	CDS	1,136.2	0.045	5,099,323	113.6	1,022.6	\$18,694,104	\$18,281
K6	CDS	1,431.5	0.045	6,424,644	143.2	1,288.4	\$17,000,254	\$13,195

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> Controlled emission levels based on 90% control.

<sup>C</sup> See Appendix A for total annual cost calculations.

Table 3-3. SO<sub>2</sub> Cost effectiveness of Fuel Switching to a Residual Oil/ULSD Blend

Unit	Current Residual Oil (0.50% maximum Sulfur) <sup>A</sup>					Residual Oil/ULSD Blend (0.25% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content (%)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup>		SO <sub>2</sub> Cost Effectiveness (\$/ton)
										(\$/Gal)	(\$/yr)	
K1	0.42%	149,479	25,274,725	3,778,041	841.8	143,071	26,406,754	493.0	348.8	0.18	\$4,621,182	13,250
K2	0.42%	149,479	19,801,237	2,959,869	659.5	143,071	20,688,114	386.3	273.2	0.18	\$3,620,420	13,250
K3	0.42%	149,479	25,109,590	3,753,356	836.3	143,071	26,234,222	489.8	346.5	0.18	\$4,590,989	13,250
K4	0.42%	149,479	25,815,168	3,858,826	859.8	143,071	26,971,403	503.6	356.2	0.18	\$4,719,995	13,250
K5	0.42%	149,479	34,113,973	5,099,323	1,136.2	143,071	35,641,903	665.5	470.7	0.18	\$6,237,333	13,250
K6	0.42%	149,479	42,980,244	6,424,644	1,431.5	143,071	44,905,284	838.4	593.1	0.18	\$7,858,425	13,250

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on a blend of 50.0% residual oil and 50.0% ULSD and the weighted average of the 2017 fuel HHV and density for residual oil and ULSD, and contract fuel sulfur limits.

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 3-4. SO<sub>2</sub> Cost effectiveness of Fuel Switching to ULSD**

Unit	Current Residual Oil (0.50% maximum Sulfur) <sup>A</sup>					ULSD (0.0015% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content (%)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup>		SO <sub>2</sub> Cost Effectiveness (\$/ton)
										(\$/Gal)	(\$/yr)	
K1	0.42%	149,479	25,274,725	3,778,041	841.8	136,662	27,645,144	3.8	838.0	0.36	\$9,814,026	11,711
K2	0.42%	149,479	19,801,237	2,959,869	659.5	136,662	21,658,318	3.0	656.5	0.36	\$7,688,703	11,711
K3	0.42%	149,479	25,109,590	3,753,356	836.3	136,662	27,464,521	3.8	832.5	0.36	\$9,749,905	11,711
K4	0.42%	149,479	25,815,168	3,858,826	859.8	136,662	28,236,273	3.9	855.9	0.36	\$10,023,877	11,711
K5	0.42%	149,479	34,113,973	5,099,323	1,136.2	136,662	37,313,391	5.1	1,131.1	0.36	\$13,246,254	11,711
K6	0.42%	149,479	42,980,244	6,424,644	1,431.5	136,662	47,011,195	6.4	1,425.1	0.36	\$16,688,974	11,711

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on 2017 average HHV and density for residual oil, AP-42 HHV and density for diesel, and contract fuel sulfur limits.

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

emissions. Post-combustion controls convert NO<sub>x</sub> in the flue gas to molecular nitrogen and water. Available NO<sub>x</sub> control technologies for the boilers are:

- Fuel Switching to a residual/distillate blended fuel or a distillate fuel
- Combustion Controls (K1 – K5)
  - Flue Gas Recirculation (FGR)
  - Overfire Air (OFA)
  - Low NO<sub>x</sub> Burners (LNB)
- Post-Combustion Controls (K1 – K6)
  - Selective Catalytic Reduction (SCR)
  - Selective Non-Catalytic Reduction (SNCR)
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.

#### 4.1.1. Fuel Switching

The Kahe boilers currently burn residual oil. Blending the current residual oil with distillate fuel or switching to a distillate fuel will result in minor reductions in NO<sub>x</sub> emissions due to the lower fuel bound nitrogen content. The NO<sub>x</sub> four-factor analysis evaluates both options. Table 4-2 provides the estimated control levels for fuel switching.

**Table 4-2. NO<sub>x</sub> Reduction from Fuel Switching**

Fuel Scenario	AP-42 NO <sub>x</sub> Emission Factors <sup>A</sup>		Percent NO <sub>x</sub> Reduction from Fuel Switching <sup>B</sup>		
	Wall-Fired Boilers (lb/MMBtu)	Tangentially-Fired Boilers (lb/MMBtu)	K1, K2 & K5	K3 & K4	K6 <sup>C</sup>
Residual Oil (LSFO)	0.313	0.213	--	--	--
Distillate (No. 2 Fuel Oil)	0.171	0.171	45%	20%	36%
Residual Oil w/LNB <sup>C</sup>	0.267	--	--	--	--
50/50 Blend	--	--	23%	10%	18%

<sup>A</sup> The listed emission factors are from AP-42, Table 1.3-1, dated May 2010.

<sup>B</sup> The percent reduction is based on the ratio of AP-42 emissions factors for residual fuel oil and No. 2 fuel oil.

<sup>C</sup> K6 is equipped with LNB.

#### 4.1.2. Combustion Controls

##### 4.1.2.1. Flue Gas Recirculation (FGR)

FGR uses flue gas as an inert material to reduce flame temperatures. In a typical FGR system, flue gas is collected from the combustion chamber or stack and returned to the burner via a duct and blower. The addition of flue gas reduces the oxygen content of the “combustion air” (air + flue gas) in the burner. The lower oxygen level in the combustion zone reduces flame temperatures, which in turn reduces thermal NO<sub>x</sub> formation. When FGR is operated without additional controls, the NO<sub>x</sub> control range for wall-fired boilers (K1, K2, and K5) with FGR is approximately 0.25-0.30 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.15-0.20 lb/MMBtu.<sup>15</sup> This control is a technically feasible option for the Kahe boilers. When FGR is combined with LNB, the estimated NO<sub>x</sub> control range on wall-fired boilers with LNB (K6) is approximately 0.20-0.25 lb/MMBtu which includes the K6’s permitted NO<sub>x</sub>

<sup>15</sup> *Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler*, EPA, 1994.

limit of 0.23 lb/MMBtu. Therefore, the addition of FGR to K6 with LNB is not expected to significantly reduce NO<sub>x</sub> emissions.

#### 4.1.2.2. Overfire Air (OFA)

OFA diverts a portion of the total combustion air from the burners and injects it through separate air ports above the top level of burners. Staging of the combustion air creates an initial fuel-rich combustion zone with a lower peak flame temperature. This reduces the formation of thermal NO<sub>x</sub> by lowering combustion temperature and limiting the availability of oxygen in the combustion zone where NO<sub>x</sub> is most likely to be formed. When OFA is operated without additional controls, the NO<sub>x</sub> control range for wall-fired boilers (K1, K2, and K5) is approximately 0.30-0.45 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.20-0.30 lb/MMBtu.<sup>16</sup> This control is a technically feasible option for the Kahe boilers. When OFA is combined with LNB, the estimated NO<sub>x</sub> control range on wall-fired boilers with LNB (K6) is approximately 0.25-0.30 lb/MMBtu which is close to K6's permitted NO<sub>x</sub> limit of 0.23 lb/MMBtu. Therefore, the addition of OFA to K6 with LNB is not expected to significantly reduce NO<sub>x</sub> emissions.

#### 4.1.2.3. Low NO<sub>x</sub> Burners (LNB)



LNB technology utilizes advanced burner design to reduce NO<sub>x</sub> formation through the restriction of oxygen, lowering of flame temperature, and/or reduced residence time. In the primary zone, NO<sub>x</sub> formation is limited by either one of two methods. Under staged fuel-rich conditions, low oxygen levels limit flame temperatures resulting in less NO<sub>x</sub> formation. The primary zone is then followed by a secondary zone in which the incomplete combustion products formed in the primary zone act as reducing agents. Alternatively, under staged fuel-lean conditions, excess air will reduce flame temperature to reduce NO<sub>x</sub> formation. In the secondary zone, combustion products formed in the primary zone act to lower the local oxygen concentration, resulting in a decrease in NO<sub>x</sub> formation.

The estimated NO<sub>x</sub> control range for LNBs on wall-fired boilers (K1, K2, and K5) is approximately 0.25-0.35 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.15-0.20 lb/MMBtu.<sup>17</sup> When combined with OFA, the estimated NO<sub>x</sub> control range on wall-fired boilers (K1, K2, and K5) is approximately 0.25-0.30 lb/MMBtu, and for tangentially-fired boilers (K3 and K4) is approximately 0.15-0.20 lb/MMBtu.<sup>18</sup> LNB systems and LNB systems with OFA are technically feasible for the Kahe boilers K1, K2, K3, K4, and K5.

### 4.1.3. Post Combustion Controls

#### 4.1.3.1. Selective Catalytic Reduction (SCR)

SCR refers to the process in which NO<sub>x</sub> is reduced by ammonia over a heterogeneous catalyst in the presence of oxygen. The process is termed selective because the ammonia preferentially reacts with NO<sub>x</sub> rather than oxygen, although the oxygen enhances the reaction and is a necessary component of the process. The overall reactions are:



The SCR process requires a reactor, catalyst, ammonia storage, and an ammonia injection system. The effectiveness of an SCR system is dependent on a variety of factors, including the inlet NO<sub>x</sub> concentration, the exhaust temperature, the ammonia injection rate, and the type of catalyst. The

<sup>16</sup> Ibid.

<sup>17</sup> Ibid.

<sup>18</sup> Ibid.

**Table 4-3. Control Effectiveness of Technically Feasible NO<sub>x</sub> Control Technologies**

Control Technology	Estimated Controlled Level	
	Wall-Fired Boilers	Tangentially-Fired Boilers
	(lb/MMBtu)	(lb/MMBtu)
SCR+Combustion Controls	0.05	0.05
SCR	0.05 - 0.10	0.03 - 0.10
LNB & OFA	0.25 - 0.30	0.15 - 0.20
FGR	0.25 - 0.30	0.15 - 0.20
LNB	0.25 - 0.35	0.15 - 0.20
SNCR+Combustion Controls	0.20 - 0.40	0.15 - 0.25
SNCR	0.30 - 0.40	0.20 - 0.25
OFA	0.30 - 0.45	0.20 - 0.30
Fuel Switching	0.27 - 0.62	0.28 - 0.34

The control levels in Table 4-3 are presented as a range because the specific level of control that is achievable for the Kahe boilers based on the application of the controls listed in Table 4-3 is unknown. Engineering studies would be required for each boiler to determine the best combustion control option or combinations of control options and the level of control achievable. It is estimated that such an engineering study could take an up to ten (10) months to complete at a cost of approximately \$532,500 for the Kahe Generating Station. It is anticipated that combustion controls such as LNB with OFA, or LNB with FGR and possibly LNB, FGR, or OFA alone can achieve NO<sub>x</sub> emission levels of approximately 0.30 lb/MMBtu for K1, K2, and K5 and 0.20 lb/MMBtu for K3 and K4. As noted in Table 4-1, the Kahe boilers are currently emitting in the range of 0.196 lb/MMBtu to 0.802 lb/MMBtu. Further, it is believed that SCR can achieve a NO<sub>x</sub> emissions level of approximately 0.10 lb/MMBtu and 0.05 lb/MMBtu when SCR is combined with combustion controls. The addition of SNCR can achieve a NO<sub>x</sub> emissions levels of 0.40 lb/MMBtu for K1, K2, and K5, 0.15 lb/MMBtu for K6 and 0.25 lb/MMBtu for K3 and K4. SNCR combined with combustion controls can achieve a NO<sub>x</sub> emissions levels of 0.20 lb/MMBtu for K1, K2, and K5 and 0.15 lb/MMBtu for K3 and K4.

## 4.2. FOUR-FACTOR ANALYSIS

As discussed above, fuel switching, combustion controls, SNCR and SCR are the best feasible options to reduce NO<sub>x</sub> emissions from the boilers. For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors for adding NO<sub>x</sub> controls are discussed in the following sections.

### 4.2.1. Cost of Compliance

For purposes of this four-factor analysis, the capital costs, operating costs, and cost effectiveness of combustion controls, SNCR, and SCR have been estimated for the boilers. The cost effectiveness of combustion controls is based on a controlled NO<sub>x</sub> emissions level of 0.30 lb/MMBtu for K1, K2, and K5 and 0.20 lb/MMBtu for K3 and K4. At this time, it is unknown if LNB, OFA or FGR alone can achieve this level of emissions or if LNB combined with OFA or FGR would be required to meet this level. Therefore, the costing is based on the range of cost for LNB with OFA, the cost of FGR and LNB with FGR are

expected to be covered by this range and have a similar level of NO<sub>x</sub> control. The costing assumes that a NO<sub>x</sub> emissions level of 0.30 lb/MMBtu for K1, K2, and K5 and 0.20 lb/MMBtu for K3 and K4 can be achieved with combustion controls. This level of NO<sub>x</sub> emissions is comparable to SNCR; the only other control expected to result in lower achievable NO<sub>x</sub> emissions is SCR. The cost effectiveness of SNCR is based on a NO<sub>x</sub> emissions levels of 0.40 lb/MMBtu for K1, K2, and K5, 0.15 lb/MMBtu for K6 and 0.25 lb/MMBtu for K3 and K4. The cost effectiveness of SNCR combined with combustion controls is based on a NO<sub>x</sub> emissions levels of 0.20 lb/MMBtu for K1, K2, and K5 and 0.15 lb/MMBtu for K3 and K4. The cost effectiveness of SCR is based on a controlled NO<sub>x</sub> emissions level of 0.10 lb/MMBtu and 0.05 lb/MMBtu when combustion controls are combined with SCR. The cost of fuel switching is discussed in Section 3.2.1.

Table 4-4 presents a summary of the cost effectiveness of fuel switching, adding combustion controls, SNCR, SNCR combined with combustion controls, SCR and SCR combined with combustion controls to the boiler. The cost effectiveness is determined by dividing the annual cost by the annual reduction in NO<sub>x</sub> emissions. The cost effectiveness of fuel switching ranges from \$13,266 per ton to more than \$70,000 per ton of NO<sub>x</sub> emissions in the different units and the total cost exceeds 32 million dollars (\$32,000,000) annually and 960 million dollars (\$960,000,000) over thirty (30) years. The cost effectiveness of combustion controls ranges from \$499 per ton to \$1,318 per ton of NO<sub>x</sub> emissions in the different units and the total cost equals 2 million dollars (\$2,000,000) annually and 60 million dollars (\$60,000,000) over thirty (30) years. The cost effectiveness of SNCR ranges from \$1,326 per ton to \$4,824 per ton of NO<sub>x</sub> in the different units and the total cost equals 5 million (\$5,000,000) annually and 150 million dollars (\$150,000,000) over thirty (30) years. The cost effectiveness of SNCR plus combustion controls ranges from \$1,302 per ton to \$2,987 per ton of NO<sub>x</sub> in the different units and the total cost exceeds 7 million (\$7,000,000) annually and 210 million dollars (\$210,000,000) over thirty (30) years. The cost effectiveness of SCR ranges from \$1,709 per ton to \$6,488 per ton of NO<sub>x</sub> emissions in the different units and the total cost equals 15 million dollars (\$15,000,000) annually and 450 million dollars (\$450,000,000) over thirty (30) years. For units K1 through K5, the cost effectiveness of SCR plus combustion control ranges from \$1,929 per ton to \$4,434 per ton of NO<sub>x</sub> emissions in the different units and the total cost equals 14 million dollars (\$14,000,000) annually and 420 million dollars (\$420,000,000) over thirty (30) years.

#### 4.2.2. Time Necessary to Achieve Compliance

If the DOH determines that controls are needed to achieve reasonable progress, it is anticipated that these changes could be implemented within three to five years.

#### 4.2.3. Energy and Non-Air Quality Environmental Impacts

SNCR and SCR systems require electricity to operate the ancillary equipment. The need for electricity to help power some of the ancillary equipment creates a demand for energy that currently does not exist. SNCR and SCR can potentially cause significant environmental impacts related to the storage of ammonia, and the storage of aqueous ammonia above 10,000 pounds is regulated by the EPA's Risk Management Program (RMP) because the accidental release of ammonia has the potential to cause serious injury and death to persons in the vicinity of the release. SNCR and SCR will likely also cause the release of unreacted ammonia to the atmosphere. This is referred to as ammonia slip. Ammonia slip from SNCR and SCR systems occurs either from ammonia injection at temperatures too low for effective reaction with NO<sub>x</sub>, leading to an excess of unreacted ammonia, or from over-injection of reagent leading to uneven distribution, which also leads to an excess of unreacted ammonia. Ammonia released from SNCR and SCR systems will react with sulfates and nitrates in the atmosphere to form ammonium sulfate and ammonium nitrate. Together, ammonium sulfate and ammonium nitrate are the predominant sources of regional haze.

**Table 4-4. NO<sub>x</sub> Cost effectiveness of Controls Summary**

Unit	Control Option	2017 NO <sub>x</sub> Emissions <sup>A</sup> (tpy)	Controlled Emission Level <sup>B,C</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled NO <sub>x</sub> Emissions (tpy)	NO <sub>x</sub> Reduced (ton/yr)	Total Annual Cost <sup>D,E</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	Residual Oil/ULSD Blend	932.7	0.38	3,778,041	718.2	214.5	\$4,621,182	\$21,542
	ULSD	932.7	0.27	3,778,041	513.0	419.7	\$9,814,026	\$23,383
	Combustion Controls	932.7	0.30	3,778,041	566.7	366.0	\$482,550	\$1,318
	SNCR	932.7	0.40	3,778,041	755.6	177.1	\$854,332	\$4,824
	SNCR+Combustion Controls	932.7	0.20	3,778,041	377.8	554.9	\$1,336,882	\$2,409
	SCR	932.7	0.10	3,778,041	188.9	743.8	\$2,210,698	\$2,972
K2	SCR+Combustion Controls	932.7	0.05	3,778,041	94.5	838.2	\$2,693,248	\$3,213
	Residual Oil/ULSD Blend	963.0	0.50	2,959,869	741.5	221.5	\$3,620,420	\$16,346
	ULSD	963.0	0.36	2,959,869	529.7	433.4	\$7,688,703	\$17,742
	Combustion Controls	963.0	0.30	2,959,869	444.0	519.0	\$467,426	\$901
	SNCR <sup>F</sup>	963.0	0.40	2,959,869	592.0	371.0	\$854,332	\$2,303
	SNCR+Combustion Controls	963.0	0.20	2,959,869	296.0	667.0	\$1,321,758	\$1,982
K3	SCR	963.0	0.10	2,959,869	148.0	815.0	\$2,083,950	\$2,557
	SCR+Combustion Controls	963.0	0.05	2,959,869	74.0	889.0	\$2,551,376	\$2,870
	Residual Oil/ULSD Blend	661.7	0.32	3,753,356	595.5	66.2	\$4,590,989	\$69,382
	ULSD	661.7	0.28	3,753,356	529.4	132.3	\$9,749,905	\$73,673
	Combustion Controls	661.7	0.20	3,753,356	375.3	286.4	\$346,310	\$1,209
	SNCR	661.7	0.25	3,753,356	469.2	192.5	\$789,403	\$4,100
K4	SNCR+Combustion Controls	661.7	0.15	3,753,356	281.5	380.2	\$1,135,713	\$2,987
	SCR	661.7	0.10	3,753,356	187.7	474.0	\$2,171,338	\$4,581
	SCR+Combustion Controls	661.7	0.05	3,753,356	93.8	567.9	\$2,517,649	\$4,434
	Residual Oil/ULSD Blend	732.2	0.34	3,858,826	659.0	73.2	\$4,719,995	\$64,463
	ULSD	732.2	0.30	3,858,826	585.8	146.4	\$10,023,877	\$68,450
	Combustion Controls	732.2	0.20	3,858,826	385.9	346.3	\$349,044	\$1,008
K5	SNCR <sup>F</sup>	732.2	0.25	3,858,826	482.4	249.8	\$789,403	\$3,160
	SNCR+Combustion Controls	732.2	0.15	3,858,826	289.4	442.8	\$1,138,447	\$2,571
	SCR	732.2	0.10	3,858,826	192.9	539.3	\$2,202,873	\$4,085
	SCR+Combustion Controls	732.2	0.05	3,858,826	96.5	635.7	\$2,551,917	\$4,014
	Residual Oil/ULSD Blend	2,044.2	0.62	5,099,323	1,574.0	470.2	\$6,237,333	\$13,266
	ULSD	2,044.2	0.44	5,099,323	1,124.3	919.9	\$13,246,254	\$14,400
K6	Combustion Controls	2,044.2	0.30	5,099,323	764.9	1,279.3	\$638,537	\$499
	SNCR	2,044.2	0.40	5,099,323	1,019.9	1,024.3	\$1,358,582	\$1,326
	SNCR+Combustion Controls	2,044.2	0.20	5,099,323	509.9	1,534.3	\$1,997,119	\$1,302
	SCR	2,044.2	0.10	5,099,323	255.0	1,789.2	\$3,058,173	\$1,709
	SCR+Combustion Controls	2,044.2	0.05	5,099,323	127.5	1,916.7	\$3,696,710	\$1,929
	Residual Oil/ULSD Blend	630.1	0.16	6,424,644	516.7	113.4	\$7,858,425	\$69,287
K6	ULSD	630.1	0.13	6,424,644	403.3	226.8	\$16,688,974	\$73,573
	SNCR <sup>G</sup>	630.1	0.15	6,424,644	481.8	148.3	\$883,819	\$5,962
	SCR <sup>G</sup>	630.1	0.05	6,424,644	160.6	469.5	\$3,045,798	\$6,488

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> The controlled emission level for ULSD is based on the No. 2 fuel oil emission factor from AP-42, Table 1.3-1, dated May 2010. The controlled emission level for the 50/50 residual oil/ULSD blend is based on the average of the AP-42 emission factor for No. 2 fuel oil and the 2017 emission factor.

<sup>C</sup> Controlled emission levels based on "Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler" EPA, 1994.

<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-3 and 3-4. The annual costs of fuel switching are based on 2019 dollars.

<sup>E</sup> See Appendix A for the total annual cost calculations for combustion controls, SNCR and SCR.

<sup>F</sup> The annual cost for K2 is based on K1 which has a similar design and rating and the annual cost for K4 is based on K3 which has a similar design and rating.

<sup>G</sup> K6 is equipped with combustion controls, the level of SCR control was reduced to 0.05 lb/MMBtu to account for the combined level of control.



Table 5-3. PM<sub>10</sub> Cost Effectiveness Summary

Unit	Control Option	2017 PM <sub>10</sub> Emissions <sup>A</sup> (tpy)	Controlled Emission Level <sup>B</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled PM <sub>10</sub> Emissions (tpy)	PM <sub>10</sub> Reduced (ton/yr)	Total Annual Cost <sup>C</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	Residual Oil/ULSD Blend	55.7	0.0203	3,778,041	38.4	17.3	\$4,621,182	\$267,631
	ULSD	55.7	0.0112	3,778,041	21.2	34.5	\$9,814,026	\$284,184
K2	Residual Oil/ULSD Blend	39.3	0.0183	2,959,869	27.1	12.2	\$3,620,420	\$297,170
	ULSD	39.3	0.0101	2,959,869	14.9	24.4	\$7,688,703	\$315,550
K3	Residual Oil/ULSD Blend	51.7	0.0190	3,753,356	35.7	16.0	\$4,590,989	\$286,453
	ULSD	51.7	0.0105	3,753,356	19.6	32.1	\$9,749,905	\$304,171
K4	Residual Oil/ULSD Blend	50.5	0.0181	3,858,826	34.8	15.7	\$4,719,995	\$301,501
	ULSD	50.5	0.0099	3,858,826	19.2	31.3	\$10,023,877	\$320,149
K5	Residual Oil/ULSD Blend	78.7	0.0213	5,099,323	54.3	24.4	\$6,237,333	\$255,660
	ULSD	78.7	0.0117	5,099,323	29.9	48.8	\$13,246,254	\$271,473
K6	Residual Oil/ULSD Blend	108.6	0.0233	6,424,644	74.9	33.7	\$7,858,425	\$233,423
	ULSD	108.6	0.0128	6,424,644	41.3	67.3	\$16,688,974	\$247,861

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> The controlled emission level for ULSD is based on the No. 2 fuel oil emission factor from AP-42, Table 1.3-1, dated May 2010. The controlled emission level for the 50/50 residual oil/ULSD blend is based on the average of the AP-42 emission factor for No. 2 fuel oil and the 2017 emission factor.

<sup>C</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-3 and 3-4. The annual costs of fuel switching are based on 2019 dollars.

**Appendix Table A-1. CDS Capital and O&M Cost Estimate**

Unit MW Rating (Nominal) Classification	K1 92 Fuel Oil	K2 90 Fuel Oil	K3 92 Fuel Oil	K4 93 Fuel Oil	K5 142 Fuel Oil	K6 142 Fuel Oil
<b>Capital Cost</b>						
<b>Direct Costs</b>						
Total Direct Costs (DC)	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 61,988,000	\$ 61,988,000
<b>Indirect Costs</b>						
Summary of Indirect Costs not including Contingency	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 19,142,000	\$ 19,142,000
Contingencies	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 21,468,000	\$ 21,468,000
Total Indirect Costs (IC)	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 40,610,000	\$ 40,610,000
<b>Allowance for Funds Used During Construction (AFDC)</b>	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 10,466,000	\$ 10,466,000
<b>Total Capital Investment (TCI)</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 113,064,000</b>	<b>\$ 113,064,000</b>
<b>Annual Cost</b>						
<b>Direct Annual Costs</b>						
<b>Fixed Annual Costs</b>						
Maintenance labor and materials	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Total Fixed Annual Costs	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
<b>Variable Annual Costs</b>						
Byproduct disposal	\$ 273,000	\$ 294,000	\$ 377,000	\$ 314,000	\$ 478,000	\$ 352,000
Reagent Cost (lime)	\$ 632,000	\$ 679,000	\$ 864,000	\$ 740,000	\$ 1,582,000	\$ 1,204,000
Water Cost	\$ 51,000	\$ 54,000	\$ 69,000	\$ 58,000	\$ 116,000	\$ 88,000
Power (ID and Aux) Cost	\$ 1,561,000	\$ 1,675,000	\$ 2,151,000	\$ 1,805,000	\$ 4,259,000	\$ 3,161,000
Total Variable Annual Costs	\$ 2,517,000	\$ 2,702,000	\$ 3,461,000	\$ 2,917,000	\$ 6,435,000	\$ 4,805,000
Total Direct Annual Costs (DAC)	\$ 4,305,000	\$ 4,490,000	\$ 5,249,000	\$ 4,705,000	\$ 8,878,000	\$ 7,248,000
<b>Indirect Annual Costs</b>						
Cost for capital recovery <sup>2</sup>	\$ 5,903,196	\$ 5,903,196	\$ 5,903,196	\$ 5,903,196	\$ 9,111,421	\$ 9,111,421
Total Indirect Annual Costs (IDAC)	\$ 5,903,196	\$ 5,903,196	\$ 5,903,196	\$ 5,903,196	\$ 9,111,421	\$ 9,111,421
<b>Total Annual Cost (TAC) - 2012 Dollars</b>	<b>\$ 10,208,196</b>	<b>\$ 10,393,196</b>	<b>\$ 11,152,196</b>	<b>\$ 10,608,196</b>	<b>\$ 17,989,421</b>	<b>\$ 16,359,421</b>
<b>Total Annual Cost (TAC) - 2019 Dollars<sup>3</sup></b>	<b>\$ 10,608,072</b>	<b>\$ 10,800,319</b>	<b>\$ 11,589,051</b>	<b>\$ 11,023,741</b>	<b>\$ 18,694,104</b>	<b>\$ 17,000,254</b>

<sup>1</sup> Costing from an Hawaiian Electric internal study dated July 2012.

<sup>2</sup> Capital Recovery Factor (CRF) =  $[I \times (1+i)^a] / [(1+i)^a - 1]$  CRF = 0.08

Where:

I = Interest Rate (7% interest)

a = Equipment life (30 yrs)

<sup>3</sup> Cost scaled to 2019 dollars using the Chemical Engineering Plant Cost Index (CEPCI) for 2012 (584.6) and 2019 (607.5). As published in Chemical Engineering Magazine - Revision: 18, Apr 16, 2019 and <https://www.chemengonline.com/2019-chemical-engineering-plant-cost-index-annual-average/>

**Appendix Table A-2. Combustion Controls Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4	K5
Boiler design capacity, mmBtu/hr (C)		903	900	892	918	1468
Boiler Type		Normal	Normal	Tangential	Tangential	Normal
2017 Annual Heat Input, MMBtu/yr (H)		3,778,041	2,959,869	3,753,356	3,858,826	5,099,323
Unit Size, kW (kW)		92,000	90,000	92,000	93,000	142,000
Unit Size, MW (MW)		92.0	90.0	92.0	93.0	142.0
Capital recovery factor a. Equipment CRF, 30-yr life, 7% interest	$= [ I \times (1+i)^a ] / [ (1+i)^a - 1 ]$ where I = interest rate, a = equipment life	0.08	0.08	0.08	0.08	0.08
Cost Index (CI) <sup>A</sup> a. 2019 b. 2004	607.5 444.2					
Total Capital Investment <sup>B,C</sup> TCI (\$)	$= \$24/kW \times kW \times (300/MW)^{0.359} \times (CI_{2018}/CI_{2004})$ - Wall $= \$18/kW \times kW \times (300/MW)^{0.359} \times (CI_{2018}/CI_{2004})$ - Tangential	\$4,615,869	\$4,551,295	\$3,461,902	\$3,485,976	\$6,096,525
Direct Annual Operating Costs \$/yr Variable O&M Costs <sup>D</sup>	$= (\$0.08 \text{ mills/kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times H \times 10^6$ $\text{Btu/mmBtu} \times (CI_{2018}/CI_{2004})$ - Wall $\$0.03 \text{ mills/kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times H \times 10^6$ $\text{Btu/mmBtu} \times (CI_{2018}/CI_{2004})$ - Tangential	\$41,336	\$32,384	\$15,400	\$15,832	\$55,792
Indirect Annual Costs, \$/yr 1. Fixed O&M Costs <sup>E</sup>  2. Capital recovery	$= \$0.36/kW \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW/MW}) \times$ $(300/MW)^{0.359} \times (CI_{2018}/CI_{2004})$ - Wall $= \$0.27/kW \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW/MW}) \times$ $(300/MW)^{0.359} \times (CI_{2018}/CI_{2004})$ - Tangential $= \text{Equipment CRF} \times \text{TCI}$	\$69,238  \$371,976	\$68,269  \$366,772	\$51,929  \$278,982	\$52,290  \$280,922	\$91,448  \$491,297
<b>Total Annual Cost \$/yr</b>	$= \text{Direct Annual Costs} + \text{Indirect Annual Costs}$	<b>\$482,550</b>	<b>\$467,426</b>	<b>\$346,310</b>	<b>\$349,044</b>	<b>\$638,537</b>

**Source:** All costs were estimated using Section 4.3 and Appendix D of the WRAP guidance document, *Analysis of Combustion Controls for Reducing NOx Emissions from Coal-fired EGUs in the WRAP Region*, dated September 6, 2005. The cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). As published in Chemical Engineering Magazine - Revision: 18, Apr 16, 2019 and <https://www.chemengonline.com/2019-chemical-engineering-plant-cost-index-annual-average/>

<sup>B</sup> TCI for LNB and LNB w/over fire air ranges from \$6/kW to \$24/kW for wall boilers and \$10/kW to \$18/kW for tangential boilers, the high end of the range was used due to Hawai'i's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>C</sup> Scaling factor =  $(300/\text{Nameplate capacity})^{0.359}$

<sup>D</sup> The variable O&M costs for LNB and LNB w/over fire air ranges from 0.05 mills/kW-hr to 0.08 mills/kW-hr for wall boilers and 0.027 mills/kW-hr to 0.03 mills/kW-hr for tangential boilers, the high end of the range was used due to Hawai'i's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>E</sup> The fixed O&M costs for LNB and LNB w/over fire air ranges from \$0.09/kW to \$0.36/kW for wall boilers and \$0.15/kW to \$0.27/kW for tangential boilers, the high end of the range was used due to Hawai'i's remote location.

## Attachment Table A-3a. Kahe K1 - SCR Costing

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility

What type of fuel does the unit burn? Fuel Oil

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1.5

\* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 92 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWhs output? 384,917 MWhs

Enter the net plant heat input rate (NPHR) 9.8152 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) =   percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Attachment Table A-3a. Kahe K1 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.494 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>			
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*	<u>Densities of typical SCR reagents:</u> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used	Ammonia		

Enter the cost data for the proposed SCR:

Desired dollar-year	2019		
CEPCI for 2019	607.5	541.7	2016 CEPCI
Annual Interest Rate (i)	7.00 Percent	CEPCI = Chemical Engineering Plant Cost Index	
Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*	<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>	
Electricity (Cost <sub>elec</sub> )	0.2521 \$/kWh		
Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)	<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>	
Operator Labor Rate	60.00 \$/hour (including benefits)*	<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>	
Operator Hours/Day	4.00 hours/day*	<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>	
<small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small>			

## Attachment Table A-3a. Kahe K1 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

## Attachment Table A-3a. Kahe K1 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	903	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	805,920	MWhs
Estimated Actual Annual MWhs Output (Boutput) =		384,917	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.98	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tplant) =$	0.478	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4184	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	79.7	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	355.55	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	743.80	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	1.00	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700)N_{scr} =$	418,214	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	111.61	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7) / 518.6]^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

Not applicable; factor applies only to coal-fired boilers

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / (1 + interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x_{adj}} \times S_{adj} \times (T_{adj}/N_{scr})$	3,746.95	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	436	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Attachment Table A-3a. Kahe K1 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	501	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.4	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	52	feet

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft <sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_G \times EF \times SRF \times MW_N) / MW_{NO_x}$	138	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / CSol =$	476	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	64	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	45,900	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i = Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	511.08	kW



## Attachment Table A-3a. Kahe K1 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEVF \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEVF \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,543,429</b>	<b>in 2019 dollars</b>

## Attachment Table A-3a. Kahe K1 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$793,017 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,417,681 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$2,210,698 in 2019 dollars
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$87,717 in 2019 dollars
Annual Reagent Cost =	$m_{SO_2} \times Cost_{reag} \times t_{op} =$	\$78,028 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$539,069 in 2019 dollars
Annual Catalyst Replacement Cost =		\$88,203 in 2019 dollars
	$n_{SCR} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	
Direct Annual Cost =		\$793,017 in 2019 dollars
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,681 in 2019 dollars
Capital Recovery Costs (CR) =	$CRF \times TCI =$	\$1,414,000 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$1,417,681 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,210,698 per year in 2019 dollars
NOx Removed =		744 tons/year
Cost Effectiveness =		\$2,972 per ton of NOx removed in 2019 dollars

## Appendix Table A-3b. Kahe K2 - SCR Costing

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility

What type of fuel does the unit burn? Fuel Oil

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1.5

\* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 90 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWhs output? 295,987 MWhs

Enter the net plant heat input rate (NPHR) 10.0000 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) =   percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Appendix Table A-3b. Kahe K2 - SCR Costing

Enter the following design parameters for the proposed SCR:

<p>Number of days the SCR operates (<math>t_{SCR}</math>)</p> <p>Number of days the boiler operates (<math>t_{plant}</math>)</p> <p>Inlet NO<sub>x</sub> Emissions (NO<sub>x<sub>in</sub></sub>) to SCR</p> <p>Outlet NO<sub>x</sub> Emissions (NO<sub>x<sub>out</sub></sub>) from SCR</p> <p>Stoichiometric Ratio Factor (SRF)</p> <p><small>**The SRF value of 1.05 is a default value. User should enter actual value, if known.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">0.651 lb/MMBtu</td></tr> <tr><td style="text-align: center;">0.1 lb/MMBtu</td></tr> <tr><td style="text-align: center;">1.050</td></tr> </table>	365 days	365 days	0.651 lb/MMBtu	0.1 lb/MMBtu	1.050	<p>Number of SCR reactor chambers (<math>n_{scr}</math>)</p> <p>Number of catalyst layers (<math>R_{layer}</math>)</p> <p>Number of empty catalyst layers (<math>R_{empty}</math>)</p> <p>Ammonia Slip (Slip) provided by vendor</p> <p>Volume of the catalyst layers (<math>Vol_{catalyst}</math>) (Enter "UNK" if value is not known)</p> <p>Flue gas flow rate (<math>Q_{fluegas}</math>) (Enter "UNK" if value is not known)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">3</td></tr> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">2 ppm</td></tr> <tr><td style="text-align: center;">UNK Cubic feet</td></tr> <tr><td style="text-align: center;">UNK acfm</td></tr> </table>	1	3	1	2 ppm	UNK Cubic feet	UNK acfm
365 days														
365 days														
0.651 lb/MMBtu														
0.1 lb/MMBtu														
1.050														
1														
3														
1														
2 ppm														
UNK Cubic feet														
UNK acfm														
<p>Estimated operating life of the catalyst (<math>H_{catalyst}</math>)</p> <p>Estimated SCR equipment life</p> <p><small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">24,000 hours</td></tr> <tr><td style="text-align: center;">30 Years*</td></tr> </table>	24,000 hours	30 Years*	<p>Gas temperature at the SCR inlet (T)</p> <p>Base case fuel gas volumetric flow rate factor (<math>Q_{fuel}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">650 °F</td></tr> <tr><td style="text-align: center;">484 ft<sup>3</sup>/min-MMBtu/hour</td></tr> </table>	650 °F	484 ft <sup>3</sup> /min-MMBtu/hour							
24,000 hours														
30 Years*														
650 °F														
484 ft <sup>3</sup> /min-MMBtu/hour														
<p>Concentration of reagent as stored (<math>C_{stored}</math>)</p> <p>Density of reagent as stored (<math>\rho_{stored}</math>)</p> <p>Number of days reagent is stored (<math>t_{storage}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">29 percent*</td></tr> <tr><td style="text-align: center;">56 lb/cubic feet*</td></tr> <tr><td style="text-align: center;">30 days</td></tr> </table>	29 percent*	56 lb/cubic feet*	30 days	<p><small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small></p>									
29 percent*														
56 lb/cubic feet*														
30 days														
<p>Select the reagent used <span style="border: 1px solid black; padding: 2px;">Ammonia</span></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td colspan="2" style="text-align: center;"><b>Densities of typical SCR reagents:</b></td></tr> <tr><td style="width: 50%;">50% urea solution</td><td style="text-align: right;">71 lbs/ft<sup>3</sup></td></tr> <tr><td>29.4% aqueous NH<sub>3</sub></td><td style="text-align: right;">56 lbs/ft<sup>3</sup></td></tr> </table>			<b>Densities of typical SCR reagents:</b>		50% urea solution	71 lbs/ft <sup>3</sup>	29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>					
<b>Densities of typical SCR reagents:</b>														
50% urea solution	71 lbs/ft <sup>3</sup>													
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>													

Enter the cost data for the proposed SCR:

<p>Desired dollar-year</p> <p>CEPCI for 2019</p> <p>Annual Interest Rate (i)</p> <p>Reagent (Cost<sub>reag</sub>)</p> <p>Electricity (Cost<sub>elec</sub>)</p> <p>Catalyst cost (CC<sub>replace</sub>)</p> <p>Operator Labor Rate</p> <p>Operator Hours/Day</p> <p>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">2019</td></tr> <tr><td style="text-align: center;">607.5</td></tr> <tr><td style="text-align: center;">7.0 Percent</td></tr> <tr><td style="text-align: center;">0.293 \$/gallon for 29% ammonia*</td></tr> <tr><td style="text-align: center;">0.2521 \$/kWh</td></tr> <tr><td style="text-align: center;">227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)</td></tr> <tr><td style="text-align: center;">60.00 \$/hour (including benefits)*</td></tr> <tr><td style="text-align: center;">4.00 hours/day*</td></tr> </table>	2019	607.5	7.0 Percent	0.293 \$/gallon for 29% ammonia*	0.2521 \$/kWh	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)	60.00 \$/hour (including benefits)*	4.00 hours/day*	<p>CEPCI = Chemical Engineering Plant Cost Index</p> <p><small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small></p> <p><small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small></p> <p><small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small></p> <p><small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small></p>
2019										
607.5										
7.0 Percent										
0.293 \$/gallon for 29% ammonia*										
0.2521 \$/kWh										
227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)										
60.00 \$/hour (including benefits)*										
4.00 hours/day*										

## Appendix Table A-3b. Kahe K2 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

## Appendix Table A-3b. Kahe K2 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	900	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	788,400	MWhs
Estimated Actual Annual MWhs Output (Boutput) =		295,987	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.00	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tplant) =$	0.375	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	3289	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	84.6	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	495.63	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	815.01	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	1.06	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \rho_{scr} =$	416,824	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	101.67	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7) / 518.6]^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgc.nasa.gov/education/rocket/atmos.html>.

Not applicable; factor applies only to coal-fired boilers

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / (1 + interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x_{in}} \times S_{adj} \times (T_{adj}/N_{scr})$	4,099.76	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	434	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Appendix Table A-3b. Kahe K2 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	499	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.3	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	54	feet

**Reagent Data:**

Type of reagent used Ammonia Molecular Weight of Reagent (MW) = 17.03 g/mole  
Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_G \times EF \times SRF \times MW_N) / MW_{NO_x}$	193	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	664	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	89	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	63,900	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1$ Where n = Equipment Life and i = Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	504.00	kW

## Appendix Table A-3b. Kahe K2 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEVF \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEVF \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,294,581</b>	<b>in 2019 dollars</b>



## Appendix Table A-3b. Kahe K2 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$686,341 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,397,609 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$2,083,950 in 2019 dollars</b>
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$86,473 in 2019 dollars
Annual Reagent Cost =	$m_{SO_2} \times Cost_{reag} \times t_{op} =$	\$85,498 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$417,862 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{SCR} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$96,508 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$686,341 in 2019 dollars</b>
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,666 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,393,943 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$1,397,609 in 2019 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,083,950 per year in 2019 dollars
NOx Removed =		815 tons/year
<b>Cost Effectiveness =</b>		<b>\$2,557 per ton of NOx removed in 2019 dollars</b>

## Appendix Table A-3c. Kahe K3 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWhs output?  MWhs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Appendix Table A-3c. Kahe K3 - SCR Costing

Enter the following design parameters for the proposed SCR:

<p>Number of days the SCR operates (<math>t_{SCA}</math>)</p> <p>Number of days the boiler operates (<math>t_{plant}</math>)</p> <p>Inlet NO<sub>x</sub> Emissions (NO<sub>x<sub>in</sub></sub>) to SCR</p> <p>Outlet NO<sub>x</sub> Emissions (NO<sub>x<sub>out</sub></sub>) from SCR</p> <p>Stoichiometric Ratio Factor (SRF)</p> <p><small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">0.353 lb/MMBtu</td></tr> <tr><td style="text-align: center;">0.1 lb/MMBtu</td></tr> <tr><td style="text-align: center;">1.050</td></tr> </table>	365 days	365 days	0.353 lb/MMBtu	0.1 lb/MMBtu	1.050	<p>Number of SCR reactor chambers (<math>n_{scr}</math>)</p> <p>Number of catalyst layers (<math>R_{layer}</math>)</p> <p>Number of empty catalyst layers (<math>R_{empty}</math>)</p> <p>Ammonia Slip (Slip) provided by vendor</p> <p>Volume of the catalyst layers (<math>Vol_{catalyst}</math>) (Enter "UNK" if value is not known)</p> <p>Flue gas flow rate (<math>Q_{fluegas}</math>) (Enter "UNK" if value is not known)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">3</td></tr> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">2 ppm</td></tr> <tr><td style="text-align: center;">UNK Cubic feet</td></tr> <tr><td style="text-align: center;">UNK acfm</td></tr> </table>	1	3	1	2 ppm	UNK Cubic feet	UNK acfm
365 days														
365 days														
0.353 lb/MMBtu														
0.1 lb/MMBtu														
1.050														
1														
3														
1														
2 ppm														
UNK Cubic feet														
UNK acfm														
<p>Estimated operating life of the catalyst (<math>H_{catalyst}</math>)</p> <p>Estimated SCR equipment life</p> <p><small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">24,000 hours</td></tr> <tr><td style="text-align: center;">30 Years*</td></tr> </table>	24,000 hours	30 Years*	<p>Gas temperature at the SCR inlet (T)</p> <p>Base case fuel gas volumetric flow rate factor (<math>Q_{fuel}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">650 °F</td></tr> <tr><td style="text-align: center;">484 ft<sup>3</sup>/min-MMBtu/hour</td></tr> </table>	650 °F	484 ft <sup>3</sup> /min-MMBtu/hour							
24,000 hours														
30 Years*														
650 °F														
484 ft <sup>3</sup> /min-MMBtu/hour														
<p>Concentration of reagent as stored (<math>C_{stored}</math>)</p> <p>Density of reagent as stored (<math>\rho_{stored}</math>)</p> <p>Number of days reagent is stored (<math>t_{storage}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">29 percent*</td></tr> <tr><td style="text-align: center;">56 lb/cubic feet*</td></tr> <tr><td style="text-align: center;">30 days</td></tr> </table>	29 percent*	56 lb/cubic feet*	30 days	<p><small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small></p>									
29 percent*														
56 lb/cubic feet*														
30 days														
<p>Select the reagent used <span style="float: right;">Ammonia ▼</span></p>	<p><b>Densities of typical SCR reagents:</b></p> <table border="0" style="width: 100%;"> <tr> <td>50% urea solution</td> <td style="text-align: right;">71 lbs/ft<sup>3</sup></td> </tr> <tr> <td>29.4% aqueous NH<sub>3</sub></td> <td style="text-align: right;">56 lbs/ft<sup>3</sup></td> </tr> </table>			50% urea solution	71 lbs/ft <sup>3</sup>	29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>							
50% urea solution	71 lbs/ft <sup>3</sup>													
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>													

Enter the cost data for the proposed SCR:

<p>Desired dollar-year</p> <p>CEPCI for 2019</p> <p>Annual Interest Rate (i)</p> <p>Reagent (Cost<sub>reag</sub>)</p> <p>Electricity (Cost<sub>elec</sub>)</p> <p>Catalyst cost (CC<sub>replace</sub>)</p> <p>Operator Labor Rate</p> <p>Operator Hours/Day</p> <p>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">2019</td></tr> <tr><td style="text-align: center;">607.5</td></tr> <tr><td style="text-align: center;">7.0 Percent</td></tr> <tr><td style="text-align: center;">0.293 \$/gallon for 29% ammonia*</td></tr> <tr><td style="text-align: center;">0.2521 \$/kWh</td></tr> <tr><td style="text-align: center;">227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)</td></tr> <tr><td style="text-align: center;">60.00 \$/hour (including benefits)*</td></tr> <tr><td style="text-align: center;">4.00 hours/day*</td></tr> </table>	2019	607.5	7.0 Percent	0.293 \$/gallon for 29% ammonia*	0.2521 \$/kWh	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)	60.00 \$/hour (including benefits)*	4.00 hours/day*	<p>CEPCI = Chemical Engineering Plant Cost Index</p> <p><small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small></p> <p><small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small></p> <p><small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small></p> <p><small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small></p>
2019										
607.5										
7.0 Percent										
0.293 \$/gallon for 29% ammonia*										
0.2521 \$/kWh										
227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)										
60.00 \$/hour (including benefits)*										
4.00 hours/day*										

## Appendix Table A-3c. Kahe K3 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

## Appendix Table A-3c. Kahe K3 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	892	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	805,920	MWhs
Estimated Actual Annual MWhs Output (Boutput) =		387,117	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.97	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tplant) =$	0.480	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4208	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	71.6	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	225.31	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	474.03	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.90	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700)N_{scr} =$	413,119	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	126.44	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7) / 518.6]^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / (1 + interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x_{in}} \times S_{adj} \times (T_{adj}/N_{scr})$	3,267.24	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	430	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Appendix Table A-3c. Kahe K3 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	495	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.2	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used: Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole  
Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_G \times EF \times SRF \times MW_N) / MW_{NO_x}$	88	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / CSol =$	302	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	40	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	29,100	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1)$ Where n = Equipment Life and i = Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	508.40	kW

### Appendix Table A-3c. Kahe K3 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEVF \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEVF \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,543,429</b>	<b>in 2019 dollars</b>

## Appendix Table A-3c. Kahe K3 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$753,657 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,417,681 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$2,171,338 in 2019 dollars
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$87,717 in 2019 dollars
Annual Reagent Cost =	$m_{SO_2} \times Cost_{reag} \times t_{op} =$	\$49,728 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$539,302 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{SCR} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$76,910 in 2019 dollars
Direct Annual Cost =		\$753,657 in 2019 dollars
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,681 in 2019 dollars
Capital Recovery Costs (CR) =	$CRF \times TCI =$	\$1,414,000 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$1,417,681 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,171,338 per year in 2019 dollars
NOx Removed =		474 tons/year
Cost Effectiveness =		\$4,581 per ton of NOx removed in 2019 dollars



## Appendix Table A-3d. Kahe K4 - SCR Costing

### Data Inputs

**Enter the following data for your combustion unit:**

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWhs output?  MWhs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Appendix Table A-3d. Kahe K4 - SCR Costing

Enter the following design parameters for the proposed SCR:

<p>Number of days the SCR operates (<math>t_{SCR}</math>)</p> <p>Number of days the boiler operates (<math>t_{plant}</math>)</p> <p>Inlet NO<sub>x</sub> Emissions (NO<sub>x,in</sub>) to SCR</p> <p>Outlet NO<sub>x</sub> Emissions (NO<sub>x,out</sub>) from SCR</p> <p>Stoichiometric Ratio Factor (SRF)</p> <p><small>**The SRF value of 1.05 is a default value. User should enter actual value, if known.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">0.379 lb/MMBtu</td></tr> <tr><td style="text-align: center;">0.1 lb/MMBtu</td></tr> <tr><td style="text-align: center;">1.050</td></tr> </table>	365 days	365 days	0.379 lb/MMBtu	0.1 lb/MMBtu	1.050	<p>Number of SCR reactor chambers (<math>n_{scr}</math>)</p> <p>Number of catalyst layers (<math>R_{layer}</math>)</p> <p>Number of empty catalyst layers (<math>R_{empty}</math>)</p> <p>Ammonia Slip (Slip) provided by vendor</p> <p>Volume of the catalyst layers (<math>Vol_{catalyst}</math>) (Enter "UNK" if value is not known)</p> <p>Flue gas flow rate (<math>Q_{fluegas}</math>) (Enter "UNK" if value is not known)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">3</td></tr> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">2 ppm</td></tr> <tr><td style="text-align: center;">UNK Cubic feet</td></tr> <tr><td style="text-align: center;">UNK acfm</td></tr> </table>	1	3	1	2 ppm	UNK Cubic feet	UNK acfm
365 days														
365 days														
0.379 lb/MMBtu														
0.1 lb/MMBtu														
1.050														
1														
3														
1														
2 ppm														
UNK Cubic feet														
UNK acfm														
<p>Estimated operating life of the catalyst (<math>H_{catalyst}</math>)</p> <p>Estimated SCR equipment life</p> <p><small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">24,000 hours</td></tr> <tr><td style="text-align: center;">30 Years*</td></tr> </table>	24,000 hours	30 Years*	<p>Gas temperature at the SCR inlet (T)</p> <p>Base case fuel gas volumetric flow rate factor (<math>Q_{fuel}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">650 °F</td></tr> <tr><td style="text-align: center;">484 ft<sup>3</sup>/min-MMBtu/hour</td></tr> </table>	650 °F	484 ft <sup>3</sup> /min-MMBtu/hour							
24,000 hours														
30 Years*														
650 °F														
484 ft <sup>3</sup> /min-MMBtu/hour														
<p>Concentration of reagent as stored (<math>C_{stored}</math>)</p> <p>Density of reagent as stored (<math>\rho_{stored}</math>)</p> <p>Number of days reagent is stored (<math>t_{storage}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">29 percent*</td></tr> <tr><td style="text-align: center;">56 lb/cubic feet*</td></tr> <tr><td style="text-align: center;">30 days</td></tr> </table>	29 percent*	56 lb/cubic feet*	30 days	<p><small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small></p>									
29 percent*														
56 lb/cubic feet*														
30 days														
<p>Select the reagent used <span style="float: right;">Ammonia ▼</span></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td colspan="2" style="text-align: center;"><b>Densities of typical SCR reagents:</b></td></tr> <tr><td style="width: 50%;">50% urea solution</td><td style="text-align: right;">71 lbs/ft<sup>3</sup></td></tr> <tr><td>29.4% aqueous NH<sub>3</sub></td><td style="text-align: right;">56 lbs/ft<sup>3</sup></td></tr> </table>			<b>Densities of typical SCR reagents:</b>		50% urea solution	71 lbs/ft <sup>3</sup>	29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>					
<b>Densities of typical SCR reagents:</b>														
50% urea solution	71 lbs/ft <sup>3</sup>													
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>													

Enter the cost data for the proposed SCR:

<p>Desired dollar-year</p> <p>CEPCI for 2019</p> <p>Annual Interest Rate (i)</p> <p>Reagent (Cost<sub>reag</sub>)</p> <p>Electricity (Cost<sub>elec</sub>)</p> <p>Catalyst cost (CC<sub>replace</sub>)</p> <p>Operator Labor Rate</p> <p>Operator Hours/Day</p> <p><small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">2019</td></tr> <tr><td style="text-align: center;">607.5</td></tr> <tr><td style="text-align: center;">7.0 Percent</td></tr> <tr><td style="text-align: center;">0.293 \$/gallon for 29% ammonia*</td></tr> <tr><td style="text-align: center;">0.2521 \$/kWh</td></tr> <tr><td style="text-align: center;">227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)</td></tr> <tr><td style="text-align: center;">60.00 \$/hour (including benefits)*</td></tr> <tr><td style="text-align: center;">4.00 hours/day*</td></tr> </table>	2019	607.5	7.0 Percent	0.293 \$/gallon for 29% ammonia*	0.2521 \$/kWh	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)	60.00 \$/hour (including benefits)*	4.00 hours/day*	<p>CEPCI = Chemical Engineering Plant Cost Index</p> <p><small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small></p> <p><small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small></p> <p><small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small></p> <p><small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small></p>	
2019											
607.5											
7.0 Percent											
0.293 \$/gallon for 29% ammonia*											
0.2521 \$/kWh											
227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)											
60.00 \$/hour (including benefits)*											
4.00 hours/day*											

## Appendix Table A-3d. Kahe K4 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

## Appendix Table A-3d. Kahe K4 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	918	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	814,680	MWhs
Estimated Actual Annual MWhs Output (Boutput) =		390,927	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.99	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tplant) =$	0.480	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4204	hours
NOx Removal Efficiency (EF) =	$(NOx_{in} - NOx_{scr})/NOx_{in} =$	73.6	percent
NOx removed per hour =	$NOx_{in} \times EF \times Q_b =$	256.58	lb/hour
Total NO <sub>x</sub> removed per year =	$(NOx_{in} \times EF \times Q_b \times t_{op})/2000 =$	539.26	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.92	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700)N_{scr} =$	425,161	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	122.82	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7) / 518.6]^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / (1 + interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{scr} \times Slipadj \times NOx_{scr} \times S_{scr} \times (T_{scr}/N_{scr})$	3,461.60	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	443	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Appendix Table A-3d. Kahe K4 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	509	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.6	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/ft <sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_G \times EF \times SRF \times MW_N) / MW_{NO_x}$	100	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / CSol =$	344	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	46	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	33,100	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i = Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	517.90	kW

## Appendix Table A-3d. Kahe K4 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEVF \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEVF \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,667,143</b>	<b>in 2019 dollars</b>

## Appendix Table A-3d. Kahe K4 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$775,213 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,427,660 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$2,202,873 in 2019 dollars</b>
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$88,336 in 2019 dollars
Annual Reagent Cost =	$m_{SO_2} \times Cost_{reag} \times t_{op} =$	\$56,571 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$548,821 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{SCR} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$81,486 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$775,213 in 2019 dollars</b>
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,688 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,423,972 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$1,427,660 in 2019 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,202,873 per year in 2019 dollars
NOx Removed =		539 tons/year
<b>Cost Effectiveness =</b>		<b>\$4,085 per ton of NOx removed in 2019 dollars</b>

## Appendix Table A-3e. Kahe K5 - SCR Costing

### Data Inputs

**Enter the following data for your combustion unit:**

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWhs output?  MWhs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable



## Appendix Table A-3e. Kahe K5 - SCR Costing

Enter the following design parameters for the proposed SCR:

<p>Number of days the SCR operates (<math>t_{SCR}</math>)</p> <p>Number of days the boiler operates (<math>t_{plant}</math>)</p> <p>Inlet NO<sub>x</sub> Emissions (NO<sub>x<sub>in</sub></sub>) to SCR</p> <p>Outlet NO<sub>x</sub> Emissions (NO<sub>x<sub>out</sub></sub>) from SCR</p> <p>Stoichiometric Ratio Factor (SRF)</p> <p><small>**The SRF value of 1.05 is a default value. User should enter actual value, if known.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">0.802 lb/MMBtu</td></tr> <tr><td style="text-align: center;">0.1 lb/MMBtu</td></tr> <tr><td style="text-align: center;">1.050</td></tr> </table>	365 days	365 days	0.802 lb/MMBtu	0.1 lb/MMBtu	1.050	<p>Number of SCR reactor chambers (<math>n_{scr}</math>)</p> <p>Number of catalyst layers (<math>R_{layer}</math>)</p> <p>Number of empty catalyst layers (<math>R_{empty}</math>)</p> <p>Ammonia Slip (Slip) provided by vendor</p> <p>Volume of the catalyst layers (<math>Vol_{catalyst}</math>) (Enter "UNK" if value is not known)</p> <p>Flue gas flow rate (<math>Q_{fluegas}</math>) (Enter "UNK" if value is not known)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">3</td></tr> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">2 ppm</td></tr> <tr><td style="text-align: center;">UNK Cubic feet</td></tr> <tr><td style="text-align: center;">UNK acfm</td></tr> </table>	1	3	1	2 ppm	UNK Cubic feet	UNK acfm
365 days														
365 days														
0.802 lb/MMBtu														
0.1 lb/MMBtu														
1.050														
1														
3														
1														
2 ppm														
UNK Cubic feet														
UNK acfm														
<p>Estimated operating life of the catalyst (<math>H_{catalyst}</math>)</p> <p>Estimated SCR equipment life</p> <p><small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">24,000 hours</td></tr> <tr><td style="text-align: center;">30 Years*</td></tr> </table>	24,000 hours	30 Years*	<p>Gas temperature at the SCR inlet (T)</p> <p>Base case fuel gas volumetric flow rate factor (<math>Q_{fuel}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">650 °F</td></tr> <tr><td style="text-align: center;">484 ft<sup>3</sup>/min-MMBtu/hour</td></tr> </table>	650 °F	484 ft <sup>3</sup> /min-MMBtu/hour							
24,000 hours														
30 Years*														
650 °F														
484 ft <sup>3</sup> /min-MMBtu/hour														
<p>Concentration of reagent as stored (<math>C_{stored}</math>)</p> <p>Density of reagent as stored (<math>\rho_{stored}</math>)</p> <p>Number of days reagent is stored (<math>t_{storage}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">29 percent*</td></tr> <tr><td style="text-align: center;">56 lb/cubic feet*</td></tr> <tr><td style="text-align: center;">30 days</td></tr> </table>	29 percent*	56 lb/cubic feet*	30 days	<p><small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small></p>									
29 percent*														
56 lb/cubic feet*														
30 days														
<p>Select the reagent used</p>	<p style="text-align: center;">Ammonia</p>	<p><b>Densities of typical SCR reagents:</b></p> <table border="0" style="width: 100%;"> <tr> <td>50% urea solution</td> <td style="text-align: right;">71 lbs/ft<sup>3</sup></td> </tr> <tr> <td>29.4% aqueous NH<sub>3</sub></td> <td style="text-align: right;">56 lbs/ft<sup>3</sup></td> </tr> </table>		50% urea solution	71 lbs/ft <sup>3</sup>	29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>							
50% urea solution	71 lbs/ft <sup>3</sup>													
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>													

Enter the cost data for the proposed SCR:

<p>Desired dollar-year</p> <p>CEPCI for 2019</p> <p>Annual Interest Rate (i)</p> <p>Reagent (Cost<sub>reag</sub>)</p> <p>Electricity (Cost<sub>elec</sub>)</p> <p>Catalyst cost (CC<sub>replace</sub>)</p> <p>Operator Labor Rate</p> <p>Operator Hours/Day</p> <p>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">2019</td></tr> <tr><td style="text-align: center;">607.5</td></tr> <tr><td style="text-align: center;">7.0 Percent</td></tr> <tr><td style="text-align: center;">0.293 \$/gallon for 29% ammonia*</td></tr> <tr><td style="text-align: center;">0.2521 \$/kWh</td></tr> <tr><td style="text-align: center;">227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)</td></tr> <tr><td style="text-align: center;">60.00 \$/hour (including benefits)*</td></tr> <tr><td style="text-align: center;">4.00 hours/day*</td></tr> </table>	2019	607.5	7.0 Percent	0.293 \$/gallon for 29% ammonia*	0.2521 \$/kWh	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)	60.00 \$/hour (including benefits)*	4.00 hours/day*	<p>CEPCI = Chemical Engineering Plant Cost Index</p> <p><small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small></p> <p><small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small></p> <p><small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small></p> <p><small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small></p>
2019										
607.5										
7.0 Percent										
0.293 \$/gallon for 29% ammonia*										
0.2521 \$/kWh										
227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)										
60.00 \$/hour (including benefits)*										
4.00 hours/day*										

## Appendix Table A-3e. Kahe K5 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

## Appendix Table A-3e. Kahe K5 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	1,468	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	1,243,920	MWhs
Estimated Actual Annual MWhs Output (Boutput) =		493,259	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.03	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tplant) =$	0.397	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	3474	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	87.5	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	1030.17	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	1,789.23	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	1.09	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \rho_{scr} =$	679,886	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	94.77	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7) / 518.6]^{5.256} \times (1/144)^* =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / (1 + interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x_{in}} \times S_{adj} \times (T_{adj}/N_{scr})$	7,173.70	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	708	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## Appendix Table A-3e. Kahe K5 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	814	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	28.5	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	55	feet

**Reagent Data:**

Type of reagent used: Ammonia  
 Molecular Weight of Reagent (MW) = 17.03 g/mole  
 Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_G \times EF \times SRF \times MW_N) / MW_{NO_x}$	400	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	1,381	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	184	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	132,800	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1$ Where n = Equipment Life and i = Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	806.65	kW

## Appendix Table A-3e. Kahe K5 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEVF \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEVF \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$23,261,613</b>	<b>in 2019 dollars</b>

## Appendix Table A-3e. Kahe K5 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$1,179,264 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,878,910 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$3,058,173 in 2019 dollars</b>
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$116,308 in 2019 dollars
Annual Reagent Cost =	$m_{SO_2} \times Cost_{reag} \times t_{op} =$	\$187,699 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$706,389 in 2019 dollars
Annual Catalyst Replacement Cost =		\$168,868 in 2019 dollars
	$n_{SCR} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	
<b>Direct Annual Cost =</b>		<b>\$1,179,264 in 2019 dollars</b>
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$4,024 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,874,886 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$1,878,910 in 2019 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$3,058,173 per year in 2019 dollars
NOx Removed =		1,789 tons/year
<b>Cost Effectiveness =</b>		<b>\$1,709 per ton of NOx removed in 2019 dollars</b>

## Appendix Table A-3f. Kahe K6 - SCR Costing

### Data Inputs

**Enter the following data for your combustion unit:**

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWhs output?  MWhs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in		
	Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

## Appendix Table A-3f. Kahe K6 - SCR Costing

### Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.196 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.05 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>**The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>			
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*	<u>Densities of typical SCR reagents:</u> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>**The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used	Ammonia		

### Enter the cost data for the proposed SCR:

Desired dollar-year	2019		
CEPCI for 2019	607.5	541.7	2016 CEPCI
Annual Interest Rate (i)	7.0 Percent	CEPCI = Chemical Engineering Plant Cost Index	
Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*	<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>	
Electricity (Cost <sub>elec</sub> )	0.2521 \$/kWh		
Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)	<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>	
Operator Labor Rate	60.00 \$/hour (including benefits)*	<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>	
Operator Hours/Day	4.00 hours/day*	<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>	
<small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small>			



## Appendix Table A-3f. Kahe K6 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

## Appendix Table A-3f. Kahe K6 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	1,516	MMBtu/hour	
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	1,243,920	MWhs	
Estimated Actual Annual MWhs Output (Boutput) =		601,781	MWhs	
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.07		
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (tscr/tplant) =$	0.484	fraction	
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4238	hours	
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	74.5	percent	
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	221.56	lb/hour	
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	469.48	tons/year	
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.93		
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \rho_{scr} =$	702,117	acfm	
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	129.61	/hour	
Residence Time	$1/V_{space}$	0.01	hour	
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00		
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$			Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7\ psia/P =$			Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7) / 518.6]^{5.256} \times (1/144)^* =$	14.7	psia	
Retrofit Factor (RF)	Retrofit to existing boiler	1.50		

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 / (1 + interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x_{adj}} \times S_{adj} \times (T_{adj}/N_{scr})$	5,417.25	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	731	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	3	feet

## Appendix Table A-3f. Kahe K6 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	841	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	29.0	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used: Ammonia  
 Molecular Weight of Reagent (MW) = 17.03 g/mole  
 Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,i} \times Q_G \times EF \times SRF \times MW_N) / MW_{NO_x}$	86	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / CSol =$	297	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	40	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	28,600	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i = Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	817.89	kW

## Appendix Table A-3f. Kahe K6 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEVF \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEVF \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEVF \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEVF \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$23,261,613</b>	<b>in 2019 dollars</b>

## Appendix Table A-3f. Kahe K6 - SCR Costing

Annual Costs		
<b>Total Annual Cost (TAC)</b>		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$1,166,888 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,878,910 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$3,045,798 in 2019 dollars</b>
<b>Direct Annual Costs (DAC)</b>		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$116,308 in 2019 dollars
Annual Reagent Cost =	$m_{SO_2} \times Cost_{reag} \times t_{op} =$	\$49,251 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$873,807 in 2019 dollars
Annual Catalyst Replacement Cost =		\$127,521 in 2019 dollars
	$n_{SCR} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	
<b>Direct Annual Cost =</b>		<b>\$1,166,888 in 2019 dollars</b>
<b>Indirect Annual Cost (IDAC)</b>		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$4,024 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,874,886 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$1,878,910 in 2019 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$3,045,798 per year in 2019 dollars
NOx Removed =		469 tons/year
<b>Cost Effectiveness =</b>		<b>\$6,488 per ton of NOx removed in 2019 dollars</b>

# Appendix Table A-4a. Kahe K1 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWh output?

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

## Appendix Table A-4a. Kahe K1 - SNCR Costing

Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x,in}$ ) to SNCR	0.494 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x,out}$ ) from SNCR	0.4 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

Enter the cost data for the proposed SNCR:

Desired dollar-year CEPCI for 2019	2019		
	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
Annual Interest Rate (i)	7 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu	Actual Data Used	
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water ( $Cost_{water}$ )	0.0042 \$/gallon	Default Value Used	
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

CEPCI = Chemical Engineering Plant Cost Index

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

## Appendix Table A-4a. Kahe K1 - SNCR Costing

Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	7	Office of Management and Budget (OMB) default social interest for capital projects	



## Appendix Table A-4a. Kahe K1 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q <sub>b</sub> ) =	Bmw x NPHR =	903	MMBtu/hour
Maximum Annual MWh Output =	Bmw x 8760 =	805,920	MWh
Estimated Actual Annual MWh Output (Boutput) =		384,917	MWh
Heat Rate Factor (HRF) =	NPHR/10 =	0.98	
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tsncr/365) =	0.48	fraction
Total operating time for the SNCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	4184	hours
NOx Removal Efficiency (EF) =	(NO <sub>xin</sub> - NO <sub>xout</sub> )/NO <sub>xin</sub> =	19	percent
NOx removed per hour =	NO <sub>xin</sub> x EF x Q <sub>b</sub> =	84.65	lb/hour
Total NO <sub>x</sub> removed per year =	(NO <sub>xin</sub> x EF x Q <sub>b</sub> x t <sub>op</sub> )/2000 =	177.09	tons/year
Coal Factor (Coal <sub>f</sub> ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)		Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*(1x10 <sup>6</sup> )/HHV =		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	14.7 psia/P =		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	2116x[(59-(0.00356xh))+459.7]/518.6] <sup>5.256</sup> x (1/144)* =	14.7	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

## Appendix Table A-4a. Kahe K1 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NO}_{x,\text{in}} \times Q_{\text{B}} \times \text{NSR} \times \text{MW}_{\text{R}}) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	201	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$ $(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	694	lb/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	31,200	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0944

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x,\text{in}} \times \text{NSR} \times Q_{\text{B}}) / \text{NPHR} =$	26.0	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	158	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.63	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

## Appendix Table A-4a. Kahe K1 - SNCR Costing

### Cost Estimate

#### Total Capital Investment (TCI)

For Coal-Fired Boilers:  $TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$

For Fuel Oil and Natural Gas-Fired Boilers:  $TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$1,639,022 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,714,103 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$5,659,063 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

#### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:  $SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$

For Fuel Oil and Natural Gas-Fired Utility Boilers:  $SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$

For Coal-Fired Industrial Boilers:  $SNCR_{cost} = 220,000 \times (0.1 \times Q_b \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:  $SNCR_{cost} = 147,000 \times ((Q_b/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$1,639,022 in 2019 dollars
--	-----------------------------

#### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:  $APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$

For Coal-Fired Industrial Boilers:  $APH_{cost} = 69,000 \times (0.1 \times Q_b \times HRF \times CoalF)^{0.78} \times AHF \times RF$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

## Appendix Table A-4a. Kahe K1 - SNCR Costing

Balance of Plant Costs (BOP <sub>cost</sub> )		
For Coal-Fired Utility Boilers:		
	$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$	
For Fuel Oil and Natural Gas-Fired Utility Boilers:		
	$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$	
For Coal-Fired Industrial Boilers:		
	$BOP_{cost} = 320,000 \times (0.1 \times Q_g)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$	
For Fuel Oil and Natural Gas-Fired Industrial Boilers:		
	$BOP_{cost} = 213,000 \times (Q_g/NPHR)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$	
Balance of Plant Costs (BOP <sub>cost</sub> ) =		\$2,714,103 in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$317,570 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$536,762 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$854,332 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)		
Annual Maintenance Cost =	$0.015 \times TCI =$	\$84,886 in 2019 dollars
Annual Reagent Cost =	$Q_{sol} \times Cost_{reag} \times t_{op} =$	\$113,686 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$27,473 in 2019 dollars
Annual Water Cost =	$Q_{water} \times Cost_{water} \times t_{op} =$	\$2,758 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$88,768 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
Direct Annual Cost =		\$317,570 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times \text{Annual Maintenance Cost} =$	\$2,547 in 2019 dollars
Capital Recovery Costs (CR) =	$CRF \times TCI =$	\$534,216 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$536,762 in 2019 dollars

## Appendix Table A-4a. Kahe K1 - SNCR Costing

Cost Effectiveness	
Cost Effectiveness = Total Annual Cost/ NOx Removed/year	
Total Annual Cost (TAC) =	\$854,332 per year in 2019 dollars
NOx Removed =	177 tons/year
Cost Effectiveness =	\$4,824 per ton of NOx removed in 2019 dollars

# Appendix Table A-4b. Kahe K3 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWh output?

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

---

Not applicable to units buring fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SNCR	0.353 lb/MMBtu		
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SNCR	0.25 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

### Enter the cost data for the proposed SNCR:

Desired dollar-year CEPCI for 2019	2019		
	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
Annual Interest Rate (i)	7 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu	Actual Data Used	
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water ( $Cost_{water}$ )	0.0042 \$/gallon	Default Value Used	
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

CEPCI = Chemical Engineering Plant Cost Index

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

## Appendix Table A-4b. Kahe K3 - SNCR Costing

Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	7	Office of Management and Budget (OMB) default social interest for capital projects	



## Appendix Table A-4b. Kahe K3 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q <sub>b</sub> ) =	Bmw x NPHR =	892	MMBtu/hour
Maximum Annual MWh Output =	Bmw x 8760 =	805,920	MWh
Estimated Actual Annual MWh Output (Boutput) =		387,117	MWh
Heat Rate Factor (HRF) =	NPHR/10 =	0.97	
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tsncr/365) =	0.48	fraction
Total operating time for the SNCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	4208	hours
NOx Removal Efficiency (EF) =	(NO <sub>xin</sub> - NO <sub>xout</sub> )/NO <sub>xin</sub> =	29	percent
NOx removed per hour =	NO <sub>xin</sub> x EF x Q <sub>b</sub> =	91.51	lb/hour
Total NO <sub>x</sub> removed per year =	(NO <sub>xin</sub> x EF x Q <sub>b</sub> x t <sub>op</sub> )/2000 =	192.53	tons/year
Coal Factor (Coal <sub>f</sub> ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)		Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*(1x10 <sup>6</sup> )/HHV =		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	14.7 psia/P =		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	2116x[(59-(0.00356xh))+459.7]/518.6] <sup>5.256</sup> x (1/144)* =	14.7	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

## Appendix Table A-4b. Kahe K3 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NO}_{x,\text{in}} \times Q_B \times \text{NSR} \times \text{MW}_R) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	142	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$ $(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	490	lb/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	22,000	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0944

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x,\text{in}} \times \text{NSR} \times Q_B) / \text{NPHR} =$	18.6	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	112	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.15	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### Cost Estimate

#### Total Capital Investment (TCI)

For Coal-Fired Boilers:  $TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$

For Fuel Oil and Natural Gas-Fired Boilers:  $TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$1,630,607 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,739,588 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$5,681,253 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

#### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:  $SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$

For Fuel Oil and Natural Gas-Fired Utility Boilers:  $SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$

For Coal-Fired Industrial Boilers:  $SNCR_{cost} = 220,000 \times (0.1 \times Q_b \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:  $SNCR_{cost} = 147,000 \times ((Q_b/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$1,630,607 in 2019 dollars
--	-----------------------------

#### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:  $APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$

For Coal-Fired Industrial Boilers:  $APH_{cost} = 69,000 \times (0.1 \times Q_b \times HRF \times CoalF)^{0.78} \times AHF \times RF$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

## Appendix Table A-4b. Kahe K3 - SNCR Costing

Balance of Plant Costs (BOP <sub>cost</sub> )	
For Coal-Fired Utility Boilers:	$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$
For Fuel Oil and Natural Gas-Fired Utility Boilers:	$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$
For Coal-Fired Industrial Boilers:	$BOP_{cost} = 320,000 \times (0.1 \times Q_g)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$
For Fuel Oil and Natural Gas-Fired Industrial Boilers:	$BOP_{cost} = 213,000 \times (Q_g/NPHR)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$

Balance of Plant Costs (BOP <sub>cost</sub> ) =	\$2,739,588 in 2019 dollars
---	-----------------------------

### Annual Costs

Total Annual Cost (TAC)	
TAC = Direct Annual Costs + Indirect Annual Costs	

Direct Annual Costs (DAC) =	\$250,536 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$538,867 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$789,403 in 2019 dollars

Direct Annual Costs (DAC)	
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)	

Annual Maintenance Cost =	0.015 x TCI =	\$85,219 in 2019 dollars
Annual Reagent Cost =	$Q_{sol} \times Cost_{reag} \times t_{op} =$	\$80,654 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$19,731 in 2019 dollars
Annual Water Cost =	$Q_{water} \times Cost_{water} \times t_{op} =$	\$1,956 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$62,976 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
Direct Annual Cost =		\$250,536 in 2019 dollars

Indirect Annual Cost (IDAC)	
IDAC = Administrative Charges + Capital Recovery Costs	

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,557 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$536,310 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$538,867 in 2019 dollars

## Appendix Table A-4b. Kahe K3 - SNCR Costing

Cost Effectiveness	
Cost Effectiveness = Total Annual Cost/ NOx Removed/year	
Total Annual Cost (TAC) =	\$789,403 per year in 2019 dollars
NOx Removed =	193 tons/year
Cost Effectiveness =	\$4,100 per ton of NOx removed in 2019 dollars

# Appendix Table A-4c. Kahe K5 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWh output?  MWh

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x,in}$ ) to SNCR	0.802 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x,out}$ ) from SNCR	0.40 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

### Enter the cost data for the proposed SNCR:

Desired dollar-year CEPCI for 2019	2019		
	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
		CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	7 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu		Actual Data Used
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia		Default Value Used
Water ( $Cost_{water}$ )	0.0042 \$/gallon		Default Value Used
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh		Actual Data Used
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

## Appendix Table A-4c. Kahe K5 - SNCR Costing

Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	7	Office of Management and Budget (OMB) default social interest for capital projects	



## Appendix Table A-4c. Kahe K5 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q <sub>b</sub> ) =	Bmw x NPHR =	1,468	MMBtu/hour
Maximum Annual MWh Output =	Bmw x 8760 =	1,243,920	MWh
Estimated Actual Annual MWh Output (Boutput) =		493,259	MWh
Heat Rate Factor (HRF) =	NPHR/10 =	1.03	
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tsnrcr/365) =	0.40	fraction
Total operating time for the SNCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	3474	hours
NOx Removal Efficiency (EF) =	(NO <sub>xin</sub> - NO <sub>xout</sub> )/NO <sub>xin</sub> =	50	percent
NOx removed per hour =	NO <sub>xin</sub> x EF x Q <sub>b</sub> =	589.77	lb/hour
Total NO <sub>x</sub> removed per year =	(NO <sub>xin</sub> x EF x Q <sub>b</sub> x t <sub>op</sub> )/2000 =	1,024.34	tons/year
Coal Factor (Coal <sub>f</sub> ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)		Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*(1x10 <sup>6</sup> )/HHV =		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	14.7 psia/P =		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	2116x[(59-(0.00356xh))+459.7]/518.6] <sup>5.256</sup> x (1/144)* =	14.7	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

## Appendix Table A-4c. Kahe K5 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NO}_{x,\text{in}} \times Q_{\text{B}} \times \text{NSR} \times \text{MW}_{\text{R}}) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	531	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$	1,833	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	244.8	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	82,300	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0944

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x,\text{in}} \times \text{NSR} \times Q_{\text{B}}) / \text{NPHR} =$	65.3	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	417	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	4.31	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### Cost Estimate

#### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$2,010,115 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$3,953,628 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$7,752,866 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

#### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_b \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_b/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$2,010,115 in 2019 dollars
--	-----------------------------

#### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_b \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

## Appendix Table A-4c. Kahe K5 - SNCR Costing

Balance of Plant Costs (BOP <sub>cost</sub> )		
For Coal-Fired Utility Boilers:		
	$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$	
For Fuel Oil and Natural Gas-Fired Utility Boilers:		
	$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$	
For Coal-Fired Industrial Boilers:		
	$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$	
For Fuel Oil and Natural Gas-Fired Industrial Boilers:		
	$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$	
Balance of Plant Costs (BOP <sub>cost</sub> ) = \$3,953,628 in 2019 dollars		
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$623,223 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$735,359 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$1,358,582 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)		
Annual Maintenance Cost =	$0.015 \times TCI =$	\$116,293 in 2019 dollars
Annual Reagent Cost =	$Q_{sol} \times Cost_{reag} \times t_{op} =$	\$249,165 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$57,167 in 2019 dollars
Annual Water Cost =	$Q_{water} \times Cost_{water} \times t_{op} =$	\$6,044 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$194,553 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
Direct Annual Cost =		\$623,223 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times \text{Annual Maintenance Cost} =$	\$3,489 in 2019 dollars
Capital Recovery Costs (CR) =	$CRF \times TCI =$	\$731,871 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$735,359 in 2019 dollars

## Appendix Table A-4c. Kahe K5 - SNCR Costing

Cost Effectiveness	
Cost Effectiveness = Total Annual Cost/ NOx Removed/year	
Total Annual Cost (TAC) =	\$1,358,582 per year in 2019 dollars
NOx Removed =	1,024 tons/year
Cost Effectiveness =	\$1,326 per ton of NOx removed in 2019 dollars

# Appendix Table A-4d. Kahe K6 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWh output?

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units buring fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SNCR	0.196 lb/MMBtu		
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SNCR	0.15 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

### Enter the cost data for the proposed SNCR:

Desired dollar-year CEPCI for 2019	2019		
	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
		CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	7 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu	Actual Data Used	
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water ( $Cost_{water}$ )	0.0042 \$/gallon	Default Value Used	
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

## Appendix Table A-4d. Kahe K6 - SNCR Costing

Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	7	Office of Management and Budget (OMB) default social interest for capital projects	



## Appendix Table A-4d. Kahe K6 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q <sub>b</sub> ) =	Bmw x NPHR =	1,516	MMBtu/hour
Maximum Annual MWh Output =	Bmw x 8760 =	1,243,920	MWh
Estimated Actual Annual MWh Output (Boutput) =		601,781	MWh
Heat Rate Factor (HRF) =	NPHR/10 =	1.07	
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tsncr/365) =	0.48	fraction
Total operating time for the SNCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	4238	hours
NOx Removal Efficiency (EF) =	(NO <sub>xin</sub> - NO <sub>xout</sub> )/NO <sub>xin</sub> =	24	percent
NOx removed per hour =	NO <sub>xin</sub> x EF x Q <sub>b</sub> =	69.96	lb/hour
Total NO <sub>x</sub> removed per year =	(NO <sub>xin</sub> x EF x Q <sub>b</sub> x t <sub>op</sub> )/2000 =	148.25	tons/year
Coal Factor (Coal <sub>f</sub> ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)		Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*(1x10 <sup>6</sup> )/HHV =		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	14.7 psia/P =		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	2116x[(59-(0.00356xh))+459.7]/518.6] <sup>5.256</sup> x (1/144)* =	14.7	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html>.

## Appendix Table A-4d. Kahe K6 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NO}_{x,\text{in}} \times Q_{\text{B}} \times \text{NSR} \times \text{MW}_{\text{R}}) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	134	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$ $(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	463	lb/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	20,800	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0944

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x,\text{in}} \times \text{NSR} \times Q_{\text{B}}) / \text{NPHR} =$	16.0	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	105	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.09	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### Cost Estimate

#### Total Capital Investment (TCI)

For Coal-Fired Boilers:  

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:  

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$2,037,463 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$3,061,252 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$6,628,329 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

#### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:  

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:  

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:  

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_b \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:  

$$SNCR_{cost} = 147,000 \times ((Q_b/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$2,037,463 in 2019 dollars
--	-----------------------------

#### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:  

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:  

$$APH_{cost} = 69,000 \times (0.1 \times Q_b \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

## Appendix Table A-4d. Kahe K6 - SNCR Costing

Balance of Plant Costs (BOP <sub>cost</sub> )	
For Coal-Fired Utility Boilers:	
	$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x \text{ Removed/hr})^{0.12} \times BTF \times RF$
For Fuel Oil and Natural Gas-Fired Utility Boilers:	
	$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x \text{ Removed/hr})^{0.12} \times RF$
For Coal-Fired Industrial Boilers:	
	$BOP_{cost} = 320,000 \times (0.1 \times Q_b)^{0.33} \times (NO_x \text{ Removed/hr})^{0.12} \times BTF \times RF$
For Fuel Oil and Natural Gas-Fired Industrial Boilers:	
	$BOP_{cost} = 213,000 \times (Q_b/NPHR)^{0.33} \times (NO_x \text{ Removed/hr})^{0.12} \times RF$

Balance of Plant Costs (BOP <sub>cost</sub> ) =	\$3,061,252 in 2019 dollars
---	-----------------------------

### Annual Costs

Total Annual Cost (TAC)	
TAC = Direct Annual Costs + Indirect Annual Costs	

Direct Annual Costs (DAC) =	\$255,122 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$628,697 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$883,819 in 2019 dollars

Direct Annual Costs (DAC)	
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)	

Annual Maintenance Cost =	0.015 x TCI =	\$99,425 in 2019 dollars
Annual Reagent Cost =	$Q_{sol} \times Cost_{reag} \times t_{op} =$	\$76,802 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$17,063 in 2019 dollars
Annual Water Cost =	$Q_{water} \times Cost_{water} \times t_{op} =$	\$1,863 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$59,969 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
Direct Annual Cost =		\$255,122 in 2019 dollars

Indirect Annual Cost (IDAC)	
IDAC = Administrative Charges + Capital Recovery Costs	

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,983 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$625,714 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$628,697 in 2019 dollars

## Appendix Table A-4d. Kahe K6 - SNCR Costing

Cost Effectiveness	
Cost Effectiveness = Total Annual Cost/ NOx Removed/year	
Total Annual Cost (TAC) =	\$883,819 per year in 2019 dollars
NOx Removed =	148 tons/year
Cost Effectiveness =	\$5,962 per ton of NOx removed in 2019 dollars

APPENDIX B: HAWAIIAN ELECTRIC REGIONAL HAZE VISIBILITY  
CONSIDERATIONS

---

**Appendix B:**  
**Hawaiian Electric Regional Haze Visibility Considerations**

**Fifth Factor Considerations for SO<sub>2</sub> ,NO<sub>x</sub>, and PM Controls**

AECOM Project Number: 60626547

Prepared for:



PO Box 2750  
Honolulu, HI 96840

Prepared by:

**AECOM**

AECOM Technical Services, Inc.  
250 Apollo Drive  
Chelmsford, MA 01824-3627

September 14, 2020

---

## **Hawaiian Electric<sup>1</sup> Regional Haze Visibility Considerations**

### **Fifth Factor Considerations for SO<sub>2</sub>, NO<sub>x</sub> and PM Controls**

#### **1. Executive Summary**

The EPA has issued multiple guidance documents to assist states and facilities address the requirements of the Regional Haze Rule (“RHR”). This guidance allows states to consider, as part of their review of the Four Factor evaluation of possible emission controls for the Second Decadal Review, a “5<sup>th</sup> factor” which involves consideration of visibility impacts of candidate control options. This appendix introduces several Hawai‘i-specific issues that impact the visibility impact of potential sulfur dioxide (“SO<sub>2</sub>”), nitrogen oxides (“NO<sub>x</sub>”) and particulate (“PM”) control options for Hawaiian Electric sources relative to the two Class 1 areas in Hawai‘i: the Haleakalā National Park on the island of Maui and the Hawai‘i Volcanoes National Park on Hawai‘i Island. The issues discussed in this report are summarized below:

- 1) Due to unique atmospheric chemistry, NO<sub>x</sub> emissions tend to remain in the gaseous (and invisible) phase in warm weather, and only form visible NO<sub>3</sub> (“nitrate”) particulate aerosol in cold weather. This is verified by monitoring data in the Interagency Monitoring of Protected Visual Environments (“IMPROVE”) network in the two national parks mentioned above.
- 2) The persistent East North East (“ENE”) trade winds experienced by the state of Hawai‘i places emission sources on several islands (or portions of islands such as Maui) downwind of the national parks, limiting the likelihood that any emissions from these sources would even reach the parks. Modeling conducted with the California Puff Model (“CALPUFF”) for the First Decadal Review confirms the minimal potential for haze impact of the subject Hawaiian Electric sources on the islands of O‘ahu and Maui due to the predominance of the trade winds. The EPA’s Federal Implementation Plan (“FIP”) issued in 2012 agreed with this assessment.
- 3) EPA previously determined that in Hawai‘i haze due to direct PM was a very small component of haze and that further controls would not be effective in improving visibility. The observed haze speciation is reviewed in this report to confirm this determination.
- 4) The State of Hawai‘i Department of Health Clean Air Branch (“DOH”) should request that the EPA (consistent with their first decadal review approach) set aside NO<sub>x</sub> and PM from the list of haze precursors for Hawai‘i due to the unique NO<sub>x</sub> haze chemistry and climate, leaving SO<sub>2</sub> as

---

<sup>1</sup> “Hawaiian Electric” or the “Company” refers to Hawaiian Electric Company, Inc. (or “HE”), Hawai‘i Electric Light Company, Inc. (or “HL”) and/or Maui Electric Company, Limited (or “ME”). On December 20, 2019, the State of Hawai‘i Department of Commerce and Consumer Affairs (“DCCA”) approved Hawaiian Electric Company, Inc., Hawai‘i Electric Light Company, Inc. and Maui Electric Company, Limited’s application to do business under the trade name “Hawaiian Electric” for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.



the primary precursor pollutant for haze. Hawaiian Electric requests that the DOH make this proposal to the EPA.

- 5) In the recent past, volcanic activity on Hawai'i Island has produced as much as 2 million tons of SO<sub>2</sub> emissions per year<sup>2,3</sup> (emissions vary yearly and have decreased significantly since September 2018). Additionally, the volcanic activity, although the volcano eruption ended in September 2018, has contributed significant NO<sub>x</sub> emissions in the past<sup>4</sup>. These historic volcanic SO<sub>2</sub> emissions are about three orders of magnitude (approximately 1,000 times) greater than anthropogenic SO<sub>2</sub> emissions. Although the IMPROVE monitors indicate that sulfate haze is the most important haze species, it is evident from monthly haze trends and the likelihood of winds from the volcanic activity reaching the IMPROVE monitors that the overwhelming historic sulfate haze influence comes from natural sources (i.e., volcanic activity).

The locations of the affected Hawaiian Electric sources and the two national parks are shown in Figure B-1. The remainder of this appendix presents details of the above issues and recommendations for how this information should be considered in selection of facilities for Four-Factor analyses and for evaluating potential pollutant control options.


---

<sup>2</sup> Information on the volcanic SO<sub>2</sub> emissions in 2014 was provided by the EPA in their SO<sub>2</sub> National Ambient Air Quality Technical Support Document at EPA's 2016 SO<sub>2</sub> NAAQS TSD, at <https://www.epa.gov/sites/production/files/2016-03/documents/hi-epa-tsd-r2.pdf>.

<sup>3</sup> Information on 2014-2017 volcanic SO<sub>2</sub> emissions is available in this journal article: Elias T, Kern C, Horton KA, Sutton AJ and Garbeil H. (2018) Measuring SO<sub>2</sub> Emission Rates at Kilauea Volcano, Hawaii, Using an Array of Upward-Looking UV Spectrometers, 2014–2017. *Front. Earth Sci.* 6:214. doi: 10.3389/feart.2018.00214. <https://www.frontiersin.org/articles/10.3389/feart.2018.00214/full>.

<sup>4</sup> The NO<sub>x</sub> emissions from Hawai'i Island volcanic activity is unknown, but could have historically been as high as 25,000 tons per year if the NO<sub>x</sub> emissions rate equals 6% of SO<sub>2</sub> emissions rate. The 6% is derived from worldwide volcanic NO<sub>x</sub> emissions estimate of 1.0 Teragram ("Tg" – trillion grams)/year ("yr") nitric oxide ("NO" (or 1.5 Tg/yr NO<sub>2</sub>) from <https://www.chemistryworld.com/features/a-volcanic-breath-of-life/3004482.article> and worldwide volcanic SO<sub>2</sub> estimate of 23 Tg/yr from <https://www.nature.com/articles/srep44095>.

Figure B-1:  
Location of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas



## 2. EPA Guidance Regarding Considerations of Visibility Impacts

The EPA issued “Guidance on Regional Haze State Implementation Plans for the Second Implementation Period”<sup>5</sup> in August 2019. This guidance allows states to consider, as part of its consideration of emission controls to include for the Second Decadal Review a “5<sup>th</sup> factor” which involves consideration of visibility impacts of candidate control options. A companion document<sup>6</sup> issued in September 2019 that involves the EPA’s visibility modeling results for 2028 is entitled, “Availability of Modeling Data and Associated Technical Support Document for the EPA’s Updated 2028 Visibility Air Quality Modeling”.

On Page 11 of the August 2019 guidance, the EPA states:

*“When selecting sources for analysis of control measures, a state may focus on the PM species that dominate visibility impairment at the Class I areas affected by emissions from the state and then select only sources with emissions of those dominant pollutants and their precursors.” . . .*

<sup>5</sup> Available at [https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019\\_-\\_regional\\_haze\\_guidance\\_final\\_guidance.pdf](https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019_-_regional_haze_guidance_final_guidance.pdf).

<sup>6</sup> Available at [https://www3.epa.gov/ttn/scram/reports/2028\\_Regional\\_Haze\\_Modeling-Transmittal\\_Memo.pdf](https://www3.epa.gov/ttn/scram/reports/2028_Regional_Haze_Modeling-Transmittal_Memo.pdf).

*“Also, it may be reasonable for a state to not consider measures for control of the remaining pollutants from sources that have been selected on the basis of their emissions of the dominant pollutants”*

Further, on Page 36 and 37, the EPA states:

*“Because the goal of the regional haze program is to improve visibility, it is reasonable for a state to consider whether and by how much an emission control measure would help achieve that goal.” . . .*

*“. . . EPA interprets the CAA and the Regional Haze Rule to allow a state reasonable discretion to consider the anticipated visibility benefits of an emission control measure along with the other factors when determining whether a measure is necessary to make reasonable progress.”*

Consequently, the extremely low likelihood for impact to Class I visibility impairment from control of certain facility pollutants and the plant locations relative to the Class I areas is appropriate for consideration when evaluating the need for further control of these emissions for Regional Haze Reasonable Progress.

### **3. Nitrate Haze Composition Analysis**



Nitrate haze composition analyses for the Haleakalā and Hawai'i Volcanoes National Parks are available at the IMPROVE web site at <http://vista.cira.colostate.edu/Improve/pm-and-haze-composition/>. Figure B-2 provides various charts for the haze species composition at the Haleakalā Crater IMPROVE site, and Figure B-3 provides a time series of stacked bars by species for a recent year at that site. Figures B-4 and B-5 provide similar information for the Hawai'i Volcanoes IMPROVE site. Note that these figures show information for the worst 20 percent (“%”) impaired days, which is the focus of the RHR for reducing haze. The goal for each decadal review is to track the progress of haze reduction for the worst 20% impaired days; reviewing the composition of haze on these days is a key element in understanding what precursor pollutants to control to achieve the goal.

The data for both National Parks shows that the contribution of nitrates to haze is very low as a percentage of the total, but it is also low as an absolute value for extinction (visibility impairment). The total nitrate haze impairment is approximately 1 inverse megameter (“Mm<sup>-1</sup>”), equivalent to approximately 0.25 deciview (“dv”), or less. This is the impairment at these monitors due to ALL sources, natural and anthropogenic.


The minimal impact of nitrate haze is clearly illustrated in the Hawai'i National Park monitoring data and is much smaller than found at many monitors in other Class 1 areas around the country. This is in large part due to the unique chemistry of nitrate haze, as discussed below.

Figure B-2: Charts Showing the Worst 20% Haze Days Multiple-Year Species Composition for the Haleakalā Crater IMPROVE Site

Light Extinction Summary - Most Impaired Days



Most Impaired Days 2007-2018  
Haleakala Crater



Haleakala Crater IMPROVE monitor

Data source for Figures B-2 through B-5: [http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF\\_VisSum](http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF_VisSum).

Figure B-3: Time Series of 2018 Daily Haze Extinction Composition Plots for the Haleakalā Crater IMPROVE Site






Figure B-4: Charts Showing the Worst 20% Haze Days Multiple-Year Species Composition for the Hawai'i Volcanoes IMPROVE Site





**Hawaii Volcanoes NP IMPROVE monitor**

Figure B-5: Time Series of 2018 Daily Haze Extinction Composition Plots for the Hawai'i Volcanoes IMPROVE Site




The nitrate contribution to visibility impairment in the above bar charts is shown as a narrow “red” segment. The small size relative to other constituents clearly shows that nitrate is only a small contributor. Additionally, the Figures B-6 and B-7 below which presents only the ammonium nitrate visibility impairment also shows that nitrates, already small contribution, is trending downward.





The chemistry of nitrate haze formation is highly dependent upon ambient temperature, and to a lesser extent upon humidity. As discussed in the CALPUFF model formulation<sup>7</sup> and in CALPUFF courses, total nitrate in the atmosphere ( $TNO_3 = HNO_3 + NO_3$ ) is partitioned into gaseous nitric acid (“ $HNO_3$ ”) (invisible, and not haze-producing) and nitrate (“ $NO_3$ ”) haze particles according to the equilibrium relationship between the two species, which is affected by temperature and humidity.

**Figure B-8: CALPUFF Example Plot of Aerosol Percentage of Total NOx Equilibrium**



The potential for the formation of haze due to NOx emissions is very low in Hawai‘i because of the warm weather conditions year-round. This strong dependency of the equilibrium relationship between invisible gaseous  $HNO_3$  and visible  $NO_3$  haze particles as a function of ambient temperature is illustrated in Figure B-8. In Figure B-8, it is evident that for most conditions, the percentage of total nitrate in the form of particulate ( $NO_3$ ) is less than 20% for temperatures above approximately 286 degrees Kelvin (approximately 55 degrees Fahrenheit). Temperatures at most locations in Hawai‘i rarely get that low and are not that low at any of the Hawaiian Electric plant locations.

<sup>7</sup> Documentation for the CALPUFF modeling system is available from links provided at <https://www.epa.gov/scram/air-quality-dispersion-modeling-alternative-models#calpuff>.

This dependency of nitrate haze formation as a function of temperature (and season) for more seasonally-varying locations in the United States is shown in the September 2019 EPA modeling report<sup>2</sup> in Figure B-9 (from Appendix A of that report). This figure shows that the thermodynamics of the nitrate haze equilibrium result in much greater particulate formation in winter versus other seasons for more temperate climates, while NO<sub>x</sub> emissions are expected to be relatively constant over the entire year. This implies that NO<sub>x</sub> emission reductions would only be effective for haze reduction during cold winter months, while consideration of NO<sub>x</sub> emission reductions in other months is relatively ineffective.



It should also be noted that volcanic activity on Hawai'i Island may also be a large source of NO<sub>x</sub> in the state. Volcanoes are commonly thought of as large sources of SO<sub>2</sub>, but they also can emit significant amounts of NO<sub>x</sub>. Laboratory analysis<sup>8</sup> of NO<sub>x</sub> emissions content in volcanic exhaust indicates a substantial component, likely caused by thermal contact of air with lava. The annual worldwide volcano NO<sub>x</sub> emissions (as NO<sub>2</sub>) is estimated<sup>3</sup> at approximately 1.5 teragrams ("Tg" – trillion grams).

In summary, nitrate haze is a very small component in Hawai'i's Class I areas, which is expected given nitrate chemistry and is verified by the IMPROVE monitoring data. The multiple-year average of the nitrate haze impact for worst 20% days at the two areas is approximately Mm<sup>-1</sup>, or less than 0.5 delta-dv. This total nitrate haze impact is less than the de minimis contribution threshold used to eliminate a single source from consideration for controls during the First Decadal Review period.

Due to the low haze impact of NO<sub>x</sub> (even if every source in the state and the volcano was eliminated), the state of Hawai'i should limit the haze precursors control evaluations to SO<sub>2</sub> for the Second Decadal Review. A similar conclusion was reached during the First Decadal Review, for which the EPA did not consider NO<sub>x</sub> controls to be material. The State of Hawai'i Department of Health should work with the EPA to provide this technical justification to remove NO<sub>x</sub> as a haze precursor for the state of Hawai'i.

<sup>8</sup> Mather, T., 2004. A Volcanic Breath of Life? Chemistry World, 30 November 2004 Featured Article. <https://www.chemistryworld.com/features/a-volcanic-breath-of-life/3004482.article>.

Figure B-9: Monthly Variation of Nitrate Particulate Concentrations for Selected IMPROVE Sites from EPA 2019 Modeling Report



#### **4. PM Species Haze Composition Analysis**

In their Federal Implementation Plan Technical Support Document<sup>9</sup>, EPA noted that “due to the overwhelming contribution of sulfate to visibility impairment at the nearby Hawaii Volcanoes Class I area, it is unlikely that reductions in these pollutants [NO<sub>x</sub> and PM]...would have a measurable impact on visibility at that area.”

It is clear from a review of the haze speciation shown in Figures B-2 through B-5 that the contribution to haze of direct particulate species such as elemental carbon, soil, and coarse mass is relatively low. Furthermore, emissions of coarse PM mass (ash) from the volcanic activity can be very high (clearly evident from photos of volcanic activity) to the extent that it may result in aviation alerts. These emissions can be much greater than emissions from power plants and can constitute a significant portion of the direct PM-caused haze shown in Figures B-2 through B-5. The remaining human-caused haze due to direct PM emissions is therefore a very small component of the total haze, and this determination is consistent with EPA’s 2012 assessment.

#### **5. Predominant Trade Winds in Hawai’i**

The EPA’s FIP for Hawai’i for the First Decadal Review (77 FR 61478, October 9, 2012) acknowledged the direction of the predominant trade winds in Hawai’i and thus did not require controls on upwind sources (i.e., sources on O’ahu and Maui). Figure B-10 shows the locations of the Hawaiian Electric sources and the national parks, along with wind rose plots for airports on Maui and O’ahu. The wind rose plots show that the wind is almost always from the northeast and rarely blows from the Hawaiian Electric facilities on O’ahu or Maui toward either of Hawai’i’s Class 1 areas.

The EPA CALPUFF modeling conducted for the First Decadal Review confirms the expected low impacts from sources on Maui, even though the sources were relatively close to Haleakalā National Park. This result is due to the fact, as stated above, that winds rarely blow the emissions from sources downwind from the parks back to the parks, and the CALPUFF modeling confirmed the low impact from occasional periods when the wind may blow toward the parks from the sources modeled. The Western Regional Air Partnership (“WRAP”) Q/d analysis that included several sources on the islands of O’ahu and Maui in the four-factor analysis did not consider the wind patterns. A review of past modeling and the EPA’s 2012 FIP should lead to a dismissal of those sources from inclusion in four-factor analyses for the second decadal review period.

The geometry and wind roses shown in Figure B-10 and previous CALPUFF modeling both indicate that Hawaiian Electric generating stations on O’ahu and Maui would have minimal impact to Class 1 area haze. Because of this, and the minimal impact of NO<sub>x</sub> due to nitrate chemistry, consideration of

---

<sup>9</sup> EPA, May 14, 2012. Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawaii. EPA docket EPA-R09-OAR-2012-0345-0002 via [www.regulations.gov](http://www.regulations.gov).

---

potential additional pollution controls at Hawaiian Electric facilities for Regional Haze progress should be limited to SO<sub>2</sub> for sources on Hawai'i Island.

## **6. Natural Sources of SO<sub>2</sub> From Volcanic Activity**

Volcanic activity on the Hawai'i Island represents a unique and challenging complication to understanding haze in Hawai'i Class I areas. The Kilauea volcano on Hawai'i Island has been active for several years, and the levels of SO<sub>2</sub> emissions are being monitored by the United States Geological Survey. As shown in Figure B-11<sup>10</sup> (related to the SO<sub>2</sub> National Ambient Air Quality Standards implementation and monitoring), there were over 2 million tons of SO<sub>2</sub> emissions from volcanic activity on Hawai'i Island in the year 2014, compared to roughly 2,000 tons of power plant SO<sub>2</sub> emissions for that year. As noted in a *Frontiers in Earth Science* 2018 article<sup>11</sup>, the volcanic SO<sub>2</sub> emissions have been relatively steady at levels close to 2 million TPY for the period of 2014 to 2017. The volcanic SO<sub>2</sub> emissions have decreased after the Kilauea eruption ended in September 2018, but remain significant. The USGS preliminary estimates of annual volcanic emissions of SO<sub>2</sub> for 2019 are 17,119 tons/year<sup>12</sup>.

The extremely high and variable levels of natural SO<sub>2</sub> emissions present a significant challenge for defining "impaired" haze days because the same pollutant (i.e., SO<sub>2</sub>) is emitted by volcanic activity and the power plants and other combustion sources. Therefore, the RHR glidepath for the two Class I areas in Hawai'i is difficult to establish if naturally-caused haze is to be excluded from the analysis.

There appears to be very little anthropogenic haze impairment remaining at Haleakalā National Park because there are very few sources on Maui upwind of the park and there are no land masses upwind of Maui for thousands of kilometers. For Hawai'i Island, the largest sources of SO<sub>2</sub> are natural sources that are part of (or adjacent to) the park.

Even the anthropogenic sources (from power plants) are projected to be phased out well before the end point of the RHR (i.e., 2064) by Hawai'i's State Renewable Portfolio Standards Law ("RPS") implementing requirements to convert 100% of the state's electrical generation to renewable energy sources. This RPS law (Hawai'i Revised Statute §269-92) will substantially reduce emissions of haze precursors by 2045. Further details of the past and future benefits of the RPS requirements are detailed in separate Appendix C.

---

<sup>10</sup> <https://www.epa.gov/sites/production/files/2016-03/documents/hi-epa-tds-r2.pdf>.

<sup>11</sup> Elias, T., C. Kern, K. Horton, A. Sutton, and H. Garbeil, 2018. Measuring SO<sub>2</sub> Emission Rates at Kilauea Volcano, Hawai'i, Using an Array of Upward-Looking UV Spectrometers, 2014–2017. *Front. Earth Sci.* 6:214. doi: 10.3389/feart.2018.00214. <https://www.frontiersin.org/articles/10.3389/feart.2018.00214/full>.

<sup>12</sup> Hawaii Dept. of Health comment letter to Hawaiian Electric Light Company regarding Puna Generating Station Four Factor Analysis; July 8, 2020.

Figure B-10: Geography of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas, with Wind Roses





Figure B-11: Geography of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas, with Wind Roses



## 7. Conclusions

The state of Hawai'i is isolated from all other states and has very unique regional haze issues due, in part, to its tropical climate, the prevalent trade winds, very large natural emissions of haze precursors, and statewide commitment to renewable energy.

- Emission sources on O'ahu and Maui are downwind of Hawai'i's Class 1 areas and do not contribute to haze issues, such that additional emission controls would not contribute to further reasonable progress at either of Hawai'i's Class 1 area National Parks. This is consistent with the EPA's First Decadal Review findings.
- Additionally, NO<sub>x</sub> emissions do not significantly contribute to haze in Hawai'i due the nitrate chemistry and Hawai'i's warm climate, and additional NO<sub>x</sub> controls would likewise not contribute to further reasonable progress. Therefore, NO<sub>x</sub> should not be regulated as a contributing precursor to haze in Hawai'i; especially from O'ahu and Maui sources that are downwind of the parks. If they are reviewed as precursors, consideration should be given to their insignificant contribution when evaluating possible controls.
- Direct PM emissions constitute a very small portion of the haze associated with the worst 20% haze days in the Hawai'i Class 1 areas. Furthermore, significant portions of the observed haze in the categories of elemental carbon, soil, and coarse mass are due to volcanic emissions. Therefore, further PM controls on power plant sources would not have a significant benefit for visibility at these Class 1 areas.
- For the above reasons, the only pollutant that should be considered for possible haze controls in the state of Hawai'i is SO<sub>2</sub> which is consistent with the findings of the First Decadal Review. Furthermore, the only Hawaiian Electric sources to be considered for a four factor analysis for SO<sub>2</sub> should be those that are predominantly upwind of a Class I area which include only the Puna and Kanoiehua-Hill Generating Stations on Hawai'i Island.
- Hawai'i's Class I area haze impacts are principally due to natural sources. Volcanic emissions of precursor SO<sub>2</sub> during the 2014-2017 period of analysis were three orders of magnitude greater than the anthropogenic emissions on Hawai'i Island. Since these natural emissions are the principal cause of haze at the two Class 1 areas in the state and are difficult to distinguish from the relatively small amount of anthropogenically-caused haze, photochemical grid modeling is not practical or even needed. The definition of "impaired days" for Hawai'i Volcanoes National Park as referenced in some of the figures in this report is uncertain due to the overwhelming influence of natural emissions of SO<sub>2</sub>.
- For Haleakalā National Park, with the lack of upwind anthropogenic sources, it could be reasonably concluded that natural conditions are already attained, and no further Reasonable Progress modeling (or controls) is needed. For Hawai'i Volcanoes National Park, the only United



States anthropogenic potential sources are those upwind of the park on Hawai'i Island; all other sources in the state are not contributing to haze at the Class 1 areas.

- Implementation of Hawai'i's RPS (discussed in detail in Appendix C) will provide a dramatic reduction of virtually all power plant haze-causing emissions in the state of Hawai'i well before the year 2064. This Hawai'i state law established enforceable requirements that a certain percentage of electricity must be generated from renewable energy sources by the end of identified benchmark years leading to 100percent renewable energy by 2045. The interim targets are 30 percent by 2020, 40 percent by 2030, and 70 percent by 2040 which provide an RPS "glide path" for EGUs that mirrors the RHR visibility improvement glide path for the next few decades. No separate new regional haze measures for EGUs are needed to assure reasonable progress for this decadal period.

Plans for renewable energy sources, the likely reduction in utilization of fossil-fueled electric generation in this interim period, the unique climate and wind patterns, and the difficulty of addressing the high volcanic emissions should be considered in the current planning for the Second Decadal Review process for the state of Hawai'i.

APPENDIX C: HAWAII'S RENEWABLE PORTFOLIO STANDARDS  
CONTRIBUTION TO REGIONAL HAZE PROGRESS

---

**Appendix C:  
Hawai'i's Renewable Portfolio Standards ("RPS")  
Contribution to Regional Haze Progress**

AECOM Project Number: 60626547

Prepared for:



**Hawaiian  
Electric**

PO Box 2750  
Honolulu, HI 96840

Prepared by:

**AECOM**

AECOM Technical Services, Inc.  
500 West Jefferson, Suite 1600  
Louisville, KY 40202

March 30, 020

## **Hawai'i's Renewable Portfolio Standards ("RPS") Contribution to Regional Haze Progress**

### **1. Executive Summary**

Hawai'i's ongoing conversion of fossil-fueled electric generation to renewable energy sources as mandated by the Hawai'i Revised Statute ("HRS") §269-92 Renewable Portfolio Standards ("RPS") is significantly decreasing emissions from Hawai'i's electric generating stations. Past actual and expected future decreases in usage of fossil-fueled electric generating units ("EGUs") are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the Regional Haze Rule ("RHR"). Emissions from the majority of Hawai'i's electric generating plants are not a significant contributor to haze at Class I areas (for reasons explained in Appendix B). Further, their very low impact is being mitigated under the RPS state law. This rate of progress from the RPS law can be relied upon for further emissions reductions from EGUs in the coming years and thus separate further requirements for EGU controls under the RHR are not needed at this time. The following sections of this appendix provide a background on the RPS requirements and progress to date, and high confidence of continued progress consistent with the goals of the RHR.

### **2. Renewable Portfolio Standards**

In 2002 the Hawai'i RPS legislation set voluntary goals for converting the islands' electrical generation from fossil fuels to renewable energy. In 2005, the RPS was set into law as binding requirements for Hawai'i electric utility companies. The law requires that electric utilities in Hawai'i achieve 100% of their electric generation from renewable energy sources by 2045 and meet a series of interim limits for the percentages of their electricity sales that must be provided by renewables (e.g., 30% renewable by 2020, and 40% by 2030, etc.). Renewable energy sources such as solar, hydro and wind energy have no direct emissions. Others such as biomass combustion have significantly lower emissions (especially sulfur dioxide ("SO<sub>2</sub>")) than fossil fuels. Consequently, the RPS law results in steady progress in emissions reductions from electric utilities creating, in effect, an "RPS glidepath" providing dramatic reduction of electric generating unit emissions by mid-century.

The RPS program, although not directly related to the Regional Haze Rule, is providing emissions reductions and improvements to air quality consistent with the goals of the RHR.

Table C-1 shows the interim and final RPS for EGUs along with the Regional Haze adjusted glidepath emissions reductions goals<sup>1</sup>.

<sup>1</sup> Regional Haze Adjusted Glidepath assumes consistent reductions in haze precursor emissions impacts from all U.S. anthropogenic sources from the baseline average of 2000-2004 to zero impacts in 2064, i.e. natural background.

**Table C-1 Comparison of RPS and Regional Haze Glidepaths**

Year	RPS Renewable Requirement % of Electricity Sales	Regional Haze Glidepath % Visibility Improvement
2010	10%	8%
2015	15%	17%
2020	30%	25%
2030	40%	42%
2040	70%	58%
2045	100%	67%
2065		100%

This table illustrates that the emissions reductions from EGUs under the RPS are similar to the visibility goals of the Regional Haze Program in the intermediate years and become much more stringent in later years. The RPS seeks to achieve 100% renewable electrical supply by 2045, which is twenty years earlier than the RHR target of 2065 to achieve natural background visibility in Class I areas.

**3. Historical RPS Achievement**


Hawaiian Electric<sup>2</sup>, and other electric utility providers in Hawai‘i, have made excellent progress in developing and supporting renewable energy sources. Figure C-1 below shows the percentage of all electrical sales statewide provided by renewable sources since the RPS inception (green columns).<sup>3</sup> It also shows as a line illustrating the RPS interim standards (with proportional progress assumed between RPS milestone years). This figure illustrates that Hawai‘i EGUs have made significant progress to date and have been ahead of the RPS interim targets.

Hawaiian Electric represents majority of Hawai‘i’s electric generation. Figure C-2 shows the renewable energy source percentages for this same period specifically for Hawaiian Electric. The data follows the same trend as the statewide figures and this figure also shows a breakdown of the type of renewable energy technology used.

<sup>2</sup> “Hawaiian Electric” or the “Company” refers to Hawaiian Electric Company, Inc. (or “HE”), Hawai‘i Electric Light Company, Inc. (or “HL”) and/or Maui Electric Company, Limited (or “ME”). On December 20, 2019, the State of Hawai‘i Department of Commerce and Consumer Affairs (“DCCA”) approved Hawaiian Electric Company, Inc., Hawai‘i Electric Light Company, Inc. and Maui Electric Company, Limited’s application to do business under the trade name “Hawaiian Electric” for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.


<sup>3</sup> Hawai‘i Public Utility Commission (PUC), “Report to the 2019 Legislature on Hawai‘i’s Renewable Portfolio Standards”, Dec. 2018 [https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report\\_FINAL.pdf](https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report_FINAL.pdf).

**Figure C-1 Statewide Renewable Portfolio Progress**



Source: [https://puc.Hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report\\_FINAL.pdf](https://puc.Hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report_FINAL.pdf)

**Figure C-2 Hawaiian Electric Companies RPS Achievement by Generation Technology<sup>4</sup>**



<sup>4</sup> PUC Dec. 2018 Report, Figure 2, page 7.

#### 4. Future RPS Achievability

To date, Hawai'i's electric utilities have generally met or exceeded the RPS requirements. Continued progress consistent with RPS is expected to continue. Projects and plans are already in place to continue this rapid RPS shift to renewable energy sources for the period of interest of the next decadal period of the RHR. In its December 2018 report to the state legislature, the Hawai'i Public Utility Commission ("PUC") indicated that "future renewable projects under construction or planned for the HECO Companies and KIUC should ensure that the state remains on track for meeting the 2020 and 2030 RPS targets."<sup>5</sup>

Figure C-3 below shows Hawaiian Electric's projection of percent renewables through 2030 presented in the December 2018 PUC report. This projected progress remains well ahead of the RPS requirements which also is ahead of the requirements of the Regional Haze glidepath goals.

**Figure C-3 Hawaiian Electric Companies RPS Expectation by 2030 Technology<sup>6</sup>**




Table C-2 below shows the past actual and future forecast for Hawaiian Electric from the previous two figures (from PUC's 2018 report) together with the requirements of RPS and the goals of the RHR. Hawaiian Electric's renewable energy progress and forecast is ahead of both programs. Additionally, Hawaiian Electric has an internal target to achieve 100% renewables by 2040, five years ahead of the RPS requirement and 25 years ahead of the RHR goals.

<sup>5</sup> PUC Dec. 2018 Report, page 2.


<sup>6</sup> PUC Dec. 2018 Report, Figure 2, page 16.

**Table C-2 Comparison of RPS and Regional Haze Glidepaths**

Year	RPS Renewable Requirement % of Electricity Sales	Regional Haze Glidepath % Visibility Improvement	Hawaiian Electric % Renewables
2010	10%	8%	9.5% (actual)
2015	15%	17%	23.2% (actual)
2020	30%	25%	31.9% (projection)
2030	40%	42%	47.3% (projection)
2040	70%	58%	100% (goal)
2045	100%	67%	100% (goal)

Hawaiian Electric’s latest projections show an even more rapid shift to renewable energy sources than forecasted in 2018. This will continue to decrease Hawaiian Electric facility emissions. For example, Figure C-4 illustrates Hawaiian Electric’s latest forecast emissions trends for total nitrogen oxides (“NOx”), sulfur dioxide (“SO<sub>2</sub>”) and Particulate Matter (“PM<sub>10</sub>”) emissions (in tons per year “TPY”) from the six power plants (Waiiau and Kahe Generating Stations on Oahu, Kahului and Maalaea on Maui, and Kanoiehua-Hill and Puna on Hawai’i) requested to conduct Four-Factor Analyses by the Hawai’i Department of Health (“DOH”). These dramatic emissions decreases illustrate the expected progress from RPS alone – without any additional RHR measures. The forecast emissions shown in Figure C-4 was derived from recent fuel consumption projections based on the resource plans and planning assumptions submitted to the PUC as part of Hawaiian Electric’s 2016 Power Supply Improvement Plan (“PSIP”) which was accepted by the PUC and recent renewable project applications.

**Figure C-4 Hawaiian Electric NOx Forecast Emissions**





The emissions reduction is quite rapid and most of the projected reduction by Hawaiian Electric are expected to be in place prior to 2028, the next Regional Haze planning milestone.

Although this projection is based on reasonable assumptions, plans are subject to change as there is some uncertainty regarding future projections and forecast assumptions. For this reason and due to energy security issues, Hawaiian Electric cannot commit to specific dates for particular emissions reductions or final retirements of any specific generating station. Nevertheless, Hawaiian Electric is on an aggressive path to end fossil-fueled generation and replace it with renewable energy sources – especially during this next decadal period. This progress should be sufficient for Hawaiian Electric’s contribution to the state’s efforts regarding reasonable progress of the RHR for the current Regional Haze decadal review.

## **5. Reliance on RPS for this Regional Haze Decadal Review**

The RPS requirements are part of Hawai’i state law. An electric utility failing to meet the RPS requirements is subject to enforcement action and penalties by the PUC unless the PUC determines the electric utility is unable to meet the RPS due to factors beyond its reasonable control. However, given the progress to date of the Hawai’i electric utilities acquiring renewable generation and expectations for planned renewable projects in the near future, it is reasonable to expect that RPS will result in continued steady progress, at least through 2030.

The DOH can rely on the RPS for regional haze progress without having to impose separate RHR requirements in facility permits. This is supported by EPA guidance which states that “Enforceable requirements are one reasonable basis for projecting a change in operating parameters and thus emissions; energy efficiency, renewable energy, or other such programs where there is a documented commitment to participate and verifiable basis for quantifying any change in future emissions due to operational changes may be another.”<sup>7</sup>

Even if progress were slower than currently expected, it would not prevent the RPS from being relied upon as the major EGU contribution to meeting Hawai’i’s regional haze goals. The time perspective of the Regional Haze Program is long. Making wise decisions that help achieve the long-term goals is important. Hawai’i electric utilities are currently focusing resources on advancing renewable energy projects that will permanently displace fossil-fueled unit generation and fossil-fueled combustion emissions. These ongoing RPS efforts help achieve the long-term goals of the RHR and provide permanent emissions reductions and other societal benefits. In contrast, new investments in conventional emissions controls on aging fossil-fueled units provide only modest short-term benefits impose additional costs on rate payers and will have no lasting value when those units are deactivated or retired.

<sup>7</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period – August 2019 at page 17. [https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019\\_-\\_regional\\_haze\\_guidance\\_final\\_guidance.pdf](https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019_-_regional_haze_guidance_final_guidance.pdf).



**Appendix Table D-1. Residual Low Sulfur Fuel Oil (LSFO) Cost**

Date	Residual Low Sulfur Fuel Oil (LSFO) <sup>A</sup>	
	(\$/BBL)	(\$/gal)
Jan-18	\$72.18	\$1.72
Feb-18	\$76.55	\$1.82
Mar-18	\$78.90	\$1.88
Apr-18	\$75.53	\$1.80
May-18	\$75.76	\$1.80
Jun-18	\$82.18	\$1.96
Jul-18	\$90.27	\$2.15
Aug-18	\$88.71	\$2.11
Sep-18	\$89.95	\$2.14
Oct-18	\$88.46	\$2.11
Nov-18	\$92.63	\$2.21
Dec-18	\$101.89	\$2.43
Jan-19	\$83.76	\$1.99
Feb-19	\$62.69	\$1.49
Mar-19	\$76.63	\$1.82
Apr -19 <sup>B</sup>	\$1,888.78	\$44.97
May-19	\$85.95	\$2.05
Jun-19	\$83.60	\$1.99
Jul-19	\$79.61	\$1.90
Aug-19	\$77.66	\$1.85
Sep-19	\$77.29	\$1.84
Oct-19	\$73.85	\$1.76
Nov-19	\$74.39	\$1.77
Dec-19	\$72.52	\$1.73
<b>2018-19 Annual Average</b>	<b>\$80.75</b>	<b>\$1.93</b>

<sup>A</sup> Fuel cost from the 2019 and 2018 Energy Cost Recovery Filings submitted to the Hawai'i Public Utilities Commission.

(<https://www.hawaiianelectric.com/billing-and-payment/rates-and-regulations/energy-cost-filings/oahu-energy-cost-filings>)

<sup>B</sup> April 2019 was not included in the average due to an unusually high \$/bbl.

**Appendix Table D-2. Ultra-Low Sulfur Diesel (ULSD) Import Cost**

<b>Description</b>	<b>Value</b>	<b>Units</b>
Platts 2018 Price <sup>A</sup>	86.75	\$/BBL
2019 Inflation	1.5	%
Platts 2019 Price	88.05	\$/BBL
Freight <sup>B</sup>	5.51	\$/BBL
Terminalling Fee <sup>B</sup>	2.00	\$/BBL
<b>Total ULSD Import Cost <sup>C</sup></b>	<b>95.56</b>	<b>\$/BBL</b>
	<b>2.28</b>	<b>\$/Gal</b>

<sup>A</sup> S&P Global Platts - Oilgram Price Report, listed price is Singapore spot price for Gasoil 10 ppm which is comparable to ULSD.  
([https://www.spglobal.com/platts/plattscontent/\\_assets/\\_files/en/productservices/market-reports/oilgram-proce-report-060818.pdf](https://www.spglobal.com/platts/plattscontent/_assets/_files/en/productservices/market-reports/oilgram-proce-report-060818.pdf))

<sup>B</sup> Hawaiian Electric Fuels Division Estimate.

<sup>C</sup> Platts 2019 spot price plus freight and terminalling fees.

## **Control Cost Worksheets and DOH-CAB Revisions**

## **Changes Summarized**

3.25 % interest rate for controls

30 year equipment life for SCR

20 year equipment life for all other controls\*

SNCR retrofit factor of 1

**\* Equipment life of CDS were reassess at 30 years based on upcoming revision to the cost control manual.**

Table 3-2. SO<sub>2</sub> Cost Effectiveness of CDS

Unit	Control Option	2017 SO <sub>2</sub> Emissions <sup>A</sup> (tpy)	Controlled Emission Level <sup>B</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (ton/yr)	Total Annual Cost <sup>C</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	CDS	841.8	0.045	3,778,041	84.2	757.6	\$10,608,072	\$14,002
K2	CDS	659.5	0.045	2,959,869	66.0	593.6	\$10,800,319	\$18,196
K3	CDS	836.3	0.045	3,753,356	83.6	752.7	\$11,589,051	\$15,397
K4	CDS	859.8	0.045	3,858,826	86.0	773.8	\$11,023,741	\$14,246
K5	CDS	1,136.2	0.045	5,099,323	113.6	1,022.6	\$18,694,104	\$18,281
K6	CDS	1,431.5	0.045	6,424,644	143.2	1,288.4	\$17,000,254	\$13,195

Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

Controlled emission levels based on 90% control.

See Appendix A for total annual cost calculations.

[Original Submitted Spreadsheet](#)

**Table 3-2. SO<sub>2</sub> Cost Effectiveness of CDS (20 Yrs Life)**

<b>Unit</b>	<b>Control Option</b>	<b>2017 SO<sub>2</sub> Emissions<sup>A</sup> (tpy)</b>	<b>Controlled Emission Level<sup>B</sup> (lb/MMBtu)</b>	<b>2017 Annual Heat Input (MMBtu/yr)</b>	<b>Controlled SO<sub>2</sub> Emissions (tpy)</b>	<b>SO<sub>2</sub> Reduced (ton/yr)</b>	<b>Total Annual Cost<sup>C</sup> (\$/yr)</b>	<b>Cost Effectiveness (\$/ton)</b>
K1	CDS	841.8	0.045	3,778,041	84.2	757.6	\$9,709,255	\$12,815
K2	CDS	659.5	0.045	2,959,869	66.0	593.6	\$9,901,501	\$16,682
K3	CDS	836.3	0.045	3,753,356	83.6	752.7	\$10,690,233	\$14,203
K4	CDS	859.8	0.045	3,858,826	86.0	773.8	\$10,124,923	\$13,084
K5	CDS	1,136.2	0.045	5,099,323	113.6	1,022.6	\$17,306,804	\$16,925
K6	CDS	1,431.5	0.045	6,424,644	143.2	1,288.4	\$15,612,953	\$12,119

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> Controlled emission levels based on 90% control.

<sup>C</sup> See Appendix A for total annual cost calculations.

[DOH-CAB Changed Spreadsheet \(20 Yrs Life\)](#)



**Table 3-2. SO<sub>2</sub> Cost Effectiveness of CDS (30 Yrs Life)**

<b>Unit</b>	<b>Control Option</b>	<b>2017 SO<sub>2</sub> Emissions<sup>A</sup> (tpy)</b>	<b>Controlled Emission Level<sup>B</sup> (lb/MMBtu)</b>	<b>2017 Annual Heat Input (MMBtu/yr)</b>	<b>Controlled SO<sub>2</sub> Emissions (tpy)</b>	<b>SO<sub>2</sub> Reduced (ton/yr)</b>	<b>Total Annual Cost<sup>C</sup> (\$/yr)</b>	<b>Cost Effectiveness (\$/ton)</b>
K1	CDS	841.8	0.045	3,778,041	84.2	757.6	\$8,483,898	\$11,198
K2	CDS	659.5	0.045	2,959,869	66.0	593.6	\$8,676,145	\$14,617
K3	CDS	836.3	0.045	3,753,356	83.6	752.7	\$9,464,877	\$12,575
K4	CDS	859.8	0.045	3,858,826	86.0	773.8	\$8,899,567	\$11,501
K5	CDS	1,136.2	0.045	5,099,323	113.6	1,022.6	\$15,415,500	\$15,075
K6	CDS	1,431.5	0.045	6,424,644	143.2	1,288.4	\$13,721,650	\$10,651

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> Controlled emission levels based on 90% control.

<sup>C</sup> See Appendix A for total annual cost calculations.

DOH-CAB Changed Spreadsheet (30 Yrs Life)

Table 3-3. SO<sub>2</sub> Cost Effectiveness of Fuel Switching to a Residual Oil/ULSD Blend

Unit	Current Residual Oil (0.50% maximum Sulfur) <sup>A</sup>					Residual Oil/ULSD Blend (0.25% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content	Fuel Heating Value (HHV)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup>		SO <sub>2</sub> Cost Effectiveness (\$/ton)
	(%)	(Btu/gal)	(gal/yr)	(MMBtu/yr)	(tpy)	(Btu/gal)	(gal/yr)	(tpy)	(tpy)	(\$/Gal)	(\$/yr)	
K1	0.42%	149,479	25,274,725	3,778,041	841.8	143,071	26,406,754	493.0	348.8	0.18	\$4,621,182	13,250
K2	0.42%	149,479	19,801,237	2,959,869	659.5	143,071	20,688,114	386.3	273.2	0.18	\$3,620,420	13,250
K3	0.42%	149,479	25,109,590	3,753,356	836.3	143,071	26,234,222	489.8	346.5	0.18	\$4,590,989	13,250
K4	0.42%	149,479	25,815,168	3,858,826	859.8	143,071	26,971,403	503.6	356.2	0.18	\$4,719,995	13,250
K5	0.42%	149,479	34,113,973	5,099,323	1,136.2	143,071	35,641,903	665.5	470.7	0.18	\$6,237,333	13,250
K6	0.42%	149,479	42,980,244	6,424,644	1,431.5	143,071	44,905,284	838.4	593.1	0.18	\$7,858,425	13,250

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on a blend of 50.0% residual oil and 50.0% ULSD and the weighted average of the 2017 fuel HHV and density for residual oil and ULSD, and contract fuel sulfur limits.

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

Table 3-4. SO<sub>2</sub> Cost Effectiveness of Fuel Switching to ULSD

Unit	Current Residual Oil (0.50% maximum Sulfur) <sup>A</sup>					ULSD (0.0015% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content	Fuel Heating Value (HHV)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup>		SO <sub>2</sub> Cost Effectiveness (\$/ton)
	(%)	(Btu/gal)	(gal/yr)	(MMBtu/yr)	(tpy)	(Btu/gal)	(gal/yr)	(tpy)	(tpy)	(\$/Gal)	(\$/yr)	
K1	0.42%	149,479	25,274,725	3,778,041	841.8	136,662	27,645,144	3.8	838.0	0.36	\$9,814,026	11,711
K2	0.42%	149,479	19,801,237	2,959,869	659.5	136,662	21,658,318	3.0	656.5	0.36	\$7,688,703	11,711
K3	0.42%	149,479	25,109,590	3,753,356	836.3	136,662	27,464,521	3.8	832.5	0.36	\$9,749,905	11,711
K4	0.42%	149,479	25,815,168	3,858,826	859.8	136,662	28,236,273	3.9	855.9	0.36	\$10,023,877	11,711
K5	0.42%	149,479	34,113,973	5,099,323	1,136.2	136,662	37,313,391	5.1	1,131.1	0.36	\$13,246,254	11,711
K6	0.42%	149,479	42,980,244	6,424,644	1,431.5	136,662	47,011,195	6.4	1,425.1	0.36	\$16,688,974	11,711

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on 2017 average HHV and density for residual oil, AP-42 HHV and density for diesel, and contract fuel sulfur limits.

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

Original Submitted Spreadsheet

Table 4-4. NO<sub>x</sub> Cost Effectiveness of Controls Summary

Unit	Control Option	2017 NO <sub>x</sub> Emissions <sup>A</sup> (tpy)	Controlled Emission Level <sup>B,C</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled NO <sub>x</sub> Emissions (tpy)	NO <sub>x</sub> Reduced (ton/yr)	Total Annual Cost <sup>D,E</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	Residual Oil/ULSD Blend	932.7	0.38	3,778,041	718.2	214.5	\$4,621,182	\$21,542
	ULSD	932.7	0.27	3,778,041	513.0	419.7	\$9,814,026	\$23,383
	Combustion Controls	932.7	0.30	3,778,041	566.7	366.0	\$482,550	\$1,318
	SNCR	932.7	0.40	3,778,041	755.6	177.1	\$854,332	\$4,824
	SNCR+Combustion Controls	932.7	0.20	3,778,041	377.8	554.9	\$1,336,882	\$2,409
	SCR	932.7	0.10	3,778,041	188.9	743.8	\$2,210,698	\$2,972
	SCR+Combustion Controls	932.7	0.05	3,778,041	94.5	838.2	\$2,693,248	\$3,213
K2	Residual Oil/ULSD Blend	963.0	0.50	2,959,869	741.5	221.5	\$3,620,420	\$16,346
	ULSD	963.0	0.36	2,959,869	529.7	433.4	\$7,688,703	\$17,742
	Combustion Controls	963.0	0.30	2,959,869	444.0	519.0	\$467,426	\$901
	SNCR <sup>F</sup>	963.0	0.40	2,959,869	592.0	371.0	\$854,332	\$2,303
	SNCR+Combustion Controls	963.0	0.20	2,959,869	296.0	667.0	\$1,321,758	\$1,982
	SCR	963.0	0.10	2,959,869	148.0	815.0	\$2,083,950	\$2,557
	SCR+Combustion Controls	963.0	0.05	2,959,869	74.0	889.0	\$2,551,376	\$2,870
K3	Residual Oil/ULSD Blend	661.7	0.32	3,753,356	595.5	66.2	\$4,590,989	\$69,382
	ULSD	661.7	0.28	3,753,356	529.4	132.3	\$9,749,905	\$73,673
	Combustion Controls	661.7	0.20	3,753,356	375.3	286.4	\$346,310	\$1,209
	SNCR	661.7	0.25	3,753,356	469.2	192.5	\$789,403	\$4,100
	SNCR+Combustion Controls	661.7	0.15	3,753,356	281.5	380.2	\$1,135,713	\$2,987
	SCR	661.7	0.10	3,753,356	187.7	474.0	\$2,171,338	\$4,581
	SCR+Combustion Controls	661.7	0.05	3,753,356	93.8	567.9	\$2,517,649	\$4,434
K4	Residual Oil/ULSD Blend	732.2	0.34	3,858,826	659.0	73.2	\$4,719,995	\$64,463
	ULSD	732.2	0.30	3,858,826	585.8	146.4	\$10,023,877	\$68,450
	Combustion Controls	732.2	0.20	3,858,826	385.9	346.3	\$349,044	\$1,008
	SNCR <sup>F</sup>	732.2	0.25	3,858,826	482.4	249.8	\$789,403	\$3,160
	SNCR+Combustion Controls	732.2	0.15	3,858,826	289.4	442.8	\$1,138,447	\$2,571
	SCR	732.2	0.10	3,858,826	192.9	539.3	\$2,202,873	\$4,085
	SCR+Combustion Controls	732.2	0.05	3,858,826	96.5	635.7	\$2,551,917	\$4,014
K5	Residual Oil/ULSD Blend	2,044.2	0.62	5,099,323	1,574.0	470.2	\$6,237,333	\$13,266
	ULSD	2,044.2	0.44	5,099,323	1,124.3	919.9	\$13,246,254	\$14,400
	Combustion Controls	2,044.2	0.30	5,099,323	764.9	1,279.3	\$638,537	\$499
	SNCR	2,044.2	0.40	5,099,323	1,019.9	1,024.3	\$1,358,582	\$1,326
	SNCR+Combustion Controls	2,044.2	0.20	5,099,323	509.9	1,534.3	\$1,997,119	\$1,302
	SCR	2,044.2	0.10	5,099,323	255.0	1,789.2	\$3,058,173	\$1,709
	SCR+Combustion Controls	2,044.2	0.05	5,099,323	127.5	1,916.7	\$3,696,710	\$1,929
K6	Residual Oil/ULSD Blend	630.1	0.16	6,424,644	516.7	113.4	\$7,858,425	\$69,287
	ULSD	630.1	0.13	6,424,644	403.3	226.8	\$16,688,974	\$73,573
	SNCR <sup>G</sup>	630.1	0.15	6,424,644	481.8	148.3	\$883,819	\$5,962
	SCR <sup>G</sup>	630.1	0.05	6,424,644	160.6	469.5	\$3,045,798	\$6,488

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> The controlled emission level for ULSD is based on the No. 2 fuel oil emission factor from AP-42, Table 1.3-1, dated May 2010. The controlled emission level for the 50/50 residual oil/ULSD blend is based on the average of the AP-42 emission factor for No. 2 fuel oil and the 2017 emission factor.

<sup>C</sup> Controlled emission levels based on "Alternative Control Techniques (ACT) Document - NO<sub>x</sub> Emissions from Utility Boiler" EPA, 1994.

<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-3 and 3-4. The annual costs of fuel switching are based on 2019 dollars.

<sup>E</sup> See Appendix A for the total annual cost calculations for combustion controls, SNCR and SCR.

<sup>F</sup> The annual cost for K2 is based on K1 which has a similar design and rating and the annual cost for K4 is based on K3 which has a similar design and rating.

<sup>G</sup> K6 is equipped with combustion controls, the level of SCR control was reduced to 0.05 lb/MMBtu to account for the combined level of control.

Original Submitted Spreadsheet

Table 4-4. NO<sub>x</sub> Cost Effectiveness of Controls Summary

Unit	Control Option	2017 NO <sub>x</sub> Emissions <sup>A</sup> (tpy)	Controlled Emission Level <sup>B,C</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled NO <sub>x</sub> Emissions (tpy)	NO <sub>x</sub> Reduced (ton/yr)	Total Annual Cost <sup>D,E</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	Residual Oil/ULSD Blend	932.7	0.38	3,778,041	718.2	214.5	\$4,621,182	\$21,542
	ULSD	932.7	0.27	3,778,041	513.0	419.7	\$9,814,026	\$23,383
	Combustion Controls	932.7	0.30	3,778,041	566.7	366.0	\$428,048	\$1,170
	SNCR	932.7	0.40	3,778,041	755.6	177.1	\$550,535	\$3,109
	SNCR+Combustion Controls	932.7	0.20	3,778,041	377.8	554.9	\$978,583	\$1,764
	SCR	932.7	0.10	3,778,041	188.9	743.8	\$1,386,756	\$1,864
K2	SCR+Combustion Controls	932.7	0.05	3,778,041	94.5	838.2	\$1,814,804	\$2,165
	Residual Oil/ULSD Blend	963.0	0.50	2,959,869	741.5	221.5	\$3,620,420	\$16,346
	ULSD	963.0	0.36	2,959,869	529.7	433.4	\$7,688,703	\$17,742
	Combustion Controls	963.0	0.30	2,959,869	444.0	519.0	\$413,686	\$797
	SNCR <sup>F</sup>	963.0	0.40	2,959,869	592.0	371.0	\$550,535	\$1,484
	SNCR+Combustion Controls	963.0	0.20	2,959,869	296.0	667.0	\$964,221	\$1,446
K3	SCR	963.0	0.10	2,959,869	148.0	815.0	\$1,272,051	\$1,561
	SCR+Combustion Controls	963.0	0.05	2,959,869	74.0	889.0	\$1,685,738	\$1,896
	Residual Oil/ULSD Blend	661.7	0.32	3,753,356	595.5	66.2	\$4,590,989	\$69,382
	ULSD	661.7	0.28	3,753,356	529.4	132.3	\$9,749,905	\$73,673
	Combustion Controls	661.7	0.20	3,753,356	375.3	286.4	\$305,434	\$1,067
	SNCR	661.7	0.25	3,753,356	469.2	192.5	\$484,414	\$2,516
K4	SNCR+Combustion Controls	661.7	0.15	3,753,356	281.5	380.2	\$789,848	\$2,077
	SCR	661.7	0.10	3,753,356	187.7	474.0	\$1,346,975	\$2,842
	SCR+Combustion Controls	661.7	0.05	3,753,356	93.8	567.9	\$1,652,409	\$2,910
	Residual Oil/ULSD Blend	732.2	0.34	3,858,826	659.0	73.2	\$4,719,995	\$64,463
	ULSD	732.2	0.30	3,858,826	585.8	146.4	\$10,023,877	\$68,450
	Combustion Controls	732.2	0.20	3,858,826	385.9	346.3	\$307,883	\$889
K5	SNCR <sup>F</sup>	732.2	0.25	3,858,826	482.4	249.8	\$484,414	\$1,939
	SNCR+Combustion Controls	732.2	0.15	3,858,826	289.4	442.8	\$792,297	\$1,789
	SCR	732.2	0.10	3,858,826	192.9	539.3	\$1,372,847	\$2,546
	SCR+Combustion Controls	732.2	0.05	3,858,826	96.5	635.7	\$1,680,730	\$2,644
	Residual Oil/ULSD Blend	2,044.2	0.62	5,099,323	1,574.0	470.2	\$6,237,333	\$13,266
	ULSD	2,044.2	0.44	5,099,323	1,124.3	919.9	\$13,246,254	\$14,400
K6	Combustion Controls	2,044.2	0.30	5,099,323	764.9	1,279.3	\$566,552	\$443
	SNCR	2,044.2	0.40	5,099,323	1,019.9	1,024.3	\$942,382	\$920
	SNCR+Combustion Controls	2,044.2	0.20	5,099,323	509.9	1,534.3	\$1,508,934	\$983
	SCR	2,044.2	0.10	5,099,323	255.0	1,789.2	\$1,967,607	\$1,100
	SCR+Combustion Controls	2,044.2	0.05	5,099,323	127.5	1,916.7	\$2,534,159	\$1,322
	Residual Oil/ULSD Blend	630.1	0.16	6,424,644	516.7	113.4	\$7,858,425	\$69,287
K6	ULSD	630.1	0.13	6,424,644	403.3	226.8	\$16,688,974	\$73,573
	SNCR <sup>G</sup>	630.1	0.15	6,424,644	481.8	148.3	\$527,988	\$3,561
	SCR <sup>G</sup>	630.1	0.05	6,424,644	160.6	469.5	\$1,953,690	\$4,161

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).  
<sup>B</sup> The controlled emission level for ULSD is based on the No. 2 fuel oil emission factor from AP-42, Table 1.3-1, dated May 2010. The controlled emission level for the 50/50 residual oil/ULSD blend is based on the average of the AP-42 emission factor for No. 2 fuel oil and the 2017 emission factor.  
<sup>C</sup> Controlled emission levels based on "Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler" EPA, 1994.  
<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-3 and 3-4. The annual costs of fuel switching are based on 2019 dollars.  
<sup>E</sup> See Appendix A for the total annual cost calculations for combustion controls, SNCR and SCR.  
<sup>F</sup> The annual cost for K2 is based on K1 which has a similar design and rating and the annual cost for K4 is based on K3 which has a similar design and rating.  
<sup>G</sup> K6 is equipped with combustion controls, the level of SCR control was reduced to 0.05 lb/MMBtu to account for the combined level of control.

DOH-CAB Changed Spreadsheet

Table 5-3. PM<sub>10</sub> Cost Effectiveness Summary

Unit	Control Option	2017 PM <sub>10</sub> Emissions <sup>A</sup> (tpy)	Controlled Emission Level <sup>B</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled PM <sub>10</sub> Emissions (tpy)	PM <sub>10</sub> Reduced (ton/yr)	Total Annual Cost <sup>C</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	Residual Oil/ULSD Blend	55.7	0.0203	3,778,041	38.4	17.3	\$4,621,182	\$267,631
	ULSD	55.7	0.0112	3,778,041	21.2	34.5	\$9,814,026	\$284,184
K2	Residual Oil/ULSD Blend	39.3	0.0183	2,959,869	27.1	12.2	\$3,620,420	\$297,170
	ULSD	39.3	0.0101	2,959,869	14.9	24.4	\$7,688,703	\$315,550
K3	Residual Oil/ULSD Blend	51.7	0.0190	3,753,356	35.7	16.0	\$4,590,989	\$286,453
	ULSD	51.7	0.0105	3,753,356	19.6	32.1	\$9,749,905	\$304,171
K4	Residual Oil/ULSD Blend	50.5	0.0181	3,858,826	34.8	15.7	\$4,719,995	\$301,501
	ULSD	50.5	0.0099	3,858,826	19.2	31.3	\$10,023,877	\$320,149
K5	Residual Oil/ULSD Blend	78.7	0.0213	5,099,323	54.3	24.4	\$6,237,333	\$255,660
	ULSD	78.7	0.0117	5,099,323	29.9	48.8	\$13,246,254	\$271,473
K6	Residual Oil/ULSD Blend	108.6	0.0233	6,424,644	74.9	33.7	\$7,858,425	\$233,423
	ULSD	108.6	0.0128	6,424,644	41.3	67.3	\$16,688,974	\$247,861

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> The controlled emission level for ULSD is based on the No. 2 fuel oil emission factor from AP-42, Table 1.3-1, dated May 2010. The controlled emission level for the 50/50 residual oil/ULSD blend is based on the average of the AP-42 emission factor for No. 2 fuel oil and the 2017 emission factor.

<sup>C</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-3 and 3-4. The annual costs of fuel switching are based on 2019 dollars.

[Original Submitted Spreadsheet](#)

**Table 6-1 Total Cost Effectiveness of Fuel Switching**

<b>Unit</b>	<b>Control Option</b>	<b>SO<sub>2</sub> Reduced<sup>A</sup> (ton/yr)</b>	<b>NO<sub>x</sub> Reduced<sup>A</sup> (ton/yr)</b>	<b>PM<sub>10</sub> Reduced<sup>A</sup> (ton/yr)</b>	<b>Total SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> Reduced (ton/yr)</b>	<b>Total Annual Cost<sup>B</sup> (\$/yr)</b>	<b>Cost Effectiveness (\$/ton)</b>
K1	Residual Oil/ULSD Blend	348.8	214.5	17.3	580.6	\$4,621,182	\$7,960
	ULSD	838.0	419.7	34.5	1,292.3	\$9,814,026	\$7,594
K2	Residual Oil/ULSD Blend	273.2	221.5	12.2	506.9	\$3,620,420	\$7,142
	ULSD	656.5	433.4	24.4	1,114.3	\$7,688,703	\$6,900
K3	Residual Oil/ULSD Blend	346.5	66.2	16.0	428.7	\$4,590,989	\$10,709
	ULSD	832.5	132.3	32.1	996.9	\$9,749,905	\$9,780
K4	Residual Oil/ULSD Blend	356.2	73.2	15.7	445.1	\$4,719,995	\$10,604
	ULSD	855.9	146.4	31.3	1,033.7	\$10,023,877	\$9,697
K5	Residual Oil/ULSD Blend	470.7	470.2	24.4	965.3	\$6,237,333	\$6,462
	ULSD	1,131.1	919.9	48.8	2,099.8	\$13,246,254	\$6,308
K6	Residual Oil/ULSD Blend	593.1	113.4	33.7	740.2	\$7,858,425	\$10,617
	ULSD	1,425.1	226.8	67.3	1,719.2	\$16,688,974	\$9,707

<sup>A</sup> The SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> reduced are from Tables 3-3 and 3-4, Table 4-4, and Table 5-3, respectively.

<sup>B</sup> Annual costs for switching to a residual oil/distillate blend or distillate are from Tables 3-3 and 3-4. The annual costs of fuel switching are based on 2019

[Original Submitted Spreadsheet](#)

## Appendix Table A-3a. Kahe K1 - SCR Costing

Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

What type of fuel does the unit burn? Fuel Oil

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1.5

\* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 92 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWhs output? 384,917 MWhs

Enter the net plant heat input rate (NPHR) 9.8152 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) =   percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

Original Submitted Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

Enter the following design parameters for the proposed SCR:

<p>Number of days the SCR operates (<math>t_{SCR}</math>)</p> <p>Number of days the boiler operates (<math>t_{plant}</math>)</p> <p>Inlet NO<sub>x</sub> Emissions (NO<sub>x,in</sub>) to SCR</p> <p>Outlet NO<sub>x</sub> Emissions (NO<sub>x,out</sub>) from SCR</p> <p>Stoichiometric Ratio Factor (SRF)</p> <p><small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">365 days</td></tr> <tr><td style="text-align: center;">0.494 lb/MMBtu</td></tr> <tr><td style="text-align: center;">0.1 lb/MMBtu</td></tr> <tr><td style="text-align: center;">1.050</td></tr> </table>	365 days	365 days	0.494 lb/MMBtu	0.1 lb/MMBtu	1.050	<p>Number of SCR reactor chambers (<math>n_{scr}</math>)</p> <p>Number of catalyst layers (<math>R_{catalyst}</math>)</p> <p>Number of empty catalyst layers (<math>R_{empty}</math>)</p> <p>Ammonia Slip (Slip) provided by vendor</p> <p>Volume of the catalyst layers (<math>Vol_{catalyst}</math>) (Enter "UNK" if value is not known)</p> <p>Flue gas flow rate (<math>Q_{fluegas}</math>) (Enter "UNK" if value is not known)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">3</td></tr> <tr><td style="text-align: center;">1</td></tr> <tr><td style="text-align: center;">2 ppm</td></tr> <tr><td style="text-align: center;">UNK Cubic feet</td></tr> <tr><td style="text-align: center;">UNK acfm</td></tr> </table>	1	3	1	2 ppm	UNK Cubic feet	UNK acfm
365 days														
365 days														
0.494 lb/MMBtu														
0.1 lb/MMBtu														
1.050														
1														
3														
1														
2 ppm														
UNK Cubic feet														
UNK acfm														
<p>Estimated operating life of the catalyst (<math>H_{catalyst}</math>)</p> <p>Estimated SCR equipment life</p> <p><small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small></p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">24,000 hours</td></tr> <tr><td style="text-align: center;">30 Years*</td></tr> </table>	24,000 hours	30 Years*	<p>Gas temperature at the SCR inlet (T)</p> <p>Base case fuel gas volumetric flow rate factor (<math>Q_{fuel}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">650 °F</td></tr> <tr><td style="text-align: center;">484 ft<sup>3</sup>/min-MMBtu/hour</td></tr> </table>	650 °F	484 ft <sup>3</sup> /min-MMBtu/hour							
24,000 hours														
30 Years*														
650 °F														
484 ft <sup>3</sup> /min-MMBtu/hour														
<p>Concentration of reagent as stored (<math>C_{stored}</math>)</p> <p>Density of reagent as stored (<math>\rho_{stored}</math>)</p> <p>Number of days reagent is stored (<math>t_{storage}</math>)</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">29 percent*</td></tr> <tr><td style="text-align: center;">56 lb/cubic feet*</td></tr> <tr><td style="text-align: center;">30 days</td></tr> </table>	29 percent*	56 lb/cubic feet*	30 days	<p><small>*The reagent concentration of 29% and density of 56 lbs/ft<sup>3</sup> are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td colspan="2" style="text-align: center;"><b>Densities of typical SCR reagents:</b></td></tr> <tr><td>50% urea solution</td><td style="text-align: right;">71 lbs/ft<sup>3</sup></td></tr> <tr><td>29.4% aqueous NH<sub>3</sub></td><td style="text-align: right;">56 lbs/ft<sup>3</sup></td></tr> </table>		<b>Densities of typical SCR reagents:</b>		50% urea solution	71 lbs/ft <sup>3</sup>	29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>		
29 percent*														
56 lb/cubic feet*														
30 days														
<b>Densities of typical SCR reagents:</b>														
50% urea solution	71 lbs/ft <sup>3</sup>													
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>													
<p>Select the reagent used</p>	<p style="text-align: center;">Ammonia <span style="float: right;">▼</span></p>													

Enter the cost data for the proposed SCR:

<p>Desired dollar-year</p> <p>CEPCI for 2019</p> <p>Annual Interest Rate (i)</p> <p>Reagent (Cost<sub>reag</sub>)</p> <p>Electricity (Cost<sub>elect</sub>)</p> <p>Catalyst cost (CC<sub>replace</sub>)</p> <p>Operator Labor Rate</p> <p>Operator Hours/Day</p> <p>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">2019</td></tr> <tr><td style="text-align: center;">607.5</td></tr> <tr><td style="text-align: center;">7.00 Percent</td></tr> <tr><td style="text-align: center;">0.293 \$/gallon for 29% ammonia*</td></tr> <tr><td style="text-align: center;">0.2521 \$/kWh</td></tr> <tr><td style="text-align: center;">227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)</td></tr> <tr><td style="text-align: center;">60.00 \$/hour (including benefits)*</td></tr> <tr><td style="text-align: center;">4.00 hours/day*</td></tr> </table>	2019	607.5	7.00 Percent	0.293 \$/gallon for 29% ammonia*	0.2521 \$/kWh	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)	60.00 \$/hour (including benefits)*	4.00 hours/day*	<p>2016 CEPCI</p> <p>CEPCI = Chemical Engineering Plant Cost Index</p> <p><small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small></p> <p><small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small></p> <p><small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small></p> <p><small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small></p>
2019										
607.5										
7.00 Percent										
0.293 \$/gallon for 29% ammonia*										
0.2521 \$/kWh										
227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)										
60.00 \$/hour (including benefits)*										
4.00 hours/day*										

Original Submitted Spreadsheet



## Appendix Table A-3a. Kahe K1 - SCR Costing

**Maintenance and Administrative Charges Cost Factors:**

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

**Data Sources Values Used in Calculations:**

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility What type of fuel does the unit burn? Fuel Oil

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 92 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWs output? 384,917 MWs

Enter the net plant heat input rate (NPHR) 9.8152 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) =   percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

DOH-CAB Changed Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.494 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $VOL_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used: <span style="border: 1px solid black; padding: 2px;">Ammonia</span>			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	3.25 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*				<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)				<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Hours/Day	4.00 hours/day*				<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>		Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.					

DOH-CAB Changed Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

**Maintenance and Administrative Charges Cost Factors:**

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

**Data Sources Values Used in Calculations:**

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	903	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	805,920	MWhs
Estimated Actual Annual MWs Output (Boutput) =		384,917	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.98	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.478	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4184	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	79.7	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	355.55	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	743.80	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	1.00	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \eta_{scr} =$	418,214	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	111.61	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgrc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{SCR} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x_{adj}} \times S_{adj} \times (T_{adj}/N_{scr})$	3,746.95	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	436	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

Original Submitted Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	501	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.4	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	52	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NOx_{in} \times Q_g \times EF \times SRF \times MW_R) / MW_{NOx}$	138	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	476	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	64	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	45,900	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1)$ Where n = Equipment Life and i = Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	511.08	kW

Original Submitted Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	903	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	805,920	MWhs
Estimated Actual Annual MWs Output (Boutput) =		384,917	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.98	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.478	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4184	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	79.7	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	355.55	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	743.80	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	1.00	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \eta_{scr} =$	418,214	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	111.61	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgrc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(\text{interest rate}) / (1 + (\text{interest rate})^Y - 1)$ , where $Y = H_{catalyst} / (t_{SCR} \times 24 \text{ hours})$ rounded to the nearest integer	0.3227	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x_{adj}} \times S_{adj} \times (T_{adj}/N_{scr})$	3,746.95	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\text{ft}/\text{sec} \times 60\ \text{sec}/\text{min})$	436	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

### DOH-CAB Changed Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	501	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.4	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	52	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NOx_{in} \times Q_g \times EF \times SRF \times MW_R) / MW_{NOx}$	138	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	476	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	64	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	45,900	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1)$ Where n = Equipment Life and i = Interest Rate	0.0527

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	511.08	kW

DOH-CAB Changed Spreadsheet



## Appendix Table A-3a. Kahe K1 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV F \times RF$	
Total Capital Investment (TCI) =	\$17,543,429	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$793,017 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,417,681 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$2,210,698 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$87,717 in 2019 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$78,028 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$539,069 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$88,203 in 2019 dollars
Direct Annual Cost =		\$793,017 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,681 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,414,000 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$1,417,681 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,210,698 per year in 2019 dollars
NOx Removed =		744 tons/year
Cost Effectiveness =		\$2,972 per ton of NOx removed in 2019 dollars

Original Submitted Spreadsheet

## Appendix Table A-3a. Kahe K1 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_B \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_B \times ELEV \times RF$	
Total Capital Investment (TCI) =	\$11,695,620	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$767,067 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$619,689 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$1,386,756 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$58,478 in 2019 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$78,028 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$539,069 in 2019 dollars
Annual Catalyst Replacement Cost =		\$91,492 in 2019 dollars
	$n_{scr} \times Vol_{cat} \times (CC_{replac}/R_{layer}) \times FWF$	
Direct Annual Cost =		\$767,067 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,330 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$616,359 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$619,689 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$1,386,756 per year in 2019 dollars
NOx Removed =		744 tons/year
Cost Effectiveness =		\$1,864 per ton of NOx removed in 2019 dollars

DOH-CAB Changed Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility What type of fuel does the unit burn? Fuel Oil

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1.5 \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 90 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWs output? 295,987 MWs

Enter the net plant heat input rate (NPHR) 10.0000 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) =   percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

Original Submitted Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{SCR}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.651 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $VOL_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used: <span style="border: 1px solid black; padding: 2px;">Ammonia</span>			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*			
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)			<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Hours/Day	4.00 hours/day*			<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>		Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.				

Original Submitted Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =  
 Administrative Charges Factor (ACF) =

0.005
0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?  What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWs output?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

DOH-CAB Changed Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.651 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $VOL_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used: <span style="border: 1px solid black; padding: 2px;">Ammonia</span>			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	3.25 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*	<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>		
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh			
Catalyst cost (CC <sub>replace</sub> )	227.00	Catalyst cost (CC <sub>replace</sub> )	227.00	<small>\$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)</small>		
Operator Labor Rate	60.00	Operator Labor Rate	60.00	<small>\$/hour (including benefits)*</small>		
Operator Hours/Day	4.00	Operator Hours/Day	4.00	<small>hours/day*</small>		
<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>						
<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>						
Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.						

DOH-CAB Changed Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet



## Appendix Table A-3b. Kahe K2 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q <sub>b</sub> ) =	Bmw x NPHR =	900	MMBtu/hour
Maximum Annual MW Output (Bmw) =	Bmw x 8760 =	788,400	MWhs
Estimated Actual Annual MWhs Output (Boutput) =		295,987	MWhs
Heat Rate Factor (HRF) =	NPHR/10 =	1.00	
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tscr/tplant) =	0.375	fraction
Total operating time for the SCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	3289	hours
NOx Removal Efficiency (EF) =	(NO <sub>xin</sub> - NO <sub>xout</sub> )/NO <sub>xin</sub> =	84.6	percent
NOx removed per hour =	NO <sub>xin</sub> x EF x Q <sub>b</sub> =	495.63	lb/hour
Total NO <sub>x</sub> removed per year =	(NO <sub>xin</sub> x EF x Q <sub>b</sub> x t <sub>op</sub> )/2000 =	815.01	tons/year
NO <sub>x</sub> removal factor (NRF) =	EF/80 =	1.06	
Volumetric flue gas flow rate (q <sub>flue gas</sub> ) =	Q <sub>fuel</sub> x QB x (460 + T)/(460 + 700)n <sub>scr</sub> =	416,824	acfm
Space velocity (V <sub>space</sub> ) =	q <sub>flue gas</sub> /Vol <sub>catalyst</sub> =	101.67	/hour
Residence Time	1/V <sub>space</sub>	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*1x10 <sup>6</sup> /HHV =		
Elevation Factor (ELEVf) =	14.7 psia/P =		
Atmospheric pressure at sea level (P) =	2116 x [(59-(0.00356xh)+459.7)/518.6] <sup>5.256</sup> x (1/144)* =	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

Not applicable; factor applies only to coal-fired boilers

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgrc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	(interest rate)/(1+(1+ interest rate) <sup>Y</sup> - 1), where Y = H <sub>catalyst</sub> /t <sub>SCR</sub> x 24 hours rounded to the nearest integer	0.3111	fraction
Catalyst volume (Vol <sub>catalyst</sub> ) =	2.81 x Q <sub>b</sub> x EF <sub>adj</sub> x Slipadj x NO <sub>xadj</sub> x S <sub>adj</sub> x (T <sub>adj</sub> /N <sub>scr</sub> )	4,099.76	Cubic feet
Cross sectional area of the catalyst (A <sub>catalyst</sub> ) =	q <sub>flue gas</sub> / (16ft/sec x 60 sec/min)	434	ft <sup>2</sup>
Height of each catalyst layer (H <sub>layer</sub> ) =	(Vol <sub>catalyst</sub> /(R <sub>layer</sub> x A <sub>catalyst</sub> )) + 1 (rounded to next highest integer)	4	feet

]

Original Submitted Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	499	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.3	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	54	feet

**Reagent Data:**

Type of reagent used: Ammonia Molecular Weight of Reagent (MW) = 17.03 g/mole  
Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,in} \times Q_g \times EF \times SRF \times MW_R) / MW_{NO_x} =$	193	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / Csol =$	664	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density} =$	89	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	63,900	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage: Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	504.00	kW

]

Original Submitted Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_B$ ) =	$Bmw \times NPHR =$	900	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	788,400	MWhs
Estimated Actual Annual MWs Output (Boutput) =		295,987	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.00	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.375	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	3289	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	84.6	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	495.63	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	815.01	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	1.06	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \eta_{scr} =$	416,824	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	101.67	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgrc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{SCR} \times 24\ hours)$ rounded to the nearest integer	0.3227	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_B \times EF_{adj} \times Slip_{adj} \times NO_{x_{adj}} \times S_{adj} \times (T_{adj}/N_{scr})$	4,099.76	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	434	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

DOH-CAB Changed Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	499	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.3	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	54	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x_{in}} \times Q_g \times EF \times SRF \times MW_R) / MW_{NO_x}$	193	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	664	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	89	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	63,900	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1)$ Where n = Equipment Life and i= Interest Rate	0.0527

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	504.00	kW

DOH-CAB Changed Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_B \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_B \times ELEV F \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$17,294,581</b>	<b>in 2019 dollars</b>
Annual Costs		
Total Annual Cost (TAC)		
$TAC = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$		
Direct Annual Costs (DAC) =		\$686,341 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,397,609 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$2,083,950 in 2019 dollars</b>
Direct Annual Costs (DAC)		
$DAC = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Catalyst Cost})$		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$86,473 in 2019 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$85,498 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$417,862 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replac}/R_{layer}) \times FWF$	\$96,508 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$686,341 in 2019 dollars</b>
Indirect Annual Cost (IDAC)		
$IDAC = \text{Administrative Charges} + \text{Capital Recovery Costs}$		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,666 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,393,943 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$1,397,609 in 2019 dollars</b>
Cost Effectiveness		
$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$		
Total Annual Cost (TAC) =		\$2,083,950 per year in 2019 dollars
NOx Removed =		815 tons/year
<b>Cost Effectiveness =</b>		<b>\$2,557 per ton of NOx removed in 2019 dollars</b>

Original Submitted Spreadsheet

## Appendix Table A-3b. Kahe K2 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_B \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_B \times ELEV F \times RF$	
<b>Total Capital Investment (TCI) =</b>	<b>\$11,529,720</b>	<b>in 2019 dollars</b>
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$661,115 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$610,936 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>		<b>\$1,272,051 in 2019 dollars</b>
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$57,649 in 2019 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$85,498 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$417,862 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$100,106 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$661,115 in 2019 dollars</b>
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,320 in 2019 dollars
Capital Recovery Costs (CR) =	$CRF \times TCI =$	\$607,616 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$610,936 in 2019 dollars</b>
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
<b>Total Annual Cost (TAC) =</b>		<b>\$1,272,051 per year in 2019 dollars</b>
<b>NOx Removed =</b>		<b>815 tons/year</b>
<b>Cost Effectiveness =</b>		<b>\$1,561 per ton of NOx removed in 2019 dollars</b>

DOH-CAB Changed Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

Data Inputs

**Enter the following data for your combustion unit:**

Is the combustion unit a utility or industrial boiler? Utility

What type of fuel does the unit burn? Fuel Oil

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1.5

\* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 92 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWhs output? 387,117 MWhs

Enter the net plant heat input rate (NPHR) 9.6957 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) = percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

]

Original Submitted Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days
Number of days the boiler operates ( $t_{plant}$ )	365 days
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.353 lb/MMBtu
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu
Stoichiometric Ratio Factor (SRF)	1.050

\*The SRF value of 1.05 is a default value. User should enter actual value, if known.

Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours
Estimated SCR equipment life	30 Years*
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*
Number of days reagent is stored ( $t_{storage}$ )	30 days

\* For utility boilers, the typical equipment life of an SCR is at least 30 years.

\*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.

Number of SCR reactor chambers ( $n_{scr}$ )	1
Number of catalyst layers ( $R_{layer}$ )	3
Number of empty catalyst layers ( $R_{empty}$ )	1
Ammonia Slip (Slip) provided by vendor	2 ppm
Volume of the catalyst layers ( $VOL_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm

Gas temperature at the SCR inlet (T)	650 °F
Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour

Densities of typical SCR reagents:	
50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

Select the reagent used Ammonia

Enter the cost data for the proposed SCR:

Desired dollar-year	2019
CEPCI for 2019	607.5
Annual Interest Rate (i)	7.0 Percent
Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*
Electricity (Cost <sub>elec</sub> )	0.2521 \$/kWh
Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)
Operator Labor Rate	60.00 \$/hour (including benefits)*
Operator Hours/Day	4.00 hours/day*

CEPCI = Chemical Engineering Plant Cost Index

\* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.

\* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.

\* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.

\* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

1

Original Submitted Spreadsheet



## Appendix Table A-3c. Kahe K3 - SCR Costing

**Maintenance and Administrative Charges Cost Factors:**

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

**Data Sources Values Used in Calculations:**

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

1

Original Submitted Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?  What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWs output?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

DOH-CAB Changed Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{SCR}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.353 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers (VOL <sub>catalyst</sub> ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate (Q <sub>fluegas</sub> ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst (H <sub>catalyst</sub> )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor (Q <sub>fuel</sub> )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored (C <sub>stored</sub> )	29 percent*		
Density of reagent as stored (ρ <sub>stored</sub> )	56 lb/cubic feet*		
Number of days reagent is stored (t <sub>storage</sub> )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used <span style="float: right;">Ammonia ▼</span>			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	3.25 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*				<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)				<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Hours/Day	4.00 hours/day*				<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known. * 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>
Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.							

DOH-CAB Changed Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =  
 Administrative Charges Factor (ACF) =

0.005
0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	892	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	805,920	MWhts
Estimated Actual Annual MWhts Output (Boutput) =		387,117	MWhts
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.97	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.480	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4208	hours
NOx Removal Efficiency (EF) =	$(NOx_{in} - NOx_{out})/NOx_{in} =$	71.6	percent
NOx removed per hour =	$NOx_{in} \times EF \times Q_b =$	225.31	lb/hour
Total NO <sub>x</sub> removed per year =	$(NOx_{in} \times EF \times Q_b \times t_{op})/2000 =$	474.03	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.90	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \eta_{scr} =$	413,119	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	126.44	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NOx_{adj} \times S_{adj} \times (T_{adj}/N_{scr})$	3,267.24	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	430	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

Original Submitted Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	495	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.2	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x_{in}} \times Q_g \times EF \times SRF \times MW_R) / MW_{NO_x}$	88	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	302	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	40	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	29,100	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1)$ Where n = Equipment Life and i= Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	508.40	kW

[Original Submitted Spreadsheet](#)

## Appendix Table A-3c. Kahe K3 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	892	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	805,920	MWhs
Estimated Actual Annual MWs Output (Boutput) =		387,117	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.97	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.480	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4208	hours
NOx Removal Efficiency (EF) =	$(NOx_{in} - NOx_{out})/NOx_{in} =$	71.6	percent
NOx removed per hour =	$NOx_{in} \times EF \times Q_b =$	225.31	lb/hour
Total NO <sub>x</sub> removed per year =	$(NOx_{in} \times EF \times Q_b \times t_{op})/2000 =$	474.03	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.90	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700)_{N_{scr}} =$	413,119	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	126.44	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemns.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3227	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NOx_{adj} \times S_{adj} \times (T_{adj}/N_{scr})$	3,267.24	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	430	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

DOH-CAB Changed Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	495	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.2	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x_{in}} \times Q_g \times EF \times SRF \times MW_R) / MW_{NO_x}$	88	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	302	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	40	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	29,100	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / (1+i)^n - 1 =$ Where n = Equipment Life and i= Interest Rate	0.0527

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	508.40	kW

DOH-CAB Changed Spreadsheet



## Appendix Table A-3c. Kahe K3 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
Total Capital Investment (TCI) =	\$17,543,429	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$753,657 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,417,681 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$2,171,338 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$87,717 in 2019 dollars
Annual Reagent Cost =	$m_{sol} \times Cost_{reag} \times t_{op} =$	\$49,728 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$539,302 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$76,910 in 2019 dollars
Direct Annual Cost =		\$753,657 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,681 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,414,000 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$1,417,681 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,171,338 per year in 2019 dollars
NOx Removed =		474 tons/year
Cost Effectiveness =		\$4,581 per ton of NOx removed in 2019 dollars

1

Original Submitted Spreadsheet

## Appendix Table A-3c. Kahe K3 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV F \times RF$	
Total Capital Investment (TCI) =	\$11,695,620	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$727,286 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$619,689 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$1,346,975 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	0.005 x TCI =	\$58,478 in 2019 dollars
Annual Reagent Cost =	$m_{so_2} \times Cost_{reag} \times t_{op} =$	\$49,728 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$539,302 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$79,778 in 2019 dollars
Direct Annual Cost =		\$727,286 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$3,330 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$616,359 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$619,689 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$1,346,975 per year in 2019 dollars
NOx Removed =		474 tons/year
Cost Effectiveness =		\$2,842 per ton of NOx removed in 2019 dollars

DOH-CAB Changed Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility What type of fuel does the unit burn? Fuel Oil

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1.5 \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 93 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWs output? 390,927 MWs

Enter the net plant heat input rate (NPHR) 9.8710 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) =   percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

Original Submitted Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{SCR}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.379 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers (Vol <sub>catalyst</sub> ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate (Q <sub>fluegas</sub> ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst (H <sub>catalyst</sub> )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor (Q <sub>fuel</sub> )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored (C <sub>stored</sub> )	29 percent*		
Density of reagent as stored (ρ <sub>stored</sub> )	56 lb/cubic feet*		
Number of days reagent is stored (t <sub>storage</sub> )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used      Ammonia      ▼			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*				<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)				<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Hours/Day	4.00 hours/day*				<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>		Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.					

Original Submitted Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

**Maintenance and Administrative Charges Cost Factors:**

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

**Data Sources Values Used in Calculations:**

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?  What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWs output?  MWs

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation  Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

DOH-CAB Changed Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{SCR}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.379 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers (VOL <sub>catalyst</sub> ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate (Q <sub>fluegas</sub> ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst (H <sub>catalyst</sub> )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor (Q <sub>fuel</sub> )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored (C <sub>stored</sub> )	29 percent*		
Density of reagent as stored (ρ <sub>stored</sub> )	56 lb/cubic feet*		
Number of days reagent is stored (t <sub>storage</sub> )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used      Ammonia      ▼			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	3.25 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*				<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)				<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Hours/Day	4.00 hours/day*				<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>		Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.					

DOH-CAB Changed Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =  
 Administrative Charges Factor (ACF) =

0.005
0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet



## Appendix Table A-3d. Kahe K4 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	918	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	814,680	MWhs
Estimated Actual Annual MWs Output (Boutput) =		390,927	MWhs
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.99	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.480	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4204	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	73.6	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	256.58	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	539.26	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.92	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \eta_{scr} =$	425,161	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	122.82	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	Fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NO_{x_{adj}} \times S_{adj} \times (T_{adj}/N_{scr})$	3,461.60	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	443	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

Original Submitted Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	509	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.6	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NOx_{in} \times Q_g \times EF \times SRF \times MW_R) / MW_{NOx} =$	100	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	344	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	46	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	33,100	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	517.90	kW

[Original Submitted Spreadsheet](#)

## Appendix Table A-3d. Kahe K4 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	918	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	814,680	MWhts
Estimated Actual Annual MWhts Output (Boutput) =		390,927	MWhts
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.99	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.480	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4204	hours
NOx Removal Efficiency (EF) =	$(NOx_{in} - NOx_{out})/NOx_{in} =$	73.6	percent
NOx removed per hour =	$NOx_{in} \times EF \times Q_b =$	256.58	lb/hour
Total NO <sub>x</sub> removed per year =	$(NOx_{in} \times EF \times Q_b \times t_{op})/2000 =$	539.26	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.92	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700)_{N_{scr}} =$	425,161	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	122.82	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgrc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3227	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NOx_{adj} \times S_{adj} \times (T_{adj}/N_{scr})$	3,461.60	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	443	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

## DOH-CAB Changed Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	509	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	22.6	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NOx_{in} \times Q_g \times EF \times SRF \times MW_R) / MW_{NOx} =$	100	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	344	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	46	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	33,100	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0527

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	517.90	kW

DOH-CAB Changed Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
Total Capital Investment (TCI) =	\$17,667,143	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$775,213 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,427,660 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$2,202,873 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$88,336 in 2019 dollars
Annual Reagent Cost =	$m_{so_2} \times Cost_{reag} \times t_{op} =$	\$56,571 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$548,821 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$81,486 in 2019 dollars
Direct Annual Cost =		\$775,213 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,688 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,423,972 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$1,427,660 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$2,202,873 per year in 2019 dollars
NOx Removed =		539 tons/year
Cost Effectiveness =		\$4,085 per ton of NOx removed in 2019 dollars

Original Submitted Spreadsheet

## Appendix Table A-3d. Kahe K4 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV F \times RF$	
Total Capital Investment (TCI) =	\$11,778,095	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$748,806 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$624,040 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$1,372,847 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$58,890 in 2019 dollars
Annual Reagent Cost =	$m_{so_2} \times Cost_{reag} \times t_{op} =$	\$56,571 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$548,821 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$84,524 in 2019 dollars
Direct Annual Cost =		\$748,806 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,335 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$620,706 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$624,040 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$1,372,847 per year in 2019 dollars
NOx Removed =		539 tons/year
Cost Effectiveness =		\$2,546 per ton of NOx removed in 2019 dollars

DOH-CAB Changed Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility

What type of fuel does the unit burn? Fuel Oil

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1.5

\* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 142 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWs output? 493,259 MWs

Enter the net plant heat input rate (NPHR) 10.3380 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) =   percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

Original Submitted Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{SCR}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.802 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used: <span style="border: 1px solid black; padding: 2px;">Ammonia</span>			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*				<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)				<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Hours/Day	4.00 hours/day*				<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>		Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.					

Original Submitted Spreadsheet



## Appendix Table A-3e. Kahe K5 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

### Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWs output?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the *Cost Estimate* tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

DOH-CAB Changed Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{SCR}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.802 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.1 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers ( $Vol_{catalyst}$ ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate ( $Q_{fluegas}$ ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst ( $H_{catalyst}$ )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor ( $Q_{fuel}$ )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored ( $C_{stored}$ )	29 percent*		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/cubic feet*		
Number of days reagent is stored ( $t_{storage}$ )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used <span style="float: right;">Ammonia <input type="button" value="v"/></span>			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	3.25 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*				<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)				<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Hours/Day	4.00 hours/day*				<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>		Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.					

DOH-CAB Changed Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =  
 Administrative Charges Factor (ACF) =

0.005
0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	1,468	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	1,243,920	MWht
Estimated Actual Annual MWht Output (Boutput) =		493,259	MWht
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.03	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.397	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	3474	hours
NOx Removal Efficiency (EF) =	$(NOx_{in} - NOx_{out})/NOx_{in} =$	87.5	percent
NOx removed per hour =	$NOx_{in} \times EF \times Q_b =$	1030.17	lb/hour
Total NOx removed per year =	$(NOx_{in} \times EF \times Q_b \times t_{op})/2000 =$	1,789.23	tons/year
NOx removal factor (NRF) =	$EF/80 =$	1.09	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \eta_{scr} =$	679,886	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	94.77	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemns.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NOx_{adj} \times S_{adj} \times (T_{adj}/N_{scr})$	7,173.70	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	708	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	4	feet

Original Submitted Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	814	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	28.5	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	55	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x_{in}} \times Q_g \times EF \times SRF \times MW_R) / MW_{NO_x}$	400	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	1,381	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	184	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	132,800	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1)$ Where n = Equipment Life and i= Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	806.65	kW

[Original Submitted Spreadsheet](#)

## Appendix Table A-3e. Kahe K5 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q <sub>b</sub> ) =	Bmw x NPHR =	1,468	MMBtu/hour
Maximum Annual MW Output (Bmw) =	Bmw x 8760 =	1,243,920	MWhs
Estimated Actual Annual MWhs Output (Boutput) =		493,259	MWhs
Heat Rate Factor (HRF) =	NPHR/10 =	1.03	
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tscr/tplant) =	0.397	fraction
Total operating time for the SCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	3474	hours
NOx Removal Efficiency (EF) =	(NO <sub>xin</sub> - NO <sub>xout</sub> )/NO <sub>xin</sub> =	87.5	percent
NOx removed per hour =	NO <sub>xin</sub> x EF x Q <sub>b</sub> =	1030.17	lb/hour
Total NO <sub>x</sub> removed per year =	(NO <sub>xin</sub> x EF x Q <sub>b</sub> x t <sub>op</sub> )/2000 =	1,789.23	tons/year
NO <sub>x</sub> removal factor (NRF) =	EF/80 =	1.09	
Volumetric flue gas flow rate (q <sub>flue gas</sub> ) =	Q <sub>fuel</sub> x QB x (460 + T)/(460 + 700)n <sub>scr</sub> =	679,886	acfm
Space velocity (V <sub>space</sub> ) =	q <sub>flue gas</sub> /Vol <sub>catalyst</sub> =	94.77	/hour
Residence Time	1/V <sub>space</sub>	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*1x10 <sup>6</sup> /HHV =		
Elevation Factor (ELEVf) =	14.7 psia/P =		
Atmospheric pressure at sea level (P) =	2116 x [(59-(0.00356xh)+459.7)/518.6] <sup>5.256</sup> x (1/144)* =	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

Not applicable; factor applies only to coal-fired boilers

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	(interest rate)/(1+(1+ interest rate) <sup>Y</sup> - 1), where Y = H <sub>catalyst</sub> /t <sub>SCR</sub> x 24 hours rounded to the nearest integer	0.3227	fraction
Catalyst volume (Vol <sub>catalyst</sub> ) =	2.81 x Q <sub>b</sub> x EF <sub>adj</sub> x Slipadj x NO <sub>xadj</sub> x S <sub>adj</sub> x (T <sub>adj</sub> /N <sub>scr</sub> )	7,173.70	Cubic feet
Cross sectional area of the catalyst (A <sub>catalyst</sub> ) =	q <sub>flue gas</sub> / (16ft/sec x 60 sec/min)	708	ft <sup>2</sup>
Height of each catalyst layer (H <sub>layer</sub> ) =	(Vol <sub>catalyst</sub> /(R <sub>layer</sub> x A <sub>catalyst</sub> )) + 1 (rounded to next highest integer)	4	feet

]

DOH-CAB Changed Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{catalyst}$	814	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	28.5	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	55	feet

**Reagent Data:**

Type of reagent used: Ammonia  
 Molecular Weight of Reagent (MW) = 17.03 g/mole  
 Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,in} \times Q_g \times EF \times SRF \times MW_R) / MW_{NO_x} =$	400	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / Csol =$	1,381	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	184	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density} =$	132,800	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0527

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43} =$ where A = Bmw for utility boilers	806.65	kW

]

DOH-CAB Changed Spreadsheet



## Appendix Table A-3e. Kahe K5 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV \times RF$	
Total Capital Investment (TCI) =	\$23,261,613	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$1,179,264 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,878,910 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$3,058,173 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	0.005 x TCI =	\$116,308 in 2019 dollars
Annual Reagent Cost =	$m_{so_2} \times Cost_{reag} \times t_{op} =$	\$187,699 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$706,389 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$168,868 in 2019 dollars
Direct Annual Cost =		\$1,179,264 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	0.03 x (Operator Cost + 0.4 x Annual Maintenance Cost) =	\$4,024 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$1,874,886 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$1,878,910 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$3,058,173 per year in 2019 dollars
NOx Removed =		1,789 tons/year
Cost Effectiveness =		\$1,709 per ton of NOx removed in 2019 dollars

Original Submitted Spreadsheet

## Appendix Table A-3e. Kahe K5 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_B \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_B \times ELEV \times RF$	
Total Capital Investment (TCI) =	\$15,507,742	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$1,146,791 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$820,816 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$1,967,607 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$77,539 in 2019 dollars
Annual Reagent Cost =	$m_{so_2} \times Cost_{reag} \times t_{op} =$	\$187,699 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$706,389 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$175,165 in 2019 dollars
Direct Annual Cost =		\$1,146,791 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,558 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$817,258 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$820,816 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$1,967,607 per year in 2019 dollars
NOx Removed =		1,789 tons/year
Cost Effectiveness =		\$1,100 per ton of NOx removed in 2019 dollars

DOH-CAB Changed Spreadsheet

# Appendix Table A-3f. Kahe K6 - SCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler? Utility What type of fuel does the unit burn? Fuel Oil

Is the SCR for a new boiler or retrofit of an existing boiler? Retrofit

Please enter a retrofit factor between 0.8 and 1.5 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty. 1.5 \* A retrofit factor of 1.5 is appropriate for the proposed project due to Hawaii's remote location and the existing site layout.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)? 142 MW

What is the higher heating value (HHV) of the fuel? 149,479 Btu/gallon

What is the estimated actual annual MWs output? 601,781 MWs

Enter the net plant heat input rate (NPHR) 10.6761 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Plant Elevation 10 Feet above sea level

Not applicable to units burning fuel oil or natural gas

Type of coal burned: Not Applicable

Enter the sulfur content (%S) =   percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV and %S. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

Coal Type	Fraction in Coal Blend	%S	HHV (Btu/lb)
Bituminous	0	1.84	11,841
Sub-Bituminous	0	0.41	8,826
Lignite	0	0.82	6,685

Please click the calculate button to calculate weighted average values based on the data in the table above.

For coal-fired boilers, you may use either Method 1 or Method 2 to calculate the catalyst replacement cost. The equations for both methods are shown on rows 85 and 86 on the **Cost Estimate** tab. Please select your preferred method:

Method 1  
 Method 2  
 Not applicable

Original Submitted Spreadsheet

## Appendix Table A-3f. Kahe K6 - SCR Costing

Enter the following design parameters for the proposed SCR:

Number of days the SCR operates ( $t_{SCR}$ )	365 days	Number of SCR reactor chambers ( $n_{SCR}$ )	1
Number of days the boiler operates ( $t_{plant}$ )	365 days	Number of catalyst layers ( $R_{layer}$ )	3
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SCR	0.196 lb/MMBtu	Number of empty catalyst layers ( $R_{empty}$ )	1
Outlet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SCR	0.05 lb/MMBtu	Ammonia Slip (Slip) provided by vendor	2 ppm
Stoichiometric Ratio Factor (SRF)	1.050	Volume of the catalyst layers (VOL <sub>catalyst</sub> ) (Enter "UNK" if value is not known)	UNK Cubic feet
<small>*The SRF value of 1.05 is a default value. User should enter actual value, if known.</small>		Flue gas flow rate (Q <sub>fluegas</sub> ) (Enter "UNK" if value is not known)	UNK acfm
Estimated operating life of the catalyst (H <sub>catalyst</sub> )	24,000 hours	Gas temperature at the SCR inlet (T)	650 °F
Estimated SCR equipment life	30 Years*	Base case fuel gas volumetric flow rate factor (Q <sub>fuel</sub> )	484 ft <sup>3</sup> /min-MMBtu/hour
<small>* For utility boilers, the typical equipment life of an SCR is at least 30 years.</small>		<b>Densities of typical SCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	
Concentration of reagent as stored (C <sub>stored</sub> )	29 percent*		
Density of reagent as stored (ρ <sub>stored</sub> )	56 lb/cubic feet*		
Number of days reagent is stored (t <sub>storage</sub> )	30 days		
<small>*The reagent concentration of 29% and density of 56 lbs/cft are default values for ammonia reagent. User should enter actual values for reagent, if different from the default values provided.</small>			
Select the reagent used      Ammonia      ▼			

Enter the cost data for the proposed SCR:

Desired dollar-year	2019	CEPCI for 2019	607.5	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index	
Annual Interest Rate (i)	7.0 Percent	Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for 29% ammonia*				<small>* \$0.293/gallon is a default value for 29% ammonia. User should enter actual value, if known.</small>
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Catalyst cost (CC <sub>replace</sub> )	227.00 \$/cubic foot (includes removal and disposal/regeneration of existing catalyst and installation of new catalyst)				<small>* \$227/cf is a default value for the catalyst cost based on 2016 prices. User should enter actual value, if known.</small>
Operator Labor Rate	60.00 \$/hour (including benefits)*	Operator Hours/Day	4.00 hours/day*				<small>* \$60/hour is a default value for the operator labor rate. User should enter actual value, if known.</small>
<small>Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&amp;S) is acceptable.</small>		<small>* 4 hours/day is a default value for the operator labor. User should enter actual value, if known.</small>					

Original Submitted Spreadsheet

## Appendix Table A-3f. Kahe K6 - SCR Costing

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.005
Administrative Charges Factor (ACF) =	0.03

### Data Sources Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon 29% ammonia solution ammonia cost for 29% solution	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Catalyst Cost (\$/cubic foot)	227	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Operator Labor Rate (\$/hour)	\$60.00	U.S. Environmental Protection Agency (EPA). Documentation for EPA's Power Sector Modeling Platform v6 Using the Integrated Planning Model. Office of Air and Radiation. May 2018. Available at: <a href="https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6">https://www.epa.gov/airmarkets/documentation-epas-power-sector-modeling-platform-v6</a> .	
Interest Rate (Percent)	7.00	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet

## Appendix Table A-3f. Kahe K6 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$Bmw \times NPHR =$	1,516	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	1,243,920	MWhts
Estimated Actual Annual MWhts Output (Boutput) =		601,781	MWhts
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.07	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.484	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4238	hours
NOx Removal Efficiency (EF) =	$(NOx_{in} - NOx_{out})/NOx_{in} =$	74.5	percent
NOx removed per hour =	$NOx_{in} \times EF \times Q_b =$	221.56	lb/hour
Total NO <sub>x</sub> removed per year =	$(NOx_{in} \times EF \times Q_b \times t_{op})/2000 =$	469.48	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.93	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \times N_{scr} =$	702,117	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	129.61	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.50	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgrc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3111	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_b \times EF_{adj} \times Slip_{adj} \times NOx_{adj} \times S_{adj} \times (T_{adj}/N_{scr})$	5,417.25	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	731	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	3	feet

Original Submitted Spreadsheet

## Appendix Table A-3f. Kahe K6 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	841	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	29.0	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x_{in}} \times Q_g \times EF \times SRF \times MW_R) / MW_{NO_x}$	86	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	297	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	40	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	28,600	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1)$ Where n = Equipment Life and i = Interest Rate	0.0806

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	817.89	kW

[Original Submitted Spreadsheet](#)

## Appendix Table A-3f. Kahe K6 - SCR Costing

### SCR Design Parameters

The following design parameters for the SCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_B$ ) =	$Bmw \times NPHR =$	1,516	MMBtu/hour
Maximum Annual MW Output (Bmw) =	$Bmw \times 8760 =$	1,243,920	MWhts
Estimated Actual Annual MWhts Output (Boutput) =		601,781	MWhts
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.07	
Total System Capacity Factor ( $CF_{total}$ ) =	$(Boutput/Bmw) \times (t_{scr}/t_{plant}) =$	0.484	fraction
Total operating time for the SCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4238	hours
NOx Removal Efficiency (EF) =	$(NOx_{in} - NOx_{out})/NOx_{in} =$	74.5	percent
NOx removed per hour =	$NOx_{in} \times EF \times Q_B =$	221.56	lb/hour
Total NO <sub>x</sub> removed per year =	$(NOx_{in} \times EF \times Q_B \times t_{op})/2000 =$	469.48	tons/year
NO <sub>x</sub> removal factor (NRF) =	$EF/80 =$	0.93	
Volumetric flue gas flow rate ( $q_{flue\ gas}$ ) =	$Q_{fuel} \times QB \times (460 + T)/(460 + 700) \eta_{scr} =$	702,117	acfm
Space velocity ( $V_{space}$ ) =	$q_{flue\ gas}/Vol_{catalyst} =$	129.61	/hour
Residence Time	$1/V_{space}$	0.01	hour
Coal Factor (CoalF) =	1 for oil and natural gas; 1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)	1.00	
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times 1 \times 10^6 / HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVf) =	$14.7\ psia/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144) * =$	14.7	psia
Retrofit Factor (RF)	Retrofit to existing boiler	1.00	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

#### Catalyst Data:

Parameter	Equation	Calculated Value	Units
Future worth factor (FWF) =	$(interest\ rate) / (1 + (interest\ rate)^Y - 1)$ , where $Y = H_{catalyst} / (t_{scr} \times 24\ hours)$ rounded to the nearest integer	0.3227	fraction
Catalyst volume ( $Vol_{catalyst}$ ) =	$2.81 \times Q_B \times EF_{adj} \times Slip_{adj} \times NOx_{adj} \times S_{adj} \times (T_{adj}/N_{scr})$	5,417.25	Cubic feet
Cross sectional area of the catalyst ( $A_{catalyst}$ ) =	$q_{flue\ gas} / (16\ ft/sec \times 60\ sec/min)$	731	ft <sup>2</sup>
Height of each catalyst layer ( $H_{layer}$ ) =	$(Vol_{catalyst} / (R_{layer} \times A_{catalyst})) + 1$ (rounded to next highest integer)	3	feet

### DOH-CAB Changed Spreadsheet



## Appendix Table A-3f. Kahe K6 - SCR Costing

**SCR Reactor Data:**

Parameter	Equation	Calculated Value	Units
Cross sectional area of the reactor ( $A_{SCR}$ ) =	$1.15 \times A_{Catalyst}$	841	ft <sup>2</sup>
Reactor length and width dimensions for a square reactor =	$(A_{SCR})^{0.5}$	29.0	feet
Reactor height =	$(R_{layer} + R_{empty}) \times (7ft + h_{layer}) + 9ft$	51	feet

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole

Density = 56 lb/ft<sup>3</sup>

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x_{in}} \times Q_g \times EF \times SRF \times MW_R) / MW_{NO_x}$	86	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol}$	297	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density}$	40	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24) / \text{Reagent Density}$	28,600	gallons (storage needed to store a 30 day reagent supply rounded to t

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i(1+i)^n / ((1+i)^n - 1)$ Where n = Equipment Life and i= Interest Rate	0.0527

Other parameters	Equation	Calculated Value	Units
Electricity Usage:			
Electricity Consumption (P) =	$A \times 1,000 \times 0.0056 \times (\text{CoalF} \times \text{HRF})^{0.43}$ where A = Bmw for utility boilers	817.89	kW

DOH-CAB Changed Spreadsheet

## Appendix Table A-3f. Kahe K6 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_B)^{0.35} \times Q_B \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_B)^{0.35} \times Q_B \times ELEV \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_B \times ELEV \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_B \times ELEV \times RF$	
Total Capital Investment (TCI) =	\$23,261,613	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$1,166,888 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$1,878,910 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$3,045,798 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$116,308 in 2019 dollars
Annual Reagent Cost =	$m_{SO_2} \times Cost_{reag} \times t_{op} =$	\$49,251 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$873,807 in 2019 dollars
Annual Catalyst Replacement Cost =		\$127,521 in 2019 dollars
	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	
Direct Annual Cost =		\$1,166,888 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$4,024 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$1,874,886 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$1,878,910 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$3,045,798 per year in 2019 dollars
NOx Removed =		469 tons/year
Cost Effectiveness =		\$6,488 per ton of NOx removed in 2019 dollars

Original Submitted Spreadsheet

## Appendix Table A-3f. Kahe K6 - SCR Costing

Cost Estimate		
Total Capital Investment (TCI)		
TCI for Oil and Natural Gas Boilers		
For Oil and Natural Gas-Fired Utility Boilers between 25MW and 500 MW:	$TCI = 86,380 \times (200/B_{MW})^{0.35} \times B_{MW} \times ELEV F \times RF$	
For Oil and Natural Gas-Fired Utility Boilers >500 MW:	$TCI = 62,680 \times B_{MW} \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers between 275 and 5,500 MMBTU/hour :	$TCI = 7,850 \times (2,200/Q_b)^{0.35} \times Q_b \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers between 205 and 4,100 MMBTU/hour :	$TCI = 10,530 \times (1,640/Q_b)^{0.35} \times Q_b \times ELEV F \times RF$	
For Oil-Fired Industrial Boilers >5,500 MMBtu/hour:	$TCI = 5,700 \times Q_b \times ELEV F \times RF$	
For Natural Gas-Fired Industrial Boilers >4,100 MMBtu/hour:	$TCI = 7,640 \times Q_b \times ELEV F \times RF$	
Total Capital Investment (TCI) =	\$15,507,742	in 2019 dollars
Annual Costs		
Total Annual Cost (TAC)		
TAC = Direct Annual Costs + Indirect Annual Costs		
Direct Annual Costs (DAC) =		\$1,132,873 in 2019 dollars
Indirect Annual Costs (IDAC) =		\$820,816 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC		\$1,953,690 in 2019 dollars
Direct Annual Costs (DAC)		
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Catalyst Cost)		
Annual Maintenance Cost =	$0.005 \times TCI =$	\$77,539 in 2019 dollars
Annual Reagent Cost =	$m_{so_2} \times Cost_{reag} \times t_{op} =$	\$49,251 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$873,807 in 2019 dollars
Annual Catalyst Replacement Cost =	$n_{scr} \times Vol_{cat} \times (CC_{replace}/R_{layer}) \times FWF$	\$132,276 in 2019 dollars
Direct Annual Cost =		\$1,132,873 in 2019 dollars
Indirect Annual Cost (IDAC)		
IDAC = Administrative Charges + Capital Recovery Costs		
Administrative Charges (AC) =	$0.03 \times (\text{Operator Cost} + 0.4 \times \text{Annual Maintenance Cost}) =$	\$3,558 in 2019 dollars
Capital Recovery Costs (CR)=	$CRF \times TCI =$	\$817,258 in 2019 dollars
Indirect Annual Cost (IDAC) =	$AC + CR =$	\$820,816 in 2019 dollars
Cost Effectiveness		
Cost Effectiveness = Total Annual Cost/ NOx Removed/year		
Total Annual Cost (TAC) =		\$1,953,690 per year in 2019 dollars
NOx Removed =		469 tons/year
Cost Effectiveness =		\$4,161 per ton of NOx removed in 2019 dollars

DOH-CAB Changed Spreadsheet

# Appendix - Table A-4a. Kahe K1 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?       What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.       \* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWh output?

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

Original Submitted Spreadsheet

## Appendix - Table A-4a. Kahe K1 - SNCR Costing

Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet NO <sub>x</sub> Emissions (NO <sub>x,in</sub> ) to SNCR	0.494 lb/MMBtu		
Oulet NO <sub>x</sub> Emissions (NO <sub>x,out</sub> ) from SNCR	0.4 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

Enter the cost data for the proposed SNCR:

Desired dollar-year CEPCI for 2019	2019		
	607.5	Enter the CEPCI value for 2019	541.7
		2016 CEPCI	
Annual Interest Rate (i)	7 Percent	CEPCI = Chemical Engineering Plant Cost Index	
Fuel (Cost <sub>fuel</sub> )	13.01 \$/MMBtu	Actual Data Used	
Reagent (Cost <sub>reag</sub> )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water (Cost <sub>water</sub> )	0.0042 \$/gallon	Default Value Used	
Electricity (Cost <sub>elect</sub> )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) (Cost <sub>ash</sub> )	\$/ton		

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

Original Submitted Spreadsheet

## Appendix - Table A-4a. Kahe K1 - SNCR Costing

### Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	7	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet

# Appendix - Table A-4a. Kahe K1 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWh output?

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units buring fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

DOH-CAB Changed Spreadsheet

## Appendix - Table A-4a. Kahe K1 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x_{in}}$ ) to SNCR	0.494 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x_{out}}$ ) from SNCR	0.4 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia <input type="button" value="v"/>		

Densities of typical SNCR reagents:	
50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

### Enter the cost data for the proposed SNCR:

Desired dollar-year	2019		
CEPCI for 2019	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
Annual Interest Rate (i)	3.25 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu	Actual Data Used	
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water ( $Cost_{water}$ )	0.0042 \$/gallon	Default Value Used	
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

DOH-CAB Changed Spreadsheet



## Appendix - Table A-4a. Kahe K1 - SNCR Costing

### Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet

## Appendix - Table A-4a. Kahe K1 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate ( $Q_b$ ) =	$B_{mw} \times NPHR =$	903	MMBtu/hour	
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	805,920	MWh	
Estimated Actual Annual MWh Output (Boutput) =		384,917	MWh	
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.98		
Total System Capacity Factor ( $CF_{total}$ ) =	$(B_{output}/B_{mw}) \times (t_{snrcr}/365) =$	0.48	fraction	
Total operating time for the SNCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4184	hours	
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	19	percent	
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_b =$	84.65	lb/hour	
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_b \times t_{op})/2000 =$	177.09	tons/year	
Coal Factor ( $Coal_f$ ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)			Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$			Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEVF) =	$14.7 \text{ psia}/P =$			Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7] / 518.6^{5.256} \times (1/144)^*$	14.7	psia	
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightssystemsgrc.nasa.gov/education/rocket/atmos.html>.

Original Submitted Spreadsheet

## Appendix - Table A-4a. Kahe K1 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x,in} \times Q_g \times NSR \times MW_R) / (MW_{NO_x} \times SR) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	201	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	694	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density} =$	92.7	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	31,200	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0944

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times NO_{x,in} \times NSR \times Q_g) / NPHR =$	26.0	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{sol} / \text{Density of water}) \times ((C_{stored} / C_{inj}) - 1) =$	158	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta Fuel$ ) =	$H_v \times m_{reagent} \times ((1/C_{inj}) - 1) =$	1.63	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta ash$ ) =	$(\Delta fuel \times \%Ash \times 1 \times 10^6) / HHV =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

Original Submitted Spreadsheet

## Appendix - Table A-4a. Kahe K1 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate ( $Q_B$ ) =	$B_{mw} \times NPHR =$	903	MMBtu/hour	
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	805,920	MWh	
Estimated Actual Annual MWh Output (Boutput) =		384,917	MWh	
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.98		
Total System Capacity Factor ( $CF_{total}$ ) =	$(B_{output}/B_{mw}) \times (tsnscr/365) =$	0.48	fraction	
Total operating time for the SNCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4184	hours	
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	19	percent	
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	84.65	lb/hour	
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	177.09	tons/year	
Coal Factor ( $Coal_f$ ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)			Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$			Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEV <sub>F</sub> ) =	$14.7 \text{ psia}/P =$			Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144)^*$	14.7	psia	
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00		

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html>.

DOH-CAB Changed Spreadsheet

## Appendix - Table A-4a. Kahe K1 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x_{in}} \times Q_B \times NSR \times MW_R) / (MW_{NO_x} \times SR) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	201	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	694	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density} =$	92.7	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	31,200	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0688

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times NO_{x_{in}} \times NSR \times Q_B) / \text{NPHR} =$	26.0	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{sol} / \text{Density of water}) \times ((C_{stored} / C_{inj}) - 1) =$	158	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{reagent} \times ((1/C_{inj}) - 1) =$	1.63	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

DOH-CAB Changed Spreadsheet

# Appendix - Table A-4a. Kahe K1 - SNCR Costing

## Cost Estimate

### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$1,639,022 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,714,103 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$5,659,063 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$1,639,022 in 2019 dollars
--	-----------------------------

### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

### Balance of Plant Costs ( $BOP_{cost}$ )

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times RF$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times RF$$

Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,714,103 in 2019 dollars
---	-----------------------------

[Original Submitted Spreadsheet](#)

## Appendix - Table A-4a. Kahe K1 - SNCR Costing

### Annual Costs

**Total Annual Cost (TAC)**  
TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$317,570 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$536,762 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>	<b>\$854,332 in 2019 dollars</b>

**Direct Annual Costs (DAC)**  
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$84,886 in 2019 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$113,686 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$27,473 in 2019 dollars
Annual Water Cost =	$q_{water} \times Cost_{water} \times t_{op} =$	\$2,758 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$88,768 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$317,570 in 2019 dollars</b>

**Indirect Annual Cost (IDAC)**  
IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,547 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$534,216 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$536,762 in 2019 dollars</b>

### Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$854,332 per year in 2019 dollars
NOx Removed =	177 tons/year
<b>Cost Effectiveness =</b>	<b>\$4,824 per ton of NOx removed in 2019 dollars</b>

Original Submitted Spreadsheet

# Appendix - Table A-4a. Kahe K1 - SNCR Costing

## Cost Estimate

### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$1,092,682 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$1,809,402 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$3,772,708 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$1,092,682 in 2019 dollars
--	-----------------------------

### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

### Balance of Plant Costs ( $BOP_{cost}$ )

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$$

Balance of Plant Costs ( $BOP_{cost}$ ) =	\$1,809,402 in 2019 dollars
---	-----------------------------

DOH-CAB Changed Spreadsheet



## Appendix - Table A-4a. Kahe K1 - SNCR Costing

### Annual Costs

#### Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$289,275 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$261,260 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>	<b>\$550,535 in 2019 dollars</b>

#### Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Water Cost}) + (\text{Annual Fuel Cost}) + (\text{Annual Ash Cost})$$

Annual Maintenance Cost =	0.015 x TCI =	\$56,591 in 2019 dollars
Annual Reagent Cost =	$q_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$113,686 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$27,473 in 2019 dollars
Annual Water Cost =	$q_{\text{water}} \times \text{Cost}_{\text{water}} \times t_{\text{op}} =$	\$2,758 in 2019 dollars
Additional Fuel Cost =	$\Delta \text{Fuel} \times \text{Cost}_{\text{fuel}} \times t_{\text{op}} =$	\$88,768 in 2019 dollars
Additional Ash Cost =	$\Delta \text{Ash} \times \text{Cost}_{\text{ash}} \times t_{\text{op}} \times (1/2000) =$	\$0 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$289,275 in 2019 dollars</b>

#### Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$1,698 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$259,562 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$261,260 in 2019 dollars</b>

### Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$550,535 per year in 2019 dollars
NOx Removed =	177 tons/year
<b>Cost Effectiveness =</b>	<b>\$3,109 per ton of NOx removed in 2019 dollars</b>

DOH-CAB Changed Spreadsheet

# Appendix Table A-4b. Kahe K3 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWh output?  MWh

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

---

Not applicable to units buring fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

Original Submitted Spreadsheet

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x_{in}}$ ) to SNCR	0.353 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x_{out}}$ ) from SNCR	0.25 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

### Enter the cost data for the proposed SNCR:

Desired dollar-year	2019		
CEPCI for 2019	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
Annual Interest Rate (i)	7 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu	Actual Data Used	
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water ( $Cost_{water}$ )	0.0042 \$/gallon	Default Value Used	
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

CEPCI = Chemical Engineering Plant Cost Index

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

Original Submitted Spreadsheet

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	7	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet

# Appendix Table A-4b. Kahe K3 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

Utility

What type of fuel does the unit burn?

Fuel Oil

Is the SNCR for a new boiler or retrofit of an existing boiler?

Retrofit

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

1

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

92 MW

What is the higher heating value (HHV) of the fuel?

149,479 Btu/gallon

What is the estimated actual annual MWh output?

387,117 MWh

Is the boiler a fluid-bed boiler?

No

Enter the net plant heat input rate (NPHR)

9.6957 MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Not Applicable

Enter the sulfur content (%S) = \_\_\_\_\_ percent by weight  
or

Select the appropriate SO<sub>2</sub> emission rate:

Not Applicable

Ash content (%Ash):

\_\_\_\_\_ percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

DOH-CAB Changed Spreadsheet

## Appendix Table A-4b. Kahe K3 - SNCR Costing

Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x_{in}}$ ) to SNCR	0.353 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x_{out}}$ ) from SNCR	0.25 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

Enter the cost data for the proposed SNCR:

Desired dollar-year CEPCI for 2019	2019		
	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
	CEPCI = Chemical Engineering Plant Cost Index		
Annual Interest Rate (i)	3.25 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu	Actual Data Used	
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water ( $Cost_{water}$ )	0.0042 \$/gallon	Default Value Used	
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

DOH-CAB Changed Spreadsheet

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q <sub>g</sub> ) =	Bmw x NPHR =	892	MMBtu/hour	
Maximum Annual MWh Output =	Bmw x 8760 =	805,920	MWh	
Estimated Actual Annual MWh Output (Boutput) =		387,117	MWh	
Heat Rate Factor (HRF) =	NPHR/10 =	0.97		
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tsncr/365) =	0.48	fraction	
Total operating time for the SNCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	4208	hours	
NOx Removal Efficiency (EF) =	(NO <sub>xin</sub> - NO <sub>xout</sub> )/NO <sub>xin</sub> =	29	percent	
NOx removed per hour =	NO <sub>xin</sub> x EF x Q <sub>g</sub> =	91.51	lb/hour	
Total NO <sub>x</sub> removed per year =	(NO <sub>xin</sub> x EF x Q <sub>g</sub> x t <sub>op</sub> )/2000 =	192.53	tons/year	
Coal Factor (Coal <sub>f</sub> ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)			Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*(1x10 <sup>6</sup> )/HHV =			Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEV <sub>F</sub> ) =	14.7 psia/P =			Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	2116x[(59-(0.00356xh)+459.7)/518.6] <sup>5.256</sup> x (1/144)* =	14.7	psia	
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

Original Submitted Spreadsheet



## Appendix Table A-4b. Kahe K3 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NOx}_{\text{in}} \times Q_{\text{B}} \times \text{NSR} \times \text{MW}_{\text{R}}) / (\text{MW}_{\text{NOx}} \times \text{SR}) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	142	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$	490	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	65.4	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	22,000	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0944

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NOx}_{\text{in}} \times \text{NSR} \times Q_{\text{B}}) / \text{NPHR} =$	18.6	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	112	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.15	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

Original Submitted Spreadsheet

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate ( $Q_B$ ) =	$B_{mw} \times NPHR =$	892	MMBtu/hour	
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	805,920	MWh	
Estimated Actual Annual MWh Output (Boutput) =		387,117	MWh	
Heat Rate Factor (HRF) =	$NPHR/10 =$	0.97		
Total System Capacity Factor ( $CF_{total}$ ) =	$(B_{output}/B_{mw}) \times (tsnscr/365) =$	0.48	fraction	
Total operating time for the SNCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4208	hours	
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	29	percent	
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	91.51	lb/hour	
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	192.53	tons/year	
Coal Factor ( $Coal_f$ ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)			Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$			Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEV <sub>F</sub> ) =	$14.7 \text{ psia}/P =$			Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144)^*$	14.7	psia	
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00		

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

DOH-CAB Changed Spreadsheet

## Appendix Table A-4b. Kahe K3 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{reagent}$ ) =	$(NO_{x_{in}} \times Q_B \times NSR \times MW_R) / (MW_{NO_x} \times SR) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	142	lb/hour
Reagent Usage Rate ( $m_{sol}$ ) =	$m_{reagent} / C_{sol} =$	490	lb/hour
	$(m_{sol} \times 7.4805) / \text{Reagent Density} =$	65.4	gal/hour
Estimated tank volume for reagent storage =	$(m_{sol} \times 7.4805 \times t_{storage} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	22,000	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0688

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times NO_{x_{in}} \times NSR \times Q_B) / \text{NPHR} =$	18.6	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{sol} / \text{Density of water}) \times ((C_{stored} / C_{inj}) - 1) =$	112	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{reagent} \times ((1/C_{inj}) - 1) =$	1.15	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

DOH-CAB Changed Spreadsheet

# Appendix Table A-4b. Kahe K3 - SNCR Costing

## Cost Estimate

### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$1,630,607 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,739,588 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$5,681,253 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$1,630,607 in 2019 dollars
--	-----------------------------

### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

### Balance of Plant Costs ( $BOP_{cost}$ )

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times RF$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times RF$$

Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,739,588 in 2019 dollars
---	-----------------------------

[Original Submitted Spreadsheet](#)

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### Annual Costs

#### Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$250,536 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$538,867 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>	<b>\$789,403 in 2019 dollars</b>

#### Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Water Cost}) + (\text{Annual Fuel Cost}) + (\text{Annual Ash Cost})$$

Annual Maintenance Cost =	0.015 x TCI =	\$85,219 in 2019 dollars
Annual Reagent Cost =	$q_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$80,654 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$19,731 in 2019 dollars
Annual Water Cost =	$q_{\text{water}} \times \text{Cost}_{\text{water}} \times t_{\text{op}} =$	\$1,956 in 2019 dollars
Additional Fuel Cost =	$\Delta \text{Fuel} \times \text{Cost}_{\text{fuel}} \times t_{\text{op}} =$	\$62,976 in 2019 dollars
Additional Ash Cost =	$\Delta \text{Ash} \times \text{Cost}_{\text{ash}} \times t_{\text{op}} \times (1/2000) =$	\$0 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$250,536 in 2019 dollars</b>

#### Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,557 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$536,310 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$538,867 in 2019 dollars</b>

### Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$789,403 per year in 2019 dollars
NOx Removed =	193 tons/year
<b>Cost Effectiveness =</b>	<b>\$4,100 per ton of NOx removed in 2019 dollars</b>

Original Submitted Spreadsheet

# Appendix Table A-4b. Kahe K3 - SNCR Costing

## Cost Estimate

### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR (SNCR <sub>cost</sub> ) =	\$1,087,071 in 2019 dollars
Air Pre-Heater Costs (APH <sub>cost</sub> )* =	\$0 in 2019 dollars
Balance of Plant Costs (BOP <sub>cost</sub> ) =	\$1,826,392 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$3,787,502 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

### SNCR Capital Costs (SNCR<sub>cost</sub>)

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

SNCR Capital Costs (SNCR <sub>cost</sub> ) =	\$1,087,071 in 2019 dollars
--	-----------------------------

### Air Pre-Heater Costs (APH<sub>cost</sub>)\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

Air Pre-Heater Costs (APH <sub>cost</sub> ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

### Balance of Plant Costs (BOP<sub>cost</sub>)

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

Balance of Plant Costs (BOP <sub>cost</sub> ) =	\$1,826,392 in 2019 dollars
---	-----------------------------

DOH-CAB Changed Spreadsheet

## Appendix Table A-4b. Kahe K3 - SNCR Costing

### Annual Costs

**Total Annual Cost (TAC)**  
TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$222,130 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$262,285 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>	<b>\$484,414 in 2019 dollars</b>

**Direct Annual Costs (DAC)**  
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$56,813 in 2019 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$80,654 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$19,731 in 2019 dollars
Annual Water Cost =	$q_{water} \times Cost_{water} \times t_{op} =$	\$1,956 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$62,976 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$222,130 in 2019 dollars</b>

**Indirect Annual Cost (IDAC)**  
IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$1,704 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$260,580 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$262,285 in 2019 dollars</b>

### Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$484,414 per year in 2019 dollars
NOx Removed =	193 tons/year
<b>Cost Effectiveness =</b>	<b>\$2,516 per ton of NOx removed in 2019 dollars</b>

DOH-CAB Changed Spreadsheet

# Appendix Table A-4c. Kahe K5 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWh output?  MWh

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units buring fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

[Original Submitted Spreadsheet](#)



## Appendix Table A-4c. Kahe K5 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x_{in}}$ ) to SNCR	0.802 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x_{out}}$ ) from SNCR	0.40 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

### Enter the cost data for the proposed SNCR:

Desired dollar-year	2019			
CEPCI for 2019	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7 Percent			
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu			Actual Data Used
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia			Default Value Used
Water ( $Cost_{water}$ )	0.0042 \$/gallon			Default Value Used
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh			Actual Data Used
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton			

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

Original Submitted Spreadsheet

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	7	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet

# Appendix Table A-4c. Kahe K5 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?  MW

What is the higher heating value (HHV) of the fuel?  Btu/gallon

What is the estimated actual annual MWh output?  MWh

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)  MMBtu/MW

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units burning fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

DOH-CAB Changed Spreadsheet

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x_{in}}$ ) to SNCR	0.802 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x_{out}}$ ) from SNCR	0.40 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

### Enter the cost data for the proposed SNCR:

Desired dollar-year CEPCI for 2019	2019		
	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
	CEPCI = Chemical Engineering Plant Cost Index		
Annual Interest Rate (i)	3.25 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu	Actual Data Used	
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water ( $Cost_{water}$ )	0.0042 \$/gallon	Default Value Used	
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

DOH-CAB Changed Spreadsheet

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate (Q <sub>g</sub> ) =	Bmw x NPHR =	1,468	MMBtu/hour
Maximum Annual MWh Output =	Bmw x 8760 =	1,243,920	MWh
Estimated Actual Annual MWh Output (Boutput) =		493,259	MWh
Heat Rate Factor (HRF) =	NPHR/10 =	1.03	
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tsncr/365) =	0.40	fraction
Total operating time for the SNCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	3474	hours
NOx Removal Efficiency (EF) =	(NO <sub>x,in</sub> - NO <sub>x,out</sub> )/NO <sub>x,in</sub> =	50	percent
NOx removed per hour =	NO <sub>x,in</sub> x EF x Q <sub>g</sub> =	589.77	lb/hour
Total NO <sub>x</sub> removed per year =	(NO <sub>x,in</sub> x EF x Q <sub>g</sub> x t <sub>op</sub> )/2000 =	1,024.34	tons/year
Coal Factor (Coal <sub>f</sub> ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)		
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*(1x10 <sup>6</sup> )/HHV =		
Elevation Factor (ELEV <sub>F</sub> ) =	14.7 psia/P =		
Atmospheric pressure at 10 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7) / 518.6]^{5.256} \times (1/144)^*$	14.7	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50	

Not applicable; factor applies only to coal-fired boilers

Not applicable; factor applies only to coal-fired boilers

Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

Original Submitted Spreadsheet

## Appendix Table A-4c. Kahe K5 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NO}_{x\text{in}} \times Q_B \times \text{NSR} \times \text{MW}_R) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for $\text{NH}_3$ ; 2 for Urea)	531	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$	1,833	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	244.8	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	82,300	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0944

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x\text{in}} \times \text{NSR} \times Q_B) / \text{NPHR} =$	65.3	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	417	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	4.31	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

Original Submitted Spreadsheet

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units
Maximum Annual Heat Input Rate ( $Q_B$ ) =	$B_{mw} \times NPHR =$	1,468	MMBtu/hour
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	1,243,920	MWh
Estimated Actual Annual MWh Output (Boutput) =		493,259	MWh
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.03	
Total System Capacity Factor ( $CF_{total}$ ) =	$(B_{output}/B_{mw}) \times (t_{snocr}/365) =$	0.40	fraction
Total operating time for the SNCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	3474	hours
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	50	percent
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	589.77	lb/hour
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	1,024.34	tons/year
Coal Factor ( $Coal_f$ ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)		Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$		Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEV <sub>F</sub> ) =	$14.7 \text{ psia}/P =$		Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h) + 459.7)/518.6]^{5.256} \times (1/144)^*$	14.7	psia
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00	

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflightsystems.grc.nasa.gov/education/rocket/atmos.html>.

DOH-CAB Changed Spreadsheet



## Appendix Table A-4c. Kahe K5 - SNCR Costing

**Reagent Data:**

Type of reagent used

Ammonia

Molecular Weight of Reagent (MW) = 17.03 g/mole  
Density = 56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NO}_{x_{\text{in}}} \times Q_B \times \text{NSR} \times \text{MW}_R) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	531	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$	1,833	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	244.8	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	82,300	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0688

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x_{\text{in}}} \times \text{NSR} \times Q_B) / \text{NPHR} =$	65.3	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	417	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	4.31	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

DOH-CAB Changed Spreadsheet

# Appendix Table A-4c. Kahe K5 - SNCR Costing

## Cost Estimate

### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$2,010,115 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$3,953,628 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$7,752,866 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$2,010,115 in 2019 dollars
--	-----------------------------

### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

### Balance of Plant Costs ( $BOP_{cost}$ )

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times RF$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times BTF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (NO_x \text{Removed/hr})^{0.12} \times RF$$

Balance of Plant Costs ( $BOP_{cost}$ ) =	\$3,953,628 in 2019 dollars
---	-----------------------------

[Original Submitted Spreadsheet](#)

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### Annual Costs

**Total Annual Cost (TAC)**  
TAC = Direct Annual Costs + Indirect Annual Costs

Direct Annual Costs (DAC) =	\$623,223 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$735,359 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>	<b>\$1,358,582 in 2019 dollars</b>

**Direct Annual Costs (DAC)**  
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)

Annual Maintenance Cost =	0.015 x TCI =	\$116,293 in 2019 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$249,165 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$57,167 in 2019 dollars
Annual Water Cost =	$q_{water} \times Cost_{water} \times t_{op} =$	\$6,044 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$194,553 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$623,223 in 2019 dollars</b>

**Indirect Annual Cost (IDAC)**  
IDAC = Administrative Charges + Capital Recovery Costs

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$3,489 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$731,871 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$735,359 in 2019 dollars</b>

### Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$1,358,582 per year in 2019 dollars
NOx Removed =	1,024 tons/year
<b>Cost Effectiveness =</b>	<b>\$1,326 per ton of NOx removed in 2019 dollars</b>

Original Submitted Spreadsheet

# Appendix Table A-4c. Kahe K5 - SNCR Costing

## Cost Estimate

### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$1,340,077 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,635,752 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$5,168,577 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times \text{CoalF} \times \text{BTF} \times \text{ELEV} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times \text{ELEV} \times \text{RF}$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$1,340,077 in 2019 dollars
--	-----------------------------

### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times \text{CoalF})^{0.78} \times \text{AHF} \times \text{RF}$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

### Balance of Plant Costs ( $BOP_{cost}$ )

For Coal-Fired Utility Boilers:

$$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

For Coal-Fired Industrial Boilers:

$$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{BTF} \times \text{RF}$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (\text{NO}_x\text{Removed/hr})^{0.12} \times \text{RF}$$

Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,635,752 in 2019 dollars
---	-----------------------------

DOH-CAB Changed Spreadsheet

## Appendix Table A-4c. Kahe K5 - SNCR Costing

### Annual Costs

#### Total Annual Cost (TAC)

$$\text{TAC} = \text{Direct Annual Costs} + \text{Indirect Annual Costs}$$

Direct Annual Costs (DAC) =	\$584,458 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$357,924 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>	<b>\$942,382 in 2019 dollars</b>

#### Direct Annual Costs (DAC)

$$\text{DAC} = (\text{Annual Maintenance Cost}) + (\text{Annual Reagent Cost}) + (\text{Annual Electricity Cost}) + (\text{Annual Water Cost}) + (\text{Annual Fuel Cost}) + (\text{Annual Ash Cost})$$

Annual Maintenance Cost =	0.015 x TCI =	\$77,529 in 2019 dollars
Annual Reagent Cost =	$q_{\text{sol}} \times \text{Cost}_{\text{reag}} \times t_{\text{op}} =$	\$249,165 in 2019 dollars
Annual Electricity Cost =	$P \times \text{Cost}_{\text{elect}} \times t_{\text{op}} =$	\$57,167 in 2019 dollars
Annual Water Cost =	$q_{\text{water}} \times \text{Cost}_{\text{water}} \times t_{\text{op}} =$	\$6,044 in 2019 dollars
Additional Fuel Cost =	$\Delta \text{Fuel} \times \text{Cost}_{\text{fuel}} \times t_{\text{op}} =$	\$194,553 in 2019 dollars
Additional Ash Cost =	$\Delta \text{Ash} \times \text{Cost}_{\text{ash}} \times t_{\text{op}} \times (1/2000) =$	\$0 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$584,458 in 2019 dollars</b>

#### Indirect Annual Cost (IDAC)

$$\text{IDAC} = \text{Administrative Charges} + \text{Capital Recovery Costs}$$

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,326 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$355,598 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$357,924 in 2019 dollars</b>

### Cost Effectiveness

$$\text{Cost Effectiveness} = \text{Total Annual Cost} / \text{NOx Removed/year}$$

Total Annual Cost (TAC) =	\$942,382 per year in 2019 dollars
NOx Removed =	1,024 tons/year
<b>Cost Effectiveness =</b>	<b>\$920 per ton of NOx removed in 2019 dollars</b>

DOH-CAB Changed Spreadsheet

# Appendix Table A-4d. Kahe K6 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.  \* NOTE: You must document why a retrofit factor of 1.5 is appropriate for the proposed project.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWh output?

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units buring fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

Original Submitted Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x,in}$ ) to SNCR	0.196 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x,out}$ ) from SNCR	0.15 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia	<b>Densities of typical SNCR reagents:</b> 50% urea solution                      71 lbs/ft <sup>3</sup> 29.4% aqueous NH <sub>3</sub> 56 lbs/ft <sup>3</sup>	

### Enter the cost data for the proposed SNCR:

Desired dollar-year	2019			
CEPCI for 2019	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI	CEPCI = Chemical Engineering Plant Cost Index
Annual Interest Rate (i)	7 Percent			
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu			Actual Data Used
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia			Default Value Used
Water ( $Cost_{water}$ )	0.0042 \$/gallon			Default Value Used
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh			Actual Data Used
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton			

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

Original Submitted Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	7	Office of Management and Budget (OMB) default social interest for capital projects	

Original Submitted Spreadsheet



# Appendix Table A-4d. Kahe K6 - SNCR Costing

## Data Inputs

Enter the following data for your combustion unit:

Is the combustion unit a utility or industrial boiler?

What type of fuel does the unit burn?

Is the SNCR for a new boiler or retrofit of an existing boiler?

Please enter a retrofit factor equal to or greater than 0.84 based on the level of difficulty. Enter 1 for projects of average retrofit difficulty.

Complete all of the highlighted data fields:

What is the MW rating at full load capacity (Bmw)?

What is the higher heating value (HHV) of the fuel?

What is the estimated actual annual MWh output?

Is the boiler a fluid-bed boiler?

Enter the net plant heat input rate (NPHR)

If the NPHR is not known, use the default NPHR value:

Fuel Type	Default NPHR
Coal	10 MMBtu/MW
Fuel Oil	11 MMBtu/MW
Natural Gas	8.2 MMBtu/MW

Not applicable to units burning fuel oil or natural gas

Type of coal burned:

Enter the sulfur content (%S) =  percent by weight  
or  
Select the appropriate SO<sub>2</sub> emission rate:

Ash content (%Ash):  percent by weight

Not applicable to units buring fuel oil or natural gas

Note: The table below is pre-populated with default values for HHV, %S, %Ash and cost. Please enter the actual values for these parameters in the table below. If the actual value for any parameter is not known, you may use the default values provided.

	Fraction in Coal Blend	%S	%Ash	HHV (Btu/lb)	Fuel Cost (\$/MMBtu)
Bituminous	0	1.84	9.23	11,841	2.4
Sub-Bituminous	0	0.41	5.84	8,826	1.89
Lignite	0	0.82	13.6	6,626	1.74

Please click the calculate button to calculate weighted values based on the data in the table above.

DOH-CAB Changed Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### Enter the following design parameters for the proposed SNCR:

Number of days the SNCR operates ( $t_{SNCR}$ )	365 days	Plant Elevation	10 Feet above sea level
Inlet $NO_x$ Emissions ( $NO_{x_{in}}$ ) to SNCR	0.196 lb/MMBtu		
Outlet $NO_x$ Emissions ( $NO_{x_{out}}$ ) from SNCR	0.15 lb/MMBtu		
Estimated Normalized Stoichiometric Ratio (NSR)	1.22		
Concentration of reagent as stored ( $C_{stored}$ )	29 Percent		
Density of reagent as stored ( $\rho_{stored}$ )	56 lb/ft <sup>3</sup>		
Concentration of reagent injected ( $C_{inj}$ )	10 percent		
Number of days reagent is stored ( $t_{storage}$ )	14 days		
Estimated equipment life	20 Years		
Select the reagent used	Ammonia		

**Densities of typical SNCR reagents:**

50% urea solution	71 lbs/ft <sup>3</sup>
29.4% aqueous NH <sub>3</sub>	56 lbs/ft <sup>3</sup>

### Enter the cost data for the proposed SNCR:

Desired dollar-year	2019		
CEPCI for 2019	607.5 <span style="color: red;">Enter the CEPCI value for 2019</span>	541.7	2016 CEPCI
Annual Interest Rate (i)	3.25 Percent		
Fuel ( $Cost_{fuel}$ )	13.01 \$/MMBtu	Actual Data Used	
Reagent ( $Cost_{reag}$ )	0.293 \$/gallon for a 29 percent solution of ammonia	Default Value Used	
Water ( $Cost_{water}$ )	0.0042 \$/gallon	Default Value Used	
Electricity ( $Cost_{elect}$ )	0.2521 \$/kWh	Actual Data Used	
Ash Disposal (for coal-fired boilers only) ( $Cost_{ash}$ )	\$/ton		

CEPCI = Chemical Engineering Plant Cost Index

Note: The use of CEPCI in this spreadsheet is not an endorsement of the index, but is there merely to allow for availability of a well-known cost index to spreadsheet users. Use of other well-known cost indexes (e.g., M&S) is acceptable.

### Maintenance and Administrative Charges Cost Factors:

Maintenance Cost Factor (MCF) =	0.015
Administrative Charges Factor (ACF) =	0.03

DOH-CAB Changed Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### Data Sources and Default Values Used in Calculations:

Data Element	Default Value	Sources for Default Value	If you used your own site-specific values, please enter the value used and the reference source . . .
Reagent Cost (\$/gallon)	\$0.293/gallon of 29% Ammonia	U.S. Geological Survey, Minerals Commodity Summaries, January 2017 ( <a href="https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf">https://minerals.usgs.gov/minerals/pubs/commodity/nitrogen/mcs-2017-nitro.pdf</a> )	
Water Cost (\$/gallon)	0.00417	Average water rates for industrial facilities in 2013 compiled by Black & Veatch. (see 2012/2013 "50 Largest Cities Water/Wastewater Rate Survey." Available at <a href="http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf">http://www.saws.org/who_we_are/community/RAC/docs/2014/50-largest-cities-brochure-water-wastewater-rate-survey.pdf</a> .)	
Electricity Cost (\$/kWh)	0.2521	U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.	
Fuel Cost (\$/MMBtu)	13.01	2019 Average Fuel Cost	
Ash Disposal Cost (\$/ton)	-	Not applicable	Not Applicable
Percent sulfur content for Coal (% weight)	-	Not applicable	Not Applicable
Percent ash content for Coal (% weight)	-	Not applicable	Not Applicable
Higher Heating Value (HHV) (Btu/lb)	149,479	2017 Annual Average	
Interest Rate (%)	3.25	Current prime interest rate	

DOH-CAB Changed Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate (Q <sub>B</sub> ) =	Bmw x NPHR =	1,516	MMBtu/hour	
Maximum Annual MWh Output =	Bmw x 8760 =	1,243,920	MWh	
Estimated Actual Annual MWh Output (Boutput) =		601,781	MWh	
Heat Rate Factor (HRF) =	NPHR/10 =	1.07		
Total System Capacity Factor (CF <sub>total</sub> ) =	(Boutput/Bmw)*(tsnrcr/365) =	0.48	fraction	
Total operating time for the SNCR (t <sub>op</sub> ) =	CF <sub>total</sub> x 8760 =	4238	hours	
NOx Removal Efficiency (EF) =	(NO <sub>xin</sub> - NO <sub>xout</sub> )/NO <sub>xin</sub> =	24	percent	
NOx removed per hour =	NO <sub>xin</sub> x EF x Q <sub>B</sub> =	69.96	lb/hour	
Total NO <sub>x</sub> removed per year =	(NO <sub>xin</sub> x EF x Q <sub>B</sub> x t <sub>op</sub> )/2000 =	148.25	tons/year	
Coal Factor (Coal <sub>f</sub> ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)			Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	(%S/100)x(64/32)*(1x10 <sup>6</sup> )/HHV =			Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEV <sub>F</sub> ) =	14.7 psia/P =			Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	2116x[(59-(0.00356xh))+459.7]/518.6] <sup>5.256</sup> x (1/144)* =	14.7	psia	
Retrofit Factor (RF) =	Retrofit to existing boiler	1.50		

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

Original Submitted Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NO}_{x_n} \times Q_B \times \text{NSR} \times \text{MW}_R) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for NH <sub>3</sub> ; 2 for Urea)	134	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$	463	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	61.9	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	20,800	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0944

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x_n} \times \text{NSR} \times Q_B) / \text{NPHR} =$	16.0	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	105	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.09	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

[Original Submitted Spreadsheet](#)

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### SNCR Design Parameters

The following design parameters for the SNCR were calculated based on the values entered on the *Data Inputs* tab. These values were used to prepare the costs shown on the *Cost Estimate* tab.

Parameter	Equation	Calculated Value	Units	
Maximum Annual Heat Input Rate ( $Q_B$ ) =	$B_{mw} \times NPHR =$	1,516	MMBtu/hour	
Maximum Annual MWh Output =	$B_{mw} \times 8760 =$	1,243,920	MWh	
Estimated Actual Annual MWh Output (Boutput) =		601,781	MWh	
Heat Rate Factor (HRF) =	$NPHR/10 =$	1.07		
Total System Capacity Factor ( $CF_{total}$ ) =	$(B_{output}/B_{mw}) \times (t_{snrcr}/365) =$	0.48	fraction	
Total operating time for the SNCR ( $t_{op}$ ) =	$CF_{total} \times 8760 =$	4238	hours	
NOx Removal Efficiency (EF) =	$(NO_{x_{in}} - NO_{x_{out}})/NO_{x_{in}} =$	24	percent	
NOx removed per hour =	$NO_{x_{in}} \times EF \times Q_B =$	69.96	lb/hour	
Total NO <sub>x</sub> removed per year =	$(NO_{x_{in}} \times EF \times Q_B \times t_{op})/2000 =$	148.25	tons/year	
Coal Factor ( $Coal_p$ ) =	1 for bituminous; 1.05 for sub-bituminous; 1.07 for lignite (weighted average is used for coal blends)			Not applicable; factor applies only to coal-fired boilers
SO <sub>2</sub> Emission rate =	$(\%S/100) \times (64/32) \times (1 \times 10^6)/HHV =$			Not applicable; factor applies only to coal-fired boilers
Elevation Factor (ELEV <sub>F</sub> ) =	$14.7 \text{ psia}/P =$			Not applicable; elevation factor does not apply to plants located at elevations below 500 feet.
Atmospheric pressure at 10 feet above sea level (P) =	$2116 \times [(59 - (0.00356 \times h)) + 459.7]/518.6]^{5.256} \times (1/144)^*$	14.7	psia	
Retrofit Factor (RF) =	Retrofit to existing boiler	1.00		

\* Equation is from the National Aeronautics and Space Administration (NASA), Earth Atmosphere Model. Available at <https://spaceflight systems.grc.nasa.gov/education/rocket/atmos.html>.

DOH-CAB Changed Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

**Reagent Data:**

Type of reagent used	Ammonia	Molecular Weight of Reagent (MW) =	17.03 g/mole
		Density =	56 lb/gallon

Parameter	Equation	Calculated Value	Units
Reagent consumption rate ( $m_{\text{reagent}}$ ) =	$(\text{NO}_{x\text{in}} \times Q_B \times \text{NSR} \times \text{MW}_R) / (\text{MW}_{\text{NO}_x} \times \text{SR}) =$ (whre SR = 1 for $\text{NH}_3$ ; 2 for Urea)	134	lb/hour
Reagent Usage Rate ( $m_{\text{sol}}$ ) =	$m_{\text{reagent}} / C_{\text{sol}} =$	463	lb/hour
	$(m_{\text{sol}} \times 7.4805) / \text{Reagent Density} =$	61.9	gal/hour
Estimated tank volume for reagent storage =	$(m_{\text{sol}} \times 7.4805 \times t_{\text{storage}} \times 24 \text{ hours/day}) / \text{Reagent Density} =$	20,800	gallons (storage needed to store a 14 day reagent supply rounded up to the nearest 100 gallons)

**Capital Recovery Factor:**

Parameter	Equation	Calculated Value
Capital Recovery Factor (CRF) =	$i (1+i)^n / ((1+i)^n - 1) =$ Where n = Equipment Life and i= Interest Rate	0.0688

Parameter	Equation	Calculated Value	Units
<b>Electricity Usage:</b>			
Electricity Consumption (P) =	$(0.47 \times \text{NO}_{x\text{in}} \times \text{NSR} \times Q_B) / \text{NPHR} =$	16.0	kW/hour
<b>Water Usage:</b>			
Water consumption ( $q_w$ ) =	$(m_{\text{sol}} / \text{Density of water}) \times ((C_{\text{stored}} / C_{\text{inj}}) - 1) =$	105	gallons/hour
<b>Fuel Data:</b>			
Additional Fuel required to evaporate water in injected reagent ( $\Delta\text{Fuel}$ ) =	$H_v \times m_{\text{reagent}} \times ((1/C_{\text{inj}}) - 1) =$	1.09	MMBtu/hour
<b>Ash Disposal:</b>			
Additional ash produced due to increased fuel consumption ( $\Delta\text{ash}$ ) =	$(\Delta\text{fuel} \times \% \text{Ash} \times 1 \times 10^6) / \text{HHV} =$	0.0	lb/hour

Not applicable - Ash disposal cost applies only to coal-fired boilers

DOH-CAB Changed Spreadsheet

# Appendix Table A-4d. Kahe K6 - SNCR Costing

## Cost Estimate

### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$2,037,463 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$3,061,252 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$6,628,329 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$2,037,463 in 2019 dollars
--	-----------------------------

### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

[Original Submitted Spreadsheet](#)



## Appendix Table A-4d. Kahe K6 - SNCR Costing

Balance of Plant Costs (BOP <sub>cost</sub> )	
For Coal-Fired Utility Boilers:	$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$
For Fuel Oil and Natural Gas-Fired Utility Boilers:	$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$
For Coal-Fired Industrial Boilers:	$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$
For Fuel Oil and Natural Gas-Fired Industrial Boilers:	$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$

Balance of Plant Costs (BOP <sub>cost</sub> ) =	\$3,061,252 in 2019 dollars
---	-----------------------------

### Annual Costs

Total Annual Cost (TAC)	
TAC = Direct Annual Costs + Indirect Annual Costs	

Direct Annual Costs (DAC) =	\$255,122 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$628,697 in 2019 dollars
Total annual costs (TAC) = DAC + IDAC	\$883,819 in 2019 dollars

Direct Annual Costs (DAC)	
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)	

Annual Maintenance Cost =	0.015 x TCI =	\$99,425 in 2019 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$76,802 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$17,063 in 2019 dollars
Annual Water Cost =	$q_{water} \times Cost_{water} \times t_{op} =$	\$1,863 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$59,969 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
Direct Annual Cost =		\$255,122 in 2019 dollars

Indirect Annual Cost (IDAC)	
IDAC = Administrative Charges + Capital Recovery Costs	

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$2,983 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$625,714 in 2019 dollars
Indirect Annual Cost (IDAC) =	AC + CR =	\$628,697 in 2019 dollars

Original Submitted Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$883,819 per year in 2019 dollars
NOx Removed =	148 tons/year
Cost Effectiveness =	\$5,962 per ton of NOx removed in 2019 dollars

[Original Submitted Spreadsheet](#)

# Appendix Table A-4d. Kahe K6 - SNCR Costing

## Cost Estimate

### Total Capital Investment (TCI)

For Coal-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + APH_{cost} + BOP_{cost})$$

For Fuel Oil and Natural Gas-Fired Boilers:

$$TCI = 1.3 \times (SNCR_{cost} + BOP_{cost})$$

Capital costs for the SNCR ( $SNCR_{cost}$ ) =	\$1,358,309 in 2019 dollars
Air Pre-Heater Costs ( $APH_{cost}$ )* =	\$0 in 2019 dollars
Balance of Plant Costs ( $BOP_{cost}$ ) =	\$2,040,834 in 2019 dollars
<b>Total Capital Investment (TCI) =</b>	<b>\$4,418,886 in 2019 dollars</b>

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emits equal to or greater than 0.3lb/MMBtu of sulfur dioxide.

### SNCR Capital Costs ( $SNCR_{cost}$ )

For Coal-Fired Utility Boilers:

$$SNCR_{cost} = 220,000 \times (B_{MW} \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Utility Boilers:

$$SNCR_{cost} = 147,000 \times (B_{MW} \times HRF)^{0.42} \times ELEVF \times RF$$

For Coal-Fired Industrial Boilers:

$$SNCR_{cost} = 220,000 \times (0.1 \times Q_B \times HRF)^{0.42} \times CoalF \times BTF \times ELEVF \times RF$$

For Fuel Oil and Natural Gas-Fired Industrial Boilers:

$$SNCR_{cost} = 147,000 \times ((Q_B/NPHR) \times HRF)^{0.42} \times ELEVF \times RF$$

SNCR Capital Costs ( $SNCR_{cost}$ ) =	\$1,358,309 in 2019 dollars
--	-----------------------------

### Air Pre-Heater Costs ( $APH_{cost}$ )\*

For Coal-Fired Utility Boilers:

$$APH_{cost} = 69,000 \times (B_{MW} \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

For Coal-Fired Industrial Boilers:

$$APH_{cost} = 69,000 \times (0.1 \times Q_B \times HRF \times CoalF)^{0.78} \times AHF \times RF$$

Air Pre-Heater Costs ( $APH_{cost}$ ) =	\$0 in 2019 dollars
---	---------------------

\* Not applicable - This factor applies only to coal-fired boilers that burn bituminous coal and emit equal to or greater than 3lb/MMBtu of sulfur dioxide.

DOH-CAB Changed Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

Balance of Plant Costs (BOP <sub>cost</sub> )	
For Coal-Fired Utility Boilers:	$BOP_{cost} = 320,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$
For Fuel Oil and Natural Gas-Fired Utility Boilers:	$BOP_{cost} = 213,000 \times (B_{MW})^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$
For Coal-Fired Industrial Boilers:	$BOP_{cost} = 320,000 \times (0.1 \times Q_B)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times BTF \times RF$
For Fuel Oil and Natural Gas-Fired Industrial Boilers:	$BOP_{cost} = 213,000 \times (Q_B/NPHR)^{0.33} \times (NO_x\text{Removed/hr})^{0.12} \times RF$

Balance of Plant Costs (BOP <sub>cost</sub> ) =	\$2,040,834 in 2019 dollars
---	-----------------------------

### Annual Costs

Total Annual Cost (TAC)	
TAC = Direct Annual Costs + Indirect Annual Costs	

Direct Annual Costs (DAC) =	\$221,980 in 2019 dollars
Indirect Annual Costs (IDAC) =	\$306,008 in 2019 dollars
<b>Total annual costs (TAC) = DAC + IDAC</b>	<b>\$527,988 in 2019 dollars</b>

Direct Annual Costs (DAC)	
DAC = (Annual Maintenance Cost) + (Annual Reagent Cost) + (Annual Electricity Cost) + (Annual Water Cost) + (Annual Fuel Cost) + (Annual Ash Cost)	

Annual Maintenance Cost =	0.015 x TCI =	\$66,283 in 2019 dollars
Annual Reagent Cost =	$q_{sol} \times Cost_{reag} \times t_{op} =$	\$76,802 in 2019 dollars
Annual Electricity Cost =	$P \times Cost_{elect} \times t_{op} =$	\$17,063 in 2019 dollars
Annual Water Cost =	$q_{water} \times Cost_{water} \times t_{op} =$	\$1,863 in 2019 dollars
Additional Fuel Cost =	$\Delta Fuel \times Cost_{fuel} \times t_{op} =$	\$59,969 in 2019 dollars
Additional Ash Cost =	$\Delta Ash \times Cost_{ash} \times t_{op} \times (1/2000) =$	\$0 in 2019 dollars
<b>Direct Annual Cost =</b>		<b>\$221,980 in 2019 dollars</b>

Indirect Annual Cost (IDAC)	
IDAC = Administrative Charges + Capital Recovery Costs	

Administrative Charges (AC) =	0.03 x Annual Maintenance Cost =	\$1,988 in 2019 dollars
Capital Recovery Costs (CR)=	CRF x TCI =	\$304,019 in 2019 dollars
<b>Indirect Annual Cost (IDAC) =</b>	<b>AC + CR =</b>	<b>\$306,008 in 2019 dollars</b>

DOH-CAB Changed Spreadsheet

## Appendix Table A-4d. Kahe K6 - SNCR Costing

### Cost Effectiveness

Cost Effectiveness = Total Annual Cost/ NOx Removed/year

Total Annual Cost (TAC) =	\$527,988 per year in 2019 dollars
NOx Removed =	148 tons/year
Cost Effectiveness =	\$3,561 per ton of NOx removed in 2019 dollars

[DOH-CAB Changed Spreadsheet](#)

**Appendix Table A-1. CDS Capital and O&M Cost Estimate**

Unit MW Rating (Nominal) Classification	K1 92 Fuel Oil	K2 90 Fuel Oil	K3 92 Fuel Oil	K4 93 Fuel Oil	K5 142 Fuel Oil	K6 142 Fuel Oil
<b>Capital Cost</b>						
<b>Direct Costs</b>						
Total Direct Costs (DC)	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 61,988,000	\$ 61,988,000
<b>Indirect Costs</b>						
Summary of Indirect Costs not including Contingency	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 19,142,000	\$ 19,142,000
Contingencies	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 21,468,000	\$ 21,468,000
Total Indirect Costs (IC)	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 40,610,000	\$ 40,610,000
<b>Allowance for Funds Used During Construction (AFDC)</b>	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 10,466,000	\$ 10,466,000
<b>Total Capital Investment (TCI)</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 113,064,000</b>	<b>\$ 113,064,000</b>
<b>Annual Cost</b>						
<b>Direct Annual Costs</b>						
Fixed Annual Costs						
Maintenance labor and materials	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Total Fixed Annual Costs	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Variable Annual Costs						
Byproduct disposal	\$ 273,000	\$ 294,000	\$ 377,000	\$ 314,000	\$ 478,000	\$ 352,000
Reagent Cost (lime)	\$ 632,000	\$ 679,000	\$ 864,000	\$ 740,000	\$ 1,582,000	\$ 1,204,000
Water Cost	\$ 51,000	\$ 54,000	\$ 69,000	\$ 58,000	\$ 116,000	\$ 88,000
Power (ID and Aux) Cost	\$ 1,561,000	\$ 1,675,000	\$ 2,151,000	\$ 1,805,000	\$ 4,259,000	\$ 3,161,000
Total Variable Annual Costs	\$ 2,517,000	\$ 2,702,000	\$ 3,461,000	\$ 2,917,000	\$ 6,435,000	\$ 4,805,000
Total Direct Annual Costs (DAC)	\$ 4,305,000	\$ 4,490,000	\$ 5,249,000	\$ 4,705,000	\$ 8,878,000	\$ 7,248,000
<b>Indirect Annual Costs</b>						
Cost for capital recovery <sup>2</sup>	\$ 5,903,196	\$ 5,903,196	\$ 5,903,196	\$ 5,903,196	\$ 9,111,421	\$ 9,111,421
Total Indirect Annual Costs (IDAC)	\$ 5,903,196	\$ 5,903,196	\$ 5,903,196	\$ 5,903,196	\$ 9,111,421	\$ 9,111,421
<b>Total Annual Cost (TAC)</b>	<b>\$ 10,208,196</b>	<b>\$ 10,393,196</b>	<b>\$ 11,152,196</b>	<b>\$ 10,608,196</b>	<b>\$ 17,989,421</b>	<b>\$ 16,359,421</b>
<b>Total Annual Cost (TAC) - 2019 Dollars <sup>3</sup></b>	<b>\$ 10,608,072</b>	<b>\$ 10,800,319</b>	<b>\$ 11,589,051</b>	<b>\$ 11,023,741</b>	<b>\$ 18,694,104</b>	<b>\$ 17,000,254</b>

<sup>1</sup> Costing from an Hawaiian Electric internal study dated July 2012.

<sup>2</sup> Capital Recovery Factor (CRF) =  $[I \times (1+i)^a] / [(1+i)^a - 1]$  CRF = 0.08

Where:

I = Interest Rate (7% interest)

a = Equipment life (30 yrs)

<sup>3</sup> Cost scaled to 2019 dollars using the Chemical Engineering Plant Cost Index (CEPCI) for 2012 (584.6) and 2019 (607.5). As published in Chemical Engineering Magazine - Revision: 18, Apr 16, 2019 and <https://www.chemengonline.com/2019-chemical-engineering-plant-cost-index-annual-average/>

Original Submitted Spreadsheet

**Appendix Table A-1. CDS Capital and O&M Cost Estimate (20 Yrs Life)**

Unit MW Rating (Nominal) Classification	K1 92 Fuel Oil	K2 90 Fuel Oil	K3 92 Fuel Oil	K4 93 Fuel Oil	K5 142 Fuel Oil	K6 142 Fuel Oil
<b>Capital Cost</b>						
<b>Direct Costs</b>						
Total Direct Costs (DC)	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 61,988,000	\$ 61,988,000
<b>Indirect Costs</b>						
Summary of Indirect Costs not including Contingency	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 19,142,000	\$ 19,142,000
Contingencies	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 21,468,000	\$ 21,468,000
Total Indirect Costs (IC)	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 40,610,000	\$ 40,610,000
<b>Allowance for Funds Used During Construction (AFDC)</b>	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 10,466,000	\$ 10,466,000
<b>Total Capital Investment (TCI)</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 113,064,000</b>	<b>\$ 113,064,000</b>
<b>Annual Cost</b>						
<b>Direct Annual Costs</b>						
Fixed Annual Costs						
Maintenance labor and materials	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Total Fixed Annual Costs	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Variable Annual Costs						
Byproduct disposal	\$ 273,000	\$ 294,000	\$ 377,000	\$ 314,000	\$ 478,000	\$ 352,000
Reagent Cost (lime)	\$ 632,000	\$ 679,000	\$ 864,000	\$ 740,000	\$ 1,582,000	\$ 1,204,000
Water Cost	\$ 51,000	\$ 54,000	\$ 69,000	\$ 58,000	\$ 116,000	\$ 88,000
Power (ID and Aux) Cost	\$ 1,561,000	\$ 1,675,000	\$ 2,151,000	\$ 1,805,000	\$ 4,259,000	\$ 3,161,000
Total Variable Annual Costs	\$ 2,517,000	\$ 2,702,000	\$ 3,461,000	\$ 2,917,000	\$ 6,435,000	\$ 4,805,000
Total Direct Annual Costs (DAC)	\$ 4,305,000	\$ 4,490,000	\$ 5,249,000	\$ 4,705,000	\$ 8,878,000	\$ 7,248,000
<b>Indirect Annual Costs</b>						
Cost for capital recovery <sup>2</sup>	\$ 5,038,260	\$ 5,038,260	\$ 5,038,260	\$ 5,038,260	\$ 7,776,416	\$ 7,776,416
Total Indirect Annual Costs (IDAC)	\$ 5,038,260	\$ 5,038,260	\$ 5,038,260	\$ 5,038,260	\$ 7,776,416	\$ 7,776,416
<b>Total Annual Cost (TAC)</b>	<b>\$ 9,343,260</b>	<b>\$ 9,528,260</b>	<b>\$ 10,287,260</b>	<b>\$ 9,743,260</b>	<b>\$ 16,654,416</b>	<b>\$ 15,024,416</b>
<b>Total Annual Cost (TAC) - 2019 Dollars<sup>3</sup></b>	<b>\$ 9,709,255</b>	<b>\$ 9,901,501</b>	<b>\$ 10,690,233</b>	<b>\$ 10,124,923</b>	<b>\$ 17,306,804</b>	<b>\$ 15,612,953</b>

<sup>1</sup> Costing from an Hawaiian Electric internal study dated July 2012.

<sup>2</sup> Capital Recovery Factor (CRF) =  $[I \times (1+i)^a] / [(1+i)^a - 1]$  CRF = 0.07

Where:

I = Interest Rate (3.25% interest)

a = Equipment life (20 yrs)

<sup>3</sup> Cost scaled to 2019 dollars using the Chemical Engineering Plant Cost Index (CEPCI) for 2012 (584.6) and 2019 (607.5). As published in Chemical Engineering Magazine - Revision: 18, Apr 16, 2019 and <https://www.chemengonline.com/2019-chemical-engineering-plant-cost-index-annual-average/>

DOH-CAB Changed Spreadsheet (20 Yrs Life)

**Appendix Table A-1. CDS Capital and O&M Cost Estimate (30 Yrs Life)**

Unit MW Rating (Nominal) Classification	K1 92 Fuel Oil	K2 90 Fuel Oil	K3 92 Fuel Oil	K4 93 Fuel Oil	K5 142 Fuel Oil	K6 142 Fuel Oil
<b>Capital Cost</b>						
<b>Direct Costs</b>						
Total Direct Costs (DC)	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 40,161,000	\$ 61,988,000	\$ 61,988,000
<b>Indirect Costs</b>						
Summary of Indirect Costs not including Contingency	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 12,402,000	\$ 19,142,000	\$ 19,142,000
Contingencies	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 13,909,000	\$ 21,468,000	\$ 21,468,000
Total Indirect Costs (IC)	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 26,311,000	\$ 40,610,000	\$ 40,610,000
<b>Allowance for Funds Used During Construction (AFDC)</b>	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 6,781,000	\$ 10,466,000	\$ 10,466,000
<b>Total Capital Investment (TCI)</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 73,253,000</b>	<b>\$ 113,064,000</b>	<b>\$ 113,064,000</b>
<b>Annual Cost</b>						
<b>Direct Annual Costs</b>						
Fixed Annual Costs						
Maintenance labor and materials	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Total Fixed Annual Costs	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 1,788,000	\$ 2,443,000	\$ 2,443,000
Variable Annual Costs						
Byproduct disposal	\$ 273,000	\$ 294,000	\$ 377,000	\$ 314,000	\$ 478,000	\$ 352,000
Reagent Cost (lime)	\$ 632,000	\$ 679,000	\$ 864,000	\$ 740,000	\$ 1,582,000	\$ 1,204,000
Water Cost	\$ 51,000	\$ 54,000	\$ 69,000	\$ 58,000	\$ 116,000	\$ 88,000
Power (ID and Aux) Cost	\$ 1,561,000	\$ 1,675,000	\$ 2,151,000	\$ 1,805,000	\$ 4,259,000	\$ 3,161,000
Total Variable Annual Costs	\$ 2,517,000	\$ 2,702,000	\$ 3,461,000	\$ 2,917,000	\$ 6,435,000	\$ 4,805,000
Total Direct Annual Costs (DAC)	\$ 4,305,000	\$ 4,490,000	\$ 5,249,000	\$ 4,705,000	\$ 8,878,000	\$ 7,248,000
<b>Indirect Annual Costs</b>						
Cost for capital recovery <sup>2</sup>	\$ 3,859,094	\$ 3,859,094	\$ 3,859,094	\$ 3,859,094	\$ 5,956,406	\$ 5,956,406
Total Indirect Annual Costs (IDAC)	\$ 3,859,094	\$ 3,859,094	\$ 3,859,094	\$ 3,859,094	\$ 5,956,406	\$ 5,956,406
<b>Total Annual Cost (TAC)</b>	<b>\$ 8,164,094</b>	<b>\$ 8,349,094</b>	<b>\$ 9,108,094</b>	<b>\$ 8,564,094</b>	<b>\$ 14,834,406</b>	<b>\$ 13,204,406</b>
<b>Total Annual Cost (TAC) - 2019 Dollars <sup>3</sup></b>	<b>\$ 8,483,898</b>	<b>\$ 8,676,145</b>	<b>\$ 9,464,877</b>	<b>\$ 8,899,567</b>	<b>\$ 15,415,500</b>	<b>\$ 13,721,650</b>

<sup>1</sup> Costing from an Hawaiian Electric internal study dated July 2012.

<sup>2</sup> Capital Recovery Factor (CRF) =  $[I \times (1+i)^a] / [(1+i)^a - 1]$  CRF = 0.05

Where:

I = Interest Rate (3.25% interest)

a = Equipment life (30yrs)

<sup>3</sup> Cost scaled to 2019 dollars using the Chemical Engineering Plant Cost Index (CEPCI) for 2012 (584.6) and 2019 (607.5). As published in Chemical Engineering Magazine - Revision: 18, Apr 16, 2019 and <https://www.chemengonline.com/2019-chemical-engineering-plant-cost-index-annual-average/>

DOH-CAB Changed Spreadsheet (30 Yrs Life)



**Appendix Table A-2. Combustion Controls Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4	K5
Boiler design capacity, mmBtu/hr (C)		903	900	892	918	1468
Boiler Type		Normal	Normal	Tangential	Tangential	Normal
2017 Annual Heat Input, MMBtu/yr (H)		3,778,041	2,959,869	3,753,356	3,858,826	5,099,323
Unit Size, kW (kW)		92,000	90,000	92,000	93,000	142,000
Unit Size, MW (MW)		92.0	90.0	92.0	93.0	142.0
Capital recovery factor						
a. Equipment CRF, 30-yr life, 7% interest	$= [ I \times (1+i)^a ] / [(1+i)^a - 1]$ where I = interest rate, a = equipment life	0.08	0.08	0.08	0.08	0.08
Cost Index (CI) <sup>A</sup>						
a. 2019	607.5					
b. 2004	444.2					
Total Capital Investment <sup>B,C</sup>						
TCI (\$)	$= \$24/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004}) - \text{Wall}$ $= \$18/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004}) - \text{Tangential}$	\$4,615,869	\$4,551,295	\$3,461,902	\$3,485,976	\$6,096,525
Direct Annual Operating Costs \$/yr						
Variable O&M Costs <sup>D</sup>	$= (\$0.08 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times \text{H} \times 10^6$ $\text{Btu}/\text{mmBtu} \times (\text{CI}_{2018}/\text{CI}_{2004}) - \text{Wall}$ $\$0.03 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times \text{H} \times 10^6$ $\text{Btu}/\text{mmBtu} \times (\text{CI}_{2018}/\text{CI}_{2004}) - \text{Tangential}$	\$41,336	\$32,384	\$15,400	\$15,832	\$55,792
Indirect Annual Costs, \$/yr						
1. Fixed O&M Costs <sup>E</sup>	$= \$0.36/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times$ $(300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004}) - \text{Wall}$ $= \$0.27/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times$ $(300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004}) - \text{Tangential}$	\$69,238	\$68,269	\$51,929	\$52,290	\$91,448
2. Capital recovery	= Equipment CRF x TCI	\$371,976	\$366,772	\$278,982	\$280,922	\$491,297
<b>Total Annual Cost \$/yr</b>	= Direct Annual Costs + Indirect Annual Costs	<b>\$482,550</b>	<b>\$467,426</b>	<b>\$346,310</b>	<b>\$349,044</b>	<b>\$638,537</b>

**Source:** All costs were estimated using Section 4.3 and Appendix D of the WRAP guidance document, *Analysis of Combustion Controls for Reducing NOx Emissions from Coal-fired EGUs in the WRAP Region*, dated September 6, 2005. The cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). As published in Chemical Engineering Magazine - Revision: 18, Apr 16, 2019 and <https://www.chemengonline.com/2019-chemical-engineering-plant-cost-index-annual-average/>

<sup>B</sup> TCI for LNB and LNB w/over fire air ranges from \$6/kW to \$24/kW for wall boilers and \$10/kW to \$18/kW for tangential boilers, the high end of the range was used due to Hawai'i's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>C</sup> Scaling factor = (300/Nameplate capacity)<sup>0.359</sup>

<sup>D</sup> The variable O&M costs for LNB and LNB w/over fire air ranges from 0.05 mills/kW-hr to 0.08 mills/kW-hr for wall boilers and 0.027 mills/kW-hr to 0.03 mills/kW-hr for tangential boilers, the high end of the range was used due to Hawai'i's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>E</sup> The fixed O&M costs for LNB and LNB w/over fire air ranges from \$0.09/kW to \$0.36/kW for wall boilers and \$0.15/kW to \$0.27/kW for tangential boilers, the high end of the range was used due to Hawai'i's remote location.

Original Submitted Spreadsheet

**Appendix Table A-2. Combustion Controls Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4	K5
Boiler design capacity, mmBtu/hr (C)		903	900	892	918	1468
Boiler Type		Normal	Normal	Tangential	Tangential	Normal
2017 Annual Heat Input, MMBtu/yr (H)		3,778,041	2,959,869	3,753,356	3,858,826	5,099,323
Unit Size, kW (kW)		92,000	90,000	92,000	93,000	142,000
Unit Size, MW (MW)		92.0	90.0	92.0	93.0	142.0
Capital recovery factor a. Equipment CRF, 20-yr life, 3.25% interest	$= [I \times (1+i)^a] / [(1+i)^a - 1]$ where I = interest rate, a = equipment life	0.07	0.07	0.07	0.07	0.07
Cost Index (CI) <sup>A</sup> a. 2019 b. 2004	607.5 444.2					
Total Capital Investment <sup>B,C</sup> TCI (\$)	$= \$24/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2019}/\text{CI}_{2004})$ - Wall $= \$18/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2019}/\text{CI}_{2004})$ - Tangential	\$4,615,869	\$4,551,295	\$3,461,902	\$3,485,976	\$6,096,525
Direct Annual Operating Costs \$/yr Variable O&M Costs <sup>D</sup>	$= (\$0.08 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times \text{H} \times 10^6$ Btu/mmBtu $\times (\text{CI}_{2019}/\text{CI}_{2004})$ - Wall $\$0.03 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times \text{H} \times 10^6$ Btu/mmBtu $\times (\text{CI}_{2019}/\text{CI}_{2004})$ - Tangential	\$41,336	\$32,384	\$15,400	\$15,832	\$55,792
Indirect Annual Costs, \$/yr 1. Fixed O&M Costs <sup>E</sup>	$= \$0.36/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times (300/\text{MW})^{0.359} \times (\text{CI}_{2019}/\text{CI}_{2004})$ - Wall $= \$0.27/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times (300/\text{MW})^{0.359} \times (\text{CI}_{2019}/\text{CI}_{2004})$ - Tangential	\$69,238	\$68,269	\$51,929	\$52,290	\$91,448
2. Capital recovery	= Equipment CRF x TCI	\$317,474	\$313,033	\$238,106	\$239,762	\$419,312
<b>Total Annual Cost \$/yr</b>	= Direct Annual Costs + Indirect Annual Costs	<b>\$428,048</b>	<b>\$413,686</b>	<b>\$305,434</b>	<b>\$307,883</b>	<b>\$566,552</b>

**Source:** All costs were estimated using Section 4.3 and Appendix D of the WRAP guidance document, *Analysis of Combustion Controls for Reducing NOx Emissions from Coal-fired EGUs in the WRAP*

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). As published in Chemical Engineering Magazine - Revision: 18, Apr 16, 2019 and <https://www.chemengonline.com/2019-chemical>

<sup>B</sup> TCI for LNB and LNB w/over fire air ranges from \$6/kW to \$24/kW for wall boilers and \$10/kW to \$18/kW for tangential boilers, the high end of the range was used due to Hawaii's remote

<sup>C</sup> Scaling factor =  $(300/\text{Nameplate capacity})^{0.359}$

<sup>D</sup> The variable O&M costs for LNB and LNB w/over fire air ranges from 0.05 mills/kW-hr to 0.08 mills/kW-hr for wall boilers and 0.027 mills/kW-hr to 0.03 mills/kW-hr for tangential boilers, the

<sup>E</sup> The fixed O&M costs for LNB and LNB w/over fire air ranges from \$0.09/kW to \$0.36/kW for wall boilers and \$0.15/kW to \$0.27/kW for tangential boilers, the high end of the range was used

DOH-CAB Changed Spreadsheet

## Final Conclusion and Action

The control cost summarized in the table below were based on a four-factor analyses of the Hawaiian Electric Kahe Power Plant after the facility was initially identified with Q/d to significantly affect visibility in the national parks. The cost per ton of pollutant removed, highlighted in green, are costs after changes were made to worksheets by DOH-CAB to align with EPA guidance and comments provided by EPA and the FLMs. For costs highlighted in green, the DOH-CAB assumed a remaining useful life thirty (30) years for SCR and twenty (20) years for all other controls. Costs for scrubbers that are highlighted in blue were based on a remaining useful life of thirty (30) years. An SCR retrofit factor of 1.0 was used instead of 1.5. A 3.25% prime interest rate was used versus a 7% interest rate.

Table D. Four-Factor Analysis for Hawaiian Electric Kahe Power Plant Oahu			
Unit	Description	Primary Fuel	Control Measures & Cost per Ton <sup>a,b,c,d,e</sup>
K-1	92 MW Boiler	Fuel Oil No. 6 with 0.5% maximum sulfur content	Fuel switch to residual/ULSD fuel blend with 0.25% maximum sulfur content - \$13,250/ton SO <sub>2</sub> for K1 to K6 Fuel switch to ULSD with 0.0015% maximum sulfur content - \$11,711/ton SO <sub>2</sub> for K1 to K6 Fuel switch to ULSD with 0.0015% sulfur content - \$7,594/ton SO <sub>2</sub> , NO <sub>x</sub> , and PM <sub>10</sub> combined for K1 Fuel switch to ULSD with 0.0015% sulfur content - \$6,900/ton SO <sub>2</sub> , NO <sub>x</sub> , and PM <sub>10</sub> combined for K2
K-2	90 MW Boiler	Fuel Oil No. 6 with 0.5% maximum sulfur content	Fuel switch to ULSD with 0.0015% sulfur content - \$9,780/ton SO <sub>2</sub> , NO <sub>x</sub> , and PM <sub>10</sub> combined for K3 Fuel switch to ULSD with 0.0015% sulfur content - \$9,697/ton SO <sub>2</sub> , NO <sub>x</sub> , and PM <sub>10</sub> combined for K4 Fuel switch to ULSD with 0.0015% sulfur content - \$6,308/ton SO <sub>2</sub> , NO <sub>x</sub> , and PM <sub>10</sub> combined for K5 Fuel switch to ULSD with 0.0015% sulfur content - \$9,707/ton SO <sub>2</sub> , NO <sub>x</sub> , and PM <sub>10</sub> combined for K6
K-3	92 MW Boiler	Fuel Oil No. 6 with 0.5% maximum sulfur content	CDS for K-1 - \$14,002 (\$12,815) (\$11,198)/ton SO <sub>2</sub> CDS for K-2 - \$18,196 (\$16,682) (\$14,617)/ton SO <sub>2</sub> CDS for K-3 - \$15,397 (\$14,203) (\$12,575)/ton SO <sub>2</sub> CDS for K-4 - \$14,246 (\$13,084) (\$11,501)/ton SO <sub>2</sub> CDS for K-5 - \$18,281 (\$16,925) (\$15,075)/ton SO <sub>2</sub> CDS for K-6 - \$13,195 (\$12,119) (\$10,651)/ton SO <sub>2</sub> LNB w/OFA/FGR for K-1 - \$1,318 (\$1,170)/ton NO <sub>x</sub> LNB w/OFA/FGR for K-2 - \$901 (\$797)/ton NO <sub>x</sub> LNB w/OFA/FGR for K-3 - \$1,209 (\$1,067)/ton NO <sub>x</sub> LNB w/OFA/FGR for K-4 - \$1,008 (\$889)/ton NO <sub>x</sub> LNB w/OFA/FGR for K-5 - \$499 (\$443)/ton NO <sub>x</sub> SCR for K-1 - \$2,972 (\$1,864)/ton NO <sub>x</sub> SCR for K-2 - \$2,557 (\$1,561)/ton NO <sub>x</sub> SCR for K-3 - \$4,581 (\$2,842)/ton NO <sub>x</sub> SCR for K-4 - \$4,085 (\$2,546)/ton NO <sub>x</sub> SCR for K-5 - \$1,709 (\$1,100)/ton NO <sub>x</sub> SCR for K-6 - \$6,488 (\$4,161)/ton NO <sub>x</sub>
K-4	93 MW Boiler	Fuel Oil No. 6 with 0.5% maximum sulfur content	SCR+Combustion Controls for K-1 - \$3,213 (\$2,165)/ton NO <sub>x</sub> SCR+Combustion Controls for K-2 - \$2,870 (\$1,896)/ton NO <sub>x</sub> SCR+Combustion Controls for K-3 - \$4,434 (\$2,910)/ton NO <sub>x</sub>

Table D. Four-Factor Analysis for Hawaiian Electric Kahe Power Plant Oahu			
Unit	Description	Primary Fuel	Control Measures & Cost per Ton <sup>a,b,c,d,e</sup>
K-5	142 MW Boiler	Fuel Oil No. 6 with 0.5% maximum sulfur content	SCR+Combustion Controls for K-4 - \$4,014 (\$2,644)/ton NO <sub>x</sub>
			SCR+Combustion Controls for K-5 - \$1,929 (\$1,322)/ton NO <sub>x</sub>
			SNCR for K-1 - \$4,824 (\$3,109)/ton NO <sub>x</sub>
			SNCR for K-2 - \$2,303 (\$1,484)/ton NO <sub>x</sub>
			SNCR for K-3 - \$4,100 (\$2,516)/ton NO <sub>x</sub>
			SNCR for K-4 - \$3,160 (\$1,939)/ton NO <sub>x</sub>
			SNCR for K-5 - \$1,326 (\$920)/ton NO <sub>x</sub>
K-6	142 MW Boiler	Fuel Oil No. 6 with 0.5% maximum sulfur content	SNCR+Combustion Controls for K-1 - \$2,409 (\$1,764)/ton NO <sub>x</sub>
			SNCR+Combustion Controls for K-2 - \$1,982 (\$1,446)/ton NO <sub>x</sub>
			SNCR+Combustion Controls for K-3 - \$2,987 (\$2,077)/ton NO <sub>x</sub>
			SNCR+Combustion Controls for K-4 - \$2,571 (\$1,789)/ton NO <sub>x</sub>
			SNCR+Combustion Controls for K-6 - \$5,962 (\$3,561)/ton NO <sub>x</sub>

- CDS-circulating dry scrubber, LNB-low NO<sub>x</sub> burner, MW-megawatt, OFA-overfire air, SCR-selective catalytic reduction, SNCR-selective noncatalytic reduction, ULSD-ultra-low sulfur diesel, and combustion controls are LNB with OFA and/or FGR.
- For particulate control, the Kahe boilers are subject to a filterable PM standard of 0.030 lb/MMBtu on a thirty-boiler operating day rolling average for non-continental liquid oil-fired units in accordance with EGU MACT standards 40 CFR, Part 63, Subpart UUUUU.
- Annual SNCR cost for Kahe Boiler K1 was used to determine the cost per ton of NO<sub>x</sub> removed by SNCR for Kahe Boiler K2.
- Annual SNCR cost for Kahe Boiler K3 was used to determine the cost per ton of NO<sub>x</sub> removed by SNCR for Kahe Boiler K4.
- According to the four-factor analysis, it is unknown if LNB alone can achieve a controlled NO<sub>x</sub> emission level of 0.30 lb/MMBtu for K1, K2, and K5 and 0.20 lb/MMBtu for K3 and K4. Therefore, costing is based on a range of costs cost for LNB with OFA. The cost of FGR and LNB with FGR are expected to be covered by this range and have similar NO<sub>x</sub> control.

Due to the low relative potential of the Hawaiian Electric Kahe Power Plant to contribute to visibility impairment at the Class I Areas as identified in the WEP/AOI analysis after initial Q/d screening, control measures identified in the four-factor analysis to be cost effective are not required. Note that prevailing trade winds transport pollutants from point sources on Oahu located down-wind of the Class I Areas a majority of the time. Unlike Q/d, the more sophisticated WEP/AOI analysis inherently accounts for meteorological data, such as wind patterns, and the specific light extinction contribution of each particle species.