


**Appendix I: Regional Haze Four-Factor Analysis  
Maui Electric Company, Ltd. Kahului Generating Station**

## **Initial Four – Factor Analysis**



**REGIONAL HAZE FOUR-FACTOR ANALYSIS**  
**Kahului Generating Station**



Prepared By:

J. Stephen Beene – Senior Consultant  
Jeremy Jewell – Principal Consultant

**TRINITY CONSULTANTS**  
12700 Park Central Drive  
Suite 2100  
Dallas, TX 75251

March 2020

Project 194401.0299



*EHS solutions delivered uncommonly well*

## TABLE OF CONTENTS

<b>1. EXECUTIVE SUMMARY</b>	<b>1-1</b>
<b>2. BACKGROUND AND ADDITIONAL FACTORS</b>	<b>2-2</b>
2.1. Regional Haze Rule Background .....	2-2
2.2. Additional Factors.....	2-4
<b>3. SULFUR DIOXIDE FOUR-FACTOR ANALYSIS</b>	<b>3-1</b>
3.1. Sulfur Dioxide Control Options.....	3-1
3.2. Four-Factor Analysis.....	3-2
3.3. Sulfur Dioxide Conclusion .....	3-5
<b>4. NITROGEN OXIDES FOUR-FACTOR ANALYSIS</b>	<b>4-1</b>
4.1. Nitrogen Oxides Control Options .....	4-1
4.2. Four-Factor Analysis.....	4-4
4.3. Nitrogen Oxides Conclusion.....	4-7
<b>5. PARTICULATE MATTER FOUR-FACTOR ANALYSIS</b>	<b>5-1</b>
5.1. Particulate Matter Control Options.....	5-1
5.2. Four-Factor Analysis.....	5-2
5.3. Particulate Matter Conclusion .....	5-5
<b>APPENDIX A: DETAILED COSTING</b>	<b>A-1</b>
<b>APPENDIX B: HAWAIIAN ELECTRIC REGIONAL HAZE VISIBILITY CONSIDERATIONS</b>	<b>B-1</b>
<b>APPENDIX C: HAWAII'S RENEWABLE PORTFOLIO STANDARDS CONTRIBUTION TO REGIONAL HAZE PROGRESS</b>	<b>C-1</b>



## LIST OF TABLES

---

Table 3-1. Baseline SO <sub>2</sub> Emissions	3-1
Table 3-2. SO <sub>2</sub> Cost Effectiveness of Switching to a Residual/Distillate Blended Fuel	3-4
Table 3-3. SO <sub>2</sub> Cost Effectiveness of Switching to Distillate Fuel	3-4
Table 4-1. Baseline NO <sub>x</sub> Emissions	4-1
Table 4-2. Control Effectiveness of Technically Feasible NO <sub>x</sub> Control Technologies	4-4
Table 4-3. NO <sub>x</sub> Cost Effectiveness of LNB with OFA and SCR	4-6
Table 5-1. Baseline PM <sub>10</sub> Emissions	5-1
Table 5-2. PM <sub>10</sub> Cost Effectiveness of Wet ESP, Wet Scrubber and Switching to Distillate Fuel	5-4

## 1. EXECUTIVE SUMMARY

---

The State of Hawai'i has two Class I areas (National Parks) that trigger compliance with the Regional Haze Rule (RHR); Hawai'i's Mandatory Federal Class I Areas are Haleakalā National Park on Maui Island and Hawai'i Volcanoes National Park on the Hawai'i Island. This report documents the results of the RHR second planning period four-factor analysis conducted by Trinity Consultants (Trinity) on behalf of Hawaiian Electric<sup>1</sup> for the four boilers at the Kahului Generating Station (Kahului): K1, K2, K3, and K4. The boilers are each wall-fired and currently burn residual oil. The boilers have nominal ratings of 5.0 megawatts (MW), 5.0 MW, 11.5 MW and 12.5 MW, respectively. Also, Appendix B and Appendix C contain analyses performed by AECOM Technical Services, Inc. (AECOM) of a fifth factor that includes a review of visibility impacts.

This report addresses the options that could be considered that have the potential to lower emissions and show reasonable progress toward the RHR goals. The results of the four-factor analysis herein are consistent with the conclusions reached for the first planning period Best Available Retrofit Technology (BART) five-factor analysis for Kahului. Other long-term emission reduction strategies, such as those included as part of Hawai'i's Renewable Portfolio Standards (RPS), are viable alternatives to emissions reductions from add-on controls and changes in the method of operations.

Hawaiian Electric and AECOM met with the Department of Health (DOH) on February 12, 2020 to present special circumstances applicable in Hawai'i that should be given consideration in the development of the Hawai'i Regional Haze SIP. Significant among those circumstances is Hawai'i's Statutory RPS which have put the state on a timetable to accomplish the same goals as the RHR twenty (20) years before the actual Regional Haze 2064 target date. These same issues were addressed by the EPA in the Federal Implementation Plan (FIP) and the DOH in its Progress Report<sup>2</sup> that was approved by the EPA effective on September 11, 2019. These special considerations are discussed further in Appendix B and Appendix C to this report.

Based on the four-factor analysis, Hawaiian Electric does not propose any emissions reduction measures in addition to its RPS program to meet the RHR requirements.

<sup>1</sup> Hawaiian Electric" or the "Company" refers to Hawaiian Electric Company, Inc. (or "HE"), Hawai'i Electric Light Company, Inc. (or "HL") and/or Maui Electric Company, Limited (or "ME"). On December 20, 2019, the State of Hawai'i Department of Commerce and Consumer Affairs ("DCCA") approved Hawaiian Electric Company, Inc., Hawai'i Electric Light Company, Inc. and Maui Electric Company, Limited's application to do business under the trade name "Hawaiian Electric" for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.

<sup>2</sup> 5-Year Regional Haze Progress Report For Federal Implementation Plan, Hawai'i State Department of Health, October 2017, EPA-R09-OAR-2018-0744-0004.

## 2. BACKGROUND AND ADDITIONAL FACTORS

### 2.1. REGIONAL HAZE RULE BACKGROUND

In the 1977 amendments to the federal Clean Air Act (CAA), the U.S. Congress set a nation-wide goal to restore national parks and wilderness areas to natural visibility conditions by remedying existing, anthropogenic visibility impairment and preventing future impairments. On July 1, 1999, the EPA published the final RHR (40 CFR Part 51, Subpart P). The objective of the RHR is to restore visibility to natural conditions in 156 specific areas across the United States, known as Federal Class I areas. The CAA defines Class I areas as certain national parks (over 6,000 acres), wilderness areas (over 5,000 acres), national memorial parks (over 5,000 acres)<sup>3</sup>, and international parks that were in existence on August 7, 1977.

The RHR requires states to set goals that provide for reasonable progress towards achieving natural visibility conditions for each Class I area in their jurisdiction. In establishing a reasonable progress goal for a Class I area, each state must:

- (A) *Consider the costs of compliance, the time necessary for compliance, the energy and non-air quality environmental impacts of compliance, and the remaining useful life of any potentially affected sources, and include a demonstration showing how these factors were taken into consideration in selecting the goal. 40 CFR 51. 308(d)(1)(i)(A).* This is known as a four-factor analysis.
- (B) *Analyze and determine the rate of progress needed to attain natural visibility conditions by the year 2064. To calculate this rate of progress, the State must compare baseline visibility conditions to natural visibility conditions in the mandatory Federal Class I area and determine the uniform rate of visibility improvement (measured in deciviews) that would need to be maintained during each implementation period in order to attain natural visibility conditions by 2064. In establishing the reasonable progress goal, the State must consider the uniform rate of improvement in visibility and the emission reduction. 40 CFR 51. 308(d)(1)(i)(B).* The uniform rate of progress or improvement is sometimes referred to as the glidepath and is part of the state's Long Term Strategy (LTS).

During the first implementation period the EPA issued a FIP (77 FR 61478, October 9, 2012; see also *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawaii* Air Division U.S. EPA Region 9, May 14, 2012) which determined for the first planning period that nitrogen oxides (NO<sub>x</sub>) was not contributing to regional haze significantly as to require control measures, and that the Oahu sources were not significantly contributing to regional haze. Additionally, as part of the EPA's decision with respect to BART controls, the EPA took into account that controls would result in "unduly increasing electricity rates in Hawai'i." (see 77 FR 31707, May 29, 2012).

The control measures that were imposed established an emissions cap of 3,550 tons of sulfur dioxide (SO<sub>2</sub>) per year from the fuel oil-fired boilers at Hawai'i Electric Light's Hill, Shipman and Puna generating stations, beginning in January 1, 2018, at an estimated cost of 7.9 million dollars per year. According to the FIP, this represents a reduction of 1,400 tons per year from the total projected 2018 annual emissions of SO<sub>2</sub> from these facilities. This control measure, in conjunction with SO<sub>2</sub> and NO<sub>x</sub> emissions control requirements that are already in place, was found to ensure that reasonable progress

<sup>3</sup> The Class I areas in the state of Hawai'i include the Hawai'i Volcanoes National Park on the Hawai'i Island, and Haleakalā National Park on Maui.

is made during this first planning period toward the national goal of no anthropogenic visibility impairment by 2064 at Hawai'i's two Class I areas.

The second implementation planning period (2019-2028) for the national regional haze efforts is currently underway. The EPA's *Guidance on Regional Haze State Implementation Plans for the Second Implementation Period* (SIP Guidance)<sup>4</sup> provides guidance for the development of the implementation plans. There are a few key distinctions from the processes that took place during the first planning period (2004-2018). Most notably, the second planning period analysis distinguishes between natural (or "biogenic") and manmade (or "anthropogenic") sources of emissions. EPA's *Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program* (Visibility Guidance)<sup>5</sup> provides guidance to states on methods for selecting the twenty (20) percent most impaired days to track visibility and determining natural visibility conditions. The approach described in this guidance document does not expressly attempt to account for haze formed from natural volcanic emissions; however, the 2017 RHR defines visibility impairment or anthropogenic visibility impairment as:

*any humanly perceptible difference due to air pollution from anthropogenic sources between actual visibility and natural visibility on one or more days. Because natural visibility can only be estimated or inferred, visibility impairment also is estimated or inferred rather than directly measured.*

EPA's Visibility Guidance states that although they did not attempt to account for haze formed by natural volcanic emissions:

*We encourage states with Class I areas affected by volcanic emissions to work with their EPA Regional office to determine an appropriate approach for determining which days are the 20 percent most anthropogenically impaired days.*

In the *5-Year Regional Haze Progress Report For Federal Implementation Plan*<sup>6</sup> the DOH acknowledges the impact of SO<sub>2</sub> from the Kilauea volcano with the following statement:

*A majority of the visibility degradation is due to the ongoing release of SO<sub>2</sub> from Kilauea volcano with emissions that vary by hundreds of thousands of tons from one year to another. Visibility improvement from significant reductions in Maui and Hawaii Island point source SO<sub>2</sub> is obscured by sulfate from natural volcanic SO<sub>2</sub> that overwhelms sulfate from anthropogenic SO<sub>2</sub> sources.*

Step 1 of the EPA's SIP Guidance is to identify the twenty (20) percent most anthropogenically impaired days and the twenty (20) percent clearest days and determine baseline, current, and natural visibility conditions for each Class I area within the state (40 CFR 51.308(f)(1)). Hawaiian Electric has concerns that this key step may not be accounted for during the second implementation planning and the development of Hawai'i's RHR SIP. The identification of the twenty (20) percent most impaired days sets the foundation for identifying any needed emission reductions.

Pursuant to 40 CFR 51.308(d)(3)(iv), the states are responsible for identifying the sources that contribute to the most impaired days in the Class I areas. To accomplish this, the Western Regional Air Partnership (WRAP), with Ramboll US Corporation, reviewed the 2014 National Emissions Inventory (NEI) and assessed each facility's impact on visibility in Class I areas with a "Q/d" analysis, where "Q" is the magnitude of emissions that impact ambient visibility and "d" is the distance of a facility to a Class I

<sup>4</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, August 2019, EPA-457/B-19-003.

<sup>5</sup> Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program, EPA-454/R-18-010, December 2018.

<sup>6</sup> 5-Year Regional Haze Progress Report For Federal Implementation Plan, Hawai'i State Department of Health, October 2017, EPA-R09-OAR-2018-0744-0004.

area. The WRAP Guidance itself states that EPA has concerns over only relying on the Q/d method for screening sources. The EPA points out that the Q/d metric is only a rough indicator of actual visibility impact because it does not consider transport direction/pathway and dispersion and photochemical processes. To address the EPA's concern, the WRAP subcommittee recommends a second step, application of the weighted emissions potential analysis (WEP), which has not been done.<sup>7</sup> On September 11, 2019, the DOH informed Hawaiian Electric that its Kahului Generating Station, among others, was identified, based on the Q/d analysis, as one of the sources potentially contributing to regional haze at the Haleakalā National Park and Volcanoes National Park. This report responds to the DOH September 2019 request to Hawaiian Electric to submit a four-factor analysis.

The SIP Guidance requires that the selection of controls necessary to make reasonable progress must consider the five required factors listed in section 51.308(f)(2)(iv), and other factors that are reasonable to consider. Hawaiian Electric and AECOM prepared summary, included in Section 2.2, which describes special circumstances that apply in Hawai'i that should be considered during the development of the Hawai'i Regional Haze SIP.

## 2.2. Additional Factors

Hawaiian Electric and AECOM met with the DOH on February 12, 2020 to present special circumstances applicable in Hawai'i that should be considered during the development of the Hawai'i Regional Haze SIP. Significant among those circumstances is Hawai'i's Statutory RPS which have put the state on a timetable to accomplish the same goals as the RHR twenty (20) years before the Regional Haze 2064 target date. These same issues were addressed by the EPA in the FIP and the DOH in its Progress Report that was approved by the EPA, effective on September 11, 2019. These special considerations are discussed further in Appendix B and Appendix C to this report and summarized in the following sections.


### 2.2.1. Lack of Contribution to Visibility Impairment Due to Prevailing Winds

As noted, the DOH did not consider actual contribution to visibility impairment when selecting sources for the Four-Factor Analysis, but this is a critical factor in establishing realistic reasonable progress goals for Class I areas. The EPA's FIP for Hawai'i for the First Decadal Review (77 FR 61478, October 9, 2012) has already acknowledged the predominant trade winds in Hawai'i and thus, did not require controls on upwind sources (i.e., sources on Oahu and Maui).

Wind rose plots for airports on Maui and Hawai'i Islands show that the wind is almost always from the northeast and rarely blows from the Kahului Power Plant toward either of Hawai'i's Class I areas. The Kahului airport wind rose plot is provided as Figure 2-1. Based on the infrequent amount of time the wind blows from Kahului Power Plant toward either of Hawai'i's Class I areas, it is unlikely that the facility's potential emissions impact visibility at Haleakalā National Park and Volcanoes National Park. Therefore, when balancing retrofit costs and visibility improvements, the DOH should remain mindful that emissions from this facility are unlikely to contribute to regional haze at Haleakalā National Park and Volcanoes National Park and as such will have no impact on a showing of further reasonable progress.

<sup>7</sup> WRAP Reasonable Progress Source Identification and Analysis Protocol For Second 10-year Regional Haze State Implementation Plans, dated February 27, 2019 (<https://www.wrapair2.org/pdf/final%20WRAP%20Reasonable%20Progress%20Source%20Identification%20and%20Analysis%20Protocol-Feb27-2019.pdf>).

Figure 2-1. Kahului Wind Rose (2015 – 2019) Predominant Wind from the Northeast



### 2.2.2. Lack of Contribution to Visibility Impairment Due to Warm Weather Conditions

The potential for the formation of haze due to  $\text{NO}_x$  emissions is very low in Hawai'i because of the warm weather conditions year-round. Nitrate Haze composition analyses for the Haleakalā and Hawai'i Volcanoes National Parks from the IMPROVE web site are included in Appendix B to this report. The data for both national parks show that the contribution of nitrates to haze is very low. It is low as a percentage of the total haze composition, but it is also low as an absolute value for extinction (visibility impairment). The minimal impact of nitrate haze is clearly illustrated in the Hawai'i National Park monitoring data and is much lower than found at many monitors in other Class I areas around the country. This is in large part due to the unique chemistry of nitrate haze which is discussed further in Appendix B to this report.

Due to the low haze impact of  $\text{NO}_x$ , the DOH should not consider  $\text{NO}_x$  controls for the Second Decadal Review for Kahului. A similar conclusion was reached during the First Decadal Review, for which the EPA did not consider  $\text{NO}_x$  controls to be material.

### 2.2.3. Contribution to Visibility Impairment from Volcanic Activity

Volcanic activity on the Hawai'i Island represents a unique challenge to understanding haze in Hawai'i Class I areas. The Kilauea volcano on Hawai'i Island has been active for several years, and the levels of  $\text{SO}_2$  emissions are being monitored by the United States Geological Survey. In addition to volcanoes being large sources of  $\text{SO}_2$ , they also emit significant amounts of  $\text{NO}_x$ . It should also be noted that volcanic activity on Hawai'i Island is the largest source of  $\text{NO}_x$  in the state. Nitrate haze is a very small component in Hawai'i's Class I areas, which is expected given the nitrate chemistry as explained in Appendix B to this report. Direct particulate matter (PM) emissions constitute a very small portion of haze and significant portions are due to volcanic emissions as explained in Appendix B to this report. Visibility improvements made from significant reductions of point source  $\text{SO}_2$  in Maui and Hawai'i Island is obscured by sulfate from natural volcanic  $\text{SO}_2$  that overwhelms sulfate from anthropogenic  $\text{SO}_2$

sources. Anthropogenic sources (from power plants) are projected to be phased out well before the end point of the Regional Haze Rule (i.e., 2064) by Hawai'i's State Law: Renewable Portfolio Standards (RPS). Thus, the DOH should not consider PM or SO<sub>2</sub> controls for the Second Decadal Period Review for Kahului.

#### **2.2.4. Renewable Portfolio Standards**

Based on AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, SO<sub>2</sub>, NO<sub>x</sub>, and particulate matter, 10 microns or less in diameter (PM<sub>10</sub>) emissions from the Kahului boilers do not significantly contribute to regional haze. The low impact that Kahului may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the Hawai'i Clean Energy Initiative (HCEI). Both past and projected future decreases in fossil-fueled electric generating unit (EGU) usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1), it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

### 3. SULFUR DIOXIDE FOUR-FACTOR ANALYSIS

AECOM’s analysis, *Appendix C: Hawai‘i’s Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that SO<sub>2</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. However, the four-factor analysis is provided in response to DOH’s request. The first step in the analysis is to establish a baseline for emissions. Per DOH’s letter dated September 11, 2019, calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 3-1 lists the baseline SO<sub>2</sub> emissions for Kahului.

**Table 3-1. Baseline SO<sub>2</sub> Emissions**

Unit	Fuel Sulfur <sup>A</sup>	SO <sub>2</sub> Emissions	
		(lb/MMBtu) <sup>B</sup>	(TPY) <sup>C</sup>
K1	1.69%	1.87	293.1
K2	1.69%	1.87	253.3
K3	1.69%	1.87	898.5
K4	1.69%	1.87	775.8
<b>Total</b>			<b>2,220.7</b>

<sup>A</sup> Calendar year 2017 annual average residual oil sulfur content.

<sup>B</sup> The SO<sub>2</sub> emission factors are based on 100% conversion of fuel sulfur to SO<sub>2</sub> and the calendar year 2017 annual average residual oil fuel density (8.34 lb/gal) and higher heating value (151,009 Btu/gal).

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

#### 3.1. SULFUR DIOXIDE CONTROL OPTIONS

The characterization of emission controls available and applicable to the source is a necessary step before the four-factors can be analyzed. SO<sub>2</sub> emissions are generated during fuel oil combustion from the oxidation of sulfur contained in the fuel. Available SO<sub>2</sub> control technologies for the boilers are:

- Flue Gas Desulfurization (FGD)
  - Dry Sorbent Injection (DSI)
  - Spray Dryer Absorber (SDA)
  - Wet Scrubber
  - Circulating Dry Scrubber (CDS)
- Fuel Switching
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.

##### 3.1.1. Post-Combustion Controls

FGD applications have not been used historically for SO<sub>2</sub> control on oil-fired boilers the size of those operated at the Kahului Generating Station. As there are no known FGD applications for similar oil-fired boilers, the performance of FGDs on oil-fired boilers is unknown. The EPA took this into account when evaluating the Best Available Retrofit Technology (BART) presumptive SO<sub>2</sub> emission rate for oil-fired units and determined that the presumptive emission rate should be based on the sulfur content of the



fuel oil, rather than on FGD<sup>8</sup>. Since there are no applications of FGD on oil-fired boilers in the U.S., FGDs are considered technically infeasible for the control of SO<sub>2</sub> from the Kahului boilers.

### 3.1.2. Fuel Switching

The Kahului boilers currently burn residual high sulfur fuel oil with a maximum sulfur content of 2.0 percent by weight. The average sulfur content of the residual high sulfur fuel oil purchased in 2017 was approximately 1.69 percent by weight. Switching to a lower sulfur fuel if technically and economically feasible would reduce SO<sub>2</sub> emissions in proportion to the reduction in fuel sulfur content.<sup>9</sup>

On Oahu, 0.5 percent by weight low sulfur fuel oil is produced and is used at Hawaiian Electric's Kahe and Waiau Generating Stations on Oahu. However, it is not a technically feasible option for Kahului. This low sulfur fuel oil has a higher viscosity and pour point than the high sulfur fuel oil used at Kahului and the current fuel supply chain from Oahu to Kahului cannot support this quality of fuel that is semi-solid at ambient temperatures. For the low sulfur fuel oil to be burned at Kahului, the piping and tanks that are used to transport and store the oil would need to be heated, at a cost of 500 thousand dollars (\$500,000) to 1 million dollars (\$1,000,000), which is not economically feasible because of the very limited remaining time that fuel oil will be burned at Kahului. There are, however, technically feasible options which include blending the current high sulfur fuel oil with a lower sulfur distillate fuel or switching to a lower sulfur distillate fuel. The SO<sub>2</sub> four-factor analysis will evaluate both options.

### 3.1.3. Renewable Portfolio Standards

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that SO<sub>2</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. The low impact that Kahului may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the HCEI. Both past and projected future decreases in fossil-fueled EGU usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1) it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

## 3.2. FOUR-FACTOR ANALYSIS

As discussed above, fuel switching to a residual/distillate blended fuel or a lower sulfur diesel is the only technically feasible option to reduce SO<sub>2</sub> emissions. For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and

<sup>8</sup> *Summary of Comments and Responses on the 2004 and 2001 Proposed Guidelines for Best Available Retrofit Technology (BART) Determinations Under the Regional Haze Regulations*, EPA Docket Number OAR-2002-0076.

<sup>9</sup> Natural gas has less sulfur than the existing residual fuel oil. However, natural gas is not a technically feasible option because there is no natural gas supply in Hawai'i.

4. The remaining useful life of any existing source subject to such requirements.

The four factors for switching to a lower sulfur residual/distillate blended fuel, or a lower sulfur diesel are discussed in the following sections.

### **3.2.1. Cost of Compliance**

The cost effectiveness of the fuel switching was determined by calculating the annual incremental cost of switching to a lower sulfur fuel divided by the reduction in SO<sub>2</sub> emissions. Switching fuel would require changes to the injectors and the fuel system; however, these expenses were not included in the analysis.

Kahului currently purchases high sulfur fuel oil from Par Hawaii Refining, LLC; current fuel costs are based on 2019 actual fuel purchases. The fuels are refined on Oahu and changes in quantities of high sulfur fuel oil and distillates fuels would require new contracts with fuel suppliers. This adds a level of uncertainty to the cost of compliance.

Table 3-2 presents a summary of the cost effectiveness of switching from a high sulfur fuel oil to high sulfur fuel oil/diesel blend with a maximum sulfur content of 1.0 percent by weight. The cost effectiveness is determined by dividing the annual cost increase in fuel by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of switching to a residual/distillate blended fuel with a maximum sulfur content of 1.0 percent by weight is \$8,234 per ton of SO<sub>2</sub> and would increase fuel cost 8 million dollars (\$8,000,000) annually and 120 million dollars over fifteen (15) years.

Table 3-3 presents a summary of the cost effectiveness of switching from residual fuel to distillate fuel with a maximum sulfur content of 0.4 percent by weight. The cost effectiveness is determined by dividing the annual cost increase in fuel by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of switching to a distillate fuel with a maximum sulfur content of 0.4 percent by weight is \$7,669 per ton of SO<sub>2</sub> and would increase fuel cost 13.3 million dollars (\$13,300,000) annually and 199.5 million dollars (\$199,500,000) over fifteen (15) years.

### **3.2.2. Time Necessary to Achieve Compliance**

If the DOH determines that switching from residual oil to a residual/distillate blended fuel or a lower sulfur diesel is needed to achieve reasonable progress, it is anticipated that this change could be implemented within two to three years.

### **3.2.3. Energy and Non-Air Quality Environmental impacts**

There are no energy and non-air quality environmental impacts of compliance for fuel switching. The cost increase associated with fuel switching to a lower sulfur fuel will increase the cost of the electricity produced by Kahului and directly impact the price of electricity for Maui Electric customers.

### **3.2.4. Remaining Useful Life**

The cost of compliance does not contain any capital cost. Therefore, the remaining useful lives of the Kahului boilers are not needed to annualize the capital cost. However, Hawaiian Electric intends to retire its four Kahului boilers following the addition of replacement capacity (currently planned to be in the form of energy storage) and a new switchyard in central Maui, both of which are currently anticipated to be completed in the 2023 to 2024 timeframe.

**Table 3-2. SO<sub>2</sub> Cost Effectiveness of Switching to a Residual/Distillate Blended Fuel**

Unit	Current Residual Oil <sup>A</sup>					Residual/Distillate Blend (1.0% maximum Sulfur) <sup>B</sup>						
	2017	Fuel	Annual	2017	2017	Fuel	Annual	Controlled	SO <sub>2</sub>	Fuel Cost	SO <sub>2</sub>	
	Average Sulfur Content (%)	Heating Value (HHV) (Btu/gal)	Fuel Usage (gal/yr)	Annual Heat Input (MMBtu/yr)	SO <sub>2</sub> Emissions (tpy)	Heating Value (HHV) (Btu/gal)	Fuel Usage (gal/yr)	SO <sub>2</sub> Emissions (tpy)	Reduced (tpy)	Differential <sup>C</sup> (\$/Gal) (\$/year)	Cost Effectiveness (\$/ton)	
K1	1.69%	151,009	2,075,864	313,473	293.1	142,359	2,201,991	164.73	128.37	0.48	1,056,956	8,234
K2	1.69%	151,009	1,793,982	270,907	253.3	142,359	1,902,983	142.36	110.94	0.48	913,432	8,234
K3	1.69%	151,009	6,363,573	960,954	898.5	142,359	6,750,218	504.98	393.52	0.48	3,240,105	8,234
K4	1.69%	151,009	5,494,558	829,725	775.8	142,359	5,828,402	436.02	339.78	0.48	2,797,633	8,234

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on a blend of 37.5% residual oil and 62.5% diesel fuel and the weighted average of the 2017 fuel HHV and density and contract fuel sulfur limits (2.0% for residual oil and 0.4% for diesel).

<sup>C</sup> Based on actual 2019 fuel purchases by Maui Electric.

**Table 3-3. SO<sub>2</sub> Cost Effectiveness of Switching to Distillate Fuel**

Unit	Current Residual Oil <sup>A</sup>					Diesel (0.4% maximum Sulfur) <sup>B</sup>						
	2017	Fuel	Annual	2017	2017	Fuel	Annual	Controlled	SO <sub>2</sub>	Fuel Cost	SO <sub>2</sub>	
	Average Sulfur Content (%)	Heating Value (HHV) (Btu/gal)	Fuel Usage (gal/yr)	Annual Heat Input (MMBtu/yr)	SO <sub>2</sub> Emissions (tpy)	Heating Value (HHV) (Btu/gal)	Fuel Usage (gal/yr)	SO <sub>2</sub> Emissions (tpy)	Reduced (tpy)	Differential <sup>C</sup> (\$/Gal) (\$/year)	Cost Effectiveness (\$/ton)	
K1	1.69%	151,009	2,075,864	313,473	293.1	137,169	2,285,312	63.64	229.46	0.77	1,759,690	7,669
K2	1.69%	151,009	1,793,982	270,907	253.3	137,169	1,974,990	54.99	198.31	0.77	1,520,742	7,669
K3	1.69%	151,009	6,363,573	960,954	898.5	137,169	7,005,638	195.07	703.43	0.77	5,394,342	7,669
K4	1.69%	151,009	5,494,558	829,725	775.8	137,169	6,048,942	168.43	607.37	0.77	4,657,685	7,669

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on 2017 average HHV and density and contract diesel sulfur limit (0.4%).

<sup>C</sup> Based on actual 2019 fuel purchases by Maui Electric.

### 3.3. SULFUR DIOXIDE CONCLUSION

The cost effectiveness of switching to a residual/distillate blended fuel with a maximum sulfur content of 1.0 percent by weight is \$8,200 per ton of SO<sub>2</sub> and would increase fuel cost 8 million dollars (\$8,000,000) annually and 120 million dollars (\$120,000,000) over fifteen (15) years. The cost effectiveness of switching to a distillate fuel with a maximum sulfur content of 0.4 percent by weight is \$7,700 per ton of SO<sub>2</sub> and would increase fuel cost 13 million dollars (\$13,300,000) annually and 199.5 million dollars (\$199,500,000) over fifteen (15) years. These costs are greater than the BART and reasonable progress thresholds established in the first planning period of \$5,600 per ton of SO<sub>2</sub> and \$5,500 per ton of SO<sub>2</sub>, respectively.<sup>10</sup> Thus, no fuel changes or add-on controls are proposed.

While there are no fuel changes or add-on controls proposed, other long-term emission reduction strategies, such as those included as part of the Hawai'i RPS, may be viable alternatives that would create greater benefits.

<sup>10</sup> *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawai'i*, U.S. EPA Region 9, May 14, 2012.

## 4. NITROGEN OXIDES FOUR-FACTOR ANALYSIS

AECOM's analysis, *Appendix C: Hawaii's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that NO<sub>x</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. However, the four-factor analysis is provided in response to DOH's request. The first step in the analysis is to establish a baseline for emissions. Per DOH's letter dated September 11, 2019, calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 4-1 lists the baseline NO<sub>x</sub> emissions for Kahului.

**Table 4-1. Baseline NO<sub>x</sub> Emissions**

Unit	NO <sub>x</sub> Emissions		(TPY) <sup>C</sup>
	Residual Oil Emissions Factor	Adjusted Emission Factor	
	(lb/MMBtu) <sup>A</sup>	(lb/MMBtu) <sup>B</sup>	
K1	0.420	0.420	65.8
K2	0.460	0.460	62.3
K3	0.609	0.609	292.6
K4	0.436	0.440	182.7
<b>Total</b>			<b>603.4</b>

<sup>A</sup> Calendar year 2017 emission factors from the 2018 Emissions Fee Report.

<sup>B</sup> The adjusted emission factors include emissions from the ignition fuels and used oil.

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

### 4.1. NITROGEN OXIDES CONTROL OPTIONS

The characterization of emission controls available and applicable to the source is a necessary step before the four-factors can be analyzed. NO<sub>x</sub> emissions are produced during fuel combustion when nitrogen contained in the fuel and combustion air is exposed to high temperatures. The origin of the nitrogen (i.e., fuel versus combustion air) has led to the use of the terms "thermal NO<sub>x</sub>" and "fuel NO<sub>x</sub>". Thermal NO<sub>x</sub> emissions are produced when elemental nitrogen in the combustion air is oxidized by high combustion temperatures. Fuel NO<sub>x</sub> emissions are created by the oxidation of nitrogen contained in the fuel. NO<sub>x</sub> emissions from residual oil can be up to fifty percent fuel NO<sub>x</sub>.<sup>11</sup>

The formation of NO<sub>x</sub> compounds in utility boilers is sensitive to the method of firing and combustion controls utilized. Nitrogen oxide (NO) is typically the predominant form of NO<sub>x</sub> emissions from fossil fuel combustion, with the remaining NO<sub>x</sub> being the form nitrogen dioxide (NO<sub>2</sub>). The NO<sub>2</sub>/NO<sub>x</sub> in-stack ratio for boilers is typically less than ten percent.

Available NO<sub>x</sub> control technologies for the boilers are categorized as combustion or post-combustion controls. Combustion controls reduce the peak flame temperature and excess air in the furnace, which minimizes NO<sub>x</sub> formation. Post-combustion controls convert NO<sub>x</sub> in the flue gas to molecular nitrogen and water. Available NO<sub>x</sub> control technologies for the boilers are:

- Combustion Controls
  - Flue Gas Recirculation (FGR)

<sup>11</sup> AP-42, Fifth Edition, Volume I, Chapter 1, Section 1.3.3.

- Overfire Air (OFA)
- Low NO<sub>x</sub> Burners (LNB)
- Post-Combustion Controls
  - Selective Catalytic Reduction (SCR)
  - Selective Non-Catalytic Reduction (SNCR)
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.

#### 4.1.1. Combustion Controls

##### 4.1.1.1. Flue Gas Recirculation (FGR)

FGR uses flue gas as an inert material to reduce flame temperatures. In a typical FGR system, flue gas is collected from the combustion chamber or stack and returned to the burner via a duct and blower. The addition of flue gas reduces the oxygen content of the “combustion air” (air + flue gas) in the burner. The lower oxygen level in the combustion zone reduces flame temperatures, which in turn reduces thermal NO<sub>x</sub> formation. When operated without additional controls, the NO<sub>x</sub> control range for wall-fired boilers with FGR is approximately 0.25-0.30 lb/MMBtu.<sup>12</sup> This control is a technically feasible option for the Kahului boilers.

##### 4.1.1.2. Overfire Air (OFA)

OFA diverts a portion of the total combustion air from the burners and injects it through separate air ports above the top level of burners. Staging of the combustion air creates an initial fuel-rich combustion zone with a lower peak flame temperature. This reduces the formation of thermal NO<sub>x</sub> by lowering combustion temperature and limiting the availability of oxygen in the combustion zone where NO<sub>x</sub> is most likely to be formed. OFA as a single NO<sub>x</sub> control technique results in estimated NO<sub>x</sub> emissions for wall-fired boilers of 0.30-0.45 lb/MMBtu.<sup>13</sup> This control is a technically feasible option for the Kahului boilers.

##### 4.1.1.3. Low NO<sub>x</sub> Burners (LNB)

LNB technology utilizes advanced burner design to reduce NO<sub>x</sub> formation through the restriction of oxygen, lowering of flame temperature, and/or reduced residence time. In the primary zone, NO<sub>x</sub> formation is limited by either one of two methods. Under staged fuel-rich conditions, low oxygen levels limit flame temperatures resulting in less NO<sub>x</sub> formation. The primary zone is then followed by a secondary zone in which the incomplete combustion products formed in the primary zone act as reducing agents. Alternatively, under staged fuel-lean conditions, excess air will reduce flame temperature to reduce NO<sub>x</sub> formation. In the secondary zone, combustion products formed in the primary zone act to lower the local oxygen concentration, resulting in a decrease in NO<sub>x</sub> formation.

The estimated NO<sub>x</sub> control range for LNBs on wall-fired boilers is 0.25-0.35 lb/MMBtu.<sup>14</sup> When combined with OFA, the estimated NO<sub>x</sub> control range on wall-fired boilers is 0.25-0.30 lb/MMBtu.<sup>15</sup> LNB systems are technically feasible for the Kahului boilers.

<sup>12</sup> *Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler*, EPA, 1994.

<sup>13</sup> *Ibid.*



<sup>14</sup> *Ibid.*

<sup>15</sup> *Ibid.*

## 4.1.2. Post Combustion Controls

### 4.1.2.1. Selective Catalytic Reduction (SCR)

SCR refers to the process in which NO<sub>x</sub> is reduced by ammonia over a heterogeneous catalyst in the presence of oxygen. The process is termed selective because the ammonia preferentially reacts with NO<sub>x</sub> rather than oxygen, although the oxygen enhances the reaction and is a necessary component of the process. The overall reactions are:



The SCR process requires a reactor, catalyst, ammonia storage, and an ammonia injection system. The effectiveness of an SCR system is dependent on a variety of factors, including the inlet NO<sub>x</sub> concentration, the exhaust temperature, the ammonia injection rate, and the type of catalyst. The estimated NO<sub>x</sub> control range for SCR is 0.05-0.10 lb/MMBtu.<sup>16</sup> When coupled with LNB plus OFA, the estimated NO<sub>x</sub> control range is 0.03 – 0.10 lb/MMBtu.<sup>17</sup> This control is a technically feasible option for the Kahului boilers.

### 4.1.2.2. Selective Non-Catalytic Reduction (SNCR)

In SNCR systems, a reagent (ammonia or urea) is injected into the flue gas in the furnace within an appropriate temperature window. The NO<sub>x</sub> and reagent react to form nitrogen and water. A typical SNCR system consists of reagent storage, multi-level reagent-injection equipment, and associated control instrumentation. The SNCR reagent storage and handling systems are similar to those for SCR systems. However, both ammonia- and urea-based SNCR processes require three or four times as much reagent as SCR systems to achieve similar NO<sub>x</sub> reductions. The estimated NO<sub>x</sub> control range for SNCR is 0.3-0.4 lb/MMBtu.<sup>18</sup> This control is a technically feasible option for the Kahului boilers.

## 4.1.3. Renewable Portfolio Standards

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that NO<sub>x</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. The low impact that Kahului may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the HCEI. Both past and projected future decreases in fossil-fueled EGU usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1) it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

<sup>16</sup> Ibid.

<sup>17</sup> Ibid.

<sup>18</sup> Ibid.

#### 4.1.4. Rank of Technically Feasible NO<sub>x</sub> Control Options by Effectiveness

The next step is to rank the technically feasible options according to effectiveness. Table 4-2 provides a ranking of the control levels for the controls listed in the previous section.

**Table 4-2. Control Effectiveness of Technically Feasible NO<sub>x</sub> Control Technologies**

Control Technology	Estimated Controlled
	Level (lb/MMBtu)
SCR	0.05 - 0.10
LNB & OFA	0.25 - 0.30
FGR	0.25 - 0.30
LNB	0.25 - 0.35
SNCR	0.30 - 0.40
OFA	0.30 - 0.45

The control levels in Table 4-2 are presented as a range because the specific level of control that is achievable for the Kahului boilers based on the application of the controls listed in Table 4-2 is unknown. Based on several discussions between Trinity and a firm that designs LNB combustion systems, it is believed that combustion controls such as LNB and possibly LNB in combination with OFA or FGR can achieve a NO<sub>x</sub> emissions level of approximately 0.30 lb/MMBtu at the Kahului boilers. As noted in Table 4-1, the Kahului boilers are currently emitting in the range of 0.42 lb/MMBtu to 0.61 lb/MMBtu. Further, it is believed that SCR can achieve a NO<sub>x</sub> emissions level of approximately 0.10 lb/MMBtu.

## 4.2. FOUR-FACTOR ANALYSIS

As discussed above, LNB and SCR together are the best feasible option to reduce NO<sub>x</sub> emissions. For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors for adding LNB and SCR are discussed in the following sections.

### 4.2.1. Cost of Compliance

For purposes of this four-factor analysis, the capital costs, operating costs, and cost effectiveness of LNB with OFA and SCR have been estimated. The cost effectiveness of LNB with OFA is based on a controlled NO<sub>x</sub> emissions level of 0.30 lb/MMBtu. At this time, it is unknown if LNBs alone can achieve this level of emissions or if LNB combined with OFA or FGR would be required to meet this level. Therefore, the costing is based on LNB with OFA, it is assumed that a NO<sub>x</sub> emissions level of 0.30 lb/MMBtu can be achieved with LNB with OFA. As the level of NO<sub>x</sub> emissions is comparable to SNCR combustion controls, the only add-on control that would be expected to result in lower achievable NO<sub>x</sub> emissions rates than combustion controls is SCR.



The cost effectiveness of SCR is based on a controlled NO<sub>x</sub> emissions level of 0.10 lb/MMBtu. The SCR costing is based on generic EPA control costing<sup>19</sup> which does not consider Hawai'i's remote location which results in additional shipping and higher construction cost. To account for these higher costs, a Maui construction cost multiplier<sup>20</sup> of 1.938 was applied to the capital SCR cost.

Table 4-3 presents a summary of the cost effectiveness of adding LNB with OFA and SCR. The cost effectiveness is determined by dividing the annual cost by the annual reduction in NO<sub>x</sub> emissions. The cost effectiveness of LNB with OFA ranges from \$1,153 per ton to \$5,417 per ton of NO<sub>x</sub> and the total cost equals 500 thousand dollars (\$500,000) annually and 7.5 million dollars (\$7,500,000) over fifteen (15) years. The cost effectiveness of SCR ranges from \$4,271 per ton to \$12,428 per ton of NO<sub>x</sub> and the total cost equals 3.3 million dollars (\$3,300,000) annually and 49.5 million dollars (\$49,500,000) over fifteen (15) years.

These cost ranges assume that the capital costs will be amortized over fifteen (15) years. However, Hawaiian Electric intends to retire its four Kahului boilers following the addition of replacement capacity (currently planned to be in the form of energy storage) and a new switchyard in central Maui, both of which are currently anticipated to be completed in the 2023 to 2024 timeframe. Thus, the amortization period will be significantly less than fifteen (15) years and the cost of removal correspondingly higher.

#### **4.2.2. Time Necessary to Achieve Compliance**

If the DOH determines that controls are needed to achieve reasonable progress goals, it is anticipated that this change could be implemented in three to five years.

#### **4.2.3. Energy and Non-Air Quality Environmental impacts**

SCR systems require electricity to operate the ancillary equipment. The need for electricity to help power some of the ancillary equipment creates a demand for energy that currently does not exist.

SCR can potentially cause significant environmental impacts related to the storage of ammonia, and the storage of aqueous ammonia above 10,000 pounds is regulated because of its potential health hazard by the EPA's Risk Management Program (RMP) because the accidental release of ammonia has the potential to cause serious injury and death to persons in the vicinity of the release. SCR will likely also cause the release of unreacted ammonia to the atmosphere. This is referred to as ammonia slip. Ammonia slip from SCR systems occurs either from ammonia injection at temperatures too low for effective reaction with NO<sub>x</sub>, leading to an excess of unreacted ammonia, or from over-injection of reagent leading to uneven distribution, which also leads to an excess of unreacted ammonia. Ammonia released from SCR systems will react with sulfates and nitrates in the atmosphere to form ammonium sulfate and ammonium nitrate. Together, ammonium sulfate and ammonium nitrate are the predominant sources of regional haze.

<sup>19</sup> Assessment of Non-EGU NO<sub>x</sub> Emission Controls, Cost of Controls, and Time for Compliance, Technical Support Document (TSD) for the Cross-State Air Pollution Rule for the 2008 Ozone NAAQS. Docket ID No. EPA-HQ-OAR-2015-0500, November 2015.

<sup>20</sup> The Maui construction cost multiplier is based on cost of construction geographical multipliers from the *RMeans Mechanical Cost Data 2016* to account for factors unique to Maui's location plus an additional factor to account for additional Hawaiian Electric loadings and overhead.

**Table 4-3. NO<sub>x</sub> Cost Effectiveness of LNB with OFA and SCR**

<b>Unit</b>	<b>Control Option</b>	<b>2017 NO<sub>x</sub> Emissions (tpy)</b>	<b>Controlled Emission Level<sup>A</sup> (lb/MMBtu)</b>	<b>2017 Annual Heat Input (MMBtu/yr)</b>	<b>Controlled NO<sub>x</sub> Emissions (tpy)</b>	<b>NO<sub>x</sub> Reduced (ton/yr)</b>	<b>Total Annual Cost<sup>B</sup> (\$/yr)</b>	<b>Cost Effectiveness (\$/ton)</b>
K1	LNB+OFA	65.8	0.30	313,473	47.0	18.8	101,720	5,417
	SCR	65.8	0.10	313,473	15.7	50.1	602,078	12,011
K2	LNB+OFA	62.3	0.30	270,907	40.6	21.7	102,323	4,723
	SCR	62.3	0.10	270,907	13.5	48.8	605,910	12,428
K3	LNB+OFA	292.6	0.30	960,954	144.1	148.5	171,148	1,153
	SCR	292.6	0.10	960,954	48.0	244.6	1,044,439	4,271
K4	LNB+OFA	182.7	0.30	829,725	124.5	58.2	172,145	2,956
	SCR	182.7	0.10	829,725	41.5	141.2	1,031,246	7,303

<sup>A</sup> Controlled emission levels based on "Alternative Control Techniques (ACT) Document - NO<sub>x</sub> Emissions from Utility Boiler" EPA, 1994.

<sup>B</sup> See Appendix A for total annual cost calculations.

#### 4.2.4. Remaining Useful Life

The remaining useful lives of the boilers do not impact the annualized capital costs of potential controls because the useful life of the boilers is assumed to be longer than the capital cost recovery period, which is fifteen (15) years, for this four-factor analysis. However, Hawaiian Electric intends to retire its four Kahului boilers following the addition of replacement capacity (currently planned to be in the form of energy storage) and a new switchyard in central Maui, both of which are currently anticipated to be completed in the 2023 to 2024 timeframe. This will significantly shorten the time the control equipment is used and increase the removal cost per ton.

### 4.3. NITROGEN OXIDES CONCLUSION

The cost effectiveness of LNB with OFA ranges from \$1,200 per ton to \$5,400 per ton of NO<sub>x</sub> and the total cost equals 500 thousand dollars (\$500,000) annually and 7.5 million dollars (\$7,500,000) over fifteen (15) years. These costs are similar to the BART analysis conducted for the first planning period. For the first planning period, the EPA concluded the emission reductions provided by LNB are unlikely to provide a measurable visibility benefit at Hawai'i Volcanoes National Park or Haleakalā National Park.<sup>21</sup>

The cost effectiveness of SCR ranges from \$4,300 per ton to \$12,400 per ton of NO<sub>x</sub> and the total cost equals 3.3 million dollars (\$3,300,000) annually and 49.5 million dollars (\$49,500,000) over fifteen (15) years. These costs are similar to the BART analysis conducted for the first planning period. For the first planning period, the EPA concluded that SCR was not cost effective.<sup>22</sup>

The results of the four-factor analysis are consistent with the conclusions reached for the first planning period. Therefore, Hawaiian Electric does not propose any NO<sub>x</sub> emissions reductions in addition to its RPS program to meet the RHR requirements.

<sup>21</sup> *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawai'i*, U.S. EPA Region 9, May 14, 2012.

<sup>22</sup> *Ibid.*

## 5. PARTICULATE MATTER FOUR-FACTOR ANALYSIS

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that PM<sub>10</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. However, the four-factor analysis is provided in response to DOH's request. The first step in the analysis is to establish a baseline for emissions. Per DOH's letter dated September 11, 2019, calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 5-1 lists the baseline PM<sub>10</sub> emissions for Kahului.

**Table 5-1. Baseline PM<sub>10</sub> Emissions**

Unit	PM <sub>10</sub> Emissions		(TPY) <sup>c</sup>
	Residual Oil Emissions Factor	Adjusted Emission Factor	
	(lb/MMBtu) <sup>A</sup>	(lb/MMBtu) <sup>B</sup>	
K1	0.0933	0.0931	14.6
K2	0.0778	0.0775	10.5
K3	0.0799	0.0799	38.4
K4	0.0495	0.0499	20.7
<b>Total</b>			<b>84.2</b>

<sup>A</sup> Calendar year 2017 emission factors from the 2018 Emissions Fee Report.

<sup>B</sup> The adjusted emission factors include emissions from the ignition fuels and used oil.

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

### 5.1. PARTICULATE MATTER CONTROL OPTIONS

PM<sub>10</sub> emissions depend predominantly on the grade of fuel fired. Combustion of lighter distillate oils results in lower PM<sub>10</sub> emissions than heavier residual oils. Distillate oils have lower ash and sulfur content than residual oil, therefore, producing less PM<sub>10</sub> emissions.

Available PM<sub>10</sub> control technologies for the boilers are:

- Post-Combustion Controls
  - Dry or Wet Electrostatic Precipitator (ESP)
  - Fabric Filters
  - Wet Scrubber
  - Cyclone
- Fuel Switching
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.

#### 5.1.1. Post-Combustion Controls

PM<sub>10</sub> emissions from residual oil-fired boilers tend to be sticky and small. Because of these properties and a general lack of existence in practice, dry ESP, cyclones, and fabric filters are not good technological matches for the Kahului boilers.

A wet ESP operates very similarly to a dry ESP but is a better technological match for oil-fired boilers because it is not sensitive to small and sticky particulates. The wet ESP utilizes water to collect and remove the particles and produces a waste-water product. Flue gas leaving the wet ESP will be saturated and may result in a visual steam plume. The estimated PM<sub>10</sub> control efficiency is up to ninety percent for a wet ESP.<sup>23</sup> Wet ESP is a technically feasible option for control of PM<sub>10</sub> for the Kahului boilers.

In wet scrubbers, PM<sub>10</sub> is removed from flue gas when the gas stream is brought into contact with a scrubbing liquid using several approaches: spraying the gas stream with the liquid, forcing the gas stream through a pool of liquid, or by some other contact method. The PM<sub>10</sub> in the gas stream is captured in the scrubbing liquid. The PM<sub>10</sub>-laden scrubbing liquid is separated from the gas stream, and the resultant scrubbing liquid is treated prior to discharge or reuse in the plant. Problems associated with scrubbers include corrosion issues, high power requirements, and water-disposal challenges. However, the use of wet scrubbers for the Kahului boilers is considered a technically feasible option. The estimated PM<sub>10</sub> removal efficiency for a wet scrubber is fifty to sixty percent.<sup>24</sup>

### 5.1.2. Fuel Switching

Residual oil has inherent ash that contributes to the emissions of filterable PM<sub>10</sub>. Distillate fuels have less ash and ultimately lower filterable PM<sub>10</sub> emissions. Filterable PM<sub>10</sub> emissions could be reduced by switching to distillate fuel. Section 3 discussed the option of fuel switching with respect to reducing SO<sub>2</sub> emissions. As discussed in Section 3, Maui Electric has limited fuel options. Switching to a distillate fuel will result in the PM<sub>10</sub> emissions reductions and is technically feasible.

### 5.1.3. Renewable Portfolio Standards

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that PM<sub>10</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. The low impact that Kahului may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the HCEI. Both past and projected future decreases in fossil-fueled EGU usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1) it was not necessary to review the RPS in the context of the four factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

## 5.2. FOUR-FACTOR ANALYSIS

As discussed above, wet ESPs, wet scrubbers, and switching to distillate fuel are the best feasible options to reduce PM<sub>10</sub> emissions. For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;

<sup>23</sup> AP-42, Fifth Edition, Volume I, Chapter 1, Section 1.3.4.1.

<sup>24</sup> Ibid.

3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors for adding wet ESPs, wet scrubbers, and switching to distillate fuel are discussed in the following sections.

### **5.2.1. Cost of Compliance**

For purposes of this four-factor analysis, the capital costs, operating costs, and cost effectiveness of wet ESPs, wet scrubbers, and switching to distillate fuel have been estimated. The cost effectiveness calculation is based on the following reduction in PM<sub>10</sub> emissions:

- Wet Scrubbers – fifty percent,
- Switching to distillate fuel – sixty-seven percent to eighty-two percent, and
- Wet ESP – ninety percent.

Table 5-2 presents a summary of the cost effectiveness of wet scrubbers, switching to distillate fuel, and wet ESPs. The cost effectiveness ranges are:

- Wet Scrubbers - \$7,500 per ton - \$25,000 per ton and the total cost equals 600 thousand dollars (\$600,000) annually and 9 million dollars (\$9,000,000) over fifteen (15) years,
- Switching to distillate fuel – \$146,000 per ton to \$335,000 per ton and the total cost equals 13.3 million dollars (\$13,300,000) annually and 199.5 million dollars (\$199,500,000) over fifteen (15) years, and
- Wet ESPs - \$44,000 per ton - \$106,000 per ton and the total cost equals 5.3 million dollars (\$5,300,000) annually and 79.5 million dollars (\$79,500,000) over fifteen (15) years.

### **5.2.2. Time Necessary to Achieve Compliance**

If the DOH determines that wet scrubbers or wet ESPs are needed to achieve reasonable progress goals, it is anticipated that this change could be implemented in three to five years. If the DOH determines that switching a distillate fuel is needed to achieve reasonable progress, it is anticipated that this change could be implemented within two to three years.

### **5.2.3. Energy and Non-Air Quality Environmental impacts**

ESPs, by design, apply energy to the particles they are collecting. This energy usage can be significant, especially if the wet ESP is designed to control submicron size particles where more energy is applied to collect more of the particles. Wet scrubbers require a substantial amount of energy to force exhaust gases through the scrubber.

Both wet ESPs and wet scrubbers generate wastewater streams that must either be treated on-site or sent to a wastewater treatment plant. Further, the wastewater treatment process will generate a filter cake that would likely require landfilling.

**Table 5-2. PM<sub>10</sub> Cost Effectiveness of Wet ESP, Wet Scrubber and Switching to Distillate Fuel**

<b>Unit</b>	<b>Control Option</b>	<b>2017 PM<sub>10</sub> Emissions (tpy)</b>	<b>Level of Control<sup>A</sup> (%)</b>	<b>Controlled PM<sub>10</sub> Emissions (tpy)</b>	<b>PM<sub>10</sub> Reduced (ton/yr)</b>	<b>Total Annual Cost<sup>B</sup> (\$/yr)</b>	<b>Cost Effectiveness (\$/ton)</b>
K1	Wet Scrubber	14.6	50	7.3	7.3	132,373	18,133
	Distillate Fuel	14.6	82	2.6	12.0	1,759,690	146,335
	Wet ESP	14.6	90	1.5	13.1	894,530	68,077
K2	Wet Scrubber	10.5	50	5.3	5.3	133,367	25,403
	Distillate Fuel	10.5	79	2.2	8.3	1,520,742	183,782
	Wet ESP	10.5	90	1.1	9.5	886,946	93,857
K3	Wet Scrubber	38.4	50	19.2	19.2	144,436	7,523
	Distillate Fuel	38.4	79	7.9	30.5	5,394,342	176,826
	Wet ESP	38.4	90	3.8	34.6	1,505,961	43,575
K4	Wet Scrubber	20.7	50	10.4	10.4	150,721	14,562
	Distillate Fuel	20.7	67	6.8	13.9	4,657,685	335,462
	Wet ESP	20.7	90	2.1	18.6	1,978,044	106,175

<sup>A</sup> Wet scrubber and wet ESP controlled emission levels based on AP-42, Fifth Edition, Volume I, Chapter 1, Section 1.3.4.1. The controlled emissions level for switching to a distillate fuel is based on the ratio of PM<sub>10</sub> emissions from distillate combustion from AP-42, Tables 1.3-2 and 1.3-6 and the baseline emission factor.

<sup>B</sup> See Appendix A for total annual cost calculations for wet scrubber and wet ESP. The annual cost of switching to a distillate fuel is based on the incremental fuel cost from Table 3-3.

#### 5.2.4. Remaining Useful Life

The remaining useful lives of the boilers do not impact the annualized capital costs of potential controls because the useful life of the boilers is assumed to be at least as long as the capital cost recovery period, which is (15) fifteen years, for this four-factor analysis. However, Hawaiian Electric intends to retire its four Kahului boilers following the addition of replacement capacity (currently planned to be in the form of energy storage) and a new switchyard in central Maui, both of which are currently anticipated to be completed in the 2023 to 2024 timeframe which will significantly shorten the time the control equipment is used and increase the removal cost per ton.

### 5.3. PARTICULATE MATTER CONCLUSION

With the exception of a wet scrubber on K3 which has a cost effectiveness of \$7,500 per ton of PM<sub>10</sub>, the cost effectiveness of the PM<sub>10</sub> controls evaluated for the boilers is more than \$10,000 per ton of PM<sub>10</sub>, and for most controls and boilers is more than \$20,000 per ton of PM<sub>10</sub>. The total cost of PM<sub>10</sub> controls ranges from 600 thousand dollars (\$600,000) annually and 9 million dollars (\$9,000,000) over fifteen (15) years to 13.3 million dollars (\$13,300,000) annually and 199.5 million dollars (\$199,500,000) over fifteen (15) years. These costs are similar to the BART analysis conducted for the first planning period. For the first planning period, the EPA concluded that PM<sub>10</sub> controls were not cost effective.<sup>25</sup>

The results of the four-factor analysis are consistent with the conclusions reached for the first planning period. Therefore, Hawaiian Electric does not propose any PM<sub>10</sub> emissions reductions in addition to its RPS program to meet the RHR requirements.

<sup>25</sup> *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawai'i*, U.S. EPA Region 9, May 14, 2012.



**APPENDIX A: DETAILED COSTING**

---

**Appendix Table A-1. LNB with OFA Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4
Boiler design capacity, mmBtu/hr (C)		94	94	172	181
2017 Annual Heat Input, MMBtu/yr (H)		313,473	270,907	960,954	829,725
Unit Size, kW (kW)		5,900	6,000	12,700	13,000
Unit Size, MW (MW)		5.9	6.0	12.7	13.0
Capital recovery factor a. Equipment CRF, 15-yr life, 7% interest	$= [ I \times (1+i)^a ] / [ (1+i)^a - 1 ]$ , where I = interest rate, a = equipment life	0.11	0.11	0.11	0.11
Cost Index (CI) <sup>A</sup> a. 2018 b. 2004	603.1 444.2				
Total Capital Investment <sup>B,C</sup> TCI (\$) = $\$24/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004})$		\$787,816	\$796,349	\$1,287,795	\$1,307,213
Direct Annual Operating Costs \$/yr Variable O&M Costs <sup>D</sup> = $(\$0.08 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times H \times 10^6 \text{ Btu}/\text{mmBtu} \times (\text{CI}_{2018}/\text{CI}_{2004})$		\$3,405	\$2,943	\$10,438	\$9,012
Indirect Annual Costs, \$/yr 1. Fixed O&M Costs <sup>E</sup> = $\$0.36/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times (300/\text{MW})^{0.359} \times (\text{CI}_{2018}/\text{CI}_{2004})$ 2. Capital recovery = Equipment CRF x TCI		\$11,817 \$86,498	\$11,945 \$87,435	\$19,317 \$141,393	\$19,608 \$143,525
<b>Total Annual Cost \$/yr</b> = Direct Annual Costs + Indirect Annual Costs		<b>\$101,720</b>	<b>\$102,323</b>	<b>\$171,148</b>	<b>\$172,145</b>

**Source:** All costs were estimated using Section 4.3 and Appendix D of the WRAP guidance document, *Analysis of Combustion Controls for Reducing NOx Emissions from Coal-fired EGUs in the WRAP Region*, dated September 6, 2005. The cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). Chemical Engineering Journal.

<sup>B</sup> TCI for LNB and LNB w/over fire air for wall boilers ranges from \$6/kW to \$24/kW, the high end of the range was used due to Hawaii's remote location.

<sup>C</sup> Scaling factor =  $(300/\text{Nameplate capacity})^{0.359}$

<sup>D</sup> The variable O&M costs for LNB and LNB w/over fire air for wall boilers ranges from 0.05 mills/kW-hr to 0.08 mills/kW-hr, the high end of the range was used due to Hawaii's remote location.

<sup>E</sup> The fixed O&M costs for LNB and LNB w/over fire air for wall boilers ranges from \$0.09/kW to \$0.36/kW, the high end of the range was used due to Hawaii's remote location.

**Appendix Table A-2. SCR Capital and O&M Cost Estimate**

	K1	K2	K3	K4
MW	5.9	6.0	12.7	13.0
Baseline NOx Emission Rate (lb/MMBtu)	0.42	0.46	0.61	0.44
2017 Annual Heat Input, MMBtu/yr	313,473	270,907	960,954	829,725
Max Heat Input (MMBtu/hr)	94	94	172	181
Capital Recovery Factor (CRF)	0.11	0.11	0.11	0.11
Cost Index <sup>A</sup>				
2018	603.1			
1999	390.6			
B = (lb/MMBtu)	0.42	0.46	0.61	0.44
C = (%)	90	90	90	90
A = (kW)	5,900	6,000	12,700	13,000
Z (Eq. 1) =	0.90	0.90	0.92	0.90
Capital Cost (Eq. 2) (\$/kW)	\$286	\$285	\$220	\$217
Capital Cost (2018) (\$)	\$2,604,237	\$2,637,052	\$4,314,456	\$4,355,654
Maui Construction Cost Multiplier <sup>B</sup>	1.938	1.938	1.938	1.938
Maui Capital Cost (2018)	\$5,047,010	\$5,110,607	\$8,361,417	\$8,441,258
Annualized Capital Cost (\$/yr)	\$554,135	\$561,117	\$918,039	\$926,805
G =	0.38	0.33	0.64	0.52
H = (MMBtu/hr)	94	94	172	181
D = (\$/kW)	\$441	\$440	\$340	\$335
Fixed O&M <sup>C</sup> (Eq. 3) (\$/yr)	\$17,188	\$17,405	\$28,475	\$28,747
Variable O&M Cost (Eq. 4) (\$/yr)	\$30,756	\$27,389	\$97,925	\$75,693
<b>Total Annual Cost (\$/yr)</b>	<b>\$602,078</b>	<b>\$605,910</b>	<b>\$1,044,439</b>	<b>\$1,031,246</b>

$$Z = \left[ \frac{B}{1.5} \right]^{0.05} \left[ \frac{C}{100} \right]^{0.4} \quad \text{Equation 1}$$

$$D = 75 \left\{ 300,000 \frac{Z}{A} \right\}^{0.35} \quad \text{Equation 2}$$

Where:

- D = Capital cost (\$/kW)
- B = NO<sub>x</sub> (lb/10<sup>6</sup> Btu) at the inlet of the SCR reactor
- C = NO<sub>x</sub> removal efficiency (%)
- A = Plant capacity (kW)

$$E = D \times A \times C \quad \text{Equation 3}$$

Where:

- E = Fixed O&M cost (\$/yr)
- D = Capital cost (\$/kW) from Equation 1
- A = Plant capacity (kW)
- C = A constant, 0.0066 yr<sup>-1</sup>

$$F = G \left\{ 225 \times \left[ 0.37B \times H \times \left( \frac{C}{100} \right) \times \left( \frac{8760}{2000} \right) \right] \times 1.005 \times 1.05 + 0.025 \times D \times A \times Z + 1.45 \times A \right\} \quad \text{Equation 4}$$

Where:

- F = Variable O&M Cost (\$/yr)
- G = Annual capacity factor (expressed as a fraction)
- B = Inlet NO<sub>x</sub> (lb/MMBtu); range of 0.15 - 2.5 lb/MMBtu
- H = Heat input (MMBtu/hr)
- C = NO<sub>x</sub> removal efficiency; range of 80-95%
- D = Capital cost (\$/kW)
- A = Plant capacity (kW)

$$\text{Capital Recovery Factor (CRF)} = \frac{I \times (1+i)^a}{I + (1+i)^a - 1} \quad \text{CRF} = 0.11$$

Where:

- I = Interest Rate (7% interest)
- a = Equipment life (15 yrs)

**Source:** *Cost of Selective Catalytic Reduction (SCR) Application for NOx Control on Coal-Fired Boilers*, EPA/600/R-01/087, October 2001. A cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI), Chemical Engineering Journal.

<sup>B</sup> The Maui construction cost multiplier is based on cost of construction geographical multipliers from the *RSMMeans Mechanical Cost Data 2016* to account for factors unique to Maui's location plus an additional factor to account for additional Hawaiian Electric loadings and overhead.

<sup>C</sup> Fixed Costs include elements such as labor, station power, capital additions/improvements

Appendix Table A-3. Scrubber Capital and O&M Cost Estimate

Parameters/Costs	Equation/Reference	K1	K2	K3	K4
Exhaust Temperature (K)	$T_{stack}$	450.2	422.2	436.2	433.2
Exhaust Temperature (F)	Converted from degrees K	350.6	300.2	325.4	320.0
Exhaust Moisture Content (%)	MS - Typical Values	12.00%	12.00%	12.00%	12.00%
Exhaust Flow Rate ( $m^3/s$ ) <sup>1</sup>	CSP Application	12.9	12.7	22.1	27.9
Exhaust Flow Rate (ACFM) <sup>1</sup>	Converted from ( $m^3/s$ )	27,246	26,999	46,908	59,181
Exhaust Flow Rate (SCFM)	$ACFM * ((68+460)/(T_{stack}+460))$	17,747	18,752	31,535	40,061
$m_w$ (lb/min)	$SCFM * MC * 18/385$	100	105	177	225
$m_a$ (lb/min)	$SCFM * (1-MC) * 29/385$	730	772	1,297	1,648
humidity ratio	$m_w/m_a$	0.14	0.14	0.14	0.14
humid volume ( $ft^3/min$ )	$h$ (Estimated from psychrometric chart)	23.00	23.00	23.00	23.00
$Q_{SAT}$	$h * m_a$	16,794.16	17,744.79	29,840.67	37,909.40
Purchased Equipment Cost (Tables 2.5 and 2.6 for a Stainless Steel Low Energy scrubber, 2002 Dollars)	$1.15 * (150 * Q_{SAT}^{0.56})$	\$40,075	\$41,330	\$55,294	\$63,225
<b>Direct Costs - Table 2.8</b>					
<b>Purchased equipment costs</b>					
Packaged Unit (A1)	As estimated, AA	\$40,075	\$41,330	\$55,294	\$63,225
Auxiliary Costs (A2)	$A2 = 0.1 * A1$	\$4,008	\$4,133	\$5,529	\$6,322
Equipment Costs (A)	$A = A1 + A2$	\$44,083	\$45,463	\$60,824	\$69,547
Instrumentation	0.10 A	\$4,408	\$4,546	\$6,082	\$6,955
Sales taxes	0.03 A	\$1,322	\$1,364	\$1,825	\$2,086
Freight	0.05 A	\$2,204	\$2,273	\$3,041	\$3,477
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$52,018</b>	<b>\$53,647</b>	<b>\$71,772</b>	<b>\$82,066</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.06 B	\$3,121	\$3,219	\$4,306	\$4,924
Handling & erection	0.40 B	\$20,807	\$21,459	\$28,709	\$32,826
Electrical	0.01 B	\$520	\$536	\$718	\$821
Piping	0.05 B	\$2,601	\$2,682	\$3,589	\$4,103
Insulation for ductwork	0.03 B	\$1,561	\$1,609	\$2,153	\$2,462
Painting	0.01 B	\$520	\$536	\$718	\$821
<b>Direct Installation Costs, DIC</b>	<b>0.56 B</b>	<b>\$29,130</b>	<b>\$30,042</b>	<b>\$40,192</b>	<b>\$45,957</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$81,148</b>	<b>\$83,689</b>	<b>\$111,965</b>	<b>\$128,023</b>
<b>Indirect Costs (installation) Table 2.8</b>					
Engineering	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Construction & field expenses	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Contractor fees	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Start-up	0.01 B	\$520	\$536	\$718	\$821
Performance test	0.01 B	\$520	\$536	\$718	\$821
Model study	--				
Contingencies	0.03B	\$1,561	\$1,609	\$2,153	\$2,462
<b>Total Indirect Costs, IC</b>	<b>0.35 B</b>	<b>\$18,206</b>	<b>\$18,776</b>	<b>\$25,120</b>	<b>\$28,723</b>
Cost Index <sup>2</sup> a. 2018 b. 2002	603.1 395.6				
Capital recovery factor (CRF)	$CRF = [1 * (1+i)^n] / [(1+i)^n - 1]$ , where $i$ = interest rate, $n$ = equipment life a. Equipment CRF, 15-yr life, 7% interest	0.11	0.11	0.11	0.11
<b>Total Capital Investment (2018 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (CI<sub>2018</sub>/CI<sub>1999</sub>) (Retrofit factor based on average provided for ESP on Page 3-41). No specific factor provided for scrubber, so factor for ESP was relied on.</b>	<b>\$212,054</b>	<b>\$218,694</b>	<b>\$292,584</b>	<b>\$334,547</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	3hr/shift*2shifts/day*360 days/yr * \$20/hr	\$43,200	\$43,200	\$43,200	\$43,200
Supervisor	15% of operator	\$6,480	\$6,480	\$6,480	\$6,480
<b>Maintenance</b>					
Assumed similar labor requirements as to that required for ESP per Section 6, Page 3-47 of OAQPS Cost manual (\$20.00/hr, 7.5 h/wk, 44 wk/yr)					
Labor		\$6,600	\$6,600	\$6,600	\$6,600
Material	100% of maintenance labor	\$6,600	\$6,600	\$6,600	\$6,600
<b>Utilities</b>					
Utilities currently not estimated due to variability					
<b>Total Direct Annual Cost</b>		<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$4,241	\$4,374	\$5,852	\$6,691
Property tax	1% of Total Capital Investment	\$2,121	\$2,187	\$2,926	\$3,345
Insurance	1% of Total Capital Investment	\$2,121	\$2,187	\$2,926	\$3,345
Overhead	60% of total labor and material costs	\$37,728	\$37,728	\$37,728	\$37,728
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$23,282	\$24,011	\$32,124	\$36,731
<b>Total Indirect Annual Costs</b>		<b>\$69,493</b>	<b>\$70,487</b>	<b>\$81,556</b>	<b>\$87,841</b>
<b>Total Annual Cost</b>		<b>\$132,373</b>	<b>\$133,367</b>	<b>\$144,436</b>	<b>\$150,721</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 2 - Wet Scrubbers for Particulate Matter, dated July 2002 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> From Chemical Engineering Plant Cost Index (CEPCI)

Appendix Table A-4. Wet ESP Capital and O&M Cost Estimate

Parameters/Costs	Equation	K1	K2	K3	K4
Average High Exhaust Flow Rate (m <sup>3</sup> /s) <sup>1</sup>		12.4	12.3	21.6	28.6
Average High Exhaust Flow Rate (ACFM) <sup>1</sup>		26,360	26,121	45,681	60,599
Annual Operating Time (hrs, θ) <sup>2</sup>		8,760	8,760	8,760	8,760
ESP efficiency (from white paper)		90%	90%	90%	90%
ESP Plate Area (ft <sup>2</sup> ) <sup>4</sup>	$ESCA = -\ln(p)/w_e \times 5.080 \times Q$	982	973	1,702	2,257
Purchased Equipment Cost (Table 3.14 for 90% Control Efficiency and 15,000 ACFM bins)	\$25.5/acfm	\$672,189	\$666,078	\$1,164,874	\$1,545,272
Basic Equipment Costs -Table 3.12	0.45 × Equipment Cost	\$302,485	\$299,735	\$524,193	\$695,372
<b>Direct Costs - Table 3.16</b>					
<b>Purchased equipment costs</b>					
ESP + auxiliary equipment (A)	As estimated, A	\$974,674	\$965,814	\$1,689,067	\$2,240,644
Instrumentation	0.10 A	\$97,467	\$96,581	\$168,907	\$224,064
Sales taxes	0.03 A	\$29,240	\$28,974	\$50,672	\$67,219
Freight	0.05 A	\$48,734	\$48,291	\$84,453	\$112,032
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$1,150,116</b>	<b>\$1,139,660</b>	<b>\$1,993,099</b>	<b>\$2,643,960</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.04 B	\$46,005	\$45,586	\$79,724	\$105,758
Handling & erection	0.50 B	\$575,058	\$569,830	\$996,549	\$1,321,980
Electrical	0.08 B	\$92,009	\$91,173	\$159,448	\$211,517
Piping	0.01 B	\$11,501	\$11,397	\$19,931	\$26,440
Insulation for ductwork	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
Painting	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
<b>Direct Installation Costs, DIC</b>	<b>0.67 B</b>	<b>\$770,578</b>	<b>\$763,572</b>	<b>\$1,335,376</b>	<b>\$1,771,453</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$1,920,694</b>	<b>\$1,903,233</b>	<b>\$3,328,475</b>	<b>\$4,415,413</b>
<b>Indirect Costs (Installation) Table 3.16</b>					
Engineering	0.20B	\$230,023	\$227,932	\$398,620	\$528,792
Construction & field expenses	0.20B	\$230,023	\$227,932	\$398,620	\$528,792
Contractor fees	0.10B	\$115,012	\$113,966	\$199,310	\$264,396
Start-up	0.01B	\$11,501	\$11,397	\$19,931	\$26,440
Performance test	0.01B	\$11,501	\$11,397	\$19,931	\$26,440
Model study	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
Contingencies	0.03B	\$34,503	\$34,190	\$59,793	\$79,319
<b>Total Indirect Costs, IC</b>	<b>0.57B</b>	<b>\$655,566</b>	<b>\$649,606</b>	<b>\$1,136,066</b>	<b>\$1,507,057</b>
Cost Index <sup>5</sup>					
a. 2018	603.1				
b. 1999	390.6				
Capital recovery factor (CRF)	$CRF = [I \times (1+i)^a] / [(1+i)^a - 1]$ , where I = interest rate, a = equipment life a. Equipment CRF, 15-yr life, 7% interest	0.11	0.11	0.11	0.11
<b>Total Capital Investment (2018 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (CI<sub>2018</sub>/CI<sub>1999</sub>) (Retrofit factor based on average provided for ESP on Page 3-41).</b>	<b>\$5,568,968</b>	<b>\$5,518,341</b>	<b>\$9,650,769</b>	<b>\$12,802,299</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	2hr/shift*2shifts/day*365 days/yr * \$20/hr	\$29,200	\$29,200	\$29,200	\$29,200
Supervisor	15% of operator	\$4,380	\$4,380	\$4,380	\$4,380
<b>Maintenance</b>					
Labor	For ESP plate area < 50,000 ft <sup>2</sup> = \$4125	\$4,125	\$4,125	\$4,125	\$4,125
<b>Utilities</b>					
	Utilities currently not estimated due to variability				
<b>Total Direct Annual Cost</b>		<b>\$37,705</b>	<b>\$37,705</b>	<b>\$37,705</b>	<b>\$37,705</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$111,379	\$110,367	\$193,015	\$256,046
Property tax	1% of Total Capital Investment	\$55,690	\$55,183	\$96,508	\$128,023
Insurance	1% of Total Capital Investment	\$55,690	\$55,183	\$96,508	\$128,023
Overhead	60% of total labor and material costs	\$22,623	\$22,623	\$22,623	\$22,623
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$611,443	\$605,884	\$1,059,603	\$1,405,624
<b>Total Indirect Annual Costs</b>		<b>\$856,825</b>	<b>\$849,241</b>	<b>\$1,468,256</b>	<b>\$1,940,339</b>
<b>TOTAL ANNUAL COST</b>		<b>\$894,530</b>	<b>\$886,946</b>	<b>\$1,505,961</b>	<b>\$1,978,044</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 3 - Electrostatic Precipitators, dated September 1999 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> Electricity cost from U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.

<sup>3</sup> Water cost from Maui County (<https://www.mauicounty.gov/216/Water-Charges>) lowest general rate.

<sup>4</sup> For ESP Plate Area (Section 3.2.1):

$p = 1 - (\text{Control Efficiency } \%)$

$5.080 \text{ ft}^2/\text{kacfm} = 1 \text{ (s/m)}$

$w_e = \text{effective migration velocity (m/s)}$ , assume  $w_e = 31.4 \text{ cm/s}$  for Bituminous coal fly ash for a design efficiency of 95% from Table 3.3 (no listings for 90% efficiency or fuel oil)

$Q = \text{system flow rate (kacfm)}$

<sup>5</sup> From Chemical Engineering Plant Cost Index (CEPCI)

## APPENDIX B: HAWAIIAN ELECTRIC REGIONAL HAZE VISIBILITY CONSIDERATIONS

---

**Appendix B:**  
**Hawaiian Electric Regional Haze Visibility Considerations**

**Fifth Factor Considerations for SO<sub>2</sub>, NO<sub>x</sub>, and PM Controls**

AECOM Project Number: 60626547

Prepared for:



**Hawaiian  
Electric**

PO Box 2750  
Honolulu, HI 96840

Prepared by:

**AECOM**

AECOM Technical Services, Inc.  
250 Apollo Drive  
Chelmsford, MA 01824-3627

March 31, 2020

# Hawaiian Electric<sup>1</sup> Regional Haze Visibility Considerations

## Fifth Factor Considerations for SO<sub>2</sub>, NO<sub>x</sub> and PM Controls

### 1. Executive Summary

The EPA has issued multiple guidance documents to assist states and facilities address the requirements of the Regional Haze Rule (“RHR”). This guidance allows states to consider, as part of their review of the Four Factor evaluation of possible emission controls for the Second Decadal Review, a “5<sup>th</sup> factor” which involves consideration of visibility impacts of candidate control options. This appendix introduces several Hawai‘i-specific issues that impact the visibility impact of potential sulfur dioxide (“SO<sub>2</sub>”), nitrogen oxides (“NO<sub>x</sub>”) and particulate matter (“PM”) control options for Hawaiian Electric sources relative to the two Class I areas in Hawai‘i: the Haleakalā National Park on the island of Maui and the Hawai‘i Volcanoes National Park on Hawai‘i Island. The issues discussed in this report are summarized below:

- 1) Due to unique atmospheric chemistry, NO<sub>x</sub> emissions tend to remain in the gaseous (and invisible) phase in warm weather, and only form NO<sub>3</sub> (“nitrate”) particulate aerosol in cold weather. This is verified by monitoring data in the Interagency Monitoring of Protected Visual Environments (“IMPROVE”) network in the two national parks mentioned above.
- 2) The persistent East North East (“ENE”) trade winds experienced by the state of Hawai‘i places emission sources on several islands (or portions of islands such as Maui) downwind of the national parks, limiting the likelihood that any emissions from these sources would even reach the parks. Modeling conducted with the California Puff Model (“CALPUFF”) for the First Decadal Review confirms the minimal potential for haze impact of the subject Hawaiian Electric sources on the islands of Oahu and Maui due to the predominance of the trade winds. The EPA’s Federal Implementation Plan (“FIP”) issued in 2012 agreed with this assessment.
- 3) EPA previously determined that in Hawai‘i haze due to direct PM was a very small component of haze and that further controls would not be effective in improving visibility. The observed haze speciation is reviewed in this report to confirm this determination.
- 4) The State of Hawai‘i Department of Health Clean Air Branch (“DOH”) should request the EPA (consistent with their first decadal review approach) to set aside NO<sub>x</sub> and PM from the list of

<sup>1</sup> “Hawaiian Electric” or the “Company” refers to Hawaiian Electric Company, Inc. (or “HE”), Hawai‘i Electric Light Company, Inc. (or “HL”) and/or Maui Electric Company, Limited (or “ME”). On December 20, 2019, the State of Hawai‘i Department of Commerce and Consumer Affairs (“DCCA”) approved Hawaiian Electric Company, Inc., Hawai‘i Electric Light Company, Inc. and Maui Electric Company, Limited’s application to do business under the trade name “Hawaiian Electric” for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.



haze precursors for Hawai'i due to the unique NOx haze chemistry and climate, leaving SO<sub>2</sub> as the primary precursor pollutant for haze. Hawaiian Electric requests that the DOH make this proposal to the EPA.

- 5) In the recent past, volcanic activity on Hawai'i Island has produced as much as 2 million tons of SO<sub>2</sub> emissions per year<sup>2,3</sup> (emissions vary yearly), as well as roughly 125,000 tons of NOx emissions per year<sup>4</sup>. These volcanic SO<sub>2</sub> emissions are about three orders of magnitude (approximately 1,000 times) greater than anthropogenic SO<sub>2</sub> emissions. Although the IMPROVE monitors indicate that sulfate haze is the most important haze species, it is evident from monthly haze trends and the likelihood of winds from the volcanic activity reaching the IMPROVE monitors that the overwhelming sulfate haze influence comes from natural sources (i.e., volcanic activity).

The locations of the affected Hawaiian Electric sources and the two national parks are shown in Figure B-1. The remainder of this appendix presents details of the above issues and recommendations for how this information should be considered in selection of facilities for Four-Factor analyses and for evaluating potential pollutant control options.


<sup>2</sup> Information on the volcanic SO<sub>2</sub> emissions in 2014 was provided by the EPA in their SO<sub>2</sub> National Ambient Air Quality Technical Support Document at EPA's 2016 SO<sub>2</sub> NAAQS TSD, at <https://www.epa.gov/sites/production/files/2016-03/documents/hi-epa-tsd-r2.pdf>.

<sup>3</sup> Information on 2014-2017 volcanic SO<sub>2</sub> emissions is available in this journal article: Elias T, Kern C, Horton KA, Sutton AJ and Garbeil H. (2018) Measuring SO<sub>2</sub> Emission Rates at Kīlauea Volcano, Hawaii, Using an Array of Upward-Looking UV Spectrometers, 2014–2017. *Front. Earth Sci.* 6:214. doi: 10.3389/feart.2018.00214. <https://www.frontiersin.org/articles/10.3389/feart.2018.00214/full>.

<sup>4</sup> The 125,000 tons per year of NOx assumes NOx emissions rate equals 6% of SO<sub>2</sub> emissions rate. The 6% is derived from worldwide volcanic NOx emissions estimate of 1.0 Teragram ("Tg" – trillion grams)/year ("yr") nitric oxide ("NO") (or 1.5 Tg/yr NO<sub>2</sub>) from <https://www.chemistryworld.com/features/a-volcanic-breath-of-life/3004482.article> and worldwide volcanic SO<sub>2</sub> estimate of 23 Tg/yr from <https://www.nature.com/articles/srep44095>.

Figure B-1:

Location of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas



## 2. EPA Guidance Regarding Considerations of Visibility Impacts

The EPA issued “Guidance on Regional Haze State Implementation Plans for the Second Implementation Period”<sup>5</sup> in August 2019. This guidance allows states to consider, as part of its consideration of emission controls to include for the Second Decadal Review a “5<sup>th</sup> factor” which involves consideration of visibility impacts of candidate control options. A companion document<sup>6</sup> issued in September 2019 that involves the EPA’s visibility modeling results for 2028 is entitled, “Availability of Modeling Data and Associated Technical Support Document for the EPA’s Updated 2028 Visibility Air Quality Modeling”.

On Page 11 of the August 2019 guidance, the EPA states:

*“When selecting sources for analysis of control measures, a state may focus on the PM species that dominate visibility impairment at the Class I areas affected by emissions from the state and then select only sources with emissions of those dominant pollutants and their precursors.” . . .*

<sup>5</sup> Available at [https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019\\_-\\_regional\\_haze\\_guidance\\_final\\_guidance.pdf](https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019_-_regional_haze_guidance_final_guidance.pdf).

<sup>6</sup> Available at [https://www3.epa.gov/ttn/scram/reports/2028\\_Regional\\_Haze\\_Modeling-Transmittal\\_Memo.pdf](https://www3.epa.gov/ttn/scram/reports/2028_Regional_Haze_Modeling-Transmittal_Memo.pdf).

*“Also, it may be reasonable for a state to not consider measures for control of the remaining pollutants from sources that have been selected on the basis of their emissions of the dominant pollutants”*

Further, on Page 36 and 37, the EPA states:

*“Because the goal of the regional haze program is to improve visibility, it is reasonable for a state to consider whether and by how much an emission control measure would help achieve that goal.” . . .*

*“. . . EPA interprets the CAA and the Regional Haze Rule to allow a state reasonable discretion to consider the anticipated visibility benefits of an emission control measure along with the other factors when determining whether a measure is necessary to make reasonable progress.”*

Consequently, the extremely low likelihood for impact to Class I visibility impairment from control of certain facility pollutants and the plant locations relative to the Class I areas is appropriate for consideration when evaluating the need for further control of these emissions for Regional Haze Reasonable Progress.

### **3. Nitrate Haze Composition Analysis**

Nitrate haze composition analyses for the Haleakalā and Hawai‘i Volcanoes National Parks are available at the IMPROVE web site at <http://vista.cira.colostate.edu/Improve/pm-and-haze-composition/>. Figure B-2 provides various charts for the haze species composition at the Haleakalā Crater IMPROVE site, and Figure B-3 provides a time series of stacked bars by species for a recent year at that site. Figures B-4 and B-5 provide similar information for the Hawai‘i Volcanoes IMPROVE site. Note that these figures show information for the worst 20 percent (“%”) impaired days, which is the focus of the RHR for reducing haze. The goal for each decadal review is to track the progress of haze reduction for the worst 20% impaired days; reviewing the composition of haze on these days is a key element in understanding what precursor pollutants to control to achieve the goal.

The data for both National Parks shows that the contribution of nitrates to haze is very low as a percentage of the total, but it is also low as an absolute value for extinction (visibility impairment). The total nitrate haze impairment is approximately 1 inverse megameter (“ $Mm^{-1}$ ”), equivalent to approximately 0.25 deciview (“dv”), or less. This is the impairment at these monitors due to ALL sources, natural and anthropogenic, and as noted below, the volcanic emissions are much greater than the entire state’s anthropogenic NO<sub>x</sub> emissions for recent years with SO<sub>2</sub> volcanic emissions of roughly 2 million tons per year (“TPY”).



The minimal impact of nitrate haze is clearly illustrated in the Hawai‘i National Park monitoring data and is much smaller than found at many monitors in other Class I areas around the country. This is in large part due to the unique chemistry of nitrate haze, as discussed below.

The chemistry of nitrate haze formation is highly dependent upon ambient temperature, and to a lesser extent upon humidity. As discussed in the CALPUFF model formulation<sup>7</sup> and in CALPUFF courses (see Figure B-8), total nitrate in the atmosphere ( $TNO_3 = HNO_3 + NO_3$ ) is partitioned into gaseous nitric acid (“ $HNO_3$ ”) (invisible, and not haze-producing) and nitrate (“ $NO_3$ ”) haze particles according to the equilibrium relationship between the two species, which is affected by temperature and humidity.


<sup>7</sup> Documentation for the CALPUFF modeling system is available from links provided at <https://www.epa.gov/scram/air-quality-dispersion-modeling-alternative-models#calpuff>.

Figure B-2: Charts Showing the Worst 20% Haze Days Multiple-Year Species Composition for the Haleakalā Crater IMPROVE Site

Light Extinction Summary - Most Impaired Days



Most Impaired Days 2007-2018  
Haleakala Crater



Haleakala Crater IMPROVE monitor

Data source for Figures B-2 through B-5: [http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF\\_VisSum](http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF_VisSum).

Figure B-3: Time Series of 2018 Daily Haze Extinction Composition Plots for the Haleakalā Crater IMPROVE Site







Figure B-4: Charts Showing the Worst 20% Haze Days Multiple-Year Species Composition for the Hawai'i Volcanoes IMPROVE Site

Light Extinction Summary - Most Impaired Days



Most Impaired Days 1988-2018  
Hawaii Volcanoes NP




Hawaii Volcanoes NP IMPROVE monitor

[a.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF\\_VisSum](http://a.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF_VisSum)

AECOM

Figure B-5: Time Series of 2018 Daily Haze Extinction Composition Plots for the Hawai'i Volcanoes IMPROVE Site





The nitrate contribution to visibility impairment in the above bar charts is shown as a narrow “red” segment. The small size relative to other constituents clearly shows that nitrate is only a small contributor. Additionally, the Figures B-6 and B-7 below which presents only the ammonium nitrate visibility impairment also shows that nitrates, already small contribution, is trending downward.






Figure B-8: CALPUFF Example Plot of Aerosol Percentage of Total NOx Equilibrium



The potential for the formation of haze due to NOx emissions is very low in Hawai'i because of the warm weather conditions year-round. This strong dependency of the equilibrium relationship between invisible gaseous HNO<sub>3</sub> and visible NO<sub>3</sub> haze particles as a function of ambient temperature is illustrated in Figure B-8. In Figure B-8, it is evident that for most conditions, the percentage of total nitrate in the form of particulate (NO<sub>3</sub>) is less than 20% for temperatures above approximately 286 degrees Kelvin (approximately 55 degrees Fahrenheit). Temperatures at most locations in Hawai'i rarely get that low and are not that low at any of the Hawaiian Electric plant locations.

This dependency of nitrate haze formation as a function of temperature (and season) for more seasonally-varying locations in the United States is shown in the September 2019 EPA modeling report<sup>2</sup> in Figure B-9 (from Appendix A of that report). This figure shows that the thermodynamics of the nitrate haze equilibrium result in much greater particulate formation in winter versus other seasons for more temperate climates, while NOx emissions are expected to be relatively constant over the entire year. This implies that NOx emission reductions would only be effective for haze reduction during cold winter months, while consideration of NOx emission reductions in other months is relatively ineffective.

It should also be noted that volcanic activity on Hawai'i Island is the largest source of NOx in the state. Volcanoes are commonly thought of as large sources of SO<sub>2</sub>, but they also emit significant amounts of NOx. Laboratory analysis<sup>8</sup> of NOx emissions content in volcanic exhaust indicates a substantial component, likely caused by thermal contact of air with lava. The annual worldwide volcano NOx emissions (as NO<sub>2</sub>) is estimated<sup>3</sup> at approximately 1.5 teragrams ("Tg" – trillion grams), while annual worldwide volcano SO<sub>2</sub> emissions are estimated<sup>9</sup> at approximately 23 Tg. This suggests that the level of NOx emissions is approximately equal to 6% of the total SO<sub>2</sub> emissions from volcanos. Hawai'i volcanic activity is estimated to have annual SO<sub>2</sub> emissions of approximately 2 million TPY of SO<sub>2</sub>. This suggests that the volcanic emissions of NOx in Hawai'i are about 125,000 TPY. This level of natural NOx emissions is approximately 3 times greater than all anthropogenic NOx emissions in the entire state of Hawai'i (vehicle exhaust, industrial emissions, and other combustion sources) based upon the EPA's state emissions trends data<sup>10</sup> for 2017. Also, these estimated volcanic NOx emissions are approximately 10 times greater than the cumulative total 2017 NOx emissions emitted by all six Hawaiian Electric plants being reviewed for the Second Decadal Review.

In summary, nitrate haze is a very small component in Hawai'i's Class I areas, which is expected given nitrate chemistry and is verified by the IMPROVE monitoring data. Additionally, the biggest NOx source is the Kilauea volcano (approximately 125,000 TPY versus statewide<sup>3</sup> approximately 21,000 TPY from transportation and approximately 21,000 TPY from fuel combustion, of which only a small fraction are from Hawaiian Electric facilities). The multiple-year average of the nitrate haze impact for worst 20% days at the two areas is approximately Mm<sup>-1</sup>, or less than 0.5 delta-dv. This total nitrate haze impact is less than the de minimis contribution threshold used to eliminate a single source from consideration for controls during the First Decadal Review period.

Due to the low haze impact of NOx (even if every source in the state and the volcano was eliminated), the state of Hawai'i should limit the haze precursors control evaluations to SO<sub>2</sub> for the Second Decadal Review. A similar conclusion was reached during the First Decadal Review, for which the EPA did not consider NOx controls to be material. The State of Hawai'i Department of Health should work with the EPA to provide this technical justification to remove NOx as a haze precursor for the state of Hawai'i.



<sup>8</sup> Mather, T., 2004. A Volcanic Breath of Life? Chemistry World, 30 November 2004 Featured Article.

<https://www.chemistryworld.com/features/a-volcanic-breath-of-life/3004482.article>.

<sup>9</sup> Carn, S., V. Fioletov, C. McLinden, C. Li, and N. Krotkov, 2017. A decade of global volcanic SO<sub>2</sub> measured from space. *Sci. Rep.* 7, 44095; doi: 10.1038/srep44095. <https://www.nature.com/articles/srep44095.pdf>.

<sup>10</sup> <https://www.epa.gov/air-emissions-inventories/air-pollutant-emissions-trends-data>.

Figure B-9: Monthly Variation of Nitrate Particulate Concentrations for Selected IMPROVE Sites from EPA 2019 Modeling Report



#### **4. PM Species Haze Composition Analysis**

In their Federal Implementation Plan Technical Support Document<sup>11</sup>, EPA noted that “due to the overwhelming contribution of sulfate to visibility impairment at the nearby Hawaii Volcanoes Class I area, it is unlikely that reductions in these pollutants [NOx and PM]...would have a measurable impact on visibility at that area.”

It is clear from a review of the haze speciation shown in Figures B-2 through B-5 that the contribution to haze of direct particulate species such as elemental carbon, soil, and coarse mass is relatively low. Furthermore, emissions of coarse PM mass (ash) from the volcanic activity can be very high (clearly evident from photos of volcanic activity) to the extent that it may result in aviation alerts. These emissions can be much greater than emissions from power plants and can constitute a significant portion of the direct PM-caused haze shown in Figures B-2 through B-5. The remaining human-caused haze due to direct PM emissions is therefore a very small component of the total haze, and this determination is consistent with EPA’s 2012 assessment.

#### **5. Predominant Trade Winds in Hawai‘i**

The EPA’s FIP for Hawai‘i for the First Decadal Review (77 FR 61478, October 9, 2012) acknowledged the direction of the predominant trade winds in Hawai‘i and thus did not require controls on upwind sources (i.e., sources on Oahu and Maui). Figure B-10 shows the locations of the Hawaiian Electric sources and the national parks, along with wind rose plots for airports on Maui and Oahu. The wind rose plots show that the wind is almost always from the northeast and rarely blows from the Hawaiian Electric facilities on Oahu or Maui toward either of Hawai‘i’s Class I areas.

The EPA CALPUFF modeling conducted for the First Decadal Review confirms the expected low impacts from sources on Maui, even though the sources were relatively close to Haleakalā National Park. This result is due to the fact, as stated above, that winds rarely blow the emissions from sources downwind from the parks back to the parks, and the CALPUFF modeling confirmed the low impact from occasional periods when the wind may blow toward the parks from the sources modeled. The Western Regional Air Partnership (“WRAP”) Q/d analysis that included several sources on the islands of Oahu and Maui in the four-factor analysis did not consider the wind patterns. A review of past modeling and the EPA’s 2012 FIP should lead to a dismissal of those sources from inclusion in four-factor analyses for the second decadal review period.

The geometry and wind roses shown Figure B-10 and previous CALPUFF modeling both indicate that Hawaiian Electric generating stations on Oahu and Maui would have minimal impact to Class I area haze. Because of this, and the minimal impact of NOx due to nitrate chemistry, consideration of potential

<sup>11</sup> EPA, May 14, 2012. Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawaii. EPA docket EPA-R09-OAR-2012-0345-0002 via [www.regulations.gov](http://www.regulations.gov).

additional pollution controls at Hawaiian Electric facilities for Regional Haze progress should be limited to SO<sub>2</sub> for sources on Hawai'i Island.

## 6. Natural Sources of SO<sub>2</sub> From Volcanic Activity

Volcanic activity on the Hawai'i Island represents a unique and challenging complication to understating haze in Hawai'i Class I areas. The Kilauea volcano on Hawai'i Island has been active for several years, and the levels of SO<sub>2</sub> emissions are being monitored by the United States Geological Survey. As shown in Figure B-11<sup>12</sup> (related to the SO<sub>2</sub> National Ambient Air Quality Standards implementation and monitoring), there were over 2 million tons of SO<sub>2</sub> emissions from volcanic activity on Hawai'i Island in the year 2014, compared to roughly 2,000 tons of power plant SO<sub>2</sub> emissions for that year. As noted in a *Frontiers in Earth Science* 2018 article<sup>13</sup>, the volcanic SO<sub>2</sub> emissions have been relatively steady at levels close to 2 million TPY for the period of 2014 to 2017.

The extremely high levels of natural SO<sub>2</sub> emissions present a significant challenge for defining "impaired" haze days because the same pollutant (i.e., SO<sub>2</sub>) is emitted by volcanic activity and the power plants and other combustion sources. Therefore, the RHR glidepath for the two Class I areas in Hawai'i is difficult to establish if naturally-caused haze is to be excluded from the analysis.

There appears to be very little anthropogenic haze impairment remaining at Haleakalā National Park because there are very few sources on Maui upwind of the park and there are no land masses upwind of Maui for thousands of kilometers. For Hawai'i Island, the natural sources of SO<sub>2</sub> are part of (or adjacent to) the park, so they are likely to be a large and continuous source of naturally-caused haze.

Even the anthropogenic sources (from power plants) are projected to be phased out well before the end point of the RHR (i.e., 2064) by Hawai'i's State Renewable Portfolio Standards Law ("RPS") implementing requirements to convert 100% of the state's electrical generation to renewable energy sources. This RPS law (Hawai'i Revised Statute §269-92) will substantially reduce emissions of haze precursors by 2045. Further details of the past and future benefits of the RPS requirements are detailed in separate Appendix C.

<sup>12</sup> <https://www.epa.gov/sites/production/files/2016-03/documents/hi-epa-tsd-r2.pdf>.

<sup>13</sup> Elias, T., C. Kern, K. Horton, A. Sutton, and H. Garbeil, 2018. Measuring SO<sub>2</sub> Emission Rates at Kilauea Volcano, Hawai'i, Using an Array of Upward-Looking UV Spectrometers, 2014–2017. *Front. Earth Sci.* 6:214. doi: 10.3389/feart.2018.00214. <https://www.frontiersin.org/articles/10.3389/feart.2018.00214/full>.

Figure B-10: Geography of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas, with Wind Roses





Figure B-11: Geography of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas, with Wind Roses



2017 SO<sub>2</sub> Emissions (from NEI)

site name	TPY SO <sub>2</sub>
HELCO - Keahole Power Plant	81.94
HELCO - Waimea Power Plant	0.00
HELCO - Kanoelehua Power Plant/ HILL	2167.18
HELCO - Puna Power Plant	186.84

2014-2017 Volcano SO<sub>2</sub> Emissions  
average about 1.86 Million TPY<sup>1</sup>



ERZ = Eastern Rift Zone

AECOM



## 7. Conclusions

The state of Hawai'i is isolated from all other states and has very unique regional haze issues due, in part, to its tropical climate, the prevalent trade winds, very large natural emissions of haze precursors, and statewide commitment to renewable energy.

- Emission sources on Oahu and Maui are downwind of Hawai'i's Class I areas and do not contribute to haze issues, such that additional emission controls would not contribute to further reasonable progress at either of Hawai'i's Class I area National Parks. This is consistent with the EPA's First Decadal Review findings.
- Additionally, NO<sub>x</sub> emissions do not significantly contribute to haze in Hawai'i due to the nitrate chemistry and Hawai'i's warm climate, and additional NO<sub>x</sub> controls would likewise not contribute to further reasonable progress. Therefore, NO<sub>x</sub> should not be regulated as a contributing precursor to haze in Hawai'i; especially from Oahu and Maui sources that are downwind of the parks. If they are reviewed as precursors, consideration should be given to their insignificant contribution when evaluating possible controls.
- Direct PM emissions constitute a very small portion of the haze associated with the worst 20% haze days in the Hawai'i Class I areas. Furthermore, significant portions of the observed haze in the categories of elemental carbon, soil, and coarse mass are due to volcanic emissions. Therefore, further PM controls on power plant sources would not have a significant benefit for visibility at these Class I areas.
- For the above reasons, the only pollutant that should be considered for possible haze controls in the state of Hawai'i is SO<sub>2</sub> which is consistent with the findings of the First Decadal Review. Furthermore, the only Hawaiian Electric sources to be considered for a four factor analysis for SO<sub>2</sub> should be those that are predominantly upwind of a Class I area which include only the Puna and Kanoelehua-Hill Generating Stations on Hawai'i Island.
- Hawai'i's Class I area haze impacts are principally due to natural sources. Volcanic emissions of precursor SO<sub>2</sub> during the 2014-2017 period of analysis were three orders of magnitude greater than the anthropogenic emissions on Hawai'i Island. Volcanic NO<sub>x</sub> emissions were about three times greater than all the state's NO<sub>x</sub> emissions. Since these natural emissions are the principal cause of haze at the two Class I areas in the state and are difficult to distinguish from the relatively small amount of anthropogenically-caused haze, photochemical grid modeling is not practical or even needed. The definition of "impaired days" for Hawai'i Volcanoes National Park as referenced in some of the figures in this report is uncertain due to the overwhelming influence of natural emissions of SO<sub>2</sub>.
- For Haleakalā National Park, with the lack of upwind anthropogenic sources, it could be reasonably concluded that natural conditions are already attained, and no further Reasonable Progress modeling (or controls) is needed. For Hawai'i Volcanoes National Park, the only United

States anthropogenic potential sources are those upwind of the park on Hawai'i Island; all other sources in the state are not contributing to haze at the Class I areas.

- Implementation of Hawai'i's RPS (discussed in detail in Appendix C) will provide a dramatic reduction of virtually all power plant haze-causing emissions in the state of Hawai'i well before the year 2064. This Hawai'i state law established enforceable requirements that a certain percentage of electricity must be generated from renewable energy sources by the end of identified benchmark years leading to 100% renewable energy by 2045. The interim targets are 30 percent by 2020, 40 percent by 2030, and 70 percent by 2040 which provide an RPS "glide path" for EGUs that mirrors the RHR visibility improvement glide path for the next few decades. No separate new regional haze measures for EGUs are needed to assure reasonable progress for this decadal period.

Plans for renewable energy sources, the likely reduction in utilization of fossil-fueled electric generation in this interim period, the unique climate and wind patterns, and the difficulty of addressing the high volcanic emissions should be considered in the current planning for the Second Decadal Review process for the state of Hawai'i.

**APPENDIX C: HAWAI'I'S RENEWABLE PORTFOLIO STANDARDS  
CONTRIBUTION TO REGIONAL HAZE PROGRESS**

---

# **Appendix C: Hawai'i's Renewable Portfolio Standards ("RPS") Contribution to Regional Haze Progress**

AECOM Project Number: 60626547

Prepared for:



**Hawaiian  
Electric**

PO Box 2750  
Honolulu, HI 96840

Prepared by:

**AECOM**

AECOM Technical Services, Inc.  
500 West Jefferson, Suite 1600  
Louisville, KY 40202

March 30, 020

# Hawai'i's Renewable Portfolio Standards ("RPS")

## Contribution to Regional Haze Progress

### 1. Executive Summary

Hawai'i's ongoing conversion of fossil-fueled electric generation to renewable energy sources as mandated by the Hawai'i Revised Statute ("HRS") §269-92 Renewable Portfolio Standards ("RPS") is significantly decreasing emissions from Hawai'i's electric generating stations. Past actual and expected future decreases in usage of fossil-fueled electric generating units ("EGUs") are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the Regional Haze Rule ("RHR"). Emissions from the majority of Hawai'i's electric generating plants are not a significant contributor to haze at Class I areas (for reasons explained in Appendix B). Further, their very low impact is being mitigated under the RPS state law. This rate of progress from the RPS law can be relied upon for further emissions reductions from EGUs in the coming years and thus separate further requirements for EGU controls under the RHR are not needed at this time. The following sections of this appendix provide a background on the RPS requirements and progress to date, and high confidence of continued progress consistent with the goals of the RHR.

### 2. Renewable Portfolio Standards

In 2002 the Hawai'i RPS legislation set voluntary goals for converting the islands' electrical generation from fossil fuels to renewable energy. In 2005, the RPS was set into law as binding requirements for Hawai'i electric utility companies. The law requires that electric utilities in Hawai'i achieve 100% of their electric generation from renewable energy sources by 2045 and meet a series of interim limits for the percentages of their electricity sales that must be provided by renewables (e.g., 30% renewable by 2020, and 40% by 2030, etc.). Renewable energy sources such as solar, hydro and wind energy have no direct emissions. Others such as biomass combustion have significantly lower emissions (especially sulfur dioxide ("SO<sub>2</sub>")) than fossil fuels. Consequently, the RPS law results in steady progress in emissions reductions from electric utilities creating, in effect, an "RPS glidepath" providing dramatic reduction of electric generating unit emissions by mid-century.

The RPS program, although not directly related to the Regional Haze Rule, is providing emissions reductions and improvements to air quality consistent with the goals of the RHR.

Table C-1 shows the interim and final RPS for EGUs along with the Regional Haze adjusted glidepath emissions reductions goals<sup>1</sup>.

<sup>1</sup> Regional Haze Adjusted Glidepath assumes consistent reductions in haze precursor emissions impacts from all U.S. anthropogenic sources from the baseline average of 2000-2004 to zero impacts in 2064, i.e. natural background.

**Table C-1 Comparison of RPS and Regional Haze Glidepaths**

Year	RPS Renewable Requirement % of Electricity Sales	Regional Haze Glidepath % Visibility Improvement
2010	10%	8%
2015	15%	17%
2020	30%	25%
2030	40%	42%
2040	70%	58%
2045	100%	67%
2065		100%

This table illustrates that the emissions reductions from EGUs under the RPS are similar to the visibility goals of the Regional Haze Program in the intermediate years and become much more stringent in later years. The RPS seeks to achieve 100% renewable electrical supply by 2045, which is twenty years earlier than the RHR target of 2065 to achieve natural background visibility in Class I areas.

**3. Historical RPS Achievement**


Hawaiian Electric<sup>2</sup>, and other electric utility providers in Hawai‘i, have made excellent progress in developing and supporting renewable energy sources. Figure C-1 below shows the percentage of all electrical sales statewide provided by renewable sources since the RPS inception (green columns).<sup>3</sup> It also shows as a line illustrating the RPS interim standards (with proportional progress assumed between RPS milestone years). This figure illustrates that Hawai‘i EGUs have made significant progress to date and have been ahead of the RPS interim targets.

Hawaiian Electric represents majority of Hawai‘i’s electric generation. Figure C-2 shows the renewable energy source percentages for this same period specifically for Hawaiian Electric. The data follows the same trend as the statewide figures and this figure also shows a breakdown of the type of renewable energy technology used.

<sup>2</sup> “Hawaiian Electric” or the “Company” refers to Hawaiian Electric Company, Inc. (or “HE”), Hawai‘i Electric Light Company, Inc. (or “HL”) and/or Maui Electric Company, Limited (or “ME”). On December 20, 2019, the State of Hawai‘i Department of Commerce and Consumer Affairs (“DCCA”) approved Hawaiian Electric Company, Inc., Hawai‘i Electric Light Company, Inc. and Maui Electric Company, Limited’s application to do business under the trade name “Hawaiian Electric” for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.


<sup>3</sup> Hawai‘i Public Utility Commission (PUC), “Report to the 2019 Legislature on Hawai‘i’s Renewable Portfolio Standards”, Dec. 2018 [https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report\\_FINAL.pdf](https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report_FINAL.pdf).

**Figure C-1 Statewide Renewable Portfolio Progress**



Source: [https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report\\_FINAL.pdf](https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report_FINAL.pdf)

**Figure C-2 Hawaiian Electric Companies RPS Achievement by Generation Technology<sup>4</sup>**



<sup>4</sup> PUC Dec. 2018 Report, Figure 2, page 7.

#### 4. Future RPS Achievability

To date, Hawai'i's electric utilities have generally met or exceeded the RPS requirements. Continued progress consistent with RPS is expected to continue. Projects and plans are already in place to continue this rapid RPS shift to renewable energy sources for the period of interest of the next decadal period of the RHR. In its December 2018 report to the state legislature, the Hawai'i Public Utility Commission ("PUC") indicated that *"future renewable projects under construction or planned for the HECO Companies and KIUC should ensure that the state remains on track for meeting the 2020 and 2030 RPS targets."*<sup>5</sup>

Figure C-3 below shows Hawaiian Electric's projection of percent renewables through 2030 presented in the December 2018 PUC report. This projected progress remains well ahead of the RPS requirements which also is ahead of the requirements of the Regional Haze glidepath goals.

**Figure C-3 Hawaiian Electric Companies RPS Expectation by 2030 Technology<sup>6</sup>**




Table C-2 below shows the past actual and future forecast for Hawaiian Electric from the previous two figures (from PUC's 2018 report) together with the requirements of RPS and the goals of the RHR. Hawaiian Electric's renewable energy progress and forecast is ahead of both programs. Additionally, Hawaiian Electric has an internal target to achieve 100% renewables by 2040, five years ahead of the RPS requirement and 25 years ahead of the RHR goals.

<sup>5</sup> PUC Dec. 2018 Report, page 2.

<sup>6</sup> PUC Dec. 2018 Report, Figure 2, page 16.




**Table C-2 Comparison of RPS and Regional Haze Glidepaths**

Year	RPS Renewable Requirement % of Electricity Sales	Regional Haze Glidepath % Visibility Improvement	Hawaiian Electric % Renewables
2010	10%	8%	9.5% (actual)
2015	15%	17%	23.2% (actual)
2020	30%	25%	31.9% (projection)
2030	40%	42%	47.3% (projection)
2040	70%	58%	100% (goal)
2045	100%	67%	100% (goal)

Hawaiian Electric’s latest projections show an even more rapid shift to renewable energy sources than forecasted in 2018. This will continue to decrease Hawaiian Electric facility emissions. For example, Figure C-4 illustrates Hawaiian Electric’s latest forecast emissions trends for total nitrogen oxides (“NOx”), sulfur dioxide (“SO<sub>2</sub>”) and Particulate Matter (“PM<sub>10</sub>”) emissions (in tons per year “TPY”) from the six power plants (Waiiau and Kahe Generating Stations on Oahu, Kahului and Maalaea on Maui, and Kanoiehua-Hill and Puna on Hawai’i) requested to conduct Four-Factor Analyses by the Hawai’i Department of Health (“DOH”). These dramatic emissions decreases illustrate the expected progress from RPS alone – without any additional RHR measures. The forecast emissions shown in Figure C-4 was derived from recent fuel consumption projections based on the resource plans and planning assumptions submitted to the PUC as part of Hawaiian Electric’s 2016 Power Supply Improvement Plan (“PSIP”) which was accepted by the PUC and recent renewable project applications.

**Figure C-4 Hawaiian Electric NOx Forecast Emissions**



The emissions reduction is quite rapid and most of the projected reduction by Hawaiian Electric are expected to be in place prior to 2028, the next Regional Haze planning milestone.

Although this projection is based on reasonable assumptions, plans are subject to change as there is some uncertainty regarding future projections and forecast assumptions. For this reason and due to energy security issues, Hawaiian Electric cannot commit to specific dates for particular emissions reductions or final retirements of any specific generating station. Nevertheless, Hawaiian Electric is on an aggressive path to end fossil-fueled generation and replace it with renewable energy sources – especially during this next decadal period. This progress should be sufficient for Hawaiian Electric’s contribution to the state’s efforts regarding reasonable progress of the RHR for the current Regional Haze decadal review.

## **5. Reliance on RPS for this Regional Haze Decadal Review**

The RPS requirements are part of Hawai’i state law. An electric utility failing to meet the RPS requirements is subject to enforcement action and penalties by the PUC unless the PUC determines the electric utility is unable to meet the RPS due to factors beyond its reasonable control. However, given the progress to date of the Hawai’i electric utilities acquiring renewable generation and expectations for planned renewable projects in the near future, it is reasonable to expect that RPS will result in continued steady progress, at least through 2030.

The DOH can rely on the RPS for regional haze progress without having to impose separate RHR requirements in facility permits. This is supported by EPA guidance which states that “Enforceable requirements are one reasonable basis for projecting a change in operating parameters and thus emissions; energy efficiency, renewable energy, or other such programs where there is a documented commitment to participate and verifiable basis for quantifying any change in future emissions due to operational changes may be another.”<sup>7</sup>

Even if progress were slower than currently expected, it would not prevent the RPS from being relied upon as the major EGU contribution to meeting Hawai’i’s regional haze goals. The time perspective of the Regional Haze Program is long. Making wise decisions that help achieve the long-term goals is important. Hawai’i electric utilities are currently focusing resources on advancing renewable energy projects that will permanently displace fossil-fueled unit generation and fossil-fueled combustion emissions. These ongoing RPS efforts help achieve the long-term goals of the RHR and provide permanent emissions reductions and other societal benefits. In contrast, new investments in conventional emissions controls on aging fossil-fueled units provide only modest short-term benefits impose additional costs on rate payers and will have no lasting value when those units are deactivated or retired.

<sup>7</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period – August 2019 at page 17. [https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019\\_-\\_regional\\_haze\\_guidance\\_final\\_guidance.pdf](https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019_-_regional_haze_guidance_final_guidance.pdf).

## **Comments on Four – Factor Analysis**

DAVID Y. IGE  
GOVERNOR OF HAWAII



BRUCE S. ANDERSON, Ph.D.  
DIRECTOR OF HEALTH

STATE OF HAWAII  
DEPARTMENT OF HEALTH  
P.O. Box 3378  
HONOLULU, HAWAII 96801-3378

In reply, please refer to:  
File:

20-325E CAB  
File No. 0232

July 10, 2020

Ms. Karen Kimura  
Director, Environmental Division  
Hawaiian Electric  
P.O. Box 2750  
Honolulu, Hawaii 96840-0001

Dear Ms. Kimura:

**Subject: Four-Factor Analysis for Regional Haze  
Covered Source Permit No. 0232-01-C  
Maui Electric Company, Ltd. (MECO)  
Kahului Generating Station  
Located At: 200 Hobron Avenue, Kahului, Maui**

The Department of Health, Clean Air Branch (CAB) acknowledges receipt of the subject four-factor analysis on March 31, 2020 and has determined the analysis to be incomplete. Please refer to the attached comments for completing the four-factor analysis. Pursuant to 40 Code of Federal Regulations (CFR) §51.308 (d)(1) of the Regional Haze Rule (RHR), the four-factor analysis will be used to establish control measures and reasonable progress goals for Hawaii's Regional Haze State Implementation Plan (RH-SIP).

The CAB requests that you address the comments and resubmit the subject four-factor analysis with the appropriate revisions by **August 10, 2020**.

If there are any questions regarding this matter, please contact Mr. Scott Takamoto of my staff at [REDACTED]

Sincerely,

A handwritten signature in blue ink, appearing to read "Marianne Rossio".

MARIANNE ROSSIO, P.E.  
Manager, Clean Air Branch

ST:rkb

Attachments

c: Debra Miller, National Park Service, Air Resources Division  
Don Shepherd, National Park Service, Air Resources Division  
Melanie Peters, National Park Service, NPS-Air

## Attachment I

After our review and feedback from the National Park Service (NPS) and Environmental Protection Agency (EPA), Region 9, we have the following comments on the four-factor analysis for Boilers K-1 through K-4:

- a. The cost per ton of sulfur dioxide (SO<sub>2</sub>) removed was provided for switching boiler fuel from high sulfur residual fuel oil No. 6 (maximum sulfur content of 2.0%) to a residual/distillate fuel blend with 1% sulfur content and from high sulfur residual fuel oil No. 6 to distillate fuel oil with 0.4% sulfur content. However, there was no cost analysis provided for a fuel switch from high sulfur residual fuel oil No. 6 to ultra-low sulfur diesel (ULSD). Please provide the following for switching boiler fuel from high sulfur residual fuel oil No. 6 to ULSD:
  - i) The cost per ton of SO<sub>2</sub>, nitrogen oxide (NO<sub>x</sub>), and particulate matter less than ten (10) microns in diameter (PM<sub>10</sub>) reduced; and
  - ii) The cost per total combined tons of SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> reduced.
- b. Section 3.2.2 of the analysis states that fuel switching could be implemented within two (2) to three (3) years. Other facilities have reported that a fuel switch could be accomplished within as short as one (1) year. The amount of time specified for switching fuels at the Kahului Generating Station seems excessive. Please explain the reason for the long compliance time and whether there are ways to reduce the time for implementing this control measure.
- c. Section 3.2.3 states that fuel switching to a lower sulfur fuel will increase the cost of electricity. Although the topic was discussed in the technical support document for the Regional Haze Federal Implementation Plan, it is not something we can generally take into consideration for the regional haze analysis in this second planning period.
- d. Sections 3.2.4, 4.2.4, and 5.2.4 state that the remaining useful life of the boilers do not impact the annualized cost of controls because the useful lives of the boilers are assumed to be at least as long as the capital cost recovery period, which is fifteen (15) years. This section of the analysis also indicates that Hawaiian Electric intends to retire Boilers K-1 through K-4, after addition of replacement capacity (energy storage) and new switchyard is installed in 2024. Please note that in the situation of an enforceable requirement for the source to cease operation before the end of the useful life of the controls under consideration, EPA guidance for the second planning period allows the use the enforceable shutdown date as the end of the remaining useful life. This measure would need to be included in the RH-SIP and/or be federally enforceable. Please see 40 CFR §51.308(f)(2). If Hawaiian Electric agrees to make a commitment to the shutdowns through federally enforceable permit limits, the remaining useful life assumed for the control measure is acceptable. The federally enforceable shutdowns could also be used as control measures for showing reasonable progress if the shutdowns occur in the second regional haze planning period (2018-2028). In the situation where an enforceable shutdown date does not exist, the remaining useful life of a control under consideration should be the full period of the useful life of that control as recommended by EPA's Control Cost Manual (CCM). The current (2019) CCM specifies a remaining useful life for SCR at power plants of 30 years and 20 years for other sources.

## Attachment I

- e. The current prime interest rate (currently at 3.25%) should be used to estimate costs of additional emission controls, rather than seven percent (7%) used in the analysis. Please see the following site for the current bank prime rate: <https://www.federalreserve.gov/releases/h15/>. The prime interest rate has not been 7% or higher in the past twelve (12) years. A three percent (3%) interest rate may also be considered.
- f. Flue gas recirculation (FGR) is listed as a technically feasible control option; however, the cost effectiveness of this FGR was not evaluated. Please evaluate the cost effectiveness of FGR for reducing boiler NO<sub>x</sub> emissions.
- g. Please add the combination of FGR plus low NO<sub>x</sub> burner (LNB) and overfire air (OFA) to Table 4.2 and evaluate the cost effectiveness of this combined control measure for the boilers.
- h. Selective non-catalytic reduction (SNCR) is listed as a technically feasible control option; however, the cost effectiveness of SNCR was not evaluated. Please evaluate the cost effectiveness of SNCR for reducing NO<sub>x</sub> emissions from the boiler.
- i. Please add the combination of SNCR plus LNB and OFA to Table 4.2 and evaluate the cost effectiveness of this combined NO<sub>x</sub> control measure for the boilers.
- j. Section 4.1.2.1 states that SCR coupled with LNB plus overfire air OFA achieves an estimated NO<sub>x</sub> control range of 0.03-0.10 pounds per million British thermal units (lb/MMBtu). Can the output rate of 0.1 lb/MMBtu for SCR alone be the same as that for SCR plus LNB and OFA combined? Please add the combination of SCR plus LNB and OFA to Table 4.2 and evaluate the cost effectiveness of this combined control measure for the boilers.
- k. A controlled emission level for NO<sub>x</sub> of 0.1 lb/MMBtu was assumed for SCR in Table 4-3. It is generally assumed that new SCR can achieve 0.05 lb/MMBtu (or lower) on an annual basis. The current (2019) CCM states that a 0.05 lb/MMBtu outlet NO<sub>x</sub> rate based on a 30-day (boiler operating) average should be obtainable by a power plant boiler with an SCR system.
- l. In Tables A-3 and A-4 of Appendix A, it is noted that a retrofit factor of 1.4 was used for retrofitting the boilers with a wet scrubber and wet electrostatic precipitator (ESP), respectively. The retrofit factor was based on the average provided for ESP on Page 3-41. Please provide Page 3-41. Also, for selecting a retrofit factor of greater than one (1), please provide additional detail on the complexities involved with the specific boiler retrofit at the Kahului Generating Station.
- m. Fuel costs are provided in 2019 dollars and the cost for SCR is in 2018 dollars. Please provide SCR costs in 2019 dollars.

## Attachment I

- n. In Footnote B for Table A-2 of Appendix A, a “Maui Construction Cost Multiplier” of 1.938 for SCR is used based on cost of construction geographical multipliers from the “RSMean Mechanical Cost Data 2016” to account for factors unique to Maui’s location plus an additional factor to account for additional Hawaiian Electric loadings and overhead. Retrofit factors pertain to the difficulty of installing a piece of hardware, regardless of location. While we recognize that it is appropriate to take into consideration the higher costs of transporting equipment and supplies, as well as higher labor rates, in unique areas like Hawaii or Alaska, those higher costs must be itemized, justified, and documented.
- o. Table A-3 of Appendix A shows the use of a retrofit factor multiplier of 1.4 for the total capital investment of a wet scrubber for the boilers. For selecting a retrofit factor of greater than one (1), please provide additional detail on the complexities involved with that specific to retrofitting the boilers with a wet scrubber at the Kahului Generating Station.
- p. Appendix B of the four-factor analysis indicated that, in the recent past, Hawaii’s volcanic SO<sub>2</sub> emissions are about 1,000 times greater than anthropogenic SO<sub>2</sub> emissions and volcanic activity in Hawaii produced as much as two (2) million tons of SO<sub>2</sub> per year. Please note that SO<sub>2</sub> emissions have significantly decreased after the Kilauea eruption ended in September 2018. The United States Geological Survey (USGS) stated, that in 2019, the summit is the only source releasing enough SO<sub>2</sub> emissions to be quantified using ultra-violet spectroscopy. Preliminary USGS results for 2019 indicate an average summit daily SO<sub>2</sub> emission rate of about 43 tons and an annual total SO<sub>2</sub> emission rate of about 17,119 tons which is far lower than the two (2) million tons of SO<sub>2</sub> reported to be emitted by the volcano in Appendix B. Note that the total combined SO<sub>2</sub> emissions from point sources screened for four-factor analyses were about 18,058 tons per year in 2017 which is 939 tons higher than preliminary USGS estimates of volcanic SO<sub>2</sub> for 2019. Since Kilauea eruptive activity ended in September 2018, those point sources now play a more significant part in SO<sub>2</sub> visibility impacts.
- q. Appendix B of the four-factor analysis also noted that volcanic activity on Hawaii Island is the largest source of NO<sub>x</sub> in the state based on a NO<sub>x</sub> emission estimate for the Kilauea Volcano of roughly 125,000 tons per year. Data, indicating worldwide volcano NO<sub>x</sub> and SO<sub>2</sub> emissions of 1.5 and 23 teragrams, respectively, was used for the estimate. It was stated that the NO<sub>x</sub> was likely caused by thermal contact of air with lava. Based on the NO<sub>x</sub>/SO<sub>2</sub> ratio using the worldwide numbers, it was then assumed that NO<sub>x</sub> emissions from Kilauea Volcano are about 6% of the volcano’s total SO<sub>2</sub> emissions. It was also assumed that Hawaii volcanic activity emits approximately two (2) million tons per year of SO<sub>2</sub>. Please note that the global ratio of NO<sub>x</sub>/SO<sub>2</sub> is likely not appropriate to use for estimating NO<sub>x</sub> emissions from the Kilauea Volcano. Interagency Monitoring of Protected Visual Environments data shows that annual light extinction from ammonium nitrates for the most impaired days at Haleakala National Park over the current visibility period (2014-2018 when the volcano was erupting) are higher than those at Hawaii Volcanoes National park where the volcano is located. Also, while volcanic SO<sub>2</sub> emissions were reported to be as high as two (2) million tons per year when the Kilauea Volcano was erupting, SO<sub>2</sub> emissions have significantly decreased after the Kilauea eruption ended in September 2018. There currently is no lava in the Kilauea summit crater. Instead, a lake of water has formed in the Kilauea crater after the volcano stopped erupting towards the end of 2018. Please refer to: <https://earthobservatory.nasa.gov/images/146687/a-new-lakewater-not-lavaon-kilauea>.

## Attachment I

- r. In the four-factor analysis, Hawaiian Electric states that no reduction measures in addition to Hawaii's RPS are proposed to meet the RHR requirements. While provisions mandated by the RPS are subject to enforcement action by the Hawaii Public Utilities Commission, these are state only enforceable requirements which are not federally enforceable under the federal Clean Air Act. The RHR requires federally enforceable emission limits and/or RH-SIP approved rule provisions in establishing the long-term strategy for regional haze. As an option, Hawaiian Electric may propose caps for the emissions of visibility impairing pollutants (SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub>) based on anticipated emission reductions from the RPS as a reasonable progress measure that could be incorporated into permits. These emission caps would need to occur in the second planning period (2018-2028) in order to be credited as a control measure for reasonable progress. Additional measures for showing reasonable progress include federally enforceable plant shutdowns as described in comment d above. In essence, Hawaiian Electric could propose: 1) federally enforceable conditions for retiring units during the second implementation planning period (2018-2028) and include those units and retirement dates in the four factor analyses along with a four factor analysis of the remaining equipment; 2) propose federally enforceable emission control measures such as fuel switching or add-on controls with the associated pollutant reductions, or 3) propose federally enforceable permit limits such as emission caps, for operational flexibility, or hour restrictions with the associated compliance dates or any combination of 1, 2, or 3 above.



## **Responses to Comments**

## Attachment 2

### Responses to the DOH's July 10, 2020 Comments

### Regional Haze Four-Factor Analysis, Dated March 31, 2020

### Kahului Generating Station

### Maui Electric Company, Ltd.

- a. The cost per ton of sulfur dioxide (SO<sub>2</sub>) removed was provided for switching boiler fuel from high sulfur residual fuel oil No. 6 (maximum sulfur content of 2.0%) to a residual/distillate fuel blend with 1% sulfur content and from high sulfur residual fuel oil No. 6 to distillate fuel oil with 0.4% sulfur content. However, there was no cost analysis provided for a fuel switch from high sulfur residual fuel oil No. 6 to ultra-low sulfur diesel (ULSD). Please provide the following for switching boiler fuel from high sulfur residual fuel oil No. 6 to ULSD:
- i) The cost per ton of SO<sub>2</sub>, nitrogen oxide (NO<sub>x</sub>), and particulate matter less than ten (10) microns in diameter (PM<sub>10</sub>) reduced; and
  - ii) The cost per total combined tons of SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> reduced.

**Response** – The requested costs will be provided in the updated four-factor analysis report.

- b. Section 3.2.2 of the analysis states that fuel switching could be implemented within two (2) to three (3) years. Other facilities have reported that a fuel switch could be accomplished within as short as one (1) year. The amount of time specified for switching fuels at the Kahului Generating Station seems excessive. Please explain the reason for the long compliance time and whether there are ways to reduce the time for implementing this control measure.

**Response** - Two to three years is a realistic estimate of the timeframe for fuel switching because of several factors: 1) Hawaiian Electric generally requests that the State of Hawai'i Public Utilities Commission approve fuel contracts and issue its Decision and Order within one year following the filing of the application to the Commission; 2) Hawaiian Electric needs to go through a formal process to request bids from fuel suppliers; 3) Negotiations with the fuel supplier can take up to four months; 4) The schedule for any required infrastructure modifications are dependent on the extent of the required changes; 5) If fuel switching is required at other Hawaiian Electric facilities, the type of fuel to be switched and used, the effect on the fuel supply and ability of the local refinery to accommodate the change may significantly be impacted; and 6) Imported fuel may be required if there is a lack of local supply.

- c. Section 3.2.3 states that fuel switching to a lower sulfur fuel will increase the cost of electricity. Although the topic was discussed in the technical support document for the Regional Haze Federal Implementation Plan, it is not something we can generally take into consideration for the regional haze analysis in this second planning period.

**Response** – Fuel costs are directly reflected in customer electricity rates on all islands Hawaiian Electric provides electricity; this is an important cost to the community that must be considered. Hawaiian Electric encourages the DOH to use the flexibility in the EPA's SIP guidance<sup>1</sup> in the selection of control measures necessary to make reasonable progress and to consider additional factors when developing the long-term strategy to improve visibility at Class I areas. Also, note that given the fragile condition of the state's fuel supply and because of Hawaiian Electric's

---

<sup>1</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, August 2019, EPA-457/B-19-003.

position as a major customer in the market, a fuel supply change could have sweeping effects on the island's market that may not be apparent from the cost estimates associated with Hawaiian Electric such as the ability of the local refinery to accommodate the change and potential need for imported fuel. Hawaiian Electric suggests that the DOH needs to take these factors into account in its decision-making process.

- d. Sections 3.2.4, 4.2.4, and 5.2.4 state that the remaining useful life of the boilers do not impact the annualized cost of controls because the useful lives of the boilers are assumed to be at least as long as the capital cost recovery period, which is fifteen (15) years. This section of the analysis also indicates that Hawaiian Electric intends to retire Boilers K-1 through K-4, after addition of replacement capacity (energy storage) and new switchyard is installed in 2024. Please note that in the situation of an enforceable requirement for the source to cease operation before the end of the useful life of the controls under consideration, EPA guidance for the second planning period allows the use the enforceable shutdown date as the end of the remaining useful life. This measure would need to be included in the RH-SIP and/or be federally enforceable. Please see 40 CFR §51.308(f)(2). If Hawaiian Electric agrees to make a commitment to the shutdowns through federally enforceable permit limits, the remaining useful life assumed for the control measure is acceptable. The federally enforceable shutdowns could also be used as control measures for showing reasonable progress if the shutdowns occur in the second regional haze planning period (2018-2028). In the situation where an enforceable shutdown date does not exist, the remaining useful life of a control under consideration should be the full period of the useful life of that control as recommended by EPA's Control Cost Manual (CCM). The current (2019) CCM specifies a remaining useful life for SCR at power plants of 30 years and 20 years for other sources.

**Response** – The capital recovery period will be increased to the CCM recommended value of 30-years for boiler controls (combustion controls, SCR, SO<sub>2</sub> post-combustion controls, and PM post-combustion controls). The capital cost recovery period updates will be included in the updated four-factor analysis report. Hawaiian Electric is still evaluating the retirement of its sources as part of the Regional Haze program, but due to the complexity of retirement factors Hawaiian Electric may provide additional information in the updated four-factor analysis report.

- e. The current prime interest rate (currently at 3.25%) should be used to estimate the costs of additional emission controls, rather than seven percent seven (7%) used in the analysis. Please see the following site for the current bank prime rate: <https://www.federalreserve.gov/releases/h15/>. The prime interest rate has not been seven percent (7%) or higher in the past twelve (12) years. A three (3%) interest rate may also be considered.

**Response** – Hawaiian Electric will continue to use an interest rate of 7% because it is more appropriate than the prime interest rate for the four-factor analyses. The cost analyses follow the Office of Management and Budget (OMB) and EPA Air Pollution Cost Control Manual (CCM) guidance by using an interest rate of 7% for evaluating the cost of capital recovery. The EPA cost manual states that:

*"when performing cost analysis, it is important to ensure that the correct interest rate is being used. Because this Manual is concerned with estimating private costs, the correct interest rate to use is the nominal interest rate, which is the rate firms actually face." <sup>2</sup>*

---

<sup>2</sup> Sorrels, J. and Walton, T. "Cost Estimation: Concepts and Methodology," *EPA Air Pollution Control Cost Manual*, Section 1, Chapter 2, p. 15. U.S. EPA Air Economics Group, November 2017. [https://www.epa.gov/sites/production/files/2017-12/documents/epaccmcostestimationmethodchapter\\_7thedition\\_2017.pdf](https://www.epa.gov/sites/production/files/2017-12/documents/epaccmcostestimationmethodchapter_7thedition_2017.pdf)

For these analyses, which evaluates equipment costs that may take place more than five (5) years into the future, it is important to ensure that the selected interest rate represents a longer-term view of corporate borrowing rates. The CCM cites the bank prime rate as one indicator of the cost of borrowing as an option for use when the specific nominal interest rate is not available. Over the past 20 years, the annual average prime rate has varied from 3.25% to 9.23%, with an overall average of 4.86% over the 20-year period.<sup>3</sup> However, the EPA CCM cautions the use of bank prime rates and states:

*"Analysts should use the bank prime rate with caution as these base rates used by banks do not reflect entity and project specific characteristics and risks including the length of the project, and credit risks of the borrowers."*<sup>4</sup>

For this reason, the prime rate should be considered the low end of the range for estimating capital cost recovery. Actual borrowing costs experienced by firms are typically higher.

For economic evaluations of the impact of federal regulations, the OMB uses an interest rate of 7%. OMB Circular A-4 states:

*"As a default position, OMB Circular A-94 states that a real discount rate of 7 percent should be used as a base-case for regulatory analysis. The 7 percent rate is an estimate of the average before-tax rate of return to private capital in the U.S. economy. It is a broad measure that reflects the returns to real estate and small business capital as well as corporate capital. It approximates the opportunity cost of capital, and it is the appropriate discount rate whenever the main effect of a regulation is to displace or alter the use of capital in the private sector."*<sup>5</sup>

The above statement is confirmed in the EPA CCM with the following statement:

*"When assessing the societal effect of regulations, such as for EPA rulemakings that are economically significant according to Executive Order 12866, analysts should use the 3% and 7% real discount rates as specified in the U.S. Office of Management and Budget (OMB)'s Circular A-4. The 3% discount rate represents the social discount rate when consumption is displaced by regulation and the 7% rate represents the social discount rate when capital investment is displaced."*<sup>6</sup>

- f. Flue gas recirculation (FGR) is listed as a technically feasible control option; however, the cost effectiveness of FGR was not evaluated. Please evaluate the cost effectiveness of FGR for reducing boiler NO<sub>x</sub> emissions.

---

<sup>3</sup> Board of Governors of the Federal Reserve System Data Download Program, "H.15 Selected Interest Rates," accessed April 16, 2020.  
<https://www.federalreserve.gov/datadownload/Download.aspx?rel=H15&series=8193c94824192497563a23e3787878ec&filetype=sheet&label=include&layout=seriescolumn&from=01/01/2000&to=12/31/2020>

<sup>4</sup> Sorrels, J. and Walton, T. "Cost Estimation: Concepts and Methodology," *EPA Air Pollution Control Cost Manual*, Section 1, Chapter 2, p. 16. U.S. EPA Air Economics Group, November 2017.  
[https://www.epa.gov/sites/production/files/2017-12/documents/epacmcostestimationmethodchapter\\_7thedition\\_2017.pdf](https://www.epa.gov/sites/production/files/2017-12/documents/epacmcostestimationmethodchapter_7thedition_2017.pdf)

<sup>5</sup> OMB Circular A-4, <https://www.whitehouse.gov/sites/whitehouse.gov/files/omb/circulars/A4/a-4.pdf> - "

<sup>6</sup> Sorrels, J. and Walton, T. "Cost Estimation: Concepts and Methodology," *EPA Air Pollution Control Cost Manual*, Section 1, Chapter 2, pp. 16-17. U.S. EPA Air Economics Group, November 2017.  
[https://www.epa.gov/sites/production/files/2017-12/documents/epacmcostestimationmethodchapter\\_7thedition\\_2017.pdf](https://www.epa.gov/sites/production/files/2017-12/documents/epacmcostestimationmethodchapter_7thedition_2017.pdf)

**Response** – The combustion controls in the four-factor analysis includes various air pollution reduction technologies and combinations of these technologies. FGR can be combined with LNB, if needed. The LNB with overfire air (OFA) costing provided in Appendix Table A-1 of the four-factor analysis was based on costing provided for LNB and LNB with overfire air. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control. Therefore, the costing provided in Appendix Table A-1 is applicable to range of various combustion controls and combinations of these controls.

For clarification, the provided costing for “LNB w/overfire” air will be renamed to “Combustion Controls” in the updated four-factor analysis report and the discussion in the four-factor analysis will be also updated accordingly.

- g. Please add the combination of FGR plus low NO<sub>x</sub> burner (LNB) and overfire air (OFA) to Table 4.2 and evaluate the cost effectiveness of this combined control measure for the boilers.

**Response** – See the response to item f.

- h. Selective non-catalytic reduction (SNCR) is listed as a technically feasible control option; however, the cost effectiveness of SNCR was not evaluated. Please evaluate the cost effectiveness of SNCR for reducing NO<sub>x</sub> emissions from the boiler.

**Response** – As stated in Section 4.1.2.2 of the four-factor analysis report, the estimated NO<sub>x</sub> control range for SNCR is approximately 0.30-0.40 lb/MMBtu. These estimated control ranges for uncontrolled boilers are in the same range as combustion controls.<sup>7</sup> SNCR is only effective in a relatively high and narrow temperature range and therefore is not suitable for all applications. Several factors determine whether SNCR is an appropriate control for a source, including temperature, residence time, the feasibility of installing reagent injection ports, and the NO<sub>x</sub> concentration.<sup>8</sup> These site-specific operating and design characteristics of the emission unit must be evaluated on a case-by-case basis to determine whether SNCR is feasible. For these reasons, the effectiveness of SNCR will be based on the upper range of the estimated controlled emissions level.

EPA’s SNCR costing spreadsheet was used to calculate the SNCR cost effectiveness for Kahe Generating Station’s units K1 and K5 (wall-fired boiler), K6 (wall-fired boiler with LNB), and K3 (tangentially-fired boiler). The SNCR cost effectiveness calculations for Kahe K1, K3, K5, and K6 are provided as representative costing for wall-fired and tangentially-fired boilers. Hawaiian Electric proposes to use this SNCR costing as a representative analysis for boilers at the Kahe, Waiiau, Kahului, Kanoiehua-Hill, and Puna Generating Stations instead of providing SNCR costing for each boiler. Due to the uncertainty in the level of control offered by SNCR, the upper control range was used (0.40 lb/MMBtu for wall-fired boilers (K1 and K5) and 0.25 lb/MMBtu for tangentially-fired boilers) in the cost effectiveness calculations. For K6 a control level of 25% (0.15 lb/MMBtu) was used in the cost effectiveness calculation.

The expanded cost effectiveness results for Kahe units K1, K3, K5, and K6 are provided in Attachment 3 included with this Response to Comments attachment. The cost effectiveness of SNCR added to uncontrolled boilers is greater than combustion controls and offers less control. SNCR has a lower cost effectiveness than SCR and SCR plus combustion controls. However, SNCR results in a lower level of control than SCR alone and SCR plus combustion controls. Based on

---

<sup>7</sup> *Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler*, EPA, 1994.

<sup>8</sup> *Cost Control Manual, Selective Noncatalytic Reduction*, EPA, 2019.

the provided SNCR results, SNCR does not offer a significantly better control option than combustion controls, SCR, or SCR plus combustion controls.

The SNCR upper control range for Kahului units K1 through K4 (wall-fired boilers) is 0.40 lb/MMBtu based on the evaluation performed for Kahe unit K1 which is also a wall-fired boiler.

The SNCR costing spreadsheet and the cost effectiveness results are provided in Attachment 4 included with this Response to Comments attachment.

- i. Please add the combination of SNCR plus LNB and OFA to Table 4.2 and evaluate the cost effectiveness of this combined NO<sub>x</sub> control measure for the boilers.

**Response** – Due to the uncertainty in the level of control offered by SNCR, the combination of combustion controls and SNCR has the same level of expected control range as SNCR alone, approximately 0.20-0.40 lb/MMBtu for wall-fired boilers and approximately 0.15-0.25 lb/MMBtu for tangentially-fired boilers. The SNCR plus combustion controls cost effectiveness calculations for Kahe K1, K5, and K3 are provided as representative costing for wall-fired and tangentially-fired boilers, respectively. The cost effectiveness calculation is based on controlled emission levels of 0.2 lb/MMBtu for Kahe K1 and K5 (wall-fired boiler) and 0.15 lb/MMBtu for Kahe K3 (tangentially-fired boiler).

The expanded cost effectiveness results for Kahe K1, K3, K5, and K6 are provided in Attachment 3 included with this Response to Comments attachment and will be also be included in the updated four-factor analysis report. SNCR plus combustion controls has a lower cost effectiveness than SCR and SCR plus combustion controls. However, SNCR plus combustion controls results in a lower level of control than SCR and SCR plus combustion controls. Based on the provided SNCR plus combustion controls results, SNCR plus combustion controls does not offer a significantly better control option than SCR or SCR plus combustion controls. Hawaiian Electric proposes to use this SNCR plus combustion controls costing as a representative analysis for boilers at the Kahe, Waiau, Kahului, Kanoolehua-Hill, and Puna Generating Stations instead of provided SNCR costing for each boiler.

- j. Section 4.1.2.1 states that SCR coupled with LNB plus overfire air OFA achieves an estimated NO<sub>x</sub> control range of 0.03-0.10 pounds per million British thermal units (lb/MMBtu). Can the output rate of 0.1 lb/MMBtu for SCR alone be the same as that for SCR plus LNB and OFA combined? Please add the combination of SCR plus LNB and OFA to Table 4.2 and evaluate the cost effectiveness of this combined control measure for the boilers.

**Response** – Section 4.1.2.1 states the estimated NO<sub>x</sub> control range for SCR is 0.05-0.10 lb/MMBtu and the estimated NO<sub>x</sub> control range for LNB plus OFA combined with SCR plus is 0.03-0.10 lb/MMBtu. The estimated NO<sub>x</sub> control ranges have different maximum levels of control. However, the minimum control levels are assumed to be the same. The cost effectiveness of SCR plus combustion controls to a level of 0.05 lb/MMBtu will be added to Table 4-3 in the updated four-factor analysis report.

- k. A controlled emission level for NO<sub>x</sub> of 0.1 lb/MMBtu was assumed for SCR in Table 4-3. It is generally assumed that new SCR can achieve 0.05 lb/MMBtu (or lower) on an annual basis. The current (2019) CCM states that a 0.05 lb/MMBtu outlet NO<sub>x</sub> rate based on a 30-day (boiler operating) average should be obtainable by a power plant boiler with an SCR system.

**Response** – The 0.05 lb/MMBtu referenced in the CCM generally applies to boilers equipped with combustion controls. As stated in the above response, the combination of SCR plus

combustion controls is expected to reduce NO<sub>x</sub> emissions to 0.05 lb/MMBtu. Several factors go into the level of control that SCR can provide. For these reasons, the level of SCR control for K1-K4 was set to 0.1lb/MMBtu. The requested updates will be provided in the updated four-factor analysis report.

- i. In Tables A-3 and A-4 of Appendix A, it is noted that a retrofit factor of 1.4 was used for retrofitting the boilers with a wet scrubber and wet electrostatic precipitator (ESP), respectively. The retrofit factor was based on the average provided for ESP on Page 3-41. Please provide Page 3-41. Also, for selecting a retrofit factor of greater than one (1), please provide additional detail on the complexities involved with the specific boiler retrofit at the Kahului Generating Station.

**Response** – The EPA Air Pollution Control Cost Manual (CCM) recommends a retrofit factor of 0.8 should be used for new construction and a retrofit factor of 1 should be used for average retrofits. The CCM lists the following specific factors that impact retrofit costs:

- The amount of available space between and around the economizer and air heater;
- Congestion downstream of the air heater (i.e., buildings, ID fan, or stack);
- The age/vintage and manufacturer of the boiler;
- The design margin of the existing ID fan (i.e., the need to upgrade or replace fan impellers, replace ID fans, or add booster fans);
- The capacity, condition, and design margins of the electrical distribution system;
- The design margins of the existing structural steel support systems;
- The positive and negative design pressure of the furnace; and
- The number, nature, and type of existing items that must be relocated to accommodate the SCR and associated systems.

Although all of the factors listed above will impact the retrofit costs for the Kahului boilers, to determine the specific degree of impact for each individual factor would require a more detailed engineering study to evaluate, provide, and itemize the cost impact of the above factors. It is estimated that such an engineering study could take an up to eight (8) months to complete at a cost of approximately \$415,000 for the Kahului Generating Station. In addition, Hawai'i's higher construction cost impacts the cost to address the required equipment upgrades and space constraints which require relocation of existing equipment. Based on these factors, rather than engage in additional time consuming and costly studies, the more conservative upper range of the retrofit factor was selected.

- m. Fuel costs are provided in 2019 dollars and the cost for SCR is in 2018 dollars. Please provide SCR costs in 2019 dollars.

**Response** – The Chemical Engineering Plant Cost Index (CEPCI) for 2019 equals 607.5 which represents a 0.7% increase in cost from 2018. The control costs will be adjusted to 2019 dollars. The requested updates will be provided in the updated four-factor analysis report.

- n. In Footnote B for Table A-2 of Appendix A, a “Maui Construction Cost Multiplier” of 1.938 for SCR is used based on cost of construction geographical multipliers from the “RSMMeans Mechanical Cost Data 2016” to account for factors unique to Maui’s location plus an additional factor to account for additional Hawaiian Electric loadings and overhead. Retrofit factors pertain to the difficulty of installing a piece of hardware, regardless of location. While we recognize that it is appropriate to take into consideration the higher costs of transporting equipment and supplies, as well as higher labor rates, in unique areas like Hawaii or Alaska, those higher costs must be itemized, justified, and documented.

**Response** – The use of a retrofit factor in lieu of itemized costing is a common method contained in the EPA CCM. The EPA CCM lists the following specific factors that impact retrofit costs:

- The amount of available space between and around the economizer and air heater;
- Congestion downstream of the air heater (i.e., buildings, ID fan, or stack);
- The age/vintage and manufacturer of the boiler;
- The design margin of the existing ID fan (i.e., the need to upgrade or replace fan impellers, replace ID fans, or add booster fans);
- The capacity, condition, and design margins of the electrical distribution system;
- The design margins of the existing structural steel support systems;
- The positive and negative design pressure of the furnace; and
- The number, nature, and type of existing items that must be relocated to accommodate the add-on controls and associated systems.

Although all of the factors listed above will impact the retrofit costs for the Kahului boilers, to determine the specific degree of impact for each individual factor would require a more detailed engineering study to evaluate, provide, and itemize the cost impact of the above factors. It is estimated that such an engineering study could take an up to eight (8) months to complete at a cost of approximately \$415,000 for the Kahului Generating Station. In addition, Hawai'i's higher construction cost impacts the cost to address the required equipment upgrades and space constraints which require relocation of existing equipment. Based on these factors, rather than engage in additional time consuming and costly studies, the more conservative upper range of the retrofit factor was selected.

- o. Table A-3 of Appendix A shows the use of a retrofit factor multiplier of 1.4 for the total capital investment of a wet scrubber for the boilers. For selecting a retrofit factor of greater than one (1), please provide additional detail on the complexities involved with that specific to retrofitting the boilers with a wet scrubber at the Kahului Generating Station.

**Response** – See response to item l.

- p. Appendix B of the four-factor analysis indicated that, in the recent past, Hawai'i's volcanic SO<sub>2</sub> emissions are about 1,000 times greater than anthropogenic SO<sub>2</sub> emissions and volcanic activity in Hawaii produced as much as two (2) million tons of SO<sub>2</sub> per year. Please note that SO<sub>2</sub> emissions have significantly decreased after the Kilauea eruption ended in September 2018. The United States Geological Survey (USGS) stated, that in 2019, the summit is the only source releasing enough SO<sub>2</sub> emissions to be quantified using ultra-violet spectroscopy. Preliminary USGS results for 2019 indicate an average summit daily SO<sub>2</sub> emission rate of about 43 tons and an annual total SO<sub>2</sub> emission rate of about 17,119 tons which is far lower than the two (2) million tons of SO<sub>2</sub> reported to be emitted by the volcano in Appendix B. Note that the total combined SO<sub>2</sub> emissions from point sources screened for four-factor analyses were about 18,058 tons per year in 2017 which is 939 tons higher than preliminary USGS estimates of volcanic SO<sub>2</sub> for 2019. Since Kilauea eruptive activity ended in September 2018, those point sources now play a more significant part in SO<sub>2</sub> visibility impacts.

**Response** – Hawaiian Electric agrees that the volcanic SO<sub>2</sub> emissions have significantly decreased since September 2018. The four-factor analysis report Appendix B will be updated to acknowledge this change in the volcanic emissions. However, Hawaiian Electric does not believe that this changes the overall conclusion of the analysis which indicated that the Maui Electric power plants are not significant contributors to visibility impairment at Hawai'i's Class I areas.



Although the percent impact of point sources will increase with less volcanic emissions, the absolute value of the point source impacts is unchanged.

Maui Electric sources on Maui are not upwind of either Class I area and do not have any significant impact on the visibility at either area. As mentioned in the four-factor analysis report, EPA CALPUFF modeling conducted for the First Decadal Review confirms the expected low impacts from these sources.

As discussed in Section 2.1 of the four-factor analysis report, Step 1 of the EPA SIP guidance is to identify the 20 percent most anthropogenically impaired days, which requires factoring out volcanic impacts. Hawaiian Electric understands that volcanic activity has decreased since the September 2018. The reduction in volcanic activity should be visible in the 2019 IMPROVE monitoring data. The DOH should review the 2019 IMPROVE monitoring data to assist with defining the level of anthropogenic impaired.

Additionally, Hawaiian Electric, as a key affected company, would like to participate as a stakeholder in discussing and reviewing the EPA's photochemical modeling and the Western Regional Air Partnership's Hybrid-Single Particle Lagrangian Integrated Trajectory (HYSPLIT) modeling mentioned during the conference call with Hawaiian Electric and the DOH on July 30, 2020.

- q. Appendix B of the four-factor analysis also noted that volcanic activity on Hawaii Island is the largest source of NO<sub>x</sub> in the state based on a NO<sub>x</sub> emission estimate for the Kilauea Volcano of roughly 125,000 tons per year. Data, indicating worldwide volcano NO<sub>x</sub> and SO<sub>2</sub> emissions of 1.5 and 23 teragrams, respectively, was used for the estimate. It was stated that the NO<sub>x</sub> was likely caused by thermal contact of air with lava. Based on the NO<sub>x</sub>/SO<sub>2</sub> ratio using the worldwide numbers, it was then assumed that NO<sub>x</sub> emissions from Kilauea Volcano are about 6% of the volcano's total SO<sub>2</sub> emissions. It was also assumed that Hawaii volcanic activity emits approximately two (2) million tons per year of SO<sub>2</sub>. Please note that the global ratio of NO<sub>x</sub>/SO<sub>2</sub> is likely not appropriate to use for estimating NO<sub>x</sub> emissions from the Kilauea Volcano. Interagency Monitoring of Protected Visual Environments data shows that annual light extinction from ammonium nitrates for the most impaired days at Haleakala National Park over the current visibility period (2014-2018 when the volcano was erupting) are higher than those at Hawaii Volcanoes National park where the volcano is located. Also, while volcanic SO<sub>2</sub> emissions were reported to be as high as two (2) million tons per year when the Kilauea Volcano was erupting, SO<sub>2</sub> emissions have significantly decreased after the Kilauea eruption ended in September 2018. There currently is no lava in the Kilauea summit crater. Instead, a lake of water has formed in the Kilauea crater after the volcano stopped erupting towards the end of 2018. Please refer to: <https://earthobservatory.nasa.gov/images/146687/a-new-lakewater-not-lava-on-kilauea>.

**Response** – Hawaiian Electric recognizes that estimates of NO<sub>x</sub> emissions from the volcano are uncertain as are the significance of its impact to nitrate haze. Appendix B of the four-factor analysis report will be updated to recognize this and acknowledge that monitoring data does not suggest a large impact from the volcanos. However, more importantly, as discussed in the four-factor analysis report, monitoring data for both National Parks shows that the total contribution of nitrates from all sources to haze is very low as both a percentage of the total impairment, but is also low as an absolute value for extinction (visibility impairment). The total nitrate haze impairment is approximately 1 inverse megameter (“Mm<sup>-1</sup>”), an extremely small value which is the total due to ALL sources, natural and anthropogenic. The small impact of NO<sub>x</sub> emissions to haze formation is due to the unique chemistry of nitrate haze and Hawai'i's generally warm weather year-round as explained in the four-factor analysis report.

Regarding the noted significant decrease in volcanic SO<sub>2</sub> emissions, see the previous response to item p.

- r. In the four-factor analysis, Hawaiian Electric states that no reduction measures in addition to Hawaii's RPS are proposed to meet the RHR requirements. While provisions mandated by the RPS are subject to enforcement action by the Hawaii Public Utilities Commission, these are state only enforceable requirements which are not federally enforceable under the federal Clean Air Act. The RHR requires federally enforceable emission limits and/or RH- SIP approved rule provisions in establishing the long-term strategy for regional haze. As an option, Hawaiian Electric may propose caps for the emissions of visibility impairing pollutants (SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub>) based on anticipated emission reductions from the RPS as a reasonable progress measure that could be incorporated into permits. These emission caps would need to occur in the second planning period (2018-2028) in order to be credited as a control measure for reasonable progress. Additional measures for showing reasonable progress include federally enforceable plant shutdowns as described in comment d above. In essence, Hawaiian Electric could propose: 1) federally enforceable conditions for retiring units during the second implementation planning period (2018-2028) and include those units and retirement dates in the four factor analyses along with a four factor analysis of the remaining equipment; 2) propose federally enforceable emission control measures such as fuel switching or add-on controls with the associated pollutant reductions, or 3) propose federally enforceable permit limits such as emission caps, for operational flexibility, or hour restrictions with the associated compliance dates or any combination of 1, 2, or 3 above.

**Response** – As Hawaiian Electric set forth in the four-factor analysis report (see in particular Appendix C) continues to assert that several of its programs can in fact be used to show that their emissions are being reduced in a manner that shows reasonable progress.

EPA's *Guidance on Regional Haze State Implementation Plans for the Second Implementation Period* (SIP Guidance) allows for the use of renewable energy programs as an alternative to permit limits. Also, the SIP Guidance encourages the use of projected 2028 emissions in selecting emission controls required to show reasonable progress and allows for energy efficiency, renewable energy, or other such programs where there is a documented commitment to participate and a verifiable basis for quantifying any change in future emissions due to operational changes. Hawaiian Electric's progress towards meeting the RPS is documented in annual reports to the Public Utility Commission (PUC) see also Appendix C to the Four Factor Reports. In addition, the status of future renewable projects are listed on the *Renewable Project Status Board* on the Hawaiian Electric website.<sup>9</sup> The addition of renewable energy is an operational change that reduces fossil fuel consumption, which results in reductions in emissions of visibility impairing pollutants.

The EPA's Regional Haze SIP Guidance supports the use of the State's RPS as an alternative to permit limits as it states:

**" Step 3: Selection of sources for analysis**

...

***Selection of emissions information when estimating visibility impacts (or surrogates) for source selection purposes***

\*\*\*\*

*All of the techniques described above require estimates of source emissions. Generally, we recommend that states use estimates of 2028 emissions (resolved by day and hour, as*

---

<sup>9</sup> Renewable Project Status Board (<https://www.hawaiianelectric.com/clean-energy-hawaii/our-clean-energy-portfolio/renewable-project-status-board>)

*appropriate) to estimate visibility impacts (or related surrogates) when selecting sources, rather than values of recent year emissions. By doing so, sources that are projected on a reasonable basis to cease or greatly reduce their operations or to install much more effective emissions controls by 2028 may be removed from further consideration early in the SIP development process, which can reduce analytical costs. Generally, the estimate of a source's 2028 emissions is based at least in part on information on the source's operation and emissions in a representative historical period. However, there may be circumstances under which it is reasonable to project that 2028 operations will differ significantly from historical emissions. Enforceable requirements are one reasonable basis for projecting a change in operating parameters and thus emissions: energy efficiency, renewable energy, or other such programs where there is a documented commitment to participate and a verifiable basis for quantifying any change in future emissions due to operational changes may be another. A state considering using assumptions about future operating parameters that are significantly different than historical operating parameters should consult with its EPA Regional office.*

*If a state uses a value for emissions in an earlier year, we recommend the state consider whether emissions have appreciably changed (or will change) between the earlier year, the current period, and the projected future year (2028). It is especially important to consider whether source emissions have increased or are likely to increase in the future compared to earlier emissions values.*

***Use of actual emissions versus allowable emissions***

*Generally, we recommend that a reasonably projected actual level of source operation in 2028 be used to estimate 2028 actual emissions for purposes of selecting sources for control measure analysis. Source operation during a historical period can inform this projection, but temporary factors that suppressed or bolstered the level of operation in the historical period should be considered, along with factors that indicate a likely increase or decrease in operation.*

...

***Step 4: Characterization of factors for emission control measures***

...

*Examples of types of emission control measures states may consider States have the flexibility to reasonably determine which control measures to evaluate, and the following is a list of example types of control measures that states may consider:*

...

*Energy efficiency and renewable energy measures that could be applied elsewhere in a state to reduce emissions from EGUs.*

...

*EPA understands that some states may be interested in exploring such measures for their second implementation period SIPs, which is generally appropriate. We suggest such states discuss the measures and programs and their incorporation into the SIP with their EPA Regional office..."<sup>10</sup>*

Based on the above EPA guidance, the selection of controls for the long-term strategy (LTS) can include alternatives to permit limits and rely on projected emissions based on the planned transition to 100% renewable energy. For example various RPS goals across the 48 contiguous

---

<sup>10</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, page 17, August 2019, EPA-457/B-19-003. <https://www.epa.gov/visibility/guidance-regional-haze-state-implementation-plans-second-implementation-period>

states were used as inputs in the EPA's Integrated Planning Model (IPM)<sup>11,12</sup> to project EGU emissions. The CAM<sub>x</sub> modeling used these projected emissions to support the LTS for 2028 (SIP Guidance Steps 5 and 6).

The Readiness Survey that was conducted by the Western Regional Air Partnership (WRAP) states:

*Hawaiian Electric plans to use Hawai'i's existing Renewable Portfolio Standard (RPS) as a measure to make reasonable progress. The RPS ultimately requires the Hawaiian Electric Company to establish 100% renewable energy sales by 2045 to reduce fossil fuel consumption for mitigating GHGs. Mitigating GHGs will also reduce pollutants that impair visibility as a co-benefit. Hawaiian Electric Companies' Power Supply Improvement Plan (PSIP) provides future plans for the utility and independent power producers to achieve 100% RPS by 2045. The PSIP may be used to establish permit conditions to limit the emissions of pollutants that impair visibility for meeting reasonable progress goals. In accordance with our Hawai'i Administrative Rules (HAR), point sources are subject to a GHG emission cap to ensure emissions from stationary sources (both minor and major) return to 1990 GHG levels by 2020. The GHG emissions cap must be at least 16% below the baseline level unless the affected facility demonstrates that a 16% reduction is unattainable.*

Although based on the analysis herein, we do not believe that permit conditions are required to use the RPS to show progress, nor is it practical to do so given the difficulty in predicting the specifics of the RPS progress. However, Hawaiian Electric intends to provide a further analysis that may include additional strategies to include these two programs in its updated four-factor analysis report.

---

<sup>11</sup> Technical Support Document for EPA's Updated 2028 Regional Haze Modeling, pages 11-12, September 2019. [https://www.epa.gov/sites/production/files/2019-10/documents/updated\\_2028\\_regional\\_haze\\_modeling-tsd-2019\\_0.pdf](https://www.epa.gov/sites/production/files/2019-10/documents/updated_2028_regional_haze_modeling-tsd-2019_0.pdf)

<sup>12</sup> Power Sector Modeling Platform v6 November 2018. <https://www.epa.gov/airmarkets/power-sector-modeling-platform-v6-november-2018>

## **Revised Four – Factor Analysis**



**REGIONAL HAZE FOUR-FACTOR ANALYSIS**  
**Kahului Generating Station**



Prepared By:

J. Stephen Beene – Senior Consultant  
Jeremy Jewell – Principal Consultant

**TRINITY CONSULTANTS**  
12700 Park Central Drive  
Suite 2100  
Dallas, TX 75251

March 2020  
Revised September 25, 2020

Project 194401.0299



*EHS solutions delivered uncommonly well*

## TABLE OF CONTENTS

<b>1. EXECUTIVE SUMMARY</b>	<b>1-1</b>
<b>2. BACKGROUND AND ADDITIONAL FACTORS</b>	<b>2-2</b>
2.1. Regional Haze Rule Background .....	2-2
2.2. Additional Factors.....	2-4
<b>3. SULFUR DIOXIDE FOUR-FACTOR ANALYSIS</b>	<b>3-1</b>
3.1. Sulfur Dioxide Control Options.....	3-1
3.2. Four-Factor Analysis.....	3-3
3.3. Sulfur Dioxide Conclusion .....	3-7
<b>4. NITROGEN OXIDES FOUR-FACTOR ANALYSIS</b>	<b>4-1</b>
4.1. Nitrogen Oxides Control Options .....	4-1
4.2. Four-Factor Analysis.....	4-5
4.3. Nitrogen Oxides Conclusion.....	4-8
<b>5. PARTICULATE MATTER FOUR-FACTOR ANALYSIS</b>	<b>5-1</b>
5.1. Particulate Matter Control Options.....	5-1
5.2. Four-Factor Analysis.....	5-3
5.3. Particulate Matter Conclusion .....	5-5
<b>6. TOTAL COST EFFECTIVENESS OF FUEL SWITCHING</b>	<b>6-1</b>
<b>APPENDIX A: DETAILED COSTING</b>	<b>A-1</b>
<b>APPENDIX B: HAWAIIAN ELECTRIC REGIONAL HAZE VISIBILITY CONSIDERATIONS</b>	<b>B-1</b>
<b>APPENDIX C: HAWAII'S RENEWABLE PORTFOLIO STANDARDS CONTRIBUTION TO REGIONAL HAZE PROGRESS</b>	<b>C-1</b>
<b>APPENDIX D: FUEL COST</b>	<b>D-1</b>

## LIST OF TABLES

---

Table 3-1. 2017 Fuel Property Data and Usage and Baseline SO <sub>2</sub> Emissions	3-1
Table 3-2. SO <sub>2</sub> Cost Effectiveness of Switching to a Residual Oil/Diesel Blended Fuel	3-5
Table 3-3. SO <sub>2</sub> Cost Effectiveness of Switching to Diesel	3-5
Table 3-4. SO <sub>2</sub> Cost Effectiveness of Switching to a Residual Oil/ULSD Blended Fuel	3-6
Table 3-5. SO <sub>2</sub> Cost Effectiveness of Switching to ULSD	3-6
Table 4-1. Baseline NO <sub>x</sub> Emissions	4-1
Table 4-2. NO <sub>x</sub> Reduction from Fuel Switching	4-2
Table 4-3. Control Effectiveness of Technically Feasible NO <sub>x</sub> Control Technologies	4-4
Table 4-4. NO <sub>x</sub> Cost Effectiveness Summary	4-7
Table 5-1. Baseline PM <sub>10</sub> Emissions	5-1
Table 5-2. PM <sub>10</sub> Reduction from Fuel Switching	5-2
Table 5-3. PM <sub>10</sub> Cost Effectiveness Summary	5-4
Table 6-1. Total Cost Effectiveness of Fuel Switching	6-1



## 1. EXECUTIVE SUMMARY

---

The State of Hawai'i has two Class I areas (National Parks) that trigger compliance with the Regional Haze Rule (RHR); Hawai'i's Mandatory Federal Class I Areas are Haleakalā National Park on Maui Island and Hawai'i Volcanoes National Park on the Hawai'i Island. This report documents the results of the RHR second planning period four-factor analysis conducted by Trinity Consultants (Trinity) on behalf of Hawaiian Electric<sup>1</sup> for the four boilers at the Kahului Generating Station (Kahului): K1, K2, K3, and K4. The boilers are each wall-fired and currently burn residual oil with a maximum sulfur content of 2.0 percent by weight (residual oil, residual high sulfur fuel oil). The boilers have nominal ratings of 5.0 megawatts (MW), 5.0 MW, 11.5 MW and 12.5 MW, respectively. Also, Appendix B and Appendix C contain analyses performed by AECOM Technical Services, Inc. (AECOM) of a fifth factor that includes a review of visibility impacts.

This report addresses the options that could be considered that have the potential to lower emissions and show reasonable progress toward the RHR goals. The results of the four-factor analysis herein are consistent with the conclusions reached for the first planning period Best Available Retrofit Technology (BART) five-factor analysis for Kahului. Other long-term emission reduction strategies, such as those included as part of Hawai'i's Renewable Portfolio Standards (RPS), the Hawaiian Electric Partnership Greenhouse Gas Emissions Reduction Plan (GHG ERP) required by Act 234 and the associated State of Hawai'i Department of Health (DOH) GHG Emissions Regulations (Hawaii Administrative Rules Title 11, Chapter 60.1, Subchapter 11) which require State enforceable GHG emissions limits, and Hawai'i's Energy Efficiency Portfolio Standard (EEPS), are viable alternatives to emissions reductions from add-on controls and changes in the method of operations.

Hawaiian Electric and AECOM met with the DOH on February 12, 2020 to present special circumstances applicable in Hawai'i that should be given consideration in the development of the Hawai'i Regional Haze State Implementation Plan (SIP). Significant among those circumstances is Hawai'i's Statutory RPS which have put the state on a timetable to accomplish the same goals as the RHR twenty (20) years before the actual Regional Haze 2064 target date. These same issues were addressed by the U.S. Environmental Protection Agency (EPA) in the Federal Implementation Plan (FIP) and the DOH in its Progress Report<sup>2</sup> that was approved by the EPA effective on September 11, 2019. These special considerations are discussed further in Appendix B and Appendix C to this report.

Based on the four-factor analysis, Hawaiian Electric does not propose any emissions reduction measures in addition to the Hawai'i RPS, EEPS, and the GHG ERP to meet the RHR requirements.

<sup>1</sup> Hawaiian Electric" or the "Company" refers to Hawaiian Electric Company, Inc. (or "HE"), Hawai'i Electric Light Company, Inc. (or "HL") and/or Maui Electric Company, Limited (or "ME"). On December 20, 2019, the State of Hawai'i Department of Commerce and Consumer Affairs ("DCCA") approved Hawaiian Electric Company, Inc., Hawai'i Electric Light Company, Inc. and Maui Electric Company, Limited's application to do business under the trade name "Hawaiian Electric" for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.

<sup>2</sup> 5-Year Regional Haze Progress Report For Federal Implementation Plan, Hawai'i State Department of Health, October 2017, EPA-R09-OAR-2018-0744-0004

## 2. BACKGROUND AND ADDITIONAL FACTORS

### 2.1. REGIONAL HAZE RULE BACKGROUND

In the 1977 amendments to the federal Clean Air Act (CAA), the U.S. Congress set a nation-wide goal to restore national parks and wilderness areas to natural visibility conditions by remedying existing, anthropogenic visibility impairment and preventing future impairments. On July 1, 1999, the EPA published the final RHR (40 CFR Part 51, Subpart P). The objective of the RHR is to restore visibility to natural conditions in 156 specific areas across the United States, known as Federal Class I areas. The CAA defines Class I areas as certain national parks (over 6,000 acres), wilderness areas (over 5,000 acres), national memorial parks (over 5,000 acres)<sup>3</sup>, and international parks that were in existence on August 7, 1977.

The RHR requires states to set goals that provide for reasonable progress towards achieving natural visibility conditions for each Class I area in their jurisdiction. In establishing a reasonable progress goal for a Class I area, each state must:

- (A) *Consider the costs of compliance, the time necessary for compliance, the energy and non-air quality environmental impacts of compliance, and the remaining useful life of any potentially affected sources, and include a demonstration showing how these factors were taken into consideration in selecting the goal. 40 CFR 51. 308(d)(1)(i)(A).* This is known as a four-factor analysis.
- (B) *Analyze and determine the rate of progress needed to attain natural visibility conditions by the year 2064. To calculate this rate of progress, the State must compare baseline visibility conditions to natural visibility conditions in the mandatory Federal Class I area and determine the uniform rate of visibility improvement (measured in deciviews) that would need to be maintained during each implementation period in order to attain natural visibility conditions by 2064. In establishing the reasonable progress goal, the State must consider the uniform rate of improvement in visibility and the emission reduction. 40 CFR 51. 308(d)(1)(i)(B).* The uniform rate of progress or improvement is sometimes referred to as the glidepath and is part of the state's Long Term Strategy (LTS).

During the first implementation period the EPA issued a FIP (77 FR 61478, October 9, 2012; see also *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawaii Air Division* U.S. EPA Region 9, May 14, 2012) which determined for the first planning period that nitrogen oxides (NO<sub>x</sub>) was not contributing to regional haze significantly as to require control measures, and that the Oahu sources were not significantly contributing to regional haze. Additionally, as part of the EPA's decision with respect to BART controls, the EPA took into account that controls would result in "unduly increasing electricity rates in Hawai'i." (see 77 FR 31707, May 29, 2012).

The control measures that were imposed established an emissions cap of 3,550 tons of sulfur dioxide (SO<sub>2</sub>) per year from the fuel oil-fired boilers at Hawai'i Electric Light's Hill, Shipman and Puna generating stations, beginning in January 1, 2018, at an estimated cost of 7.9 million dollars per year. According to the FIP, this represents a reduction of 1,400 tons per year from the total projected 2018 annual emissions of SO<sub>2</sub> from these facilities. This control measure, in conjunction with SO<sub>2</sub> and NO<sub>x</sub> emissions control requirements that are already in place, was found to ensure that reasonable progress

<sup>3</sup> The Class I areas in the state of Hawai'i include the Hawai'i Volcanoes National Park on the Hawai'i Island, and Haleakalā National Park on Maui.

is made during this first planning period toward the national goal of no anthropogenic visibility impairment by 2064 at Hawai'i's two Class I areas.

The second implementation planning period (2019-2028) for the national regional haze efforts is currently underway. The EPA's *Guidance on Regional Haze State Implementation Plans for the Second Implementation Period* (SIP Guidance)<sup>4</sup> provides guidance for the development of the implementation plans. There are a few key distinctions from the processes that took place during the first planning period (2004-2018). Most notably, the second planning period analysis distinguishes between natural (or "biogenic") and manmade (or "anthropogenic") sources of emissions. EPA's *Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program* (Visibility Guidance)<sup>5</sup> provides guidance to states on methods for selecting the twenty (20) percent most impaired days to track visibility and determining natural visibility conditions. The approach described in this guidance document does not expressly attempt to account for haze formed from natural volcanic emissions; however, the 2017 RHR defines visibility impairment or anthropogenic visibility impairment as:

*any humanly perceptible difference due to air pollution from anthropogenic sources between actual visibility and natural visibility on one or more days. Because natural visibility can only be estimated or inferred, visibility impairment also is estimated or inferred rather than directly measured.*

EPA's Visibility Guidance states that although they did not attempt to account for haze formed by natural volcanic emissions:

*We encourage states with Class I areas affected by volcanic emissions to work with their EPA Regional office to determine an appropriate approach for determining which days are the 20 percent most anthropogenically impaired days.*

In the *5-Year Regional Haze Progress Report For Federal Implementation Plan*<sup>6</sup> the DOH acknowledges the impact of SO<sub>2</sub> from the Kilauea volcano with the following statement:

*A majority of the visibility degradation is due to the ongoing release of SO<sub>2</sub> from Kilauea volcano with emissions that vary by hundreds of thousands of tons from one year to another. Visibility improvement from significant reductions in Maui and Hawaii Island point source SO<sub>2</sub> is obscured by sulfate from natural volcanic SO<sub>2</sub> that overwhelms sulfate from anthropogenic SO<sub>2</sub> sources.*

Step 1 of the EPA's SIP Guidance is to identify the twenty (20) percent most anthropogenically impaired days and the twenty (20) percent clearest days and determine baseline, current, and natural visibility conditions for each Class I area within the state (40 CFR 51.308(f)(1)). Hawaiian Electric has concerns that this key step may not be accounted for during the second implementation planning and the development of Hawai'i's RHR SIP. The identification of the twenty (20) percent most impaired days sets the foundation for identifying any needed emissions reductions.

Pursuant to 40 CFR 51.308(d)(3)(iv), the states are responsible for identifying the sources that contribute to the most impaired days in the Class I areas. To accomplish this, the Western Regional Air Partnership (WRAP), with Ramboll US Corporation, reviewed the 2014 National Emissions Inventory (NEI) and assessed each facility's impact on visibility in Class I areas with a "Q/d" analysis, where "Q" is the magnitude of emissions that impact ambient visibility and "d" is the distance of a facility to a Class I area. The WRAP Guidance itself states that EPA has concerns over only relying on the Q/d method for

<sup>4</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, August 2019, EPA-457/B-19-003

<sup>5</sup> Technical Guidance on Tracking Visibility Progress for the Second Implementation Period of the Regional Haze Program, EPA-454/R-18-010, December 2018

<sup>6</sup> 5-Year Regional Haze Progress Report For Federal Implementation Plan, Hawai'i State Department of Health, October 2017, EPA-R09-OAR-2018-0744-0004

screening sources. The EPA points out that the Q/d metric is only a rough indicator of actual visibility impact because it does not consider transport direction/pathway and dispersion and photochemical processes. To address the EPA's concern, the WRAP subcommittee recommends a second step, application of the weighted emissions potential analysis (WEP), which has not been done.<sup>7</sup> On September 11, 2019, the DOH informed Hawaiian Electric that its Kahului Generating Station, among others, was identified, based on the Q/d analysis, as one of the sources potentially contributing to regional haze at the Haleakalā National Park and Volcanoes National Park. This report responds to the DOH September 2019 request to Hawaiian Electric to submit a four-factor analysis.

The SIP Guidance requires that the selection of controls necessary to make reasonable progress must consider the five required factors listed in section 51.308(f)(2)(iv), and other factors that are reasonable to consider. Hawaiian Electric and AECOM prepared summary, included in Section 2.2, which describes special circumstances that apply in Hawai'i that should be considered during the development of the Hawai'i Regional Haze SIP.

## 2.2. ADDITIONAL FACTORS

Hawaiian Electric and AECOM met with the DOH on February 12, 2020 to present special circumstances applicable in Hawai'i that should be considered during the development of the Hawai'i Regional Haze SIP. Significant among those circumstances is Hawai'i's Statutory RPS which have put the state on a timetable to accomplish the same goals as the RHR twenty (20) years before the Regional Haze 2064 target date. These same issues were addressed by the EPA in the FIP and the DOH in its Progress Report that was approved by the EPA, effective on September 11, 2019. These special considerations are discussed further in Appendix B and Appendix C to this report and summarized in the following sections.

Additionally, Kahului is subject to the DOH's GHG ERP and the associated State enforceable Covered Source Permit limit and thereby, also reduces emissions relevant to the RHR.


### 2.2.1. Lack of Contribution to Visibility Impairment Due to Prevailing Winds

As noted, the DOH did not consider actual contribution to visibility impairment when selecting sources for the Four-Factor Analysis, but this is a critical factor in establishing realistic reasonable progress goals for Class I areas. The EPA's FIP for Hawai'i for the First Decadal Review (77 FR 61478, October 9, 2012) has already acknowledged the predominant trade winds in Hawai'i and thus, did not require controls on upwind sources (i.e., sources on Oahu and Maui).

Wind rose plots for airports on Maui and Hawai'i Islands show that the wind is almost always from the northeast and rarely blows from the Kahului Power Plant toward either of Hawai'i's Class I areas. The Kahului airport wind rose plot is provided as Figure 2-1. Based on the infrequent amount of time the wind blows from Kahului Power Plant toward either of Hawai'i's Class I areas, it is unlikely that the facility's potential emissions impact visibility at Haleakalā National Park and Volcanoes National Park. Therefore, when balancing retrofit costs and visibility improvements, the DOH should remain mindful that emissions from this facility are unlikely to contribute to regional haze at Haleakalā National Park and Volcanoes National Park and as such will have no impact on a showing of further reasonable progress.

<sup>7</sup> WRAP Reasonable Progress Source Identification and Analysis Protocol For Second 10-year Regional Haze State Implementation Plans, dated February 27, 2019  
(<https://www.wrapair2.org/pdf/final%20WRAP%20Reasonable%20Progress%20Source%20Identification%20and%20Analysis%20Protocol-Feb27-2019.pdf>)

Figure 2-1. Kahului Wind Rose (2015 – 2019) Predominant Wind from the Northeast



### 2.2.2. Lack of Contribution to Visibility Impairment Due to Warm Weather Conditions

The potential for the formation of haze due to  $\text{NO}_x$  emissions is very low in Hawai'i because of the warm weather conditions year-round. Nitrate Haze composition analyses for the Haleakalā and Hawai'i Volcanoes National Parks from the IMPROVE web site are included in Appendix B to this report. The data for both national parks show that the contribution of nitrates to haze is very low. It is low as a percentage of the total haze composition, but it is also low as an absolute value for extinction (visibility impairment). The minimal impact of nitrate haze is clearly illustrated in the Hawai'i National Park monitoring data and is much lower than found at many monitors in other Class I areas around the country. This is in large part due to the unique chemistry of nitrate haze which is discussed further in Appendix B to this report.

Due to the low haze impact of  $\text{NO}_x$ , the DOH should not consider  $\text{NO}_x$  controls for the Second Decadal Review for Kahului. A similar conclusion was reached during the First Decadal Review, for which the EPA did not consider  $\text{NO}_x$  controls to be material.

### 2.2.3. Contribution to Visibility Impairment from Volcanic Activity

Volcanic activity on the Hawai'i Island represents a unique challenge to understanding haze in Hawai'i Class I areas. The Kilauea volcano on Hawai'i Island has been active for several years, and the levels of  $\text{SO}_2$  emissions are being monitored by the United States Geological Survey. In addition to volcanoes being large sources of  $\text{SO}_2$ , they also emit significant amounts of  $\text{NO}_x$ . It should also be noted that volcanic activity on Hawai'i Island is the largest source of  $\text{NO}_x$  in the state. Nitrate haze is a very small component in Hawai'i's Class I areas, which is expected given the nitrate chemistry as explained in Appendix B to this report. Direct particulate matter (PM) emissions constitute a very small portion of haze and significant portions are due to volcanic emissions as explained in Appendix B to this report. Visibility improvements made from significant reductions of point source  $\text{SO}_2$  in Maui and Hawai'i Island is obscured by sulfate from natural volcanic  $\text{SO}_2$  that overwhelms sulfate from anthropogenic  $\text{SO}_2$

sources. Anthropogenic sources (from power plants) are projected to be eliminated well before the end point of the Regional Haze Rule (i.e., 2064) by Hawai'i's Statutory RPS. Thus, the DOH should not consider PM or SO<sub>2</sub> controls for the Second Decadal Period Review for Kahului.

#### **2.2.4. Renewable Portfolio Standards**

Based on AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, SO<sub>2</sub>, NO<sub>x</sub>, and particulate matter, 10 microns or less in diameter (PM<sub>10</sub>) emissions from the Kahului boilers do not significantly contribute to regional haze. The low impact that Kahului may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the Hawai'i Clean Energy Initiative (HCEI). Both past and projected future decreases in fossil-fueled electric generating unit (EGU) usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1), it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

### 3. SULFUR DIOXIDE FOUR-FACTOR ANALYSIS

AECOM's analysis, *Appendix C: Hawaii's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that SO<sub>2</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. However, the four-factor analysis is provided in response to DOH's request. The first step in the analysis is to establish a baseline for emissions. Per DOH's letter dated September 11, 2019, calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 3-1 lists 2017 annual average fuel property data and fuel usage rates that were used in the control costing calculations and the baseline SO<sub>2</sub> emissions for the Kahului boilers.

**Table 3-1. 2017 Fuel Property Data and Usage and Baseline SO<sub>2</sub> Emissions**

Unit	2017 Annual Average Residual Oil Properties <sup>A</sup>			Equivalent Annual Residual Oil Usage <sup>B</sup>		SO <sub>2</sub> Emissions	
	Sulfur Content	HHV (Btu/gal)	Density (lb/gal)	Volume (gal/yr)	Heat Input (MMBtu/yr)	(lb/MMBtu) <sup>C</sup>	(TPY) <sup>D</sup>
K1	1.69%	151,009	8.34	2,075,864	313,473	1.87	293.1
K2	1.69%	151,009	8.34	1,793,982	270,907	1.87	253.3
K3	1.69%	151,009	8.34	6,363,573	960,954	1.87	898.5
K4	1.69%	151,009	8.34	5,494,558	829,725	1.87	775.8
<b>Total</b>						<b>1.87</b>	<b>2,220.7</b>

<sup>A</sup> Calendar year 2017 annual average residual oil fuel properties from company records.

<sup>B</sup> To account for ignition fuels and used oil usage the equivalent annual residual oil usage was calculated from the 2017 annual average fuel properties and reported SO<sub>2</sub> emissions.

<sup>C</sup> The SO<sub>2</sub> emission factors are based on 100% conversion of fuel sulfur to SO<sub>2</sub> and the calendar year 2017 annual average residual oil fuel density and higher heating value.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

#### 3.1. SULFUR DIOXIDE CONTROL OPTIONS

The characterization of emission controls available and applicable to the source is a necessary step before the four-factors can be analyzed. SO<sub>2</sub> emissions are generated during fuel oil combustion from the oxidation of sulfur contained in the fuel. Available SO<sub>2</sub> control technologies for the boilers are:

- Flue Gas Desulfurization (FGD)
  - Dry Sorbent Injection (DSI)
  - Spray Dryer Absorber (SDA)
  - Wet Scrubber
  - Circulating Dry Scrubber (CDS)
- Fuel Switching to a residual/distillate blended fuel or a distillate fuel
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.

##### 3.1.1. Post-Combustion Controls

FGD applications have not been used historically for SO<sub>2</sub> control on oil-fired boilers the size of those operated at the Kahului Generating Station (5.0 to 12.5 MW). As there are no known FGD applications for similar oil-fired boilers, the performance of FGDs on oil-fired boilers is unknown. CDS was identified by an internal engineering study in 2012 as the best FGD option for the Hawaiian Electric Kahe and Waiiau boilers. However, the Hawaiian Electric Kahe and Waiiau Boilers range in size from 49 MW to 142

MW in comparison to the Kahului boilers which range in size from 5.0 to 12.5 MW. The SO<sub>2</sub> cost-effectiveness calculations for Kahe and Waiau showed that CDS was the least cost-effective option to reduce SO<sub>2</sub>. The EPA took this into account when evaluating the Best Available Retrofit Technology (BART) presumptive SO<sub>2</sub> emission rate for oil-fired units and determined that the presumptive emission rate should be based on the sulfur content of the fuel oil, rather than on FGD<sup>8</sup>. Since there are no applications of FGD on oil-fired boilers in the U.S., FGDs, including CDS, are considered unproven technology for the control of SO<sub>2</sub> from the Kahului boilers because of the boiler's size and lack of the technology being used in similar applications.

### 3.1.2. Fuel Switching

The Kahului boilers currently burn residual high sulfur fuel oil with a maximum sulfur content of 2.0 percent by weight. The average sulfur content of the residual high sulfur fuel oil purchased in 2017 was approximately 1.69 percent by weight. Switching to a lower sulfur fuel if technically and economically feasible would reduce SO<sub>2</sub> emissions in proportion to the reduction in fuel sulfur content.<sup>9</sup>

On Oahu, 0.5 percent by weight low sulfur fuel oil is produced and is used at Hawaiian Electric's Kahe and Waiau Generating Stations on Oahu. However, it is not a technically feasible option for Kahului. This low sulfur fuel oil has a higher viscosity and pour point than the high sulfur fuel oil used at Kahului and the current fuel supply chain from Oahu to Kahului cannot support this quality of fuel that is semi-solid at ambient temperatures. For the low sulfur fuel oil to be burned at Kahului, the piping and tanks that are used to transport and store the oil would need to be heated, at a cost of 500 thousand dollars (\$500,000) to 1 million dollars (\$1,000,000), which is not economically feasible because of the very limited remaining time that fuel oil will be burned at Kahului. There are, however, technically feasible options which include blending the current high sulfur fuel oil with a lower sulfur distillate fuel (diesel with a maximum sulfur content of 0.4 percent by weight or ultra-low sulfur diesel (ULSD) with a maximum sulfur content of 0.0015 percent by weight) or switching to a lower sulfur distillate fuel. The SO<sub>2</sub> four-factor analysis evaluates these options.

### 3.1.3. Renewable Portfolio Standards

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that SO<sub>2</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. The low impact that Kahului may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the HCEI. Both past and projected future decreases in fossil-fueled EGU usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1) it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

<sup>8</sup> *Summary of Comments and Responses on the 2004 and 2001 Proposed Guidelines for Best Available Retrofit Technology (BART) Determinations Under the Regional Haze Regulations*, EPA Docket Number OAR-2002-0076

<sup>9</sup> Natural gas has less sulfur than the existing residual fuel oil. However, natural gas is not a technically feasible option because there is no natural gas supply in Hawai'i.



## 3.2. FOUR-FACTOR ANALYSIS

As discussed above, fuel switching to a residual/distillate blended fuel or a lower sulfur diesel is the only technically feasible option to reduce SO<sub>2</sub> emissions. For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors for switching to a lower sulfur residual/distillate blended fuel, or a lower sulfur diesel are discussed in the following sections.

### 3.2.1. Cost of Compliance

The cost effectiveness of the fuel switching was determined by calculating the annual incremental cost of switching to a lower sulfur fuel divided by the reduction in SO<sub>2</sub> emissions. Switching fuel would require changes to the injectors and the fuel system; however, these expenses were not included in the analysis.

Kahului currently purchases residual high sulfur fuel oil from Par Hawaii Refining, LLC (Par Hawaii); current fuel costs are provided in Appendix D. The fuels are refined on Oahu and changes in quantities of high sulfur fuel oil and distillates fuels would require new contracts with fuel suppliers. This adds a level of uncertainty to the cost of compliance. Par Hawaii is the only refinery in Hawai'i and is near its production capacity of ULSD. Therefore, increases in ULSD use would require importing ULSD to Hawai'i and for parity, the price of diesel with a maximum sulfur content of 0.4 percent by weight is based on importing diesel to Hawai'i. Appendix D contains the estimated cost of importing ULSD and diesel to Hawai'i.

Table 3-2 presents a summary of the cost effectiveness of switching from a residual high sulfur fuel oil to residual high sulfur fuel oil/diesel blend with a maximum sulfur content of 1.0 percent by weight based on blending the current residual high sulfur fuel oil with diesel with a maximum sulfur content of 0.4 percent by weight. The cost effectiveness is determined by dividing the annual cost increase in fuel by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of switching to a residual/distillate blended fuel with a maximum sulfur content of 1.0 percent by weight is \$7,548 per ton of SO<sub>2</sub> and would increase fuel cost 7.3 million dollars (\$7,300,000) annually and 219 million dollars (\$219,000,000) over thirty (30) years.

Table 3-3 presents a summary of the cost effectiveness of switching from residual fuel to distillate fuel (diesel) with a maximum sulfur content of 0.4 percent by weight. The cost effectiveness is determined by dividing the annual cost increase in fuel by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of switching to a distillate fuel with a maximum sulfur content of 0.4 percent by weight is \$7,071 per ton of SO<sub>2</sub> and would increase fuel cost 12.3 million dollars (\$12,300,000) annually and 369 million dollars (\$369,000,000) over thirty (30) years.

Table 3-4 presents a summary of the cost effectiveness of switching from a residual high sulfur fuel oil to residual high sulfur fuel oil/ULSD blend with a maximum sulfur content of 1.0 percent by weight based on blending the current residual high sulfur fuel oil with ULSD with a maximum sulfur content of 0.0015 percent by weight. The cost effectiveness is determined by dividing the annual cost increase in fuel by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of switching to a residual/ULSD blended fuel with a maximum sulfur content of 1.0 percent by weight is \$6,535 per ton of SO<sub>2</sub> and would increase fuel cost 6.2 million dollars (\$6,200,000) annually and 186 million dollars (\$186,000,000) over thirty (30) years.

Table 3-5 presents a summary of the cost effectiveness of switching from residual fuel to ULSD with a maximum sulfur content of 0.0015 percent by weight. The cost effectiveness is determined by dividing the annual cost increase in fuel by the annual reduction in SO<sub>2</sub> emissions. The cost effectiveness of switching to ULSD fuel with a maximum sulfur content of 0.0015 percent by weight is \$5,820 per ton of SO<sub>2</sub> and would increase fuel cost 12.9 million dollars (\$12,900,000) annually and 387 million dollars (\$387,000,000) over thirty (30) years.

### **3.2.2. Time Necessary to Achieve Compliance**

If the DOH determines that switching from residual oil to a residual/distillate blended fuel or a lower sulfur diesel is needed to achieve reasonable progress, it is anticipated that this change would take two to three years to implement because of several factors: 1) Although not entirely under its control, Hawaiian Electric generally requests that the State of Hawai'i Public Utilities Commission (Commission) approve fuel contracts and issue its Decision and Order within one year following the filing of the application to the Commission; 2) Hawaiian Electric needs to go through a formal process to request bids from fuel suppliers; 3) Negotiations with the fuel supplier can take up to four months; 4) The schedule for any required infrastructure modifications are dependent on the extent on the required changes; 5) If fuel switching is required at other Hawaiian Electric facilities, the type of fuel to be used for replacement, the effect on the fuel supply, and ability of the local refinery to accommodate the change may be significantly impacted; and 6) Imported fuel may be required if there is a lack of local supply.

### **3.2.3. Energy and Non-Air Quality Environmental impacts**

There are no energy and non-air quality environmental impacts of compliance for fuel switching. The cost increase associated with fuel switching to a lower sulfur fuel will increase the cost of the electricity produced by Kahului and directly impact the price of electricity for Maui Electric customers. This is an important cost to the community that must be considered. Hawaiian Electric encourages the DOH to use the flexibility in the EPA's SIP guidance<sup>10</sup> in the selection of control measures necessary to make reasonable progress and to consider additional factors when developing the long-term strategy to improve visibility at Class I areas. Also, given the fragile condition of the state's fuel supply and Hawaiian Electric's position as a major customer in the state's fuel market, a fuel supply change could have sweeping effects on the island's fuel market that may not be apparent from the cost estimates associated with Hawaiian Electric such as the ability of the local refinery to accommodate the change and potential need for imported fuel.

### **3.2.4. Remaining Useful Life**

Hawaiian Electric intends to retire its four Kahului boilers following the addition of replacement capacity (currently planned to be in the form of energy storage) and a new switchyard in central Maui, both of which are currently anticipated to be completed in the 2023 to 2024 timeframe. Although the retirement dates are not expressly binding, this is a necessary step to meet Hawai'i's statutory requirement to discontinue the use of fossil fuels for electric generation by 2045.

<sup>10</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, August 2019, EPA-457/B-19-003.

**Table 3-2. SO<sub>2</sub> Cost Effectiveness of Switching to a Residual Oil/Diesel Blended Fuel**

Unit	Current Residual Oil <sup>A</sup>					Residual Oil/Distillate Blend (1.0% maximum Sulfur) <sup>B</sup>							
	2017 Average Sulfur Content (%)	Fuel		2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel		Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost		SO <sub>2</sub> Cost Effectiveness (\$/ton)	
		Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)			Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)			SO <sub>2</sub> Reduced (tpy)	Differential <sup>C</sup>		
											(\$/Gal)		(\$/year)
K1	1.69%	151,009	2,075,864	313,473	293.1	142,359	2,201,991	164.73	128.37	0.44	\$968,876	7,548	
K2	1.69%	151,009	1,793,982	270,907	253.3	142,359	1,902,983	142.36	110.94	0.44	\$837,313	7,548	
K3	1.69%	151,009	6,363,573	960,954	898.5	142,359	6,750,218	504.98	393.52	0.44	\$2,970,096	7,548	
K4	1.69%	151,009	5,494,558	829,725	775.8	142,359	5,828,402	436.02	339.78	0.44	\$2,564,497	7,548	

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on a blend of 37.5% residual oil and 62.5% diesel fuel and the weighted average of the 2017 fuel HHV and density and contract fuel sulfur limits (2.0% for residual oil and 0.4% for diesel).

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 3-3. SO<sub>2</sub> Cost Effectiveness of Switching to Diesel**

Unit	Current Residual Oil <sup>A</sup>					Diesel (0.4% maximum Sulfur) <sup>B</sup>							
	2017 Average Sulfur Content (%)	Fuel		2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel		Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost		SO <sub>2</sub> Cost Effectiveness (\$/ton)	
		Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)			Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)			SO <sub>2</sub> Reduced (tpy)	Differential <sup>C</sup>		
											(\$/Gal)		(\$/year)
K1	1.69%	151,009	2,075,864	313,473	293.1	137,169	2,285,312	63.64	229.46	0.71	\$1,622,571	7,071	
K2	1.69%	151,009	1,793,982	270,907	253.3	137,169	1,974,990	54.99	198.31	0.71	\$1,402,243	7,071	
K3	1.69%	151,009	6,363,573	960,954	898.5	137,169	7,005,638	195.07	703.43	0.71	\$4,974,003	7,071	
K4	1.69%	151,009	5,494,558	829,725	775.8	137,169	6,048,942	168.43	607.37	0.71	\$4,294,749	7,071	

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on 2017 average HHV and density and contract diesel sulfur limit (0.4%).

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 3-4. SO<sub>2</sub> Cost Effectiveness of Switching to a Residual Oil/ULSD Blended Fuel**

Unit	Current Residual Oil <sup>A</sup>					Residual Oil/ULSD Blend (1.0% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content (%)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup>		SO <sub>2</sub> Cost Effectiveness (\$/ton)
										(\$/Gal)	(\$/year)	
K1	1.69%	151,009	2,075,864	313,473	293.1	144,471	2,169,799	166.92	126.18	0.38	\$824,524	6,535
K2	1.69%	151,009	1,793,982	270,907	253.3	144,471	1,875,162	144.26	109.04	0.38	\$712,562	6,535
K3	1.69%	151,009	6,363,573	960,954	898.5	144,471	6,651,533	511.71	386.79	0.38	\$2,527,583	6,535
K4	1.69%	151,009	5,494,558	829,725	775.8	144,471	5,743,194	441.83	333.97	0.38	\$2,182,414	6,535

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on a blend of 50.0% residual oil and 50.0% ULSD fuel and the weighted average of the 2017 fuel HHV and density and contract fuel sulfur limits.

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 3-5. SO<sub>2</sub> Cost Effectiveness of Switching to ULSD**

Unit	Current Residual Oil					ULSD (0.0015% maximum Sulfur)						
	2017 Average Sulfur Content (%)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup>		SO <sub>2</sub> Cost Effectiveness (\$/ton)
										(\$/Gal)	(\$/year)	
K1	1.69%	151,009	2,075,864	313,473	293.1	137,934	2,272,639	0.24	292.86	0.75	\$1,704,479	5,820
K2	1.69%	151,009	1,793,982	270,907	253.3	137,934	1,964,037	0.20	253.10	0.75	\$1,473,028	5,820
K3	1.69%	151,009	6,363,573	960,954	898.5	137,934	6,966,789	0.72	897.78	0.75	\$5,225,092	5,820
K4	1.69%	151,009	5,494,558	829,725	775.8	137,934	6,015,398	0.62	775.18	0.75	\$4,511,548	5,820

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on 2017 average HHV and density and contract fuel sulfur limit.

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

### 3.3. SULFUR DIOXIDE CONCLUSION

The cost effectiveness of switching to a residual/distillate blended fuel with a maximum sulfur content of 1.0 percent by weight ranges from \$6,500 per ton of SO<sub>2</sub> to \$7,500 per ton of SO<sub>2</sub> and would increase the fuel cost over 6.2 million dollars (\$6,200,000) annually and over 186 million dollars (\$186,000,000) over thirty (30) years. The cost effectiveness of switching to diesel fuel with a maximum sulfur content of 0.4 percent by weight is \$7,000 per ton of SO<sub>2</sub> and would increase fuel cost 12.3 million dollars (\$12,300,000) annually and 369 million dollars (\$369,000,000) over thirty (30) years. The cost effectiveness of switching to ULSD fuel with a maximum sulfur content of 0.0015 percent by weight is \$5,800 per ton of SO<sub>2</sub> and would increase fuel cost 12.9 million dollars (\$12,900,000) annually and 387 million dollars (\$387,000,000) over thirty (30) years. These costs are greater than the BART and reasonable progress thresholds established in the first planning period of \$5,600 per ton of SO<sub>2</sub> and \$5,500 per ton of SO<sub>2</sub>, respectively.<sup>11</sup> Thus, no fuel changes or add-on controls are proposed.

While there are no fuel changes or add-on controls proposed, other long-term emission reduction strategies, such as those included as part of the Hawai'i RPS, EEPS, and the GHG ERP are viable alternatives that would create greater benefits and allow for the demonstration of reasonable progress.

<sup>11</sup> *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawai'i*, U.S. EPA Region 9, May 14, 2012

## 4. NITROGEN OXIDES FOUR-FACTOR ANALYSIS

AECOM's analysis, *Appendix C: Hawaii's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that NO<sub>x</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. However, the four-factor analysis is provided in response to DOH's request. The first step in the analysis is to establish a baseline for emissions. Per DOH's letter dated September 11, 2019, calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 4-1 lists the baseline NO<sub>x</sub> emissions for Kahului.

**Table 4-1. Baseline NO<sub>x</sub> Emissions**

Unit	NO <sub>x</sub> Emissions		(TPY) <sup>C</sup>
	Residual Oil Emissions Factor	Adjusted Emission Factor	
	(lb/MMBtu) <sup>A</sup>	(lb/MMBtu) <sup>B</sup>	
K1	0.420	0.420	65.8
K2	0.460	0.460	62.3
K3	0.609	0.609	292.6
K4	0.436	0.440	182.7
<b>Total</b>			<b>603.4</b>

<sup>A</sup> Calendar year 2017 emission factors from the 2018 Emissions Fee Report.

<sup>B</sup> The adjusted emission factors include emissions from the ignition fuels and used oil.

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

### 4.1. NITROGEN OXIDES CONTROL OPTIONS

The characterization of emission controls available and applicable to the source is a necessary step before the four-factors can be analyzed. NO<sub>x</sub> emissions are produced during fuel combustion when nitrogen contained in the fuel and combustion air is exposed to high temperatures. The origin of the nitrogen (i.e., fuel versus combustion air) has led to the use of the terms "thermal NO<sub>x</sub>" and "fuel NO<sub>x</sub>". Thermal NO<sub>x</sub> emissions are produced when elemental nitrogen in the combustion air is oxidized by high combustion temperatures. Fuel NO<sub>x</sub> emissions are created by the oxidation of nitrogen contained in the fuel. NO<sub>x</sub> emissions from residual oil can be up to fifty percent fuel NO<sub>x</sub>.<sup>12</sup>

The formation of NO<sub>x</sub> compounds in utility boilers is sensitive to the method of firing and combustion controls utilized. Nitrogen oxide (NO) is typically the predominant form of NO<sub>x</sub> emissions from fossil fuel combustion, with the remaining NO<sub>x</sub> being the form nitrogen dioxide (NO<sub>2</sub>). The NO<sub>2</sub>/NO<sub>x</sub> in-stack ratio for boilers is typically less than ten percent.

Available NO<sub>x</sub> control technologies for the boilers are categorized as combustion or post-combustion controls. Combustion controls reduce the peak flame temperature and excess air in the furnace, which minimizes NO<sub>x</sub> formation. Post-combustion controls convert NO<sub>x</sub> in the flue gas to molecular nitrogen and water. Available NO<sub>x</sub> control technologies for the boilers are:

- Fuel Switching to a residual/distillate blended fuel or a distillate fuel
- Combustion Controls

<sup>12</sup> AP-42, Fifth Edition, Volume I, Chapter 1, Section 1.3.3

- Flue Gas Recirculation (FGR)
- Overfire Air (OFA)
- Low NO<sub>x</sub> Burners (LNB)
- Post-Combustion Controls
  - Selective Catalytic Reduction (SCR)
  - Selective Non-Catalytic Reduction (SNCR)
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.

#### 4.1.1. Fuel Switching

The Kahului boilers currently burn residual oil. Blending the current residual oil with distillate fuel or switching to a distillate fuel will result in only minor reductions in NO<sub>x</sub> emissions due to the lower fuel bound nitrogen content. The NO<sub>x</sub> four-factor analysis evaluates both options. Table 4-2 provides the estimated control levels for fuel switching.

**Table 4-2. NO<sub>x</sub> Reduction from Fuel Switching**

Fuel Scenario	AP-42 NO <sub>x</sub> Emission Factors <sup>A</sup>		Percent NO <sub>x</sub> Reduction from Fuel Switching <sup>B</sup>	
	< 100 MMBtu/hr Boilers	> 100 MMBtu/hr Boilers	K1 & K2	K3 & K4
	(lb/MMBtu)	(lb/MMBtu)		
Residual Oil	0.367	0.313	--	--
Distillate (ULSD)	0.143	0.171	61%	45%
50/50 Blend	--	--	31%	23%

<sup>A</sup> The listed emission factors are from AP-42, Table 1.3-1, dated May 2010.

<sup>B</sup> The percent reduction is based on the ratio of AP-42 emissions factors for residual fuel oil and No. 2 fuel oil.

#### 4.1.2. Combustion Controls

##### 4.1.2.1. Flue Gas Recirculation (FGR)

FGR uses flue gas as an inert material to reduce flame temperatures. In a typical FGR system, flue gas is collected from the combustion chamber or stack and returned to the burner via a duct and blower. The addition of flue gas reduces the oxygen content of the “combustion air” (air + flue gas) in the burner. The lower oxygen level in the combustion zone reduces flame temperatures, which in turn reduces thermal NO<sub>x</sub> formation. When operated without additional controls, the NO<sub>x</sub> control range for wall-fired boilers with FGR is approximately 0.25-0.30 lb/MMBtu.<sup>13</sup> This control is a technically feasible option for the Kahului boilers.

##### 4.1.2.2. Overfire Air (OFA)

OFA diverts a portion of the total combustion air from the burners and injects it through separate air ports above the top level of burners. Staging of the combustion air creates an initial fuel-rich combustion zone with a lower peak flame temperature. This reduces the formation of thermal NO<sub>x</sub> by lowering combustion temperature and limiting the availability of oxygen in the combustion zone where NO<sub>x</sub> is most likely to be formed. OFA as a single NO<sub>x</sub> control technique results in estimated NO<sub>x</sub> emissions for wall-fired boilers of 0.30-0.45 lb/MMBtu.<sup>14</sup> This control is a technically feasible option for the Kahului boilers.

<sup>13</sup> *Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler*, EPA, 1994.

<sup>14</sup> *Ibid.*

#### 4.1.2.3. Low NO<sub>x</sub> Burners (LNB)



LNB technology utilizes advanced burner design to reduce NO<sub>x</sub> formation through the restriction of oxygen, lowering of flame temperature, and/or reduced residence time. In the primary zone, NO<sub>x</sub> formation is limited by either one of two methods. Under staged fuel-rich conditions, low oxygen levels limit flame temperatures resulting in less NO<sub>x</sub> formation. The primary zone is then followed by a secondary zone in which the incomplete combustion products formed in the primary zone act as reducing agents. Alternatively, under staged fuel-lean conditions, excess air will reduce flame temperature to reduce NO<sub>x</sub> formation. In the secondary zone, combustion products formed in the primary zone act to lower the local oxygen concentration, resulting in a decrease in NO<sub>x</sub> formation.

The estimated NO<sub>x</sub> control range for LNBs on wall-fired boilers is 0.25-0.35 lb/MMBtu.<sup>15</sup> When combined with OFA, the estimated NO<sub>x</sub> control range on wall-fired boilers is 0.25-0.30 lb/MMBtu.<sup>16</sup> LNB systems are technically feasible for the Kahului boilers.

### 4.1.3. Post Combustion Controls

#### 4.1.3.1. Selective Catalytic Reduction (SCR)

SCR refers to the process in which NO<sub>x</sub> is reduced by ammonia over a heterogeneous catalyst in the presence of oxygen. The process is termed selective because the ammonia preferentially reacts with NO<sub>x</sub> rather than oxygen, although the oxygen enhances the reaction and is a necessary component of the process. The overall reactions are:



The SCR process requires a reactor, catalyst, ammonia storage, and an ammonia injection system. The effectiveness of an SCR system is dependent on a variety of factors, including the inlet NO<sub>x</sub> concentration, the exhaust temperature, the ammonia injection rate, and the type of catalyst. The estimated NO<sub>x</sub> control range for SCR is 0.05-0.10 lb/MMBtu.<sup>17</sup> When coupled with combustion controls, the estimated NO<sub>x</sub> control range is 0.03 – 0.10 lb/MMBtu.<sup>18</sup> This control is a technically feasible option for the Kahului boilers.

#### 4.1.3.2. Selective Non-Catalytic Reduction (SNCR)

In SNCR systems, a reagent (ammonia or urea) is injected into the flue gas in the furnace within an appropriate temperature window. The NO<sub>x</sub> and reagent react to form nitrogen and water. A typical SNCR system consists of reagent storage, multi-level reagent-injection equipment, and associated control instrumentation. The SNCR reagent storage and handling systems are similar to those for SCR systems. However, both ammonia- and urea-based SNCR processes require three or four times as much reagent as SCR systems to achieve similar NO<sub>x</sub> reductions. The estimated NO<sub>x</sub> control range for SNCR is 0.30-0.40 lb/MMBtu and 0.20-0.40 lb/MMBtu when coupled with combustion controls.<sup>19</sup> The estimated control ranges for uncontrolled boilers are in the same range as combustion controls. SNCR is only effective in a relatively high and narrow temperature range and therefore, is not suitable for all applications. Several factors determine whether SNCR is an appropriate control for a source, including temperature, residence time, the feasibility of installing reagent injection ports, and the NO<sub>x</sub>

<sup>15</sup> Ibid.

<sup>16</sup> Ibid.

<sup>17</sup> Ibid.

<sup>18</sup> Ibid.

<sup>19</sup> Ibid.



concentration.<sup>20</sup> These site-specific operating and design characteristics of the emission unit must be evaluated on a case-by-case basis to determine whether SNCR is feasible. However, the cost effectiveness was evaluated.

#### 4.1.4. Renewable Portfolio Standards

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that NO<sub>x</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. The low impact that Kahului may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the HCEI. Both past and projected future decreases in fossil-fueled EGU usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the Hawai'i Progress Report for Phase 1) it was not necessary to review the RPS in the context of the four-factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

#### 4.1.5. Rank of Technically Feasible NO<sub>x</sub> Control Options by Effectiveness

The next step is to rank the technically feasible options according to effectiveness. Table 4-3 provides a ranking of the control levels for the controls listed in the previous section.

**Table 4-3. Control Effectiveness of Technically Feasible NO<sub>x</sub> Control Technologies**

<b>Control Technology</b>	<b>Estimated Controlled Level</b>
	<b>(lb/MMBtu)</b>
SCR+Combustion Controls	0.05
SCR	0.05 - 0.10
LNB & OFA	0.25 - 0.30
FGR	0.25 - 0.30
LNB	0.25 - 0.35
SNCR+Combustion Controls	0.20 - 0.40
SNCR	0.30 - 0.40
OFA	0.30 - 0.45
Fuel Switching	0.16 - 0.29

The control levels in Table 4-3 are presented as a range because the specific level of control that is achievable for the Kahului boilers based on the application of the controls listed in Table 4-3 is unknown. Engineering studies would be required for each boiler in order to determine the best combustion control option or combinations of control options and the level of control achievable. It is estimated that such an engineering study could take an up to ten (8) months to complete at a cost \$415,000 for the boilers at Kahului Generating Station. It is anticipated that combustion controls such as LNB and possibly LNB in combination with OFA or FGR can achieve a NO<sub>x</sub> emissions level of approximately 0.30 lb/MMBtu at the Kahului boilers. As noted in Table 4-1, the Kahului boilers are currently emitting in the range of 0.42 lb/MMBtu to 0.61 lb/MMBtu. Further, it is believed that SCR can achieve a NO<sub>x</sub> emissions level of approximately 0.10 lb/MMBtu and 0.05 lb/MMBtu when SCR is

<sup>20</sup> Cost Control Manual, Selective Noncatalytic Reduction, EPA, 2019.

combined with combustion controls. SNCR can achieve a NO<sub>x</sub> emissions level of approximately 0.30 lb/MMBtu and 0.20 lb/MMBtu when SNCR is combined with combustion controls.

## 4.2. FOUR-FACTOR ANALYSIS

As discussed above, fuel switching, combustion controls, SNCR and SCR are the feasible options to reduce NO<sub>x</sub> emissions. For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors for fuel switching, adding combustion controls, SNCR and SCR are discussed in the following sections.

### 4.2.1. Cost of Compliance

For purposes of this four-factor analysis, the capital costs, operating costs, and cost effectiveness of combustion controls, SNCR and SCR have been estimated. The cost effectiveness of combustion controls is based on a controlled NO<sub>x</sub> emissions level of 0.30 lb/MMBtu. At this time, it is unknown if LNBs alone can achieve this level of emissions or if LNB combined with OFA or FGR would be required to meet this level. Therefore, the costing is based on the range of cost for LNB with OFA, the cost of FGR and LNB with FGR are expected to be covered by this range and have a similar level of NO<sub>x</sub> control. The costing assumed that a NO<sub>x</sub> emissions level of 0.30 lb/MMBtu can be achieved with combustion controls. As the level of NO<sub>x</sub> emissions is comparable to SNCR combustion controls, the only add-on control that would be expected to result in lower achievable NO<sub>x</sub> emissions rates than combustion controls is SCR. The cost of fuel switching is discussed in Section 3.1.2.

The cost effectiveness of SNCR is based on a controlled NO<sub>x</sub> emissions level of 0.30 lb/MMBtu and 0.20 lb/MMBtu when combustion controls are combined with SNCR.

The cost effectiveness of SCR is based on a controlled NO<sub>x</sub> emissions level of 0.10 lb/MMBtu and 0.05 lb/MMBtu when combustion controls are combined with SCR. The SCR costing is based on generic EPA control costing<sup>21</sup> which does not consider Hawai'i's remote location which results in additional shipping and higher construction cost. To account for these higher costs, a Maui construction cost multiplier<sup>22</sup> of 1.938 was applied to the capital SCR cost.

Table 4-4 presents a summary of the cost effectiveness of fuel switching, adding combustion controls, SNCR, SNCR combined with combustion controls, SCR and SCR combined with combustion controls. The cost effectiveness is determined by dividing the annual cost by the annual reduction in NO<sub>x</sub> emissions. The cost effectiveness of fuel switching ranges from \$36,900 per ton to more than \$50,000 per ton of NO<sub>x</sub> emissions in the different units and the total cost exceeds 6.2 million dollars (\$6,200,000) annually and 186 million dollars (\$186,000,000) over thirty (30) years. The cost effectiveness of combustion controls ranges from \$900 per ton to \$4,200 per ton of NO<sub>x</sub> and the total cost equals 400 thousand dollars (\$400,000) annually and 12 million dollars (\$12,000,000) over thirty (30) years. The cost effectiveness of SCR ranges from \$3,300 per ton to \$9,400 per ton of NO<sub>x</sub> and the total cost equals 2.5

<sup>21</sup> Assessment of Non-EGU NO<sub>x</sub> Emission Controls, Cost of Controls, and Time for Compliance, Technical Support Document (TSD) for the Cross-State Air Pollution Rule for the 2008 Ozone NAAQS. Docket ID No. EPA-HQ-OAR-2015-0500, November 2015

<sup>22</sup> The Maui construction cost multiplier is based on cost of construction geographical multipliers from the *RMeans Mechanical Cost Data 2016* to account for factors unique to Maui's location plus an additional factor to account for additional Hawaiian Electric loadings and overhead.

million dollars (\$2,500,000) annually and 75 million dollars (\$75,000,000) over thirty (30) years. The cost effectiveness of SCR plus combustion control ranges from \$3,500 per ton to over \$9,700 per ton of NO<sub>x</sub> emissions in the different units and the total cost equals 2.9 million dollars (\$2,900,000) annually and 87 million dollars (\$87,000,000) over thirty (30) years.

The cost effectiveness of SNCR ranges from \$1,900 per ton to \$8,900 per ton of NO<sub>x</sub> and the total cost equals 900 thousand dollars (\$900,000) annually and 27 million dollars (\$27,000,000) over thirty (30) years. The cost effectiveness of SNCR plus combustion control ranges from \$2,100 per ton to \$7,200 per ton of NO<sub>x</sub> and the total cost equals 1.3 million dollars (\$1,300,000) annually and 39 million dollars (\$39,000,000) over thirty (30) years.

These cost ranges assume that the capital costs will be amortized over thirty (30) years with the exception of SNCR, which is amortized over twenty (20). However, Hawaiian Electric intends to retire its four Kahului boilers following the addition of replacement capacity (currently planned to be in the form of energy storage) and a new switchyard in central Maui, both of which are currently anticipated to be completed in the 2023 to 2024 timeframe. Thus, the actual amortization period will be significantly less than the capital recovery period and the cost of removal correspondingly higher.

#### **4.2.2. Time Necessary to Achieve Compliance**

If the DOH determines that controls are needed to achieve reasonable progress goals, it is anticipated that this change could be implemented in three to five years.

#### **4.2.3. Energy and Non-Air Quality Environmental impacts**

SNCR and SCR systems require electricity to operate the ancillary equipment. The need for electricity to help power some of the ancillary equipment creates a demand for energy that currently does not exist.

SNCR and SCR can potentially cause significant environmental impacts related to the storage of ammonia, and the storage of aqueous ammonia above 10,000 pounds is regulated because of its potential health hazard by the EPA's Risk Management Program (RMP) because the accidental release of ammonia has the potential to cause serious injury and death to persons in the vicinity of the release. SNCR and SCR will likely also cause the release of unreacted ammonia to the atmosphere. This is referred to as ammonia slip. Ammonia slip from SNCR and SCR systems occurs either from ammonia injection at temperatures too low for effective reaction with NO<sub>x</sub>, leading to an excess of unreacted ammonia, or from over-injection of reagent leading to uneven distribution, which also leads to an excess of unreacted ammonia. Ammonia released from SNCR and SCR systems will react with sulfates and nitrates in the atmosphere to form ammonium sulfate and ammonium nitrate. Together, ammonium sulfate and ammonium nitrate are the predominant sources of regional haze.

#### **4.2.4. Remaining Useful Life**

EPA's recommend capital cost recovery periods of thirty (30) years was used for the combustion controls and SCR costing and twenty (20) years was used for SNCR. However, Hawaiian Electric intends to retire its four Kahului boilers following the addition of replacement capacity (currently planned to be in the form of energy storage) and a new switchyard in central Maui, both of which are currently anticipated to be completed in the 2023 to 2024 timeframe. Although the retirement dates are not expressly binding, this is a necessary step to meet Hawai'i's statutory requirement to discontinue the use of fossil fuels for electric generation by 2045. These retirements will significantly shorten the time the control equipment is used and increase the removal cost per ton.

**Table 4-4. NO<sub>x</sub> Cost Effectiveness Summary**

Unit	Control Option	2017	Controlled	2017	Controlled	NO <sub>x</sub>	Total	Cost
		NO <sub>x</sub> Emissions <sup>A</sup> (tpy)	Emission Level <sup>B,C</sup> (lb/MMBtu)	Annual Heat Input (MMBtu/yr)	NO <sub>x</sub> Emissions (tpy)	Reduced (ton/yr)	Annual Cost <sup>D,E</sup> (\$/yr)	Effectiveness (\$/ton)
K1	Residual Oil/ULSD Blend <sup>D</sup>	65.8	0.29	313,473	45.4	20.4	\$824,524	\$40,422
	ULSD <sup>D</sup>	65.8	0.16	313,473	25.7	40.1	\$1,704,479	\$42,465
	Combustion Controls	65.8	0.30	313,473	47.0	18.8	\$79,284	\$4,222
	SNCR	65.8	0.30	313,473	47.0	18.8	\$167,771	\$8,934
	SNCR+Combustion Controls	65.8	0.20	313,473	31.3	34.5	\$247,055	\$7,171
	SCR	65.8	0.10	313,473	15.7	50.1	\$457,919	\$9,135
	SCR+Combustion Controls	65.8	0.05	313,473	7.8	58.0	\$537,203	\$9,268
K2	Residual Oil/ULSD Blend <sup>D</sup>	62.3	0.32	270,907	43.0	19.3	\$712,562	\$36,895
	ULSD <sup>D</sup>	62.3	0.18	270,907	24.3	38.0	\$1,473,028	\$38,761
	Combustion Controls	62.3	0.30	270,907	40.6	21.7	\$79,639	\$3,676
	SNCR	62.3	0.30	270,907	40.6	21.7	\$170,231	\$7,858
	SNCR+Combustion Controls	62.3	0.20	270,907	27.1	35.2	\$249,870	\$7,097
	SCR	62.3	0.10	270,907	13.5	48.8	\$459,913	\$9,433
	SCR+Combustion Controls	62.3	0.05	270,907	6.8	55.5	\$539,553	\$9,717
K3	Residual Oil/ULSD Blend <sup>D</sup>	292.6	0.47	960,954	225.3	67.3	\$2,527,583	\$37,558
	ULSD <sup>D</sup>	292.6	0.33	960,954	160.9	131.7	\$5,225,092	\$39,683
	Combustion Controls	292.6	0.30	960,954	144.1	148.5	\$134,508	\$906
	SNCR	292.6	0.30	960,954	144.1	148.5	\$279,823	\$1,885
	SNCR+Combustion Controls	292.6	0.20	960,954	96.1	196.5	\$414,331	\$2,109
	SCR	292.6	0.10	960,954	48.0	244.6	\$805,801	\$3,295
	SCR+Combustion Controls	292.6	0.05	960,954	24.0	268.6	\$940,308	\$3,501
K4	Residual Oil/ULSD Blend <sup>D</sup>	182.7	0.34	829,725	140.7	42.0	\$2,182,414	\$51,936
	ULSD <sup>D</sup>	182.7	0.24	829,725	100.5	82.2	\$4,511,548	\$54,875
	Combustion Controls	182.7	0.30	829,725	124.5	58.2	\$134,941	\$2,317
	SNCR	182.7	0.30	829,725	124.5	58.2	\$247,250	\$4,245
	SNCR+Combustion Controls	182.7	0.20	829,725	83.0	99.7	\$382,191	\$3,832
	SCR	182.7	0.10	829,725	41.5	141.2	\$790,239	\$5,596
	SCR+Combustion Controls	182.7	0.05	829,725	20.7	162.0	\$925,180	\$5,713

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> The controlled emission level for ULSD is based on the No. 2 fuel oil emission factor from AP-42, Table 1.3-1, dated May 2010. The controlled emission level for the 50/50 residual oil/ULSD blend is based on the average of the AP-42 emission factor for No. 2 fuel oil and the 2017 emission factor.

<sup>C</sup> Controlled emission levels based on "Alternative Control Techniques (ACT) Document – NO<sub>x</sub> Emissions from Utility Boiler" EPA, 1994.

<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars. The control options of switching to a residual oil/ULSD blend or ULSD are listed since it's a more cost-effective SO<sub>2</sub> solution than switching to a residual oil/0.4% maximum sulfur diesel blend or 0.4% maximum sulfur diesel.

<sup>E</sup> See Appendix A for total annual cost calculations.

### 4.3. NITROGEN OXIDES CONCLUSION

The cost effectiveness of fuel switching ranges from \$36,900 per ton to more than \$50,000 per ton of NO<sub>x</sub> emissions in the different units and the total cost exceeds 6.2 million dollars (\$6,200,000) annually and 186 million dollars (\$186,000,000) over thirty (30) years. Fuel switching is less effective, and the costs are well above the other NO<sub>x</sub> controls evaluated.

The cost effectiveness of adding combustion controls to the Kahului boilers ranges from \$900 per ton to \$4,200 per ton of NO<sub>x</sub> and the total cost equals 400 thousand dollars (\$400,000) annually and 12 million dollars (\$12,000,000) over thirty (30) years. These costs are similar to the BART analysis conducted for the first planning period. For the first planning period, the EPA concluded the emission reductions provided by LNB are unlikely to provide a measurable visibility benefit at Hawai'i Volcanoes National Park or Haleakalā National Park.<sup>23</sup>

The cost effectiveness of adding SCR to the Kahului boilers ranges from \$3,300 per ton to \$9,400 per ton of NO<sub>x</sub> and the total cost equals 2.5 million dollars (\$2,500,000) annually and 75 million dollars (\$75,000,000) over thirty (30) years. The cost effectiveness of SCR plus combustion control ranges from \$3,500 per ton to over \$9,700 per ton of NO<sub>x</sub> emissions in the different units and the total cost equals 2.9 million dollars (\$2,900,000) annually and 87 million dollars (\$87,000,000) over thirty (30) years. These costs are similar to the BART analysis conducted for the first planning period. For the first planning period, the EPA concluded that SCR was not cost effective.<sup>24</sup>

The cost effectiveness of adding SNCR to the Kahului boilers ranges from \$1,900 per ton to \$8,900 per ton of NO<sub>x</sub> and the total cost equals 900 thousand dollars (\$900,000) annually and 27 million dollars (\$27,000,000) over thirty (30) years. The cost effectiveness of SNCR plus combustion control ranges from \$3,500 per ton to \$9,700 per ton of NO<sub>x</sub> and the total cost equals 1.3 million dollars (\$1,300,000) annually and 39 million dollars (\$39,000,000) over thirty (30) years. The cost effectiveness of SNCR added to uncontrolled boilers is greater than combustion controls and offers less control. SNCR has a lower cost effectiveness than SCR and SCR plus combustion controls. However, SNCR results in a lower level of control than SCR alone and SCR plus combustion controls. Based on these results, SNCR does not offer a significantly better control option than combustion controls, SCR, or SCR plus combustion controls.

The results of the four-factor analysis are consistent with the conclusions reached for the first planning period. Therefore, Hawaiian Electric does not propose any NO<sub>x</sub> emissions reductions in addition to the Hawai'i RPS, EEPS, and the GHG ERP to meet the RHR requirements.

<sup>23</sup> *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawai'i*, U.S. EPA Region 9, May 14, 2012

<sup>24</sup> *Ibid.*

## 5. PARTICULATE MATTER FOUR-FACTOR ANALYSIS

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that PM<sub>10</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. However, the four-factor analysis is provided in response to DOH's request. The first step in the analysis is to establish a baseline for emissions. Per DOH's letter dated September 11, 2019, calendar year 2017 actual emissions are used to define the baseline emissions for the four-factor analysis. Table 5-1 lists the baseline PM<sub>10</sub> emissions for Kahului.

**Table 5-1. Baseline PM<sub>10</sub> Emissions**

Unit	PM <sub>10</sub> Emissions		(TPY) <sup>c</sup>
	Residual Oil Emissions Factor	Adjusted Emission Factor	
	(lb/MMBtu) <sup>A</sup>	(lb/MMBtu) <sup>B</sup>	
K1	0.0933	0.0931	14.6
K2	0.0778	0.0775	10.5
K3	0.0799	0.0799	38.4
K4	0.0495	0.0499	20.7
<b>Total</b>			<b>84.2</b>

<sup>A</sup> Calendar year 2017 emission factors from the 2018 Emissions Fee Report.

<sup>B</sup> The adjusted emission factors include emissions from the ignition fuels and used oil.

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

### 5.1. PARTICULATE MATTER CONTROL OPTIONS

PM<sub>10</sub> emissions depend predominantly on the grade of fuel fired. Combustion of lighter distillate oils results in lower PM<sub>10</sub> emissions than heavier residual oils. Distillate oils have lower ash and sulfur content than residual oil, therefore, producing less PM<sub>10</sub> emissions.

Available PM<sub>10</sub> control technologies for the boilers are:

- Post-Combustion Controls
  - Dry or Wet Electrostatic Precipitator (ESP)
  - Fabric Filters
  - Wet Scrubber
  - Cyclone
- Fuel Switching to a residual/distillate blended fuel or a distillate fuel
- Renewable Portfolio Standards (RPS)

The feasibility of these controls is discussed in the following sections.

#### 5.1.1. Post-Combustion Controls

PM<sub>10</sub> emissions from residual oil-fired boilers tend to be sticky and small. Because of these properties and a general lack of existence in practice, dry ESP, cyclones, and fabric filters are not good technological matches for the Kahului boilers.

A wet ESP operates very similarly to a dry ESP but is a better technological match for oil-fired boilers because it is not sensitive to small and sticky particulates. The wet ESP utilizes water to collect and remove the particles and produces a waste-water product. Flue gas leaving the wet ESP will be saturated and may result in a visual steam plume. The estimated PM<sub>10</sub> control efficiency is up to ninety percent for a wet ESP.<sup>25</sup> Wet ESP is a technically feasible option for control of PM<sub>10</sub> for the Kahului boilers.

In wet scrubbers, PM<sub>10</sub> is removed from flue gas when the gas stream is brought into contact with a scrubbing liquid using several approaches: spraying the gas stream with the liquid, forcing the gas stream through a pool of liquid, or by some other contact method. The PM<sub>10</sub> in the gas stream is captured in the scrubbing liquid. The PM<sub>10</sub>-laden scrubbing liquid is separated from the gas stream, and the resultant scrubbing liquid is treated prior to discharge or reuse in the plant. Problems associated with scrubbers include corrosion issues, high power requirements, and water-disposal challenges. However, the use of wet scrubbers for the Kahului boilers is considered a technically feasible option. The estimated PM<sub>10</sub> removal efficiency for a wet scrubber is fifty to sixty percent.<sup>26</sup>

### 5.1.2. Fuel Switching

Residual oil has inherent ash that contributes to the emissions of filterable PM<sub>10</sub>. Distillate fuels have less ash and ultimately lower filterable PM<sub>10</sub> emissions. Filterable PM<sub>10</sub> emissions could be reduced by switching to a residual oil/distillate blend or to a distillate fuel. Section 3 discussed the option of fuel switching with respect to reducing SO<sub>2</sub> emissions. As discussed in Section 3, Maui Electric has limited fuel options. Switching to a distillate fuel will result in the PM<sub>10</sub> emissions reductions and is technically feasible. The PM<sub>10</sub> four-factor analysis evaluates both options. Table 5-2 provides the control levels for fuel switching.

**Table 5-2. PM<sub>10</sub> Reduction from Fuel Switching**

<b>Fuel Scenario</b>	<b>AP-42 PM<sub>10</sub> Emission Factors<sup>A</sup> (lb/MMBtu)</b>	<b>Percent PM<sub>10</sub> Reduction from Fuel Switching<sup>B</sup></b>
Residual Oil	0.1540	--
Distillate (No. 2 Fuel Oil)	0.0236	85%
50/50 Blend	--	43%

<sup>A</sup> The listed emission factors are from AP-42, Tables 1.3-1 and 1.3-2, dated May 2010.

<sup>B</sup> The percent reduction is based on the ratio of AP-42 emissions factors for residual fuel oil and No. 2 fuel oil.

### 5.1.3. Renewable Portfolio Standards

AECOM's analysis, *Appendix C: Hawai'i's Renewable Portfolio Standards Contribution to Regional Haze Progress*, concluded that PM<sub>10</sub> emissions from the Kahului boilers do not significantly contribute to regional haze. The low impact that Kahului may have on haze is already being reduced through conversion of electric generation to renewable energy sources as mandated by the RPS (Hawai'i Revised Statute (HRS) §269-92) and consistent with the HCEI. Both past and projected future decreases in fossil-fueled EGU usage are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the RHR. The RPS will substantially reduce emissions of haze precursors (especially SO<sub>2</sub>) by 2045. Therefore, further requirements for controls would not affect the showing of further progress under the RHR and, thus, are not needed at this time. This is further discussed in Appendix C to this report. Although RPS is listed as a control measure (which is consistent with the

Hawai'i Progress Report for Phase 1) it was not necessary to review the RPS in the context of the four factor analysis as these measures are already planned for implementation and although there are additional costs, they are inherent in the RPS program.

## 5.2. FOUR-FACTOR ANALYSIS

As discussed above, wet ESPs, wet scrubbers, and switching to distillate fuel are the best feasible options to reduce PM<sub>10</sub> emissions. For the second planning period, the focus is on determining reasonable progress through analyses of the four factors identified in Section 169A(g)(1) of the CAA:

1. The cost of compliance;
2. The time necessary to achieve compliance;
3. The energy and non-air quality environmental impact of compliance; and
4. The remaining useful life of any existing source subject to such requirements.

The four factors for adding wet ESPs, wet scrubbers, and switching to distillate fuel are discussed in the following sections.

### 5.2.1. Cost of Compliance

For purposes of this four-factor analysis, the capital costs, operating costs, and cost effectiveness of wet ESPs, wet scrubbers, and switching to distillate fuel have been estimated. The cost effectiveness calculation is based on the following reduction in PM<sub>10</sub> emissions:

- Wet Scrubbers – fifty percent,
- Switching to a residual oil/ULSD blend or to ULSD – forty-three percent to eighty-five percent, and
- Wet ESP – ninety percent.

Table 5-3 presents a summary of the cost effectiveness of wet scrubbers, switching to distillate fuel, and wet ESPs. The cost effectiveness ranges are:

- Wet Scrubbers - \$7,100 per ton - \$24,200 per ton and the total cost equals 500 thousand dollars (\$500,000) annually and 15 million dollars (\$15,000,000) over thirty (30) years,
- Switching to a residual oil/ULSD blend or to ULSD - \$131,000 per ton to \$256,000 per ton and the total cost exceeds 6.2 million dollars (\$6,200,000) annually and 186 million dollars (\$186,000,000) over thirty (30) years, and
- Wet ESPs - \$35,700 per ton - \$86,700 per ton and the total cost equals 4.3 million dollars (\$4,300,000) annually and 129 million dollars (\$129,000,000) over thirty (30) years.

### 5.2.2. Time Necessary to Achieve Compliance

If the DOH determines that wet scrubbers or wet ESPs are needed to achieve reasonable progress goals, it is anticipated that this change could be implemented in three to five years. If the DOH determines that switching a distillate fuel is needed to achieve reasonable progress, it is anticipated that this change could be implemented within two to three years.



**Table 5-3. PM<sub>10</sub> Cost Effectiveness Summary**

<b>Unit</b>	<b>Control Option</b>	<b>2017 PM<sub>10</sub> Emissions<sup>A</sup></b> <b>(tpy)</b>	<b>Level of Control<sup>B</sup></b> <b>(%)</b>	<b>Controlled PM<sub>10</sub> Emissions</b> <b>(tpy)</b>	<b>PM<sub>10</sub> Reduced</b> <b>(ton/yr)</b>	<b>Total Annual Cost<sup>C,D</sup></b> <b>(\$/yr)</b>	<b>Cost Effectiveness</b> <b>(\$/ton)</b>
K1	Wet Scrubber	14.6	50	7.3	7.3	\$126,365	\$17,310
	Residual Oil/ULSD Blend <sup>D</sup>	14.6	43	8.3	6.3	\$824,524	\$131,335
	ULSD <sup>D</sup>	14.6	85	2.2	12.4	\$1,704,479	\$137,347
	Wet ESP	14.6	90	1.5	13.1	\$736,769	\$56,071
K2	Wet Scrubber	10.5	50	5.3	5.3	\$127,172	\$24,223
	Residual Oil/ULSD Blend <sup>D</sup>	10.5	43	6.0	4.5	\$712,562	\$157,821
	ULSD <sup>D</sup>	10.5	85	1.6	8.9	\$1,473,028	\$165,045
	Wet ESP	10.5	90	1.1	9.5	\$730,620	\$77,314
K3	Wet Scrubber	38.4	50	19.2	19.2	\$136,147	\$7,091
	Residual Oil/ULSD Blend <sup>D</sup>	38.4	43	21.9	16.5	\$2,527,583	\$153,075
	ULSD <sup>D</sup>	38.4	85	5.8	32.6	\$5,225,092	\$160,082
	Wet ESP	38.4	90	3.8	34.6	\$1,232,570	\$35,665
K4	Wet Scrubber	20.7	50	10.4	10.4	\$141,244	\$13,647
	Residual Oil/ULSD Blend <sup>D</sup>	20.7	43	11.8	8.9	\$2,182,414	\$245,187
	ULSD <sup>D</sup>	20.7	85	3.1	17.6	\$4,511,548	\$256,411
	Wet ESP	20.7	90	2.1	18.6	\$1,615,374	\$86,708

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> Wet scrubber and wet ESP controlled emission levels based on AP-42, Fifth Edition, Volume I, Chapter 1, Section 1.3.4.1. The controlled emissions level for switching to a distillate fuel is based on the ratio of PM<sub>10</sub> emissions from distillate combustion from AP-42, Tables 1.3-2 and 1.3-6 and the baseline emission factor.

<sup>C</sup> See Appendix A for total annual cost calculations for wet scrubber and wet ESP.

<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars. The control options of switching to a residual oil/ULSD blend or ULSD are listed since it's a more cost-effective SO<sub>2</sub> solution than switching to a residual oil/0.4% maximum sulfur diesel blend or 0.4% maximum sulfur diesel.

### 5.2.3. Energy and Non-Air Quality Environmental impacts

ESPs, by design, apply energy to the particles they are collecting. This energy usage can be significant, especially if the wet ESP is designed to control submicron size particles where more energy is applied to collect more of the particles. Wet scrubbers require a substantial amount of energy to force exhaust gases through the scrubber.

Both wet ESPs and wet scrubbers generate wastewater streams that must either be treated on-site or sent to a wastewater treatment plant. Further, the wastewater treatment process will generate a filter cake that would likely require landfilling.

### 5.2.4. Remaining Useful Life

A capital cost recovery period of thirty (30) years was used for the controls costing. However, Hawaiian Electric intends to retire its four Kahului boilers following the addition of replacement capacity (currently planned to be in the form of energy storage) and a new switchyard in central Maui, both of which are currently anticipated to be completed in the 2023 to 2024 timeframe which will significantly shorten the time the control equipment is used and increase the removal cost per ton.

## 5.3. PARTICULATE MATTER CONCLUSION

With the exception of a wet scrubber on K3 which has a cost effectiveness of \$7,100 per ton of PM<sub>10</sub>, the cost effectiveness of the PM<sub>10</sub> controls evaluated for the boilers is more than \$10,000 per ton of PM<sub>10</sub>, and for most controls and boilers is more than \$20,000 per ton of PM<sub>10</sub>. The total cost of PM<sub>10</sub> controls ranges from 500 thousand dollars (\$500,000) annually and 15 million dollars (\$15,000,000) over thirty (30) years to 12.9 million dollars (\$12,900,000) annually and 387 million dollars (\$387,000,000) over thirty (30) years. These costs are similar to the BART analysis conducted for the first planning period. For the first planning period, the EPA concluded that PM<sub>10</sub> controls were not cost effective.<sup>27</sup>

The results of the four-factor analysis are consistent with the conclusions reached for the first planning period. Therefore, Hawaiian Electric does not propose any PM<sub>10</sub> emissions reductions in addition to the Hawai'i RPS, EEPS, and the GHG ERP to meet the RHR requirements.

<sup>27</sup> *Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawai'i*, U.S. EPA Region 9, May 14, 2012

## 6. TOTAL COST EFFECTIVENESS OF FUEL SWITCHING

Table 6-1 lists the cost per total combined tons of SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> reduced for fuel switching the boilers from residual oil to a residual oil/ULSD blend and ULSD. The cost effectiveness is determined by dividing the annual increase in fuel cost by the annual reduction in total SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> emissions. The total cost effectiveness of fuel switching is over \$5,000 per ton of emissions and the total cost exceeds 6.2 million dollars (\$6,200,000) annually and 186 million dollars (\$186,000,000) over thirty (30) years.

**Table 6-1. Total Cost Effectiveness of Fuel Switching**

Unit	Control Option	SO <sub>2</sub>	NO <sub>x</sub>	PM <sub>10</sub>	Total SO <sub>2</sub> , NO <sub>x</sub> ,	Total	Cost
		Reduced <sup>A</sup>	Reduced <sup>A</sup>	Reduced <sup>A</sup>	and PM <sub>10</sub>	Annual	Effectiveness
		(ton/yr)	(ton/yr)	(ton/yr)	Reduced	Cost <sup>B</sup>	(\$/ton)
					(ton/yr)	(\$/yr)	
K1	Residual Oil/ULSD Blend	126.2	20.4	6.3	152.9	\$824,524	\$5,394
	ULSD	292.9	40.1	12.4	345.4	\$1,704,479	\$4,935
K2	Residual Oil/ULSD Blend	109.0	19.3	4.5	132.9	\$712,562	\$5,363
	ULSD	253.1	38.0	8.9	300.0	\$1,473,028	\$4,910
K3	Residual Oil/ULSD Blend	386.8	67.3	16.5	470.6	\$2,527,583	\$5,371
	ULSD	897.8	131.7	32.6	1,062.1	\$5,225,092	\$4,920
K4	Residual Oil/ULSD Blend	334.0	42.0	8.9	384.9	\$2,182,414	\$5,670
	ULSD	775.2	82.2	17.6	875.0	\$4,511,548	\$5,156

<sup>A</sup> The SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> reduced are from Tables 3-4 and 3-5, Table 4-4, and Table 5-3, respectively.

<sup>B</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars.

**APPENDIX A: DETAILED COSTING**

---

**Appendix Table A-1. Combustion Controls Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4
Boiler design capacity, mmBtu/hr (C)		94	94	172	181
2017 Annual Heat Input, MMBtu/yr (H)		313,473	270,907	960,954	829,725
Unit Size, kW (kW)		5,900	6,000	12,700	13,000
Unit Size, MW (MW)		5.9	6.0	12.7	13.0
Capital recovery factor a. Equipment CRF, 30-yr life, 7% interest	$= [1 \times (1+i)^a] / [(1+i)^a - 1]$ , where $i$ = interest rate, $a$ = equipment life	0.08	0.08	0.08	0.08
Cost Index (CI) <sup>A</sup> a. 2019 b. 2004	607.5 444.2				
Total Capital Investment <sup>B,C</sup> TCI (\$)	$= \$24/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (CI_{2019}/CI_{2004})$	\$793,563	\$802,159	\$1,297,190	\$1,316,750
Direct Annual Operating Costs \$/yr Variable O&M Costs <sup>D</sup>	$= (\$0.08 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times H \times 10^6 \text{ Btu}/\text{mmBtu} \times (CI_{2019}/CI_{2004})$	\$3,430	\$2,964	\$10,514	\$9,078
Indirect Annual Costs, \$/yr 1. Fixed O&M Costs <sup>E</sup> 2. Capital recovery	$= \$0.36/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times (300/\text{MW})^{0.359} \times (CI_{2019}/CI_{2004})$ $= \text{Equipment CRF} \times \text{TCI}$	\$11,903 \$63,950	\$12,032 \$64,643	\$19,458 \$104,536	\$19,751 \$106,112
<b>Total Annual Cost \$/yr</b>	<b>= Direct Annual Costs + Indirect Annual Costs</b>	<b>\$79,284</b>	<b>\$79,639</b>	<b>\$134,508</b>	<b>\$134,941</b>

**Source:** All costs were estimated using Section 4.3 and Appendix D of the WRAP guidance document, *Analysis of Combustion Controls for Reducing NOx Emissions from Coal-fired EGUs in the WRAP Region*, dated September 6, 2005. The cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). Chemical Engineering Journal.

<sup>B</sup> TCI for LNB and LNB w/over fire air for wall boilers ranges from \$6/kW to \$24/kW, the high end of the range was used due to Hawaii's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>C</sup> Scaling factor =  $(300/\text{Nameplate capacity})^{0.359}$

<sup>D</sup> The variable O&M costs for LNB and LNB w/over fire air for wall boilers ranges from 0.05 mills/kW-hr to 0.08 mills/kW-hr, the high end of the range was used due to Hawaii's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>E</sup> The fixed O&M costs for LNB and LNB w/over fire air for wall boilers ranges from \$0.09/kW to \$0.36/kW, the high end of the range was used due to Hawaii's remote location.

**Appendix Table A-2. SCR Capital and O&M Cost Estimate**

	K1	K2	K3	K4
MW	5.9	6.0	12.7	13.0
Baseline NOx Emission Rate (lb/MMBtu)	0.42	0.46	0.61	0.44
2017 Annual Heat Input, MMBtu/yr	313,473	270,907	960,954	829,725
Max Heat Input (MMBtu/hr)	94	94	172	181
Capital Recovery Factor (CRF)	0.08	0.08	0.08	0.08
Cost Index <sup>A</sup>				
2019	607.5			
1999	390.6			
B = (lb/MMBtu)	0.42	0.46	0.61	0.44
C = (%)	90	90	90	90
A = (kW)	5,900	6,000	12,700	13,000
Z (Eq. 1) =	0.90	0.90	0.92	0.90
Capital Cost (Eq. 2) (\$/kW)	\$286	\$285	\$220	\$217
Capital Cost (2019) (\$)	\$2,623,236	\$2,656,291	\$4,345,933	\$4,387,432
Maui Construction Cost Multiplier <sup>B</sup>	1.938	1.938	1.938	1.938
Maui Capital Cost (2019)	\$5,083,832	\$5,147,892	\$8,422,419	\$8,502,843
Annualized Capital Cost (\$/yr)	\$409,688	\$414,850	\$678,732	\$685,214
G =	0.38	0.33	0.64	0.52
H = (MMBtu/hr)	94	94	172	181
D = (\$/kW)	\$445	\$443	\$342	\$337
Fixed O&M <sup>C</sup> (Eq. 3) (\$/yr)	\$17,313	\$17,532	\$28,683	\$28,957
Variable O&M Cost (Eq. 4) (\$/yr)	\$30,918	\$27,532	\$98,385	\$76,068
Total Annual Cost (\$/yr)	\$457,919	\$459,913	\$805,801	\$790,239

$$Z = \left[ \frac{B}{1.5} \right]^{0.05} \left( \frac{C}{100} \right)^{0.4} \quad \text{Equation 1}$$

$$D = 75 \left\{ 300,000 \frac{Z}{A} \right\}^{0.35} \quad \text{Equation 2}$$

Where:

- D = Capital cost (\$/kW)
- B = NO<sub>x</sub> (lb/10<sup>6</sup> Btu) at the inlet of the SCR reactor
- C = NO<sub>x</sub> removal efficiency (%)
- A = Plant capacity (kW)

$$E = D \times A \times C \quad \text{Equation 3}$$

Where:

- E = Fixed O&M cost (\$/yr)
- D = Capital cost (\$/kW) from Equation 1
- A = Plant capacity (kW)
- C = A constant, 0.0066 yr<sup>-1</sup>

$$F = G \left\{ 225 \times \left[ 0.37B \times H \times \left( \frac{C}{100} \right) \times \left( \frac{8760}{2000} \right) \right] \times 1.005 \times 1.05 + 0.025 \times D \times A \times Z + 1.45 \times A \right\} \quad \text{Equation 4}$$

Where:

- F = Variable O&M Cost (\$/yr)
- G = Annual capacity factor (expressed as a fraction)
- B = Inlet NO<sub>x</sub> (lb/MMBtu); range of 0.15 - 2.5 lb/MMBtu
- H = Heat input (MMBtu/hr)
- C = NO<sub>x</sub> removal efficiency; range of 80-95%
- D = Capital cost (\$/kW)
- A = Plant capacity (kW)

$$\text{Capital Recovery Factor (CRF)} = \left[ \frac{I \times (1+i)^a}{(1+i)^a - 1} \right] \quad \text{CRF} = 0.08$$

Where:

- I = Interest Rate (7% interest)
- a = Equipment life (30 yrs)

**Source:** Cost of Selective Catalytic Reduction (SCR) Application for NOx Control on Coal-Fired Boilers, EPA/600/R-01/087, October 2001. A cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI), Chemical Engineering Journal.

<sup>B</sup> The Maui construction cost multiplier is based on cost of construction geographical multipliers from the *RSMeans Mechanical Cost Data 2016* to account for factors unique to Maui's location plus an additional factor to account for additional Hawaiian Electric loadings and overhead.

<sup>C</sup> Fixed Costs include elements such as labor, station power, capital additions/improvements

Appendix Table A-3. Scrubber Capital and O&M Cost Estimate

Parameters/Costs	Equation/Reference	K1	K2	K3	K4
Exhaust Temperature (K)	$T_{stack}$	450.2	422.2	436.2	433.2
Exhaust Temperature (F)	Converted from degrees K	350.6	300.2	325.4	320.0
Exhaust Moisture Content (%)	MS - Typical Values	12.00%	12.00%	12.00%	12.00%
Exhaust Flow Rate (m <sup>3</sup> /s) <sup>1</sup>	CSP Application	12.9	12.7	22.1	27.9
Exhaust Flow Rate (ACFM) <sup>1</sup>	Converted from (m <sup>3</sup> /s)	27,246	26,999	46,908	59,181
Exhaust Flow Rate (SCFM)	ACFM*((68+460)/(Tstack+460))	17,747	18,752	31,535	40,061
m <sub>w</sub> (lb/min)	SCFM * MC * 18/385	100	105	177	225
m <sub>a</sub> (lb/min)	SCFM * (1-MC) * 29/385	730	772	1,297	1,648
humidity ratio	m <sub>w</sub> /m <sub>a</sub>	0.14	0.14	0.14	0.14
humid volume (ft <sup>3</sup> /min)	$h$ (Estimated from psychrometric chart)	23.00	23.00	23.00	23.00
Q <sub>sat</sub>	$h * m_a$	16,794.16	17,744.79	29,840.67	37,909.40
Purchased Equipment Cost (Tables 2.5 and 2.6 for a Stainless Steel Low Energy scrubber, 2002 Dollars)	$1.15*(150*Q_{sat}^{0.56})$	\$40,075	\$41,330	\$55,294	\$63,225
<b>Direct Costs - Table 2.8</b>					
<b>Purchased equipment costs</b>					
Packaged Unit (A1)	As estimated, AA	\$40,075	\$41,330	\$55,294	\$63,225
Auxiliary Costs (A2)	A2 = 0.1*A1	\$4,008	\$4,133	\$5,529	\$6,322
Equipment Costs (A)	A = A1 + A2	\$44,083	\$45,463	\$60,824	\$69,547
Instrumentation	0.10 A	\$4,408	\$4,546	\$6,082	\$6,955
Sales taxes	0.03 A	\$1,322	\$1,364	\$1,825	\$2,086
Freight	0.05 A	\$2,204	\$2,273	\$3,041	\$3,477
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$52,018</b>	<b>\$53,647</b>	<b>\$71,772</b>	<b>\$82,066</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.06 B	\$3,121	\$3,219	\$4,306	\$4,924
Handling & erection	0.40 B	\$20,807	\$21,459	\$28,709	\$32,826
Electrical	0.01 B	\$520	\$536	\$718	\$821
Piping	0.05 B	\$2,601	\$2,682	\$3,589	\$4,103
Insulation for ductwork	0.03 B	\$1,561	\$1,609	\$2,153	\$2,462
Painting	0.01 B	\$520	\$536	\$718	\$821
<b>Direct Installation Costs, DIC</b>	<b>0.56 B</b>	<b>\$29,130</b>	<b>\$30,042</b>	<b>\$40,192</b>	<b>\$45,957</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$81,148</b>	<b>\$83,689</b>	<b>\$111,965</b>	<b>\$128,023</b>
<b>Indirect Costs (installation) Table 2.8</b>					
Engineering	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Construction & field expenses	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Contractor fees	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Start-up	0.01 B	\$520	\$536	\$718	\$821
Performance test	0.01 B	\$520	\$536	\$718	\$821
Model study	--	\$1,561	\$1,609	\$2,153	\$2,462
Contingencies	0.03B	\$1,561	\$1,609	\$2,153	\$2,462
<b>Total Indirect Costs, IC</b>	<b>0.35 B</b>	<b>\$18,206</b>	<b>\$18,776</b>	<b>\$25,120</b>	<b>\$28,723</b>
Cost Index <sup>2</sup> a. 2019 b. 2002	607.5 395.6				
Capital recovery factor (CRF)	CRF = $[1 \times (1+i)^a] / [(1+i)^a - 1]$ , where i = interest rate, a = equipment life a. Equipment CRF, 30-yr life, 7% interest	0.08	0.08	0.08	0.08
<b>Total Capital Investment (2019 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (CI<sub>2019</sub>/CI<sub>1999</sub>)</b> (Retrofit factor based on average provided for ESP on Page 3-41). No specific factor provided for scrubber, so factor for ESP was relied on.	<b>\$213,601</b>	<b>\$220,290</b>	<b>\$294,719</b>	<b>\$336,987</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	3hr/shift*2shifts/day*360 days/yr * \$20/hr	\$43,200	\$43,200	\$43,200	\$43,200
Supervisor	15% of operator	\$6,480	\$6,480	\$6,480	\$6,480
<b>Maintenance</b>					
Assumed similar labor requirements as to that required for ESP per Section 6, Page 3-47 of OAQPS Cost manual (\$20.00/hr, 7.5 h/wk, 44 wk/yr)					
Labor	100% of maintenance labor	\$6,600	\$6,600	\$6,600	\$6,600
Material		\$6,600	\$6,600	\$6,600	\$6,600
<b>Utilities</b>					
Utilities currently not estimated due to variability					
<b>Total Direct Annual Cost</b>		<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$4,272	\$4,406	\$5,894	\$6,740
Property tax	1% of Total Capital Investment	\$2,136	\$2,203	\$2,947	\$3,370
Insurance	1% of Total Capital Investment	\$2,136	\$2,203	\$2,947	\$3,370
Overhead	60% of total labor and material costs	\$37,728	\$37,728	\$37,728	\$37,728
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$17,213	\$17,752	\$23,750	\$27,157
<b>Total Indirect Annual Costs</b>		<b>\$63,485</b>	<b>\$64,292</b>	<b>\$73,267</b>	<b>\$78,364</b>
<b>Total Annual Cost</b>		<b>\$126,365</b>	<b>\$127,172</b>	<b>\$136,147</b>	<b>\$141,244</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 2 - Wet Scrubbers for Particulate Matter, dated July 2002 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> From Chemical Engineering Plant Cost Index (CEPCI)

Appendix Table A-4. Wet ESP Capital and O&M Cost Estimate

Parameters/Costs	Equation	K1	K2	K3	K4
Average High Exhaust Flow Rate (m <sup>3</sup> /s) <sup>1</sup>		12.4	12.3	21.6	28.6
Average High Exhaust Flow Rate (ACFM) <sup>1</sup>		26,360	26,121	45,681	60,599
Annual Operating Time (hrs, θ)		8,760	8,760	8,760	8,760
ESP efficiency (from white paper)		90%	90%	90%	90%
ESP Plate Area (ft <sup>2</sup> ) <sup>1</sup>	$ESCA = -\ln(p)/w_e \times 5.080 \times Q$	982	973	1,702	2,257
Purchased Equipment Cost (Table 3.14 for 90% Control Efficiency and 15,000 ACFM bins)	$\$25.5/\text{acfm}$	\$672,189	\$666,078	\$1,164,874	\$1,545,272
Basic Equipment Costs -Table 3.12	$0.45 \times \text{Equipment Cost}$	\$302,485	\$299,735	\$524,193	\$695,372
<b>Direct Costs - Table 3.16</b>					
<b>Purchased equipment costs</b>					
ESP + auxiliary equipment (A)	As estimated, A	\$974,674	\$965,814	\$1,689,067	\$2,240,644
Instrumentation	0.10 A	\$97,467	\$96,581	\$168,907	\$224,064
Sales taxes	0.03 A	\$29,240	\$28,974	\$50,672	\$67,219
Freight	0.05 A	\$48,734	\$48,291	\$84,453	\$112,032
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$1,150,116</b>	<b>\$1,139,660</b>	<b>\$1,993,099</b>	<b>\$2,643,960</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.04 B	\$46,005	\$45,586	\$79,724	\$105,758
Handling & erection	0.50 B	\$575,058	\$569,830	\$996,549	\$1,321,980
Electrical	0.08 B	\$92,009	\$91,173	\$159,448	\$211,517
Piping	0.01 B	\$11,501	\$11,397	\$19,931	\$26,440
Insulation for ductwork	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
Painting	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
<b>Direct Installation Costs, DIC</b>	<b>0.67 B</b>	<b>\$770,578</b>	<b>\$763,572</b>	<b>\$1,335,376</b>	<b>\$1,771,453</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$1,920,694</b>	<b>\$1,903,233</b>	<b>\$3,328,475</b>	<b>\$4,415,413</b>
<b>Indirect Costs (installation) Table 3.16</b>					
Engineering	0.20B	\$230,023	\$227,932	\$398,620	\$528,792
Construction & field expenses	0.20B	\$230,023	\$227,932	\$398,620	\$528,792
Contractor fees	0.10B	\$115,012	\$113,966	\$199,310	\$264,396
Start-up	0.01B	\$11,501	\$11,397	\$19,931	\$26,440
Performance test	0.01B	\$11,501	\$11,397	\$19,931	\$26,440
Model study	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
Contingencies	0.03B	\$34,503	\$34,190	\$59,793	\$79,319
<b>Total Indirect Costs, IC</b>	<b>0.57B</b>	<b>\$655,566</b>	<b>\$649,606</b>	<b>\$1,136,066</b>	<b>\$1,507,057</b>
Cost Index <sup>5</sup>					
a. 2019	607.5				
b. 1999	390.6				
Capital recovery factor (CRF)	$CRF = [1 \times (1+i)^a] / [(1+i)^a - 1]$ , where i = interest rate, a = equipment life	0.08	0.08	0.08	0.08
a. Equipment CRF, 30-yr life, 7% interest					
<b>Total Capital Investment (2019 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (CI<sub>2019</sub>/CI<sub>1999</sub>) (Retrofit factor based on average provided for ESP on Page 3-41).</b>	<b>\$5,609,598</b>	<b>\$5,558,601</b>	<b>\$9,721,178</b>	<b>\$12,895,700</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	2hr/shift*2shifts/day*365 days/yr * \$20/hr	\$29,200	\$29,200	\$29,200	\$29,200
Supervisor	15% of operator	\$4,380	\$4,380	\$4,380	\$4,380
<b>Maintenance</b>					
Labor	For ESP plate area < 50,000 ft <sup>2</sup> = \$4125	\$4,125	\$4,125	\$4,125	\$4,125
<b>Utilities</b>					
	Utilities currently not estimated due to variability				
<b>Total Direct Annual Cost</b>		<b>\$37,705</b>	<b>\$37,705</b>	<b>\$37,705</b>	<b>\$37,705</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$112,192	\$111,172	\$194,424	\$257,914
Property tax	1% of Total Capital Investment	\$56,096	\$55,586	\$97,212	\$128,957
Insurance	1% of Total Capital Investment	\$56,096	\$55,586	\$97,212	\$128,957
Overhead	60% of total labor and material costs	\$22,623	\$22,623	\$22,623	\$22,623
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$452,057	\$447,948	\$783,395	\$1,039,218
<b>Total Indirect Annual Costs</b>		<b>\$699,064</b>	<b>\$692,915</b>	<b>\$1,194,865</b>	<b>\$1,577,669</b>
<b>TOTAL ANNUAL COST</b>		<b>\$736,769</b>	<b>\$730,620</b>	<b>\$1,232,570</b>	<b>\$1,615,374</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 3 - Electrostatic Precipitators, dated September 1999 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> Electricity cost from U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.

<sup>3</sup> Water cost from Maui County (<https://www.maui-county.gov/216/Water-Charges>) lowest general rate.

<sup>4</sup> For ESP Plate Area (Section 3.2.1):

$$p = 1 - (\text{Control Efficiency \%})$$

$$5.080 \text{ ft}^2/\text{kacfm} = 1 \text{ (s/m)}$$

$$w_e = \text{effective migration velocity (m/s), assume } w_e = 31.4 \text{ cm/s for Bituminous coal fly ash for a design efficiency of 95\% from Table 3.3 (no listings for 90\% efficiency or fuel oil)}$$

$$Q = \text{system flow rate (kacfm)}$$

<sup>5</sup> From Chemical Engineering Plant Cost Index (CEPCI)



## APPENDIX B: HAWAIIAN ELECTRIC REGIONAL HAZE VISIBILITY CONSIDERATIONS

---

**Appendix B:**  
**Hawaiian Electric Regional Haze Visibility Considerations**

**Fifth Factor Considerations for SO<sub>2</sub> ,NO<sub>x</sub>, and PM Controls**

AECOM Project Number: 60626547

Prepared for:



**Hawaiian  
Electric**

PO Box 2750  
Honolulu, HI 96840

Prepared by:

**AECOM**

AECOM Technical Services, Inc.  
250 Apollo Drive  
Chelmsford, MA 01824-3627

September 14, 2020

# Hawaiian Electric<sup>1</sup> Regional Haze Visibility Considerations

## Fifth Factor Considerations for SO<sub>2</sub>, NO<sub>x</sub> and PM Controls

### 1. Executive Summary

The EPA has issued multiple guidance documents to assist states and facilities address the requirements of the Regional Haze Rule (“RHR”). This guidance allows states to consider, as part of their review of the Four Factor evaluation of possible emission controls for the Second Decadal Review, a “5<sup>th</sup> factor” which involves consideration of visibility impacts of candidate control options. This appendix introduces several Hawai‘i-specific issues that impact the visibility impact of potential sulfur dioxide (“SO<sub>2</sub>”), nitrogen oxides (“NO<sub>x</sub>”) and particulate (“PM”) control options for Hawaiian Electric sources relative to the two Class 1 areas in Hawai‘i: the Haleakalā National Park on the island of Maui and the Hawai‘i Volcanoes National Park on Hawai‘i Island. The issues discussed in this report are summarized below:

- 1) Due to unique atmospheric chemistry, NO<sub>x</sub> emissions tend to remain in the gaseous (and invisible) phase in warm weather, and only form visible NO<sub>3</sub> (“nitrate”) particulate aerosol in cold weather. This is verified by monitoring data in the Interagency Monitoring of Protected Visual Environments (“IMPROVE”) network in the two national parks mentioned above.
- 2) The persistent East North East (“ENE”) trade winds experienced by the state of Hawai‘i places emission sources on several islands (or portions of islands such as Maui) downwind of the national parks, limiting the likelihood that any emissions from these sources would even reach the parks. Modeling conducted with the California Puff Model (“CALPUFF”) for the First Decadal Review confirms the minimal potential for haze impact of the subject Hawaiian Electric sources on the islands of O‘ahu and Maui due to the predominance of the trade winds. The EPA’s Federal Implementation Plan (“FIP”) issued in 2012 agreed with this assessment.
- 3) EPA previously determined that in Hawai‘i haze due to direct PM was a very small component of haze and that further controls would not be effective in improving visibility. The observed haze speciation is reviewed in this report to confirm this determination.
- 4) The State of Hawai‘i Department of Health Clean Air Branch (“DOH”) should request that the EPA (consistent with their first decadal review approach) set aside NO<sub>x</sub> and PM from the list of haze precursors for Hawai‘i due to the unique NO<sub>x</sub> haze chemistry and climate, leaving SO<sub>2</sub> as

<sup>1</sup> “Hawaiian Electric” or the “Company” refers to Hawaiian Electric Company, Inc. (or “HE”), Hawai‘i Electric Light Company, Inc. (or “HL”) and/or Maui Electric Company, Limited (or “ME”). On December 20, 2019, the State of Hawai‘i Department of Commerce and Consumer Affairs (“DCCA”) approved Hawaiian Electric Company, Inc., Hawai‘i Electric Light Company, Inc. and Maui Electric Company, Limited’s application to do business under the trade name “Hawaiian Electric” for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.

the primary precursor pollutant for haze. Hawaiian Electric requests that the DOH make this proposal to the EPA.

- 5) In the recent past, volcanic activity on Hawai'i Island has produced as much as 2 million tons of SO<sub>2</sub> emissions per year<sup>2,3</sup> (emissions vary yearly and have decreased significantly since September 2018). Additionally, the volcanic activity, although the volcano eruption ended in September 2018, has contributed significant NO<sub>x</sub> emissions in the past<sup>4</sup>. These historic volcanic SO<sub>2</sub> emissions are about three orders of magnitude (approximately 1,000 times) greater than anthropogenic SO<sub>2</sub> emissions. Although the IMPROVE monitors indicate that sulfate haze is the most important haze species, it is evident from monthly haze trends and the likelihood of winds from the volcanic activity reaching the IMPROVE monitors that the overwhelming historic sulfate haze influence comes from natural sources (i.e., volcanic activity).


The locations of the affected Hawaiian Electric sources and the two national parks are shown in Figure B-1. The remainder of this appendix presents details of the above issues and recommendations for how this information should be considered in selection of facilities for Four-Factor analyses and for evaluating potential pollutant control options.

<sup>2</sup> Information on the volcanic SO<sub>2</sub> emissions in 2014 was provided by the EPA in their SO<sub>2</sub> National Ambient Air Quality Technical Support Document at EPA's 2016 SO<sub>2</sub> NAAQS TSD, at <https://www.epa.gov/sites/production/files/2016-03/documents/hi-epa-tds-r2.pdf>.

<sup>3</sup> Information on 2014-2017 volcanic SO<sub>2</sub> emissions is available in this journal article: Elias T, Kern C, Horton KA, Sutton AJ and Garbeil H. (2018) Measuring SO<sub>2</sub> Emission Rates at Kīlauea Volcano, Hawaii, Using an Array of Upward-Looking UV Spectrometers, 2014–2017. *Front. Earth Sci.* 6:214. doi: 10.3389/feart.2018.00214. <https://www.frontiersin.org/articles/10.3389/feart.2018.00214/full>.

<sup>4</sup> The NO<sub>x</sub> emissions from Hawai'i Island volcanic activity is unknown, but could have historically been as high as 25,000 tons per year if the NO<sub>x</sub> emissions rate equals 6% of SO<sub>2</sub> emissions rate. The 6% is derived from worldwide volcanic NO<sub>x</sub> emissions estimate of 1.0 Teragram ("Tg" – trillion grams)/year ("yr") nitric oxide ("NO") (or 1.5 Tg/yr NO<sub>2</sub>) from <https://www.chemistryworld.com/features/a-volcanic-breath-of-life/3004482.article> and worldwide volcanic SO<sub>2</sub> estimate of 23 Tg/yr from <https://www.nature.com/articles/srep44095>.

**Figure B-1:**  
**Location of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas**



## 2. EPA Guidance Regarding Considerations of Visibility Impacts

The EPA issued “Guidance on Regional Haze State Implementation Plans for the Second Implementation Period”<sup>5</sup> in August 2019. This guidance allows states to consider, as part of its consideration of emission controls to include for the Second Decadal Review a “5<sup>th</sup> factor” which involves consideration of visibility impacts of candidate control options. A companion document<sup>6</sup> issued in September 2019 that involves the EPA’s visibility modeling results for 2028 is entitled, “Availability of Modeling Data and Associated Technical Support Document for the EPA’s Updated 2028 Visibility Air Quality Modeling”.

On Page 11 of the August 2019 guidance, the EPA states:

*“When selecting sources for analysis of control measures, a state may focus on the PM species that dominate visibility impairment at the Class I areas affected by emissions from the state and then select only sources with emissions of those dominant pollutants and their precursors.” . . .*

<sup>5</sup> Available at [https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019\\_-\\_regional\\_haze\\_guidance\\_final\\_guidance.pdf](https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019_-_regional_haze_guidance_final_guidance.pdf).

<sup>6</sup> Available at [https://www3.epa.gov/ttn/scram/reports/2028\\_Regional\\_Haze\\_Modeling-Transmittal\\_Memo.pdf](https://www3.epa.gov/ttn/scram/reports/2028_Regional_Haze_Modeling-Transmittal_Memo.pdf).

*“Also, it may be reasonable for a state to not consider measures for control of the remaining pollutants from sources that have been selected on the basis of their emissions of the dominant pollutants”*

Further, on Page 36 and 37, the EPA states:

*“Because the goal of the regional haze program is to improve visibility, it is reasonable for a state to consider whether and by how much an emission control measure would help achieve that goal.” . . .*

*“. . . EPA interprets the CAA and the Regional Haze Rule to allow a state reasonable discretion to consider the anticipated visibility benefits of an emission control measure along with the other factors when determining whether a measure is necessary to make reasonable progress.”*

Consequently, the extremely low likelihood for impact to Class I visibility impairment from control of certain facility pollutants and the plant locations relative to the Class I areas is appropriate for consideration when evaluating the need for further control of these emissions for Regional Haze Reasonable Progress.

### **3. Nitrate Haze Composition Analysis**



Nitrate haze composition analyses for the Haleakalā and Hawai‘i Volcanoes National Parks are available at the IMPROVE web site at <http://vista.cira.colostate.edu/Improve/pm-and-haze-composition/>. Figure B-2 provides various charts for the haze species composition at the Haleakalā Crater IMPROVE site, and Figure B-3 provides a time series of stacked bars by species for a recent year at that site. Figures B-4 and B-5 provide similar information for the Hawai‘i Volcanoes IMPROVE site. Note that these figures show information for the worst 20 percent (“%”) impaired days, which is the focus of the RHR for reducing haze. The goal for each decadal review is to track the progress of haze reduction for the worst 20% impaired days; reviewing the composition of haze on these days is a key element in understanding what precursor pollutants to control to achieve the goal.

The data for both National Parks shows that the contribution of nitrates to haze is very low as a percentage of the total, but it is also low as an absolute value for extinction (visibility impairment). The total nitrate haze impairment is approximately 1 inverse megameter (“Mm<sup>-1</sup>”), equivalent to approximately 0.25 deciview (“dv”), or less. This is the impairment at these monitors due to ALL sources, natural and anthropogenic.


The minimal impact of nitrate haze is clearly illustrated in the Hawai‘i National Park monitoring data and is much smaller than found at many monitors in other Class 1 areas around the country. This is in large part due to the unique chemistry of nitrate haze, as discussed below.

Figure B-2: Charts Showing the Worst 20% Haze Days Multiple-Year Species Composition for the Haleakalā Crater IMPROVE Site

Light Extinction Summary - Most Impaired Days




Most Impaired Days 2007-2018  
Haleakala Crater



Haleakala Crater IMPROVE monitor

Data source for Figures B-2 through B-5: [http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF\\_VisSum](http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF_VisSum).



Figure B-3: Time Series of 2018 Daily Haze Extinction Composition Plots for the Haleakalā Crater IMPROVE Site






**B-4: Charts Showing the Worst 20% Haze Days Multiple-Year Species Composition for the Hawai'i Volcanoes IMPROVE Site**

Light Extinction Summary - Most Impaired Days



**Most Impaired Days 1988-2018**  
Hawaii Volcanoes NP




**Hawaii Volcanoes NP IMPROVE monitor**



[colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF\\_VisSum](http://colostate.edu/fed/SiteBrowser/Default.aspx?appkey=SBCF_VisSum)

**AECOM**

Figure B-5: Time Series of 2018 Daily Haze Extinction Composition Plots for the Hawai'i Volcanoes IMPROVE Site




The nitrate contribution to visibility impairment in the above bar charts is shown as a narrow “red” segment. The small size relative to other constituents clearly shows that nitrate is only a small contributor. Additionally, the Figures B-6 and B-7 below which presents only the ammonium nitrate visibility impairment also shows that nitrates, already small contribution, is trending downward.



The chemistry of nitrate haze formation is highly dependent upon ambient temperature, and to a lesser extent upon humidity. As discussed in the CALPUFF model formulation<sup>7</sup> and in CALPUFF courses, total nitrate in the atmosphere ( $TNO_3 = HNO_3 + NO_3$ ) is partitioned into gaseous nitric acid (" $HNO_3$ ") (invisible, and not haze-producing) and nitrate (" $NO_3$ ") haze particles according to the equilibrium relationship between the two species, which is affected by temperature and humidity.

Figure B-8: CALPUFF Example Plot of Aerosol Percentage of Total NOx Equilibrium



The potential for the formation of haze due to NOx emissions is very low in Hawai'i because of the warm weather conditions year-round. This strong dependency of the equilibrium relationship between invisible gaseous  $HNO_3$  and visible  $NO_3$  haze particles as a function of ambient temperature is illustrated in Figure B-8. In Figure B-8, it is evident that for most conditions, the percentage of total nitrate in the form of particulate ( $NO_3$ ) is less than 20% for temperatures above approximately 286 degrees Kelvin (approximately 55 degrees Fahrenheit). Temperatures at most locations in Hawai'i rarely get that low and are not that low at any of the Hawaiian Electric plant locations.

<sup>7</sup> Documentation for the CALPUFF modeling system is available from links provided at <https://www.epa.gov/scram/air-quality-dispersion-modeling-alternative-models#calpuff>.

This dependency of nitrate haze formation as a function of temperature (and season) for more seasonally-varying locations in the United States is shown in the September 2019 EPA modeling report<sup>2</sup> in Figure B-9 (from Appendix A of that report). This figure shows that the thermodynamics of the nitrate haze equilibrium result in much greater particulate formation in winter versus other seasons for more temperate climates, while NO<sub>x</sub> emissions are expected to be relatively constant over the entire year. This implies that NO<sub>x</sub> emission reductions would only be effective for haze reduction during cold winter months, while consideration of NO<sub>x</sub> emission reductions in other months is relatively ineffective.


It should also be noted that volcanic activity on Hawai'i Island may also be a large source of NO<sub>x</sub> in the state. Volcanoes are commonly thought of as large sources of SO<sub>2</sub>, but they also can emit significant amounts of NO<sub>x</sub>. Laboratory analysis<sup>8</sup> of NO<sub>x</sub> emissions content in volcanic exhaust indicates a substantial component, likely caused by thermal contact of air with lava. The annual worldwide volcano NO<sub>x</sub> emissions (as NO<sub>2</sub>) is estimated<sup>3</sup> at approximately 1.5 teragrams ("Tg" – trillion grams).

In summary, nitrate haze is a very small component in Hawai'i's Class I areas, which is expected given nitrate chemistry and is verified by the IMPROVE monitoring data. The multiple-year average of the nitrate haze impact for worst 20% days at the two areas is approximately Mm-1, or less than 0.5 delta-dv. This total nitrate haze impact is less than the de minimis contribution threshold used to eliminate a single source from consideration for controls during the First Decadal Review period.

Due to the low haze impact of NO<sub>x</sub> (even if every source in the state and the volcano was eliminated), the state of Hawai'i should limit the haze precursors control evaluations to SO<sub>2</sub> for the Second Decadal Review. A similar conclusion was reached during the First Decadal Review, for which the EPA did not consider NO<sub>x</sub> controls to be material. The State of Hawai'i Department of Health should work with the EPA to provide this technical justification to remove NO<sub>x</sub> as a haze precursor for the state of Hawai'i.

<sup>8</sup> Mather, T., 2004. A Volcanic Breath of Life? Chemistry World, 30 November 2004 Featured Article. <https://www.chemistryworld.com/features/a-volcanic-breath-of-life/3004482.article>.

**Figure B.9: Monthly Variation of Nitrate Particulate Concentrations for Selected IMPROVE Sites from EPA 2019 Modeling Report**



#### **4. PM Species Haze Composition Analysis**

In their Federal Implementation Plan Technical Support Document<sup>9</sup>, EPA noted that “due to the overwhelming contribution of sulfate to visibility impairment at the nearby Hawaii Volcanoes Class I area, it is unlikely that reductions in these pollutants [NO<sub>x</sub> and PM]...would have a measurable impact on visibility at that area.”

It is clear from a review of the haze speciation shown in Figures B-2 through B-5 that the contribution to haze of direct particulate species such as elemental carbon, soil, and coarse mass is relatively low. Furthermore, emissions of coarse PM mass (ash) from the volcanic activity can be very high (clearly evident from photos of volcanic activity) to the extent that it may result in aviation alerts. These emissions can be much greater than emissions from power plants and can constitute a significant portion of the direct PM-caused haze shown in Figures B-2 through B-5. The remaining human-caused haze due to direct PM emissions is therefore a very small component of the total haze, and this determination is consistent with EPA’s 2012 assessment.

#### **5. Predominant Trade Winds in Hawai‘i**

The EPA’s FIP for Hawai‘i for the First Decadal Review (77 FR 61478, October 9, 2012) acknowledged the direction of the predominant trade winds in Hawai‘i and thus did not require controls on upwind sources (i.e., sources on O‘ahu and Maui). Figure B-10 shows the locations of the Hawaiian Electric sources and the national parks, along with wind rose plots for airports on Maui and O‘ahu. The wind rose plots show that the wind is almost always from the northeast and rarely blows from the Hawaiian Electric facilities on O‘ahu or Maui toward either of Hawai‘i’s Class 1 areas.

The EPA CALPUFF modeling conducted for the First Decadal Review confirms the expected low impacts from sources on Maui, even though the sources were relatively close to Haleakalā National Park. This result is due to the fact, as stated above, that winds rarely blow the emissions from sources downwind from the parks back to the parks, and the CALPUFF modeling confirmed the low impact from occasional periods when the wind may blow toward the parks from the sources modeled. The Western Regional Air Partnership (“WRAP”) Q/d analysis that included several sources on the islands of O‘ahu and Maui in the four-factor analysis did not consider the wind patterns. A review of past modeling and the EPA’s 2012 FIP should lead to a dismissal of those sources from inclusion in four-factor analyses for the second decadal review period.

The geometry and wind roses shown in Figure B-10 and previous CALPUFF modeling both indicate that Hawaiian Electric generating stations on O‘ahu and Maui would have minimal impact to Class 1 area haze. Because of this, and the minimal impact of NO<sub>x</sub> due to nitrate chemistry, consideration of

<sup>9</sup> EPA, May 14, 2012. Technical Support Document for the Proposed Action on the Federal Implementation Plan for the Regional Haze Program in the State of Hawaii. EPA docket EPA-R09-OAR-2012-0345-0002 via [www.regulations.gov](http://www.regulations.gov).

potential additional pollution controls at Hawaiian Electric facilities for Regional Haze progress should be limited to SO<sub>2</sub> for sources on Hawai'i Island.

## 6. Natural Sources of SO<sub>2</sub> From Volcanic Activity

Volcanic activity on the Hawai'i Island represents a unique and challenging complication to understanding haze in Hawai'i Class I areas. The Kilauea volcano on Hawai'i Island has been active for several years, and the levels of SO<sub>2</sub> emissions are being monitored by the United States Geological Survey. As shown in Figure B-11<sup>10</sup> (related to the SO<sub>2</sub> National Ambient Air Quality Standards implementation and monitoring), there were over 2 million tons of SO<sub>2</sub> emissions from volcanic activity on Hawai'i Island in the year 2014, compared to roughly 2,000 tons of power plant SO<sub>2</sub> emissions for that year. As noted in a *Frontiers in Earth Science* 2018 article<sup>11</sup>, the volcanic SO<sub>2</sub> emissions have been relatively steady at levels close to 2 million TPY for the period of 2014 to 2017. The volcanic SO<sub>2</sub> emissions have decreased after the Kilauea eruption ended in September 2018, but remain significant. The USGS preliminary estimates of annual volcanic emissions of SO<sub>2</sub> for 2019 are 17,119 tons/year<sup>12</sup>.

The extremely high and variable levels of natural SO<sub>2</sub> emissions present a significant challenge for defining "impaired" haze days because the same pollutant (i.e., SO<sub>2</sub>) is emitted by volcanic activity and the power plants and other combustion sources. Therefore, the RHR glidepath for the two Class I areas in Hawai'i is difficult to establish if naturally-caused haze is to be excluded from the analysis.

There appears to be very little anthropogenic haze impairment remaining at Haleakalā National Park because there are very few sources on Maui upwind of the park and there are no land masses upwind of Maui for thousands of kilometers. For Hawai'i Island, the largest sources of SO<sub>2</sub> are natural sources that are part of (or adjacent to) the park.

Even the anthropogenic sources (from power plants) are projected to be phased out well before the end point of the RHR (i.e., 2064) by Hawai'i's State Renewable Portfolio Standards Law ("RPS") implementing requirements to convert 100% of the state's electrical generation to renewable energy sources. This RPS law (Hawai'i Revised Statute §269-92) will substantially reduce emissions of haze precursors by 2045. Further details of the past and future benefits of the RPS requirements are detailed in separate Appendix C.

<sup>10</sup> <https://www.epa.gov/sites/production/files/2016-03/documents/hi-epa-tds-r2.pdf>.

<sup>11</sup> Elias, T., C. Kern, K. Horton, A. Sutton, and H. Garbeil, 2018. Measuring SO<sub>2</sub> Emission Rates at Kilauea Volcano, Hawai'i, Using an Array of Upward-Looking UV Spectrometers, 2014–2017. *Front. Earth Sci.* 6:214. doi: 10.3389/feart.2018.00214. <https://www.frontiersin.org/articles/10.3389/feart.2018.00214/full>.

<sup>12</sup> Hawaii Dept. of Health comment letter to Hawaiian Electric Light Company regarding Puna Generating Station Four Factor Analysis; July 8, 2020.



Figure B-10: Geography of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas, with Wind Roses





Figure B-11: Geography of Hawaiian Electric Sources Asked to Conduct Four-Factor Analyses and PSD Class I Areas, with Wind Roses



## 7. Conclusions

The state of Hawai'i is isolated from all other states and has very unique regional haze issues due, in part, to its tropical climate, the prevalent trade winds, very large natural emissions of haze precursors, and statewide commitment to renewable energy.

- Emission sources on O'ahu and Maui are downwind of Hawai'i's Class 1 areas and do not contribute to haze issues, such that additional emission controls would not contribute to further reasonable progress at either of Hawai'i's Class 1 area National Parks. This is consistent with the EPA's First Decadal Review findings.
- Additionally, NO<sub>x</sub> emissions do not significantly contribute to haze in Hawai'i due the nitrate chemistry and Hawai'i's warm climate, and additional NO<sub>x</sub> controls would likewise not contribute to further reasonable progress. Therefore, NO<sub>x</sub> should not be regulated as a contributing precursor to haze in Hawai'i; especially from O'ahu and Maui sources that are downwind of the parks. If they are reviewed as precursors, consideration should be given to their insignificant contribution when evaluating possible controls.
- Direct PM emissions constitute a very small portion of the haze associated with the worst 20% haze days in the Hawai'i Class 1 areas. Furthermore, significant portions of the observed haze in the categories of elemental carbon, soil, and coarse mass are due to volcanic emissions. Therefore, further PM controls on power plant sources would not have a significant benefit for visibility at these Class 1 areas.
- For the above reasons, the only pollutant that should be considered for possible haze controls in the state of Hawai'i is SO<sub>2</sub> which is consistent with the findings of the First Decadal Review. Furthermore, the only Hawaiian Electric sources to be considered for a four factor analysis for SO<sub>2</sub> should be those that are predominantly upwind of a Class I area which include only the Puna and Kanoelehua-Hill Generating Stations on Hawai'i Island.
- Hawai'i's Class I area haze impacts are principally due to natural sources. Volcanic emissions of precursor SO<sub>2</sub> during the 2014-2017 period of analysis were three orders of magnitude greater than the anthropogenic emissions on Hawai'i Island. Since these natural emissions are the principal cause of haze at the two Class 1 areas in the state and are difficult to distinguish from the relatively small amount of anthropogenically-caused haze, photochemical grid modeling is not practical or even needed. The definition of "impaired days" for Hawai'i Volcanoes National Park as referenced in some of the figures in this report is uncertain due to the overwhelming influence of natural emissions of SO<sub>2</sub>.
- For Haleakalā National Park, with the lack of upwind anthropogenic sources, it could be reasonably concluded that natural conditions are already attained, and no further Reasonable Progress modeling (or controls) is needed. For Hawai'i Volcanoes National Park, the only United

States anthropogenic potential sources are those upwind of the park on Hawai'i Island; all other sources in the state are not contributing to haze at the Class 1 areas.

- Implementation of Hawai'i's RPS (discussed in detail in Appendix C) will provide a dramatic reduction of virtually all power plant haze-causing emissions in the state of Hawai'i well before the year 2064. This Hawai'i state law established enforceable requirements that a certain percentage of electricity must be generated from renewable energy sources by the end of identified benchmark years leading to 100percent renewable energy by 2045. The interim targets are 30 percent by 2020, 40 percent by 2030, and 70 percent by 2040 which provide an RPS "glide path" for EGUs that mirrors the RHR visibility improvement glide path for the next few decades. No separate new regional haze measures for EGUs are needed to assure reasonable progress for this decadal period.

Plans for renewable energy sources, the likely reduction in utilization of fossil-fueled electric generation in this interim period, the unique climate and wind patterns, and the difficulty of addressing the high volcanic emissions should be considered in the current planning for the Second Decadal Review process for the state of Hawai'i.

**APPENDIX C: HAWAI'I'S RENEWABLE PORTFOLIO STANDARDS  
CONTRIBUTION TO REGIONAL HAZE PROGRESS**

---

**Appendix C:  
Hawai'i's Renewable Portfolio Standards ("RPS")  
Contribution to Regional Haze Progress**

AECOM Project Number: 60626547

Prepared for:



**Hawaiian  
Electric**

PO Box 2750  
Honolulu, HI 96840

Prepared by:

**AECOM**

AECOM Technical Services, Inc.  
500 West Jefferson, Suite 1600  
Louisville, KY 40202

March 30, 020

# **Hawai'i's Renewable Portfolio Standards ("RPS")**

## **Contribution to Regional Haze Progress**

### **1. Executive Summary**

Hawai'i's ongoing conversion of fossil-fueled electric generation to renewable energy sources as mandated by the Hawai'i Revised Statute ("HRS") §269-92 Renewable Portfolio Standards ("RPS") is significantly decreasing emissions from Hawai'i's electric generating stations. Past actual and expected future decreases in usage of fossil-fueled electric generating units ("EGUs") are achieving emissions reductions at a rate consistent with, or faster than, the reasonable progress goals of the Regional Haze Rule ("RHR"). Emissions from the majority of Hawai'i's electric generating plants are not a significant contributor to haze at Class I areas (for reasons explained in Appendix B). Further, their very low impact is being mitigated under the RPS state law. This rate of progress from the RPS law can be relied upon for further emissions reductions from EGUs in the coming years and thus separate further requirements for EGU controls under the RHR are not needed at this time. The following sections of this appendix provide a background on the RPS requirements and progress to date, and high confidence of continued progress consistent with the goals of the RHR.

### **2. Renewable Portfolio Standards**

In 2002 the Hawai'i RPS legislation set voluntary goals for converting the islands' electrical generation from fossil fuels to renewable energy. In 2005, the RPS was set into law as binding requirements for Hawai'i electric utility companies. The law requires that electric utilities in Hawai'i achieve 100% of their electric generation from renewable energy sources by 2045 and meet a series of interim limits for the percentages of their electricity sales that must be provided by renewables (e.g., 30% renewable by 2020, and 40% by 2030, etc.). Renewable energy sources such as solar, hydro and wind energy have no direct emissions. Others such as biomass combustion have significantly lower emissions (especially sulfur dioxide ("SO<sub>2</sub>")) than fossil fuels. Consequently, the RPS law results in steady progress in emissions reductions from electric utilities creating, in effect, an "RPS glidepath" providing dramatic reduction of electric generating unit emissions by mid-century.

The RPS program, although not directly related to the Regional Haze Rule, is providing emissions reductions and improvements to air quality consistent with the goals of the RHR.

Table C-1 shows the interim and final RPS for EGUs along with the Regional Haze adjusted glidepath emissions reductions goals<sup>1</sup>.

<sup>1</sup> Regional Haze Adjusted Glidepath assumes consistent reductions in haze precursor emissions impacts from all U.S. anthropogenic sources from the baseline average of 2000-2004 to zero impacts in 2064, i.e. natural background.

**Table C-1 Comparison of RPS and Regional Haze Glidepaths**

Year	RPS Renewable Requirement % of Electricity Sales	Regional Haze Glidepath % Visibility Improvement
2010	10%	8%
2015	15%	17%
2020	30%	25%
2030	40%	42%
2040	70%	58%
2045	100%	67%
2065		100%

This table illustrates that the emissions reductions from EGUs under the RPS are similar to the visibility goals of the Regional Haze Program in the intermediate years and become much more stringent in later years. The RPS seeks to achieve 100% renewable electrical supply by 2045, which is twenty years earlier than the RHR target of 2065 to achieve natural background visibility in Class I areas.

### 3. Historical RPS Achievement

Hawaiian Electric<sup>2</sup>, and other electric utility providers in Hawai‘i, have made excellent progress in developing and supporting renewable energy sources. Figure C-1 below shows the percentage of all electrical sales statewide provided by renewable sources since the RPS inception (green columns).<sup>3</sup> It also shows as a line illustrating the RPS interim standards (with proportional progress assumed between RPS milestone years). This figure illustrates that Hawai‘i EGUs have made significant progress to date and have been ahead of the RPS interim targets.


Hawaiian Electric represents majority of Hawai‘i’s electric generation. Figure C-2 shows the renewable energy source percentages for this same period specifically for Hawaiian Electric. The data follows the same trend as the statewide figures and this figure also shows a breakdown of the type of renewable energy technology used.

<sup>2</sup> “Hawaiian Electric” or the “Company” refers to Hawaiian Electric Company, Inc. (or “HE”), Hawai‘i Electric Light Company, Inc. (or “HL”) and/or Maui Electric Company, Limited (or “ME”). On December 20, 2019, the State of Hawai‘i Department of Commerce and Consumer Affairs (“DCCA”) approved Hawaiian Electric Company, Inc., Hawai‘i Electric Light Company, Inc. and Maui Electric Company, Limited’s application to do business under the trade name “Hawaiian Electric” for the period from December 20, 2019 to December 19, 2024. See Certificate of Registration No. 4235929, filed December 20, 2019 in the Business Registration Division of the DCCA.

<sup>3</sup> Hawai‘i Public Utility Commission (PUC), “Report to the 2019 Legislature on Hawai‘i’s Renewable Portfolio Standards”, Dec. 2018 [https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report\\_FINAL.pdf](https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report_FINAL.pdf).




**Figure C-1 Statewide Renewable Portfolio Progress**



Source: [https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report\\_FINAL.pdf](https://puc.hawaii.gov/wp-content/uploads/2018/12/RPS-2018-Legislative-Report_FINAL.pdf)

**Figure C-2 Hawaiian Electric Companies RPS Achievement by Generation Technology<sup>4</sup>**



<sup>4</sup> PUC Dec. 2018 Report, Figure 2, page 7.

#### 4. Future RPS Achievability

To date, Hawai'i's electric utilities have generally met or exceeded the RPS requirements. Continued progress consistent with RPS is expected to continue. Projects and plans are already in place to continue this rapid RPS shift to renewable energy sources for the period of interest of the next decadal period of the RHR. In its December 2018 report to the state legislature, the Hawai'i Public Utility Commission ("PUC") indicated that *"future renewable projects under construction or planned for the HECO Companies and KIUC should ensure that the state remains on track for meeting the 2020 and 2030 RPS targets."*<sup>5</sup>

Figure C-3 below shows Hawaiian Electric's projection of percent renewables through 2030 presented in the December 2018 PUC report. This projected progress remains well ahead of the RPS requirements which also is ahead of the requirements of the Regional Haze glidepath goals.

**Figure C-3 Hawaiian Electric Companies RPS Expectation by 2030 Technology<sup>6</sup>**




Table C-2 below shows the past actual and future forecast for Hawaiian Electric from the previous two figures (from PUC's 2018 report) together with the requirements of RPS and the goals of the RHR. Hawaiian Electric's renewable energy progress and forecast is ahead of both programs. Additionally, Hawaiian Electric has an internal target to achieve 100% renewables by 2040, five years ahead of the RPS requirement and 25 years ahead of the RHR goals.

<sup>5</sup> PUC Dec. 2018 Report, page 2.


<sup>6</sup> PUC Dec. 2018 Report, Figure 2, page 16.

**Table C-2 Comparison of RPS and Regional Haze Glidepaths**

Year	RPS Renewable Requirement % of Electricity Sales	Regional Haze Glidepath % Visibility Improvement	Hawaiian Electric % Renewables
2010	10%	8%	9.5% (actual)
2015	15%	17%	23.2% (actual)
2020	30%	25%	31.9% (projection)
2030	40%	42%	47.3% (projection)
2040	70%	58%	100% (goal)
2045	100%	67%	100% (goal)

Hawaiian Electric’s latest projections show an even more rapid shift to renewable energy sources than forecasted in 2018. This will continue to decrease Hawaiian Electric facility emissions. For example, Figure C-4 illustrates Hawaiian Electric’s latest forecast emissions trends for total nitrogen oxides (“NOx”), sulfur dioxide (“SO<sub>2</sub>”) and Particulate Matter (“PM<sub>10</sub>”) emissions (in tons per year “TPY”) from the six power plants (Waiiau and Kahe Generating Stations on Oahu, Kahului and Maalaea on Maui, and Kanoelehua-Hill and Puna on Hawai’i) requested to conduct Four-Factor Analyses by the Hawai’i Department of Health (“DOH”). These dramatic emissions decreases illustrate the expected progress from RPS alone – without any additional RHR measures. The forecast emissions shown in Figure C-4 was derived from recent fuel consumption projections based on the resource plans and planning assumptions submitted to the PUC as part of Hawaiian Electric’s 2016 Power Supply Improvement Plan (“PSIP”) which was accepted by the PUC and recent renewable project applications.

**Figure C-4 Hawaiian Electric NOx Forecast Emissions**



The emissions reduction is quite rapid and most of the projected reduction by Hawaiian Electric are expected to be in place prior to 2028, the next Regional Haze planning milestone.

Although this projection is based on reasonable assumptions, plans are subject to change as there is some uncertainty regarding future projections and forecast assumptions. For this reason and due to energy security issues, Hawaiian Electric cannot commit to specific dates for particular emissions reductions or final retirements of any specific generating station. Nevertheless, Hawaiian Electric is on an aggressive path to end fossil-fueled generation and replace it with renewable energy sources – especially during this next decadal period. This progress should be sufficient for Hawaiian Electric’s contribution to the state’s efforts regarding reasonable progress of the RHR for the current Regional Haze decadal review.

## **5. Reliance on RPS for this Regional Haze Decadal Review**

The RPS requirements are part of Hawai’i state law. An electric utility failing to meet the RPS requirements is subject to enforcement action and penalties by the PUC unless the PUC determines the electric utility is unable to meet the RPS due to factors beyond its reasonable control. However, given the progress to date of the Hawai’i electric utilities acquiring renewable generation and expectations for planned renewable projects in the near future, it is reasonable to expect that RPS will result in continued steady progress, at least through 2030.

The DOH can rely on the RPS for regional haze progress without having to impose separate RHR requirements in facility permits. This is supported by EPA guidance which states that “Enforceable requirements are one reasonable basis for projecting a change in operating parameters and thus emissions; energy efficiency, renewable energy, or other such programs where there is a documented commitment to participate and verifiable basis for quantifying any change in future emissions due to operational changes may be another.”<sup>7</sup>

Even if progress were slower than currently expected, it would not prevent the RPS from being relied upon as the major EGU contribution to meeting Hawai’i’s regional haze goals. The time perspective of the Regional Haze Program is long. Making wise decisions that help achieve the long-term goals is important. Hawai’i electric utilities are currently focusing resources on advancing renewable energy projects that will permanently displace fossil-fueled unit generation and fossil-fueled combustion emissions. These ongoing RPS efforts help achieve the long-term goals of the RHR and provide permanent emissions reductions and other societal benefits. In contrast, new investments in conventional emissions controls on aging fossil-fueled units provide only modest short-term benefits impose additional costs on rate payers and will have no lasting value when those units are deactivated or retired.

<sup>7</sup> Guidance on Regional Haze State Implementation Plans for the Second Implementation Period – August 2019 at page 17. [https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019\\_-\\_regional\\_haze\\_guidance\\_final\\_guidance.pdf](https://www.epa.gov/sites/production/files/2019-08/documents/8-20-2019_-_regional_haze_guidance_final_guidance.pdf).



**Appendix Table D-1. Residual High Sulfur Fuel Oil Cost**

Date	Residual High Sulfur Fuel Oil <sup>A</sup>	
	(\$/BBL)	(\$/gal)
Jan-18	\$61.85	\$1.47
Feb-18	\$57.82	\$1.38
Mar-18	\$61.52	\$1.46
Apr-18	\$56.94	\$1.36
May-18	\$57.46	\$1.37
Jun-18	\$63.67	\$1.52
Jul-18	\$70.63	\$1.68
Aug-18	\$70.01	\$1.67
Sep-18	\$71.03	\$1.69
Oct-18	\$70.54	\$1.68
Nov-18	\$76.18	\$1.81
Dec-18	\$81.51	\$1.94
Jan-19	\$74.35	\$1.77
Feb-19	\$54.11	\$1.29
Mar-19	\$59.68	\$1.42
Apr-20	\$66.10	\$1.57
May-19	\$69.59	\$1.66
Jun-19	\$67.28	\$1.60
Jul-19	\$66.10	\$1.57
Aug-19	\$61.45	\$1.46
Sep-19	\$58.64	\$1.40
Oct-19	\$54.94	\$1.31
Nov-19	\$56.65	\$1.35
Dec-19	\$52.30	\$1.25
<b>2018-19 Annual Average</b>	<b>\$64.18</b>	<b>\$1.53</b>

<sup>A</sup> Fuel cost from the 2019 and 2018 Energy Cost Recovery Filings submitted to the Hawai'i Public Utilities Commission.

(<https://www.hawaiianelectric.com/billing-and-payment/rates-and-regulations/energy-cost-filings/maui-energy-cost-filings>)

**Appendix Table D-2. Ultra-Low Sulfur Diesel (ULSD) Import Cost**

<b>Description</b>	<b>Value</b>	<b>Units</b>
Platts 2018 Price <sup>A</sup>	86.75	\$/BBL
2019 Inflation	1.5	%
Platts 2019 Price	88.05	\$/BBL
Freight <sup>B</sup>	5.51	\$/BBL
Terminalling Fee <sup>B</sup>	2.00	\$/BBL
<b>Total ULSD Import Cost <sup>C</sup></b>	<b>95.56</b>	<b>\$/BBL</b>
	<b>2.28</b>	<b>\$/Gal</b>

<sup>A</sup> S&P Global Platts - Oilgram Price Report, listed price is Singapore spot price for Gasoil 10 ppm which is comparable to ULSD. ([https://www.spglobal.com/platts/plattscontent/\\_assets/\\_files/en/productservices/market-reports/oilgram-proce-report-060818.pdf](https://www.spglobal.com/platts/plattscontent/_assets/_files/en/productservices/market-reports/oilgram-proce-report-060818.pdf))

<sup>B</sup> Hawaiian Electric Fuels Division Estimate

<sup>C</sup> Platts 2019 spot price plus freight and terminalling fees.

**Appendix Table D-3. Diesel (0.4% Maximum Sulfur) Import Cost**

<b>Description</b>	<b>Value</b>	<b>Units</b>
Platts 2018 Price <sup>A</sup>	85.12	\$/BBL
2019 Inflation	1.5	%
Platts 2019 Price	86.40	\$/BBL
Freight <sup>B</sup>	5.51	\$/BBL
Terminalling Fee <sup>B</sup>	2.00	\$/BBL
<b>Total ULSD Import Cost <sup>C</sup></b>	<b>93.91</b>	<b>\$/BBL</b>
	<b>2.24</b>	<b>\$/Gal</b>

<sup>A</sup> S&P Global Platts - Oilgram Price Report, listed price is Singapore spot price for Gasoil 0.25% S which is comparable to the current diesel supply. ([https://www.spglobal.com/platts/plattscontent/\\_assets/\\_files/en/productservices/market-reports/oilgram-proce-report-060818.pdf](https://www.spglobal.com/platts/plattscontent/_assets/_files/en/productservices/market-reports/oilgram-proce-report-060818.pdf))

<sup>B</sup> Hawaiian Electric Fuels Division Estimate.

<sup>C</sup> Platts 2019 spot price plus freight and terminalling fees.

## **Control Cost Worksheets and DOH-CAB Revisions**



## **Changes Summarized**

3.25 % interest rate for controls

30 year equipment life for SCR

20 year equipment life for all other controls\*

SNCR retrofit factor of 1

Hawaii Island Construction Cost Multiplier from 1.938 to 1.

\* Equipment life of wet scrubbers were reassess at 30 years based on upcoming revision to the cost control manual.

**Table 3-1. 2017 Fuel Property and Fuel Usage and Baseline SO<sub>2</sub> Emissions**

Unit	2017 Annual Average Residual Oil Properties <sup>A</sup>			Equivalent Annual Residual Oil Usage <sup>B</sup>		SO <sub>2</sub> Emissions	
	Sulfur Content	HHV (Btu/gal)	Density (lb/gal)	Volume (gal/yr)	Heat Input (MMBtu/yr)	(lb/MMBtu) <sup>C</sup>	(TPY) <sup>D</sup>
K1	1.69%	151,009	8.34	2,075,864	313,473	1.87	293.1
K2	1.69%	151,009	8.34	1,793,982	270,907	1.87	253.3
K3	1.69%	151,009	8.34	6,363,573	960,954	1.87	898.5
K4	1.69%	151,009	8.34	5,494,558	829,725	1.87	775.8
<b>Total</b>						<b>1.87</b>	<b>2,220.7</b>

<sup>A</sup> Calendar year 2017 annual average residual oil fuel properties from company records.

<sup>B</sup> To account for ignition fuels and used oil usage the equivalent annual residual oil usage was calculated from the 2017 annual average fuel properties and reported SO<sub>2</sub> emissions.

<sup>C</sup> The SO<sub>2</sub> emission factors are based on 100% conversion of fuel sulfur to SO<sub>2</sub> and the calendar year 2017 annual average residual oil fuel density and higher heating value.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 4-1 Baseline NO<sub>x</sub> Emissions**

Unit	NO <sub>x</sub> Emissions		
	Residual Oil Emissions Factor (lb/MMBtu) <sup>A</sup>	Adjusted Emission Factor (lb/MMBtu) <sup>B</sup>	(TPY) <sup>C</sup>
K1	0.420	0.420	65.8
K2	0.460	0.460	62.3
K3	0.609	0.609	292.6
K4	0.436	0.440	182.7
<b>Total</b>			<b>603.4</b>

<sup>A</sup> Calendar year 2017 emission factors from the 2018 Emissions Fee Report.

<sup>B</sup> The adjusted emission factors include emissions from the ignition fuels and used oil.

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 5-1 Baseline PM<sub>10</sub> Emissions**

Unit	PM <sub>10</sub> Emissions		
	Residual Oil Emissions Factor (lb/MMBtu) <sup>A</sup>	Adjusted Emission Factor (lb/MMBtu) <sup>B</sup>	(TPY) <sup>C</sup>
K1	0.0933	0.0931	14.6
K2	0.0778	0.0775	10.5
K3	0.0799	0.0799	38.4
K4	0.0495	0.0499	20.7
<b>Total</b>			<b>84.2</b>

<sup>A</sup> Calendar year 2017 emission factors from the 2018 Emissions Fee Report.

<sup>B</sup> The adjusted emission factors include emissions from the ignition fuels and used oil.

<sup>C</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Supporting Calculations**

Fuel	(Btu/gal)	(lb/gal)	Permitted Heat Input (MMBtu/hr)	Permitted Output Nominal (MW)
Bunker	151,009	8.34	94	5.0
Bunker	151,009	8.34	94	5.0
Bunker	151,009	8.34	172	11.5
Bunker	151,009	8.34	181	12.5

**Company Records**

**Section A. Equipment Description**

- This permit encompasses the following boilers with four (4) 185 feet high x 4 feet diameter flue gas exhaust stacks inside a common stack:

Unit    Description

- K-1 5.0 MW (nominal), 94 MMBtu/hr, Combustion Engineering Boiler, serial no. 13413, with electric igniters;
- K-2 5.0 MW (nominal), 94 MMBtu/hr, Combustion Engineering Boiler, serial no. 15345, with total combined 2.5 ft<sup>3</sup>/hr capacity gas fired igniters;
- K-3 11.5 MW (nominal), 172 MMBtu/hr, Combustion Engineering Boiler, serial no.17343, with total combined 3.3 ft<sup>3</sup>/hr capacity gas fired igniters; and
- K-4 12.5 MW (nominal), 181 MMBtu/hr, Babcock and Wilcox Boiler, serial no. PFI3030 with total combined 10 ft<sup>3</sup>/hr capacity gas fired igniters.

**2017 Kahului Fuel Analyses Summary**

Destination	Fuel	Time Period	Volume Received (bbls)	Sulfur Content		Higher Heating Value		Average Density (lb/gal)	# of Samples
				Maximum (wt. %)	Average (wt. %)	Maximum (Btu/gal)	Average (Btu/gal)		
				Calculation					
Kahului	Bunker	Jan - Jun	178,430	1.83	1.74				11
		Jul - Dec	207,570	1.82	1.65				15
		Jan - Dec	386,000	1.83	1.69	152,357	151,009	8.34	26

[Original Submitted Spreadsheet](#)

**Table 3-2. SO<sub>2</sub> Cost Effectiveness of Switching to a Residual Oil/Diesel Blended Fuel**

Unit	Current Residual Oil <sup>A</sup>					Residual Oil/Distillate Blend (1.0% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content	Fuel Heating Value (HHV)	Annual Fuel Usage	2017 Annual Heat Input	2017 SO <sub>2</sub> Emissions <sup>D</sup>	Fuel Heating Value (HHV)	Annual Fuel Usage	Controlled SO <sub>2</sub> Emissions	SO <sub>2</sub> Reduced	Fuel Cost Differential <sup>C</sup>		SO <sub>2</sub> Cost Effectiveness
	(%)	(Btu/gal)	(gal/yr)	(MMBtu/yr)	(tpy)	(Btu/gal)	(gal/yr)	(tpy)	(tpy)	(\$/Gal)	(\$/year)	(\$/ton)
K1	1.69%	151,009	2,075,864	313,473	293.1	142,359	2,201,991	164.73	128.37	0.44	\$968,876	7,548
K2	1.69%	151,009	1,793,982	270,907	253.3	142,359	1,902,983	142.36	110.94	0.44	\$837,313	7,548
K3	1.69%	151,009	6,363,573	960,954	898.5	142,359	6,750,218	504.98	393.52	0.44	\$2,970,096	7,548
K4	1.69%	151,009	5,494,558	829,725	775.8	142,359	5,828,402	436.02	339.78	0.44	\$2,564,497	7,548

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> #NAME?

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 3-3. SO<sub>2</sub> Cost Effectiveness of Switching to Diesel**

Unit	Current Residual Oil <sup>A</sup>					Diesel (0.4% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content	Fuel Heating Value (HHV)	Annual Fuel Usage	2017 Annual Heat Input	2017 SO <sub>2</sub> Emissions <sup>D</sup>	Fuel Heating Value (HHV)	Annual Fuel Usage	Controlled SO <sub>2</sub> Emissions	SO <sub>2</sub> Reduced	Fuel Cost Differential <sup>C</sup>		SO <sub>2</sub> Cost Effectiveness
	(%)	(Btu/gal)	(gal/yr)	(MMBtu/yr)	(tpy)	(Btu/gal)	(gal/yr)	(tpy)	(tpy)	(\$/Gal)	(\$/year)	(\$/ton)
K1	1.69%	151,009	2,075,864	313,473	293.1	137,169	2,285,312	63.64	229.46	0.71	\$1,622,571	7,071
K2	1.69%	151,009	1,793,982	270,907	253.3	137,169	1,974,990	54.99	198.31	0.71	\$1,402,243	7,071
K3	1.69%	151,009	6,363,573	960,954	898.5	137,169	7,005,638	195.07	703.43	0.71	\$4,974,003	7,071
K4	1.69%	151,009	5,494,558	829,725	775.8	137,169	6,048,942	168.43	607.37	0.71	\$4,294,749	7,071

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on 2017 average HHV and density and contract diesel sulfur limit (0.4%).

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 3-4. SO<sub>2</sub> Cost Effectiveness of Switching to a Residual Oil/ULSD Blended Fuel**

Unit	Current Residual Oil <sup>A</sup>					Residual Oil/ULSD Blend (1.0% maximum Sulfur) <sup>B</sup>						
	2017 Average Sulfur Content (%)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup> (\$/Gal) (\$/year)		SO <sub>2</sub> Cost Effectiveness (\$/ton)
K1	1.69%	151,009	2,075,864	313,473	293.1	144,471	2,169,799	166.92	126.18	0.38	\$824,524	6,535
K2	1.69%	151,009	1,793,982	270,907	253.3	144,471	1,875,162	144.26	109.04	0.38	\$712,562	6,535
K3	1.69%	151,009	6,363,573	960,954	898.5	144,471	6,651,533	511.71	386.79	0.38	\$2,527,583	6,535
K4	1.69%	151,009	5,494,558	829,725	775.8	144,471	5,743,194	441.83	333.97	0.38	\$2,182,414	6,535

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> #NAME?

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

**Table 3-5. SO<sub>2</sub> Cost Effectiveness of Switching to ULSD**

Unit	Current Residual Oil					ULSD (0.0015% maximum Sulfur)						
	2017 Average Sulfur Content (%)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	2017 Annual Heat Input (MMBtu/yr)	2017 SO <sub>2</sub> Emissions <sup>D</sup> (tpy)	Fuel Heating Value (HHV) (Btu/gal)	Annual Fuel Usage (gal/yr)	Controlled SO <sub>2</sub> Emissions (tpy)	SO <sub>2</sub> Reduced (tpy)	Fuel Cost Differential <sup>C</sup> (\$/Gal) (\$/year)		SO <sub>2</sub> Cost Effectiveness (\$/ton)
K1	1.69%	151,009	2,075,864	313,473	293.1	137,934	2,272,639	0.24	292.86	0.75	\$1,704,479	5,820
K2	1.69%	151,009	1,793,982	270,907	253.3	137,934	1,964,037	0.20	253.10	0.75	\$1,473,028	5,820
K3	1.69%	151,009	6,363,573	960,954	898.5	137,934	6,966,789	0.72	897.78	0.75	\$5,225,092	5,820
K4	1.69%	151,009	5,494,558	829,725	775.8	137,934	6,015,398	0.62	775.18	0.75	\$4,511,548	5,820

<sup>A</sup> Based on 2017 average fuel properties and fuel usage.

<sup>B</sup> Based on 2017 average HHV and density and contract fuel sulfur limit.

<sup>C</sup> See Appendix D for fuel cost.

<sup>D</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

Original Submitted Spreadsheet

**Table 4-2. NO<sub>x</sub> Reduction from Fuel Switching**

Fuel Scenario	AP-42 NO <sub>x</sub> Emission Factors <sup>A</sup>		Percent NO <sub>x</sub> Reduction from Fuel Switching <sup>B</sup>		
	< 100 MMBtu/hr Boilers	> 100 MMBtu/hr Boilers	K1 & K2	K3 & K4	
	(lb/MMBtu)	(lb/MMBtu)			
Residual Oil	0.367	0.313	--	--	
Distillate (ULSD)	0.143	0.171		61%	45%
50/50 Blend	--	--		31%	23%

<sup>A</sup> The listed emission factors are from AP-42, Table 1.3-1, dated May 2010.

<sup>B</sup> The percent reduction is based on the ratio of AP-42 emissions factors for residual fuel oil and No. 2 fuel oil.

**Table 4-3. Control Effectiveness of Technically Feasible NO<sub>x</sub> Control Technologies**

Control Technology	Estimated Controlled Level
	(lb/MMBtu)
SCR+Combustion Controls	0.05
SCR	0.05 - 0.10
LNB & OFA	0.25 - 0.30
FGR	0.25 - 0.30
LNB	0.25 - 0.35
SNCR+Combustion Controls	0.20 - 0.40
SNCR	0.30 - 0.40
OFA	0.30 - 0.45
Fuel Switching	0.16 - 0.29

Original Submitted Spreadsheet

**Table 4-4. NO<sub>x</sub> Cost Effectiveness Summary**

Unit	Control Option	2017 NO <sub>x</sub> Emissions <sup>A</sup> (tpy)	Controlled Emission Level <sup>B,C</sup> (lb/MMBtu)	2017 Annual Heat Input (MMBtu/yr)	Controlled NO <sub>x</sub> Emissions (tpy)	NO <sub>x</sub> Reduced (ton/yr)	Total Annual Cost <sup>D,E</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	Residual Oil/ULSD Blend <sup>D</sup>	65.8	0.29	313,473	45.4	20.4	\$824,524	\$40,422
	ULSD <sup>D</sup>	65.8	0.16	313,473	25.7	40.1	\$1,704,479	\$42,465
	Combustion Controls	65.8	0.30	313,473	47.0	18.8	\$79,284	\$4,222
	SNCR	65.8	0.30	313,473	47.0	18.8	\$167,771	\$8,934
	SNCR+Combustion Controls	65.8	0.20	313,473	31.3	34.5	\$247,055	\$7,171
	SCR	65.8	0.10	313,473	15.7	50.1	\$457,919	\$9,135
	SCR+Combustion Controls	65.8	0.05	313,473	7.8	58.0	\$537,203	\$9,268
K2	Residual Oil/ULSD Blend <sup>D</sup>	62.3	0.32	270,907	43.0	19.3	\$712,562	\$36,895
	ULSD <sup>D</sup>	62.3	0.18	270,907	24.3	38.0	\$1,473,028	\$38,761
	Combustion Controls	62.3	0.30	270,907	40.6	21.7	\$79,639	\$3,676
	SNCR	62.3	0.30	270,907	40.6	21.7	\$170,231	\$7,858
	SNCR+Combustion Controls	62.3	0.20	270,907	27.1	35.2	\$249,870	\$7,097
	SCR	62.3	0.10	270,907	13.5	48.8	\$459,913	\$9,433
	SCR+Combustion Controls	62.3	0.05	270,907	6.8	55.5	\$539,553	\$9,717
K3	Residual Oil/ULSD Blend <sup>D</sup>	292.6	0.47	960,954	225.3	67.3	\$2,527,583	\$37,558
	ULSD <sup>D</sup>	292.6	0.33	960,954	160.9	131.7	\$5,225,092	\$39,683
	Combustion Controls	292.6	0.30	960,954	144.1	148.5	\$134,508	\$906
	SNCR	292.6	0.30	960,954	144.1	148.5	\$279,823	\$1,885
	SNCR+Combustion Controls	292.6	0.20	960,954	96.1	196.5	\$414,331	\$2,109
	SCR	292.6	0.10	960,954	48.0	244.6	\$805,801	\$3,295
	SCR+Combustion Controls	292.6	0.05	960,954	24.0	268.6	\$940,308	\$3,501
K4	Residual Oil/ULSD Blend <sup>D</sup>	182.7	0.34	829,725	140.7	42.0	\$2,182,414	\$51,936
	ULSD <sup>D</sup>	182.7	0.24	829,725	100.5	82.2	\$4,511,548	\$54,875
	Combustion Controls	182.7	0.30	829,725	124.5	58.2	\$134,941	\$2,317
	SNCR	182.7	0.30	829,725	124.5	58.2	\$247,250	\$4,245
	SNCR+Combustion Controls	182.7	0.20	829,725	83.0	99.7	\$382,191	\$3,832
	SCR	182.7	0.10	829,725	41.5	141.2	\$790,239	\$5,596
	SCR+Combustion Controls	182.7	0.05	829,725	20.7	162.0	\$925,180	\$5,713

Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

The controlled emission level for ULSD is based on the No. 2 fuel oil emission factor from AP-42, Table 1.3-1, dated May 2010. The controlled emission level for the 50/50 residual oil/ULSD blend is based on the average of the AP-42 emission factor for No. 2 fuel oil and the 2017 emission factor.

Controlled emission levels based on "Alternative Control Techniques (ACT) Document - NO<sub>x</sub> Emissions from Utility Boiler" EPA, 1994.

Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars. The control options of switching to a residual oil/ULSD blend or ULSD are listed since it's a more cost-effective SO<sub>2</sub> solution than switching to a residual oil/0.4% maximum sulfur diesel blend or 0.4% maximum sulfur diesel.

See Appendix A for total annual cost calculations.

**Table 4-4. NO<sub>x</sub> Cost Effectiveness Summary**

Unit	Control Option	2017	Controlled	2017	Controlled	NO <sub>x</sub>	Total	Cost
		NO <sub>x</sub> Emissions <sup>A</sup> (tpy)	Emission Level <sup>B,C</sup> (lb/MMBtu)	Annual Heat Input (MMBtu/yr)	NO <sub>x</sub> Emissions (tpy)	Reduced (ton/yr)	Annual Cost <sup>D,E</sup> (\$/yr)	Effectiveness (\$/ton)
K1	Residual Oil/ULSD Blend <sup>D</sup>	65.8	0.29	313,473	45.4	20.4	\$824,524	\$40,422
	ULSD <sup>D</sup>	65.8	0.16	313,473	25.7	40.1	\$1,704,479	\$42,465
	Combustion Controls	65.8	0.30	313,473	47.0	18.8	\$69,914	\$3,723
	SNCR	65.8	0.30	313,473	47.0	18.8	\$119,417	\$6,359
	SNCR+Combustion Controls	65.8	0.20	313,473	31.3	34.5	\$189,331	\$5,495
	SCR	65.8	0.10	313,473	15.7	50.1	\$186,428	\$3,719
	SCR+Combustion Controls	65.8	0.05	313,473	7.8	58.0	\$256,342	\$4,422
K2	Residual Oil/ULSD Blend <sup>D</sup>	62.3	0.32	270,907	43.0	19.3	\$712,562	\$36,895
	ULSD <sup>D</sup>	62.3	0.18	270,907	24.3	38.0	\$1,473,028	\$38,761
	Combustion Controls	62.3	0.30	270,907	40.6	21.7	\$70,168	\$3,239
	SNCR	62.3	0.30	270,907	40.6	21.7	\$133,830	\$6,178
	SNCR+Combustion Controls	62.3	0.20	270,907	27.1	35.2	\$203,998	\$5,794
	SCR	62.3	0.10	270,907	13.5	48.8	\$185,001	\$3,795
	SCR+Combustion Controls	62.3	0.05	270,907	6.8	55.5	\$255,169	\$4,595
K3	Residual Oil/ULSD Blend <sup>D</sup>	292.6	0.47	960,954	225.3	67.3	\$2,527,583	\$37,558
	ULSD <sup>D</sup>	292.6	0.33	960,954	160.9	131.7	\$5,225,092	\$39,683
	Combustion Controls	292.6	0.30	960,954	144.1	148.5	\$119,191	\$803
	SNCR	292.6	0.30	960,954	144.1	148.5	\$229,971	\$1,549
	SNCR+Combustion Controls	292.6	0.20	960,954	96.1	196.5	\$349,162	\$1,777
	SCR	292.6	0.10	960,954	48.0	244.6	\$356,020	\$1,456
	SCR+Combustion Controls	292.6	0.05	960,954	24.0	268.6	\$475,211	\$1,769
K4	Residual Oil/ULSD Blend <sup>D</sup>	182.7	0.34	829,725	140.7	42.0	\$2,182,414	\$51,936
	ULSD <sup>D</sup>	182.7	0.24	829,725	100.5	82.2	\$4,511,548	\$54,875
	Combustion Controls	182.7	0.30	829,725	124.5	58.2	\$119,394	\$2,050
	SNCR	182.7	0.30	829,725	124.5	58.2	\$199,211	\$3,420
	SNCR+Combustion Controls	182.7	0.20	829,725	83.0	99.7	\$318,605	\$3,195
	SCR	182.7	0.10	829,725	41.5	141.2	\$336,163	\$2,381
	SCR+Combustion Controls	182.7	0.05	829,725	20.7	162.0	\$455,557	\$2,813

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> The controlled emission level for ULSD is based on the No. 2 fuel oil emission factor from AP-42, Table 1.3-1, dated May 2010. The controlled emission level for the 50/50 residual oil/ULSD blend is based on the average of the AP-42 emission factor for No. 2 fuel oil and the 2017 emission factor.

<sup>C</sup> Controlled emission levels based on "Alternative Control Techniques (ACT) Document - NO<sub>x</sub> Emissions from Utility Boiler" EPA, 1994.

<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars. The control options of switching to a residual oil/ULSD blend or ULSD are listed since it's a more cost-effective SO<sub>2</sub> solution than switching to a residual oil/0.4% maximum sulfur diesel blend or 0.4% maximum sulfur diesel.

<sup>E</sup> See Appendix A for total annual cost calculations.



**Table 5-2. PM<sub>10</sub> Reduction from Fuel Switching**

Fuel Scenario	AP-42 PM <sub>10</sub>	Percent PM <sub>10</sub> Reduction from Fuel Switching <sup>B</sup>
	Emission Factors <sup>A</sup> (lb/MMBtu)	
Residual Oil	0.1540	--
Distillate (No. 2 Fuel Oil)	0.0236	85%
50/50 Blend	--	43%

<sup>A</sup> The listed emission factors are from AP-42, Tables 1.3-1 and 1.3-2, dated May 2010.

<sup>B</sup> The percent reduction is based on the ratio of AP-42 emissions factors for residual fuel oil and No. 2 fuel oil.

**Table 5-3. PM<sub>10</sub> Cost Effectiveness Summary**

Unit	Control Option	2017	Level of Control <sup>B</sup>	Controlled	PM <sub>10</sub> Reduced	Total	Cost Effectiveness
		PM <sub>10</sub> Emissions <sup>A</sup>		PM <sub>10</sub> Emissions		Annual Cost <sup>C,D</sup>	
		(tpy)	(%)	(tpy)	(ton/yr)	(\$/yr)	(\$/ton)
K1	Wet Scrubber	14.6	50	7.3	7.3	\$126,365	\$17,310
	Residual Oil/ULSD Blend <sup>D</sup>	14.6	43	8.3	6.3	\$824,524	\$131,335
	ULSD <sup>D</sup>	14.6	85	2.2	12.4	\$1,704,479	\$137,347
	Wet ESP	14.6	90	1.5	13.1	\$736,769	\$56,071
K2	Wet Scrubber	10.5	50	5.3	5.3	\$127,172	\$24,223
	Residual Oil/ULSD Blend <sup>D</sup>	10.5	43	6.0	4.5	\$712,562	\$157,821
	ULSD <sup>D</sup>	10.5	85	1.6	8.9	\$1,473,028	\$165,045
	Wet ESP	10.5	90	1.1	9.5	\$730,620	\$77,314
K3	Wet Scrubber	38.4	50	19.2	19.2	\$136,147	\$7,091
	Residual Oil/ULSD Blend <sup>D</sup>	38.4	43	21.9	16.5	\$2,527,583	\$153,075
	ULSD <sup>D</sup>	38.4	85	5.8	32.6	\$5,225,092	\$160,082
	Wet ESP	38.4	90	3.8	34.6	\$1,232,570	\$35,665
K4	Wet Scrubber	20.7	50	10.4	10.4	\$141,244	\$13,647
	Residual Oil/ULSD Blend <sup>D</sup>	20.7	43	11.8	8.9	\$2,182,414	\$245,187
	ULSD <sup>D</sup>	20.7	85	3.1	17.6	\$4,511,548	\$256,411
	Wet ESP	20.7	90	2.1	18.6	\$1,615,374	\$86,708

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> Wet scrubber and wet ESP controlled emission levels based on AP-42, Fifth Edition, Volume I, Chapter 1, Section 1.3.4.1. The controlled emissions level for switching to a distillate fuel is based on the ratio of PM<sub>10</sub> emissions from distillate combustion from AP-42, Tables 1.3-2 and 1.3-6 and the baseline emission factor.

<sup>C</sup> See Appendix A for total annual cost calculations for wet scrubber and wet ESP.

<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars. The control options of switching to a residual oil/ULSD blend or ULSD are listed since it's a more cost-effective SO<sub>2</sub> solution than switching to a residual oil/0.4% maximum sulfur diesel blend or 0.4% maximum sulfur diesel.

**Table 5-2. PM<sub>10</sub> Reduction from Fuel Switching**

Fuel Scenario	AP-42 PM <sub>10</sub>	
	Emission Factors <sup>A</sup> (lb/MMBtu)	Percent PM <sub>10</sub> Reduction from Fuel Switching <sup>B</sup>
Residual Oil	0.1540	--
Distillate (No. 2 Fuel Oil)	0.0236	85%
50/50 Blend	--	43%

<sup>A</sup> The listed emission factors are from AP-42, Tables 1.3-1 and 1.3-2, dated May 2010.

<sup>B</sup> The percent reduction is based on the ratio of AP-42 emissions factors for residual fuel oil and No. 2 fuel oil.

**Table 5-3. PM<sub>10</sub> Cost Effectiveness Summary (20 Yrs Life)**

Unit	Control Option	2017 PM <sub>10</sub> Emissions <sup>A</sup> (tpy)	Level of Control <sup>B</sup> (%)	Controlled PM <sub>10</sub> Emissions (tpy)	PM <sub>10</sub> Reduced (ton/yr)	Total Annual Cost <sup>C,D</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	Wet Scrubber	14.6	50	7.3	7.3	\$123,843	\$16,965
	Residual Oil/ULSD Blend <sup>D</sup>	14.6	43	8.3	6.3	\$824,524	\$131,335
	ULSD <sup>D</sup>	14.6	85	2.2	12.4	\$1,704,479	\$137,347
	Wet ESP	14.6	90	1.5	13.1	\$670,534	\$51,030
K2	Wet Scrubber	10.5	50	5.3	5.3	\$124,571	\$23,728
	Residual Oil/ULSD Blend <sup>D</sup>	10.5	43	6.0	4.5	\$712,562	\$157,821
	ULSD <sup>D</sup>	10.5	85	1.6	8.9	\$1,473,028	\$165,045
	Wet ESP	10.5	90	1.1	9.5	\$664,986	\$70,369
K3	Wet Scrubber	38.4	50	19.2	19.2	\$132,667	\$6,910
	Residual Oil/ULSD Blend <sup>D</sup>	38.4	43	21.9	16.5	\$2,527,583	\$153,075
	ULSD <sup>D</sup>	38.4	85	5.8	32.6	\$5,225,092	\$160,082
	Wet ESP	38.4	90	3.8	34.6	\$1,117,787	\$32,343
K4	Wet Scrubber	20.7	50	10.4	10.4	\$137,265	\$13,262
	Residual Oil/ULSD Blend <sup>D</sup>	20.7	43	11.8	8.9	\$2,182,414	\$245,187
	ULSD <sup>D</sup>	20.7	85	3.1	17.6	\$4,511,548	\$256,411
	Wet ESP	20.7	90	2.1	18.6	\$1,463,108	\$78,535

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> Wet scrubber and wet ESP controlled emission levels based on AP-42, Fifth Edition, Volume 1, Chapter 1, Section 1.3.4.1. The controlled emissions level for switching to a distillate fuel is based on the ratio of PM<sub>10</sub> emissions from distillate combustion from AP-42, Tables 1.3-2 and 1.3-6 and the baseline emission factor.

<sup>C</sup> See Appendix A for total annual cost calculations for wet scrubber and wet ESP.

<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars. The control options of switching to a residual oil/ULSD blend or ULSD are listed since it's a more cost-effective SO<sub>2</sub> solution than switching to a residual oil/0.4% maximum sulfur diesel blend or 0.4% maximum sulfur diesel.

DOH Changed Spreadsheet (20 Yrs Life)

**Table 5-2. PM<sub>10</sub> Reduction from Fuel Switching**

Fuel Scenario	AP-42 PM <sub>10</sub>	
	Emission Factors <sup>A</sup> (lb/MMBtu)	Percent PM <sub>10</sub> Reduction from Fuel Switching <sup>B</sup>
Residual Oil	0.1540	--
Distillate (No. 2 Fuel Oil)	0.0236	85%
50/50 Blend	--	43%

<sup>A</sup> The listed emission factors are from AP-42, Tables 1.3-1 and 1.3-2, dated May 2010.

<sup>B</sup> The percent reduction is based on the ratio of AP-42 emissions factors for residual fuel oil and No. 2 fuel oil.

**Table 5-3. PM<sub>10</sub> Cost Effectiveness Summary (30 Yr Life)**

Unit	Control Option	2017 PM <sub>10</sub> Emissions <sup>A</sup> (tpy)	Level of Control <sup>B</sup> (%)	Controlled PM <sub>10</sub> Emissions (tpy)	PM <sub>10</sub> Reduced (ton/yr)	Total Annual Cost <sup>C,D</sup> (\$/yr)	Cost Effectiveness (\$/ton)
K1	Wet Scrubber	14.6	50	7.3	7.3	\$120,405	\$16,494
	Residual Oil/ULSD Blend <sup>D</sup>	14.6	43	8.3	6.3	\$824,524	\$131,335
	ULSD <sup>D</sup>	14.6	85	2.2	12.4	\$1,704,479	\$137,347
	Wet ESP	14.6	90	1.5	13.1	\$670,534	\$51,030
K2	Wet Scrubber	10.5	50	5.3	5.3	\$121,025	\$23,052
	Residual Oil/ULSD Blend <sup>D</sup>	10.5	43	6.0	4.5	\$712,562	\$157,821
	ULSD <sup>D</sup>	10.5	85	1.6	8.9	\$1,473,028	\$165,045
	Wet ESP	10.5	90	1.1	9.5	\$664,986	\$70,369
K3	Wet Scrubber	38.4	50	19.2	19.2	\$127,923	\$6,663
	Residual Oil/ULSD Blend <sup>D</sup>	38.4	43	21.9	16.5	\$2,527,583	\$153,075
	ULSD <sup>D</sup>	38.4	85	5.8	32.6	\$5,225,092	\$160,082
	Wet ESP	38.4	90	3.8	34.6	\$1,117,787	\$32,343
K4	Wet Scrubber	20.7	50	10.4	10.4	\$131,841	\$12,738
	Residual Oil/ULSD Blend <sup>D</sup>	20.7	43	11.8	8.9	\$2,182,414	\$245,187
	ULSD <sup>D</sup>	20.7	85	3.1	17.6	\$4,511,548	\$256,411
	Wet ESP	20.7	90	2.1	18.6	\$1,463,108	\$78,535

<sup>A</sup> Calendar year 2017 actual emissions from the 2018 Criteria Pollutant Annual Fee Summary for Covered Sources (Form F-1CP).

<sup>B</sup> Wet scrubber and wet ESP controlled emission levels based on AP-42, Fifth Edition, Volume I, Chapter 1, Section 1.3.4.1. The controlled emissions level for switching to a distillate fuel is based on the ratio of PM<sub>10</sub> emissions from distillate combustion from AP-42, Tables 1.3-2 and 1.3-6 and the baseline emission factor.

<sup>C</sup> See Appendix A for total annual cost calculations for wet scrubber and wet ESP.

<sup>D</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars. The control options of switching to a residual oil/ULSD blend or ULSD are listed since it's a more cost-effective SO<sub>2</sub> solution than switching to a residual oil/0.4% maximum sulfur diesel blend or 0.4% maximum sulfur diesel.

**Table 6.1. Total Cost Effectiveness of Fuel Switching**

Unit	Control Option	SO <sub>2</sub>	NO <sub>x</sub>	PM <sub>10</sub>	Total SO <sub>2</sub> , NO <sub>x</sub> ,	Total	Cost
		Reduced <sup>A</sup>	Reduced <sup>A</sup>	Reduced <sup>A</sup>	and PM <sub>10</sub>	Annual	Effectiveness
		(ton/yr)	(ton/yr)	(ton/yr)	Reduced	Cost <sup>B</sup>	(\$/ton)
					(ton/yr)	(\$/yr)	
K1	Residual Oil/ULSD Blend	126.2	20.4	6.3	152.9	\$824,524	\$5,394
	ULSD	292.9	40.1	12.4	345.4	\$1,704,479	\$4,935
K2	Residual Oil/ULSD Blend	109.0	19.3	4.5	132.9	\$712,562	\$5,363
	ULSD	253.1	38.0	8.9	300.0	\$1,473,028	\$4,910
K3	Residual Oil/ULSD Blend	386.8	67.3	16.5	470.6	\$2,527,583	\$5,371
	ULSD	897.8	131.7	32.6	1,062.1	\$5,225,092	\$4,920
K4	Residual Oil/ULSD Blend	334.0	42.0	8.9	384.9	\$2,182,414	\$5,670
	ULSD	775.2	82.2	17.6	875.0	\$4,511,548	\$5,156

<sup>A</sup> The SO<sub>2</sub>, NO<sub>x</sub>, and PM<sub>10</sub> reduced are from Tables 3-4 and 3-5, Table 4-4, and Table 5-3, respectively.

<sup>B</sup> Annual costs for switching to a residual oil/ULSD blend or ULSD are from Tables 3-4 and 3-5. The annual costs of fuel switching are based on 2019 dollars.

**Appendix Table A-1. Combustion Controls Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4
172 Boiler design capacity, mmBtu/hr (C)					
2017 Annual Heat Input, MMBtu/yr (H)		313,473	270,907	960,954	829,725
Unit Size, kW (kW)	5,900      6,000	12,700	13,000		
13.0 Unit Size, MW (MW)					
Capital recovery factor					
a. Equipment CRF, 30-yr life, 7% interest	$= [ I \times (1+i)^a ] / [(1+i)^a - 1]$ , where I = interest rate, a = equipment life	0.08	0.08	0.08	0.08
Cost Index (CI) <sup>A</sup>					
a. 2019	607.5				
b. 2004	444.2				
Total Capital Investment <sup>BC</sup>					
TCI (\$)	$= \$24/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2019}/\text{CI}_{2004})$	\$793,563	\$802,159	\$1,297,190	\$1,316,750
Direct Annual Operating Costs \$/yr					
Variable O&M Costs <sup>D</sup>	$= (\$0.08 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times \text{H} \times 10^6 \text{ Btu}/\text{mmBtu} \times (\text{CI}_{2019}/\text{CI}_{2004})$	\$3,430	\$2,964	\$10,514	\$9,078
Indirect Annual Costs, \$/yr					
1. Fixed O&M Costs <sup>E</sup>	$= \$0.36/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times (300/\text{MW})^{0.359} \times (\text{CI}_{2019}/\text{CI}_{2004})$	\$11,903	\$12,032	\$19,458	\$19,751
2. Capital recovery	= Equipment CRF x TCI	\$63,950	\$64,643	\$104,536	\$106,112
<b>Total Annual Cost \$/yr</b>	= Direct Annual Costs + Indirect Annual Costs	<b>\$79,284</b>	<b>\$79,639</b>	<b>\$134,508</b>	<b>\$134,941</b>

**Source:** All costs were estimated using Section 4.3 and Appendix D of the WRAP guidance document, *Analysis of Combustion Controls for Reducing NOx Emissions from Coal-fired EGUs in the WRAP Region*, dated September 6, 2005. The cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). Chemical Engineering Journal.

<sup>B</sup> TCI for LNB and LNB w/over fire air for wall boilers ranges from \$6/kW to \$24/kW, the high end of the range was used due to Hawaii's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>C</sup> Scaling factor = (300/Nameplate capacity)<sup>0.359</sup>

<sup>D</sup> The variable O&M costs for LNB and LNB w/over fire air for wall boilers ranges from 0.05 mills/kW-hr to 0.08 mills/kW-hr, the high end of the range was used due to Hawaii's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>E</sup> The fixed O&M costs for LNB and LNB w/over fire air for wall boilers ranges from \$0.09/kW to \$0.36/kW, the high end of the range was used due to Hawaii's remote location.

**Appendix Table A-1. Combustion Controls Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4
Boiler design capacity, mmBtu/hr (C)		94	94	172	181
2017 Annual Heat Input, MMBtu/yr (H)		313,473	270,907	960,954	829,725
Unit Size, kW (kW)		5,900	6,000	12,700	13,000
Unit Size, MW (MW)		5.9	6.0	12.7	13.0
Capital recovery factor #NAME?	= $[1 \times (1+i)^a] / [(1+i)^a - 1]$ , where i = interest rate, a = equipment life	0.07	0.07	0.07	0.07
Cost Index (CI) <sup>A</sup> a. 2019 b. 2004	607.5 444.2				
Total Capital Investment <sup>B,C</sup> TCI (\$)	= $\$24/\text{kW} \times \text{kW} \times (300/\text{MW})^{0.359} \times (\text{CI}_{2019}/\text{CI}_{2004})$	\$793,563	\$802,159	\$1,297,190	\$1,316,750
Direct Annual Operating Costs \$/yr Variable O&M Costs <sup>D</sup>	= $(\$0.08 \text{ mills}/\text{kW-hr}/1000) \times (1 \text{ kW-hr}/10,000 \text{ Btu}) \times \text{H} \times 10^6 \text{ Btu}/\text{mmBtu} \times (\text{CI}_{2019}/\text{CI}_{2004})$	\$3,430	\$2,964	\$10,514	\$9,078
Indirect Annual Costs, \$/yr 1. Fixed O&M Costs <sup>E</sup>	= $\$0.36/\text{kW} \times \text{Nameplate capacity (MW)} \times (1000 \text{ kW}/\text{MW}) \times (300/\text{MW})^{0.359} \times (\text{CI}_{2019}/\text{CI}_{2004})$	\$11,903	\$12,032	\$19,458	\$19,751
2. Capital recovery	= Equipment CRF x TCI	\$54,580	\$55,172	\$89,219	\$90,565
<b>Total Annual Cost \$/yr</b>	= Direct Annual Costs + Indirect Annual Costs	<b>\$69,914</b>	<b>\$70,168</b>	<b>\$119,191</b>	<b>\$119,394</b>

**Source:** All costs were estimated using Section 4.3 and Appendix D of the WRAP guidance document, *Analysis of Combustion Controls for Reducing NOx Emissions from Coal-fired EGUs in the WRAP Region*, dated September 6, 2005. The cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). Chemical Engineering Journal.

<sup>B</sup> TCI for LNB and LNB w/over fire air for wall boilers ranges from \$6/kW to \$24/kW, the high end of the range was used due to Hawaii's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>C</sup> Scaling factor =  $(300/\text{Nameplate capacity})^{0.359}$

<sup>D</sup> The variable O&M costs for LNB and LNB w/over fire air for wall boilers ranges from 0.05 mills/kW-hr to 0.08 mills/kW-hr, the high end of the range was used due to Hawaii's remote location. The cost of FGR and OFA are expected to be covered by this range and have an expected similar level of NO<sub>x</sub> control.

<sup>E</sup> The fixed O&M costs for LNB and LNB w/over fire air for wall boilers ranges from \$0.09/kW to \$0.36/kW, the high end of the range was used due to Hawaii's remote location.

**Appendix Table A-2. SCR Capital and O&M Cost Estimate**

	K1	K2	K3	K4
MW	5.9	6.0	12.7	13.0
Baseline NOx Emission Rate (lb/MMBtu)	0.42	0.46	0.61	0.44
2017 Annual Heat Input, MMBtu/yr	313,473	270,907	960,954	829,725
Max Heat Input (MMBtu/hr)	94	94	172	181
Capital Recovery Factor (CRF)	0.08	0.08	0.08	0.08
Cost Index <sup>A</sup>				
2019	607.5			
1999	390.6			
B = (lb/MMBtu)	0.42	0.46	0.61	0.44
C = (%)	90	90	90	90
A = (kW)	5,900	6,000	12,700	13,000
Z (Eq. 1) =	0.90	0.90	0.92	0.90
Capital Cost (Eq. 2) (\$/kW)	\$286	\$285	\$220	\$217
Capital Cost (2019) (\$)	\$2,623,236	\$2,656,291	\$4,345,933	\$4,387,432
Maui Construction Cost Multiplier <sup>B</sup>	1.938	1.938	1.938	1.938
Maui Capital Cost (2019)	\$5,083,832	\$5,147,892	\$8,422,419	\$8,502,843
Annualized Capital Cost (\$/yr)	\$409,688	\$414,850	\$678,732	\$685,214
G =	0.38	0.33	0.64	0.52
H = (MMBtu/hr)	94	94	172	181
D = (\$/kW)	\$445	\$443	\$342	\$337
Fixed O&M <sup>C</sup> (Eq. 3) (\$/yr)	\$17,313	\$17,532	\$28,683	\$28,957
Variable O&M Cost (Eq. 4) (\$/yr)	\$30,918	\$27,532	\$98,385	\$76,068
<b>Total Annual Cost (\$/yr)</b>	<b>\$457,919</b>	<b>\$459,913</b>	<b>\$805,801</b>	<b>\$790,239</b>

$$Z = \left[ \frac{B}{1.5} \right]^{0.05} \left[ \frac{C}{100} \right]^{0.4} \quad \text{Equation 1}$$

$$D = 75 \left\{ 300,000 \frac{Z}{A} \right\}^{0.35} \quad \text{Equation 2}$$

Where:

- D = Capital cost (\$/kW)
- B = NO<sub>x</sub> (lb/10<sup>6</sup> Btu) at the inlet of the SCR reactor
- C = NO<sub>x</sub> removal efficiency (%)
- A = Plant capacity (kW)

$$E = D \times A \times C \quad \text{Equation 3}$$

Where:

- E = Fixed O&M cost (\$/yr)
- D = Capital cost (\$/kW) from Equation 1
- A = Plant capacity (kW)
- C = A constant, 0.0066 yr<sup>-1</sup>

$$F = G \left\{ 225 \times \left[ 0.37 B \times H \times \left( \frac{C}{100} \right) \times \left( \frac{8760}{2000} \right) \right] \times 1.005 \times 1.05 + 0.025 \times D \times A \times Z + 1.45 \times A \right\} \quad \text{Equation 4}$$

Where:

- F = Variable O&M Cost (\$/yr)
- G = Annual capacity factor (expressed as a fraction)
- B = Inlet NO<sub>x</sub> (lb/MMBtu); range of 0.15 - 2.5 lb/MMBtu
- H = Heat input (MMBtu/hr)
- C = NO<sub>x</sub> removal efficiency; range of 80-95%
- D = Capital cost (\$/kW)
- A = Plant capacity (kW)

$$\text{Capital Recovery Factor (CRF)} = \left[ \frac{I \times (1+i)^a}{(1+i)^a - 1} \right] \quad \text{CRF} = 0.08$$

Where:

- I = Interest Rate (7% interest)
- a = Equipment life (30 yrs)

**Source:** *Cost of Selective Catalytic Reduction (SCR) Application for NOx Control on Coal-Fired Boilers*, EPA/600/R-01/087, October 2001. A cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). Chemical Engineering Journal.

<sup>B</sup> The Maui construction cost multiplier is based on cost of construction geographical multipliers from the *RMeans Mechanical Cost Data 2016* to account for factors unique to Maui's location plus an additional factor to account for additional Hawaiian Electric loadings and overhead.

<sup>C</sup> Fixed Costs include elements such as labor, station power, capital additions/improvements

**Appendix Table A-2. SCR Capital and O&M Cost Estimate**

	K1	K2	K3	K4
MW	5.9	6.0	12.7	13.0
Baseline NOx Emission Rate (lb/MMBtu)	0.42	0.46	0.61	0.44
2017 Annual Heat Input, MMBtu/yr	313,473	270,907	960,954	829,725
Max Heat Input (MMBtu/hr)	94	94	172	181
Capital Recovery Factor (CRF)	0.05	0.05	0.05	0.05
Cost Index <sup>A</sup>				
2019	607.5			
1999	390.6			
B = (lb/MMBtu)	0.42	0.46	0.61	0.44
C = (%)	90	90	90	90
A = (kW)	5,900	6,000	12,700	13,000
Z (Eq. 1) =	0.90	0.90	0.92	0.90
Capital Cost (Eq. 2) (\$/kW)	\$286	\$285	\$220	\$217
Capital Cost (2019) (\$)	\$2,623,236	\$2,656,291	\$4,345,933	\$4,387,432
Maui Construction Cost Multiplier <sup>B</sup>	1.000	1.000	1.000	1.000
Maui Capital Cost (2019)	\$2,623,236	\$2,656,291	\$4,345,933	\$4,387,432
Annualized Capital Cost (\$/yr)	\$138,197	\$139,938	\$228,951	\$231,137
G =	0.38	0.33	0.64	0.52
H = (MMBtu/hr)	94	94	172	181
D = (\$/kW)	\$445	\$443	\$342	\$337
Fixed O&M <sup>C</sup> (Eq. 3) (\$/yr)	\$17,313	\$17,532	\$28,683	\$28,957
Variable O&M Cost (Eq. 4) (\$/yr)	\$30,918	\$27,532	\$98,385	\$76,068
Total Annual Cost (\$/yr)	\$186,428	\$185,001	\$356,020	\$336,163

$$Z = \left[ \frac{B}{1.5} \right]^{0.05} \left[ \frac{C}{100} \right]^{0.4} \quad \text{Equation 1}$$

$$D = 75 \left\{ 300,000 \frac{Z}{A} \right\}^{0.35} \quad \text{Equation 2}$$

Where:

- D = Capital cost (\$/kW)
- B = NO<sub>x</sub> (lb/10<sup>6</sup> Btu) at the inlet of the SCR reactor
- C = NO<sub>x</sub> removal efficiency (%)
- A = Plant capacity (kW)

$$E = D \times A \times C \quad \text{Equation 3}$$

Where:

- E = Fixed O&M cost (\$/yr)
- D = Capital cost (\$/kW) from Equation 1
- A = Plant capacity (kW)
- C = A constant, 0.0066 yr<sup>-1</sup>

$$F = G \left\{ 225 \times \left[ 0.37 B \times H \times \left( \frac{C}{100} \right) \times \left( \frac{8760}{2000} \right) \right] \times 1.005 \times 1.05 + 0.025 \times D \times A \times Z + 1.45 \times A \right\}^{1/4}$$

Where:

- F = Variable O&M Cost (\$/yr)
- G = Annual capacity factor (expressed as a fraction)
- B = Inlet NO<sub>x</sub> (lb/MMBtu); range of 0.15 - 2.5 lb/MMBtu
- H = Heat input (MMBtu/hr)
- C = NO<sub>x</sub> removal efficiency; range of 80-95%
- D = Capital cost (\$/kW)
- A = Plant capacity (kW)

$$\text{Capital Recovery Factor (CRF)} = \left[ \frac{1 \times (1+i)^a}{(1+i)^a - 1} \right]$$

CRF = 0.05

Where:

- i = 3.5%
- a = 30 yrs

**Source:** *Cost of Selective Catalytic Reduction (SCR) Application for NOx Control on Coal-Fired Boilers*, EPA/600/R-01/087, October 2001. A cost method developed for coal-fired EGUs was utilized for the residual oil-fired boilers being addressed by this report, since the number of EGUs of similar size and fuel type to the boilers being addressed by this report is small and cost estimates are not as established. Further, pulverized coal can burn similar to oil, and thus combustion control system options for both fuel types are similar.

<sup>A</sup> Cost Index: Chemical Engineering Plant Cost Index (CEPCI). Chemical Engineering Journal.

<sup>B</sup> The Maui construction cost multiplier is based on cost of construction geographical multipliers from the *RSMMeans Mechanical Cost Data 2016* to account for factors unique to Maui's location plus an additional factor to account for additional Hawaiian Electric loadings and overhead.

<sup>C</sup> Fixed Costs include elements such as labor, station power, capital additions/improvements



**Appendix Table A-3. Scrubber Capital and O&M Cost Estimate**

Parameters/Costs	Equation/Reference	K1	K2	K3	K4
Exhaust Temperature (K)	$T_{stack}$	450.2	422.2	436.2	433.2
Exhaust Temperature (F)	Converted from degrees K	350.6	300.2	325.4	320.0
Exhaust Moisture Content (%)	MS - Typical Values	12.00%	12.00%	12.00%	12.00%
Exhaust Flow Rate (m <sup>3</sup> /s) <sup>1</sup>	CSP Application	12.9	12.7	22.1	27.9
Exhaust Flow Rate (ACFM) <sup>1</sup>	Converted from (m <sup>3</sup> /s)	27,246	26,999	46,908	59,181
Exhaust Flow Rate (SCFM)	ACFM*((68+460)/(Tstack+460))	17,747	18,752	31,535	40,061
m <sub>wv</sub> (lb/min)	SCFM * MC * 18/385	100	105	177	225
m <sub>a</sub> (lb/min)	SCFM * (1-MC) * 29/385	730	772	1,297	1,648
humidity ratio	m <sub>wv</sub> /m <sub>a</sub>	0.14	0.14	0.14	0.14
humid volume (ft <sup>3</sup> /min)	<i>h</i> (Estimated from psychrometric chart)	23.00	23.00	23.00	23.00
Q <sub>SAT</sub>	<i>h</i> * m <sub>a</sub>	16,794.16	17,744.79	29,840.67	37,909.40
Purchased Equipment Cost (Tables 2.5 and 2.6 for a Stainless Steel Low Energy scrubber, 2002 Dollars)	$1.15*(150*Q_{SAT}^{0.56})$	\$40,075	\$41,330	\$55,294	\$63,225
<b>Direct Costs - Table 2.8</b>					
<b>Purchased equipment costs</b>					
Packaged Unit (A1)	As estimated, AA	\$40,075	\$41,330	\$55,294	\$63,225
Auxiliary Costs (A2)	A2 = 0.1*A1	\$4,008	\$4,133	\$5,529	\$6,322
Equipment Costs (A)	A = A1 + A2	\$44,083	\$45,463	\$60,824	\$69,547
Instrumentation	0.10 A	\$4,408	\$4,546	\$6,082	\$6,955
Sales taxes	0.03 A	\$1,322	\$1,364	\$1,825	\$2,086
Freight	0.05 A	\$2,204	\$2,273	\$3,041	\$3,477
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$52,018</b>	<b>\$53,647</b>	<b>\$71,772</b>	<b>\$82,066</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.06 B	\$3,121	\$3,219	\$4,306	\$4,924
Handling & erection	0.40 B	\$20,807	\$21,459	\$28,709	\$32,826
Electrical	0.01 B	\$520	\$536	\$718	\$821
Piping	0.05 B	\$2,601	\$2,682	\$3,589	\$4,103
Insulation for ductwork	0.03 B	\$1,561	\$1,609	\$2,153	\$2,462
Painting	0.01 B	\$520	\$536	\$718	\$821
<b>Direct Installation Costs, DIC</b>	<b>0.56 B</b>	<b>\$29,130</b>	<b>\$30,042</b>	<b>\$40,192</b>	<b>\$45,957</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$81,148</b>	<b>\$83,689</b>	<b>\$111,965</b>	<b>\$128,023</b>
<b>Indirect Costs (installation) Table 2.8</b>					
Engineering	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Construction & field expenses	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Contractor fees	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Start-up	0.01 B	\$520	\$536	\$718	\$821
Performance test	0.01 B	\$520	\$536	\$718	\$821
Model study	--				
Contingencies	0.03B	\$1,561	\$1,609	\$2,153	\$2,462
<b>Total Indirect Costs, IC</b>	<b>0.35 B</b>	<b>\$18,206</b>	<b>\$18,776</b>	<b>\$25,120</b>	<b>\$28,723</b>
Cost Index <sup>2</sup>					
a. 2019	607.5				
b. 2002	395.6				
Capital recovery factor (CRF)	$CRF = [i \times (1+i)^n] / [(1+i)^n - 1]$ , where <i>i</i> = interest rate, <i>n</i> = equipment life a. Equipment CRF, 30-yr life, 7% interest	0.08	0.08	0.08	0.08
<b>Total Capital Investment (2019 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (CI<sub>2019</sub>/CI<sub>1999</sub>) (Retrofit factor based on average provided for ESP on Page 3-41). No specific factor provided for scrubber, so factor for ESP was relied on.</b>	<b>\$213,601</b>	<b>\$220,290</b>	<b>\$294,719</b>	<b>\$336,987</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	3hr/shift*2shifts/day*360 days/yr * \$20/hr	\$43,200	\$43,200	\$43,200	\$43,200
Supervisor	15% of operator	\$6,480	\$6,480	\$6,480	\$6,480
<b>Maintenance</b>					
Labor	Assumed similar labor requirements as to that required for ESP per Section 6, Page 3-47 of OAQPS Cost manual (\$20.00/hr, 7.5 h/wk, 44 wk/yr.)	\$6,600	\$6,600	\$6,600	\$6,600
Material	100% of maintenance labor	\$6,600	\$6,600	\$6,600	\$6,600
<b>Utilities</b>					
Utilities	Utilities currently not estimated due to variability				
<b>Total Direct Annual Cost</b>		<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$4,272	\$4,406	\$5,894	\$6,740
Property tax	1% of Total Capital Investment	\$2,136	\$2,203	\$2,947	\$3,370
Insurance	1% of Total Capital Investment	\$2,136	\$2,203	\$2,947	\$3,370
Overhead	60% of total labor and material costs	\$37,728	\$37,728	\$37,728	\$37,728
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$17,213	\$17,752	\$23,750	\$27,157
<b>Total Indirect Annual Costs</b>		<b>\$63,485</b>	<b>\$64,292</b>	<b>\$73,267</b>	<b>\$78,364</b>
<b>Total Annual Cost</b>		<b>\$126,365</b>	<b>\$127,172</b>	<b>\$136,147</b>	<b>\$141,244</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 2 - Wet Scrubbers for Particulate Matter, dated July 2002 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> From Chemical Engineering Plant Cost Index (CEPCI)

**Appendix Table A-3. Scrubber Capital and O&M Cost Estimate (20 Yrs Life)**

Parameters/Costs	Equation/Reference	K1	K2	K3	K4
Exhaust Temperature (K)	$T_{stack}$	450.2	422.2	436.2	433.2
Exhaust Temperature (F)	Converted from degrees K	350.6	300.2	325.4	320.0
Exhaust Moisture Content (%)	MS - Typical Values	12.00%	12.00%	12.00%	12.00%
Exhaust Flow Rate (m <sup>3</sup> /s) <sup>1</sup>	CSP Application	12.9	12.7	22.1	27.9
Exhaust Flow Rate (ACFM) <sup>1</sup>	Converted from (m <sup>3</sup> /s)	27,246	26,999	46,908	59,181
Exhaust Flow Rate (SCFM)	$ACFM * ((68+460)/(T_{stack}+460))$	17,747	18,752	31,535	40,061
m <sub>wv</sub> (lb/min)	$SCFM * MC * 18/385$	100	105	177	225
m <sub>a</sub> (lb/min)	$SCFM * (1-MC) * 29/385$	730	772	1,297	1,648
humidity ratio	$m_{wv}/m_a$	0.14	0.14	0.14	0.14
humid volume (ft <sup>3</sup> /min)	<i>h (Estimated from psychrometric chart)</i>	23.00	23.00	23.00	23.00
Q <sub>SAT</sub>	$h * m_a$	16,794.16	17,744.79	29,840.67	37,909.40
Purchased Equipment Cost (Tables 2.5 and 2.6 for a Stainless Steel Low Energy scrubber, 2002 Dollars)	$1.15 * (150 * Q_{SAT}^{0.56})$	\$40,075	\$41,330	\$55,294	\$63,225
<b>Direct Costs - Table 2.8</b>					
<b>Purchased equipment costs</b>					
Packaged Unit (A1)	As estimated, AA	\$40,075	\$41,330	\$55,294	\$63,225
Auxiliary Costs (A2)	$A2 = 0.1 * A1$	\$4,008	\$4,133	\$5,529	\$6,322
Equipment Costs (A)	$A = A1 + A2$	\$44,083	\$45,463	\$60,824	\$69,547
Instrumentation	0.10 A	\$4,408	\$4,546	\$6,082	\$6,955
Sales taxes	0.03 A	\$1,322	\$1,364	\$1,825	\$2,086
Freight	0.05 A	\$2,204	\$2,273	\$3,041	\$3,477
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$52,018</b>	<b>\$53,647</b>	<b>\$71,772</b>	<b>\$82,066</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.06 B	\$3,121	\$3,219	\$4,306	\$4,924
Handling & erection	0.40 B	\$20,807	\$21,459	\$28,709	\$32,826
Electrical	0.01 B	\$520	\$536	\$718	\$821
Piping	0.05 B	\$2,601	\$2,682	\$3,589	\$4,103
Insulation for ductwork	0.03 B	\$1,561	\$1,609	\$2,153	\$2,462
Painting	0.01 B	\$520	\$536	\$718	\$821
<b>Direct Installation Costs, DIC</b>	<b>0.56 B</b>	<b>\$29,130</b>	<b>\$30,042</b>	<b>\$40,192</b>	<b>\$45,957</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$81,148</b>	<b>\$83,689</b>	<b>\$111,965</b>	<b>\$128,023</b>
<b>Indirect Costs (installation) Table 2.8</b>					
Engineering	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Construction & field expenses	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Contractor fees	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Start-up	0.01 B	\$520	\$536	\$718	\$821
Performance test	0.01 B	\$520	\$536	\$718	\$821
Model study	--				
Contingencies	0.03B	\$1,561	\$1,609	\$2,153	\$2,462
<b>Total Indirect Costs, IC</b>	<b>0.35 B</b>	<b>\$18,206</b>	<b>\$18,776</b>	<b>\$25,120</b>	<b>\$28,723</b>
Cost Index <sup>2</sup>					
a. 2019	607.5				
b. 2002	395.6				
Capital recovery factor (CRF)	$CRF = [I * (1+i)^a] / [(1+i)^a - 1]$ , where I = interest rate, a = equipment life a. Equipment CRF, 20-yr life, 3.25% interest	0.07	0.07	0.07	0.07
<b>Total Capital Investment (2019 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (CI<sub>2019</sub>/CI<sub>1999</sub>) (Retrofit factor based on average provided for ESP on Page 3-41). No specific factor provided for scrubber, so factor for ESP was relied on.</b>	<b>\$213,601</b>	<b>\$220,290</b>	<b>\$294,719</b>	<b>\$336,987</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	3hr/shift*2shifts/day*360 days/yr * \$20/hr	\$43,200	\$43,200	\$43,200	\$43,200
Supervisor	15% of operator	\$6,480	\$6,480	\$6,480	\$6,480
<b>Maintenance</b>					
Labor	Assumed similar labor requirements as to that required for ESP per Section 6, Page 3-47 of OAQPS Cost manual (\$20.00/hr, 7.5 h/wk, 44 wk/yr)	\$6,600	\$6,600	\$6,600	\$6,600
Material	100% of maintenance labor	\$6,600	\$6,600	\$6,600	\$6,600
<b>Utilities</b>	Utilities currently not estimated due to variability				
<b>Total Direct Annual Cost</b>		<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$4,272	\$4,406	\$5,894	\$6,740
Property tax	1% of Total Capital Investment	\$2,136	\$2,203	\$2,947	\$3,370
Insurance	1% of Total Capital Investment	\$2,136	\$2,203	\$2,947	\$3,370
Overhead	60% of total labor and material costs	\$37,728	\$37,728	\$37,728	\$37,728
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$14,691	\$15,151	\$20,270	\$23,178
<b>Total Indirect Annual Costs</b>		<b>\$60,963</b>	<b>\$61,691</b>	<b>\$69,787</b>	<b>\$74,385</b>
<b>Total Annual Cost</b>		<b>\$123,843</b>	<b>\$124,571</b>	<b>\$132,667</b>	<b>\$137,265</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 2 - Wet Scrubbers for Particulate Matter, dated July 2002 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> From Chemical Engineering Plant Cost Index (CEPCI)

Appendix Table A-3. Scrubber Capital and O&M Cost Estimate (30 Yrs Life)

Parameters/Costs	Equation/Reference	K1	K2	K3	K4
Exhaust Temperature (K)	$T_{stack}$	450.2	422.2	436.2	433.2
Exhaust Temperature (F)	Converted from degrees K	350.6	300.2	325.4	320.0
Exhaust Moisture Content (%)	MS - Typical Values	12.00%	12.00%	12.00%	12.00%
Exhaust Flow Rate (m <sup>3</sup> /s) <sup>1</sup>	CSP Application	12.9	12.7	22.1	27.9
Exhaust Flow Rate (ACFM) <sup>1</sup>	Converted from (m <sup>3</sup> /s)	27,246	26,999	46,908	59,181
Exhaust Flow Rate (SCFM)	$ACFM * ((68+460)/(T_{stack}+460))$	17,747	18,752	31,535	40,061
m <sub>wv</sub> (lb/min)	SCFM * MC * 18/385	100	105	177	225
m <sub>a</sub> (lb/min)	SCFM * (1-MC) * 29/385	730	772	1,297	1,648
humidity ratio	$m_{wv}/m_a$	0.14	0.14	0.14	0.14
humid volume (ft <sup>3</sup> /min)	<i>h (Estimated from psychrometric chart)</i>	23.00	23.00	23.00	23.00
Q <sub>SAT</sub>	$h * m_a$	16,794.16	17,744.79	29,840.67	37,909.40
Purchased Equipment Cost (Tables 2.5 and 2.6 for a Stainless Steel Low Energy scrubber, 2002 Dollars)	$1.15 * (150 * Q_{SAT}^{0.56})$	\$40,075	\$41,330	\$55,294	\$63,225
<b>Direct Costs - Table 2.8</b>					
<b>Purchased equipment costs</b>					
Packaged Unit (A1)	As estimated, AA	\$40,075	\$41,330	\$55,294	\$63,225
Auxiliary Costs (A2)	$A2 = 0.1 * A1$	\$4,008	\$4,133	\$5,529	\$6,322
Equipment Costs (A)	$A = A1 + A2$	\$44,083	\$45,463	\$60,824	\$69,547
Instrumentation	0.10 A	\$4,408	\$4,546	\$6,082	\$6,955
Sales taxes	0.03 A	\$1,322	\$1,364	\$1,825	\$2,086
Freight	0.05 A	\$2,204	\$2,273	\$3,041	\$3,477
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$52,018</b>	<b>\$53,647</b>	<b>\$71,772</b>	<b>\$82,066</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.06 B	\$3,121	\$3,219	\$4,306	\$4,924
Handling & erection	0.40 B	\$20,807	\$21,459	\$28,709	\$32,826
Electrical	0.01 B	\$520	\$536	\$718	\$821
Piping	0.05 B	\$2,601	\$2,682	\$3,589	\$4,103
Insulation for ductwork	0.03 B	\$1,561	\$1,609	\$2,153	\$2,462
Painting	0.01 B	\$520	\$536	\$718	\$821
<b>Direct Installation Costs, DIC</b>	<b>0.56 B</b>	<b>\$29,130</b>	<b>\$30,042</b>	<b>\$40,192</b>	<b>\$45,957</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$81,148</b>	<b>\$83,689</b>	<b>\$111,965</b>	<b>\$128,023</b>
<b>Indirect Costs (installation) Table 2.8</b>					
Engineering	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Construction & field expenses	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Contractor fees	0.10 B	\$5,202	\$5,365	\$7,177	\$8,207
Start-up	0.01 B	\$520	\$536	\$718	\$821
Performance test	0.01 B	\$520	\$536	\$718	\$821
Model study	--				
Contingencies	0.03B	\$1,561	\$1,609	\$2,153	\$2,462
<b>Total Indirect Costs, IC</b>	<b>0.35 B</b>	<b>\$18,206</b>	<b>\$18,776</b>	<b>\$25,120</b>	<b>\$28,723</b>
Cost Index <sup>2</sup>					
a. 2019	607.5				
b. 2002	395.6				
Capital recovery factor (CRF)	$CRF = [I * (1+i)^a] / [(1+i)^a - 1]$ , where I = interest rate, a = equipment life a. Equipment CRF, 30-yr life, 3.25% interest	0.05	0.05	0.05	0.05
<b>Total Capital Investment (2019 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (CI<sub>2019</sub>/CI<sub>1999</sub>) (Retrofit factor based on average provided for ESP on Page 3-41). No specific factor provided for scrubber, so factor for ESP was relied on.</b>	<b>\$213,601</b>	<b>\$220,290</b>	<b>\$294,719</b>	<b>\$336,987</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	3hr/shift*2shifts/day*360 days/yr * \$20/hr	\$43,200	\$43,200	\$43,200	\$43,200
Supervisor	15% of operator	\$6,480	\$6,480	\$6,480	\$6,480
<b>Maintenance</b>					
Assumed similar labor requirements as to that required for ESP per Section 6, Page 3-47 of OAQPS Cost manual (\$20.00/hr, 7.5 h/wk, 44 wk/yr)					
Labor	100% of maintenance labor	\$6,600	\$6,600	\$6,600	\$6,600
Material		\$6,600	\$6,600	\$6,600	\$6,600
<b>Utilities</b>					
Utilities currently not estimated due to variability					
<b>Total Direct Annual Cost</b>		<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>	<b>\$62,880</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$4,272	\$4,406	\$5,894	\$6,740
Property tax	1% of Total Capital Investment	\$2,136	\$2,203	\$2,947	\$3,370
Insurance	1% of Total Capital Investment	\$2,136	\$2,203	\$2,947	\$3,370
Overhead	60% of total labor and material costs	\$37,728	\$37,728	\$37,728	\$37,728
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$11,253	\$11,605	\$15,526	\$17,753
<b>Total Indirect Annual Costs</b>		<b>\$57,525</b>	<b>\$58,145</b>	<b>\$65,043</b>	<b>\$68,961</b>
<b>Total Annual Cost</b>		<b>\$120,405</b>	<b>\$121,025</b>	<b>\$127,923</b>	<b>\$131,841</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 2 - Wet Scrubbers for Particulate Matter, dated July 2002 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> From Chemical Engineering Plant Cost Index (CEPCI)

**Appendix Table A-4. Wet ESP Capital and O&M Cost Estimate**

Parameters/Costs	Equation	K1	K2	K3	K4
Average High Exhaust Flow Rate (m <sup>3</sup> /s) <sup>1</sup>		12.4	12.3	21.6	28.6
Average High Exhaust Flow Rate (ACFM) <sup>1</sup>		26,360	26,121	45,681	60,599
Annual Operating Time (hrs, θ) <sup>2</sup>		8,760	8,760	8,760	8,760
ESP efficiency (from white paper)		90%	90%	90%	90%
ESP Plate Area (ft <sup>2</sup> ) <sup>4</sup>	ESCA = -ln(p)/w <sub>e</sub> × 5.080 × Q	982	973	1,702	2,257
Purchased Equipment Cost (Table 3.14 for 90% Control Efficiency and 15,000 ACFM bins)	\$25.5/acfm	\$672,189	\$666,078	\$1,164,874	\$1,545,272
Basic Equipment Costs - Table 3.12	0.45 × Equipment Cost	\$302,485	\$299,735	\$524,193	\$695,372
<b>Direct Costs - Table 3.16</b>					
<b>Purchased equipment costs</b>					
ESP + auxiliary equipment (A)	As estimated, A	\$974,674	\$965,814	\$1,689,067	\$2,240,644
Instrumentation	0.10 A	\$97,467	\$96,581	\$168,907	\$224,064
Sales taxes	0.03 A	\$29,240	\$28,974	\$50,672	\$67,219
Freight	0.05 A	\$48,734	\$48,291	\$84,453	\$112,032
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$1,150,116</b>	<b>\$1,139,660</b>	<b>\$1,993,099</b>	<b>\$2,643,960</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.04 B	\$46,005	\$45,586	\$79,724	\$105,758
Handling & erection	0.50 B	\$575,058	\$569,830	\$996,549	\$1,321,980
Electrical	0.08 B	\$92,009	\$91,173	\$159,448	\$211,517
Piping	0.01 B	\$11,501	\$11,397	\$19,931	\$26,440
Insulation for ductwork	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
Painting	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
<b>Direct Installation Costs, DIC</b>	<b>0.67 B</b>	<b>\$770,578</b>	<b>\$763,572</b>	<b>\$1,335,376</b>	<b>\$1,771,453</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$1,920,694</b>	<b>\$1,903,233</b>	<b>\$3,328,475</b>	<b>\$4,415,413</b>
<b>Indirect Costs (installation) Table 3.16</b>					
Engineering	0.20B	\$230,023	\$227,932	\$398,620	\$528,792
Construction & field expenses	0.20B	\$230,023	\$227,932	\$398,620	\$528,792
Contractor fees	0.10B	\$115,012	\$113,966	\$199,310	\$264,396
Start-up	0.01B	\$11,501	\$11,397	\$19,931	\$26,440
Performance test	0.01B	\$11,501	\$11,397	\$19,931	\$26,440
Model study	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
Contingencies	0.03B	\$34,503	\$34,190	\$59,793	\$79,319
<b>Total Indirect Costs, IC</b>	<b>0.57B</b>	<b>\$655,566</b>	<b>\$649,606</b>	<b>\$1,136,066</b>	<b>\$1,507,057</b>
Cost Index <sup>2</sup>					
a. 2019	607.5				
b. 1999	390.6				
Capital recovery factor (CRF)	CRF = [ 1 x (1+i) <sup>a</sup> ] / [ (1+i) <sup>a</sup> - 1 ], where I = interest rate, a = equipment life	0.08	0.08	0.08	0.08
	#NAME?				
<b>Total Capital Investment (2019 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (C<sub>2019</sub>/C<sub>1999</sub>) (Retrofit factor based on average provided for ESP on Page 3-41).</b>	<b>\$5,609,598</b>	<b>\$5,558,601</b>	<b>\$9,721,178</b>	<b>\$12,895,700</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	2hr/shift*2shifts/day*365 days/yr * \$20/hr	\$29,200	\$29,200	\$29,200	\$29,200
Supervisor	15% of operator	\$4,380	\$4,380	\$4,380	\$4,380
<b>Maintenance</b>					
Labor	For ESP plate area < 50,000 ft <sup>2</sup> = \$4125	\$4,125	\$4,125	\$4,125	\$4,125
<b>Utilities</b>					
	Utilities currently not estimated due to variability				
<b>Total Direct Annual Cost</b>		<b>\$37,705</b>	<b>\$37,705</b>	<b>\$37,705</b>	<b>\$37,705</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$112,192	\$111,172	\$194,424	\$257,914
Property tax	1% of Total Capital Investment	\$56,096	\$55,586	\$97,212	\$128,957
Insurance	1% of Total Capital Investment	\$56,096	\$55,586	\$97,212	\$128,957
Overhead	60% of total labor and material costs	\$22,623	\$22,623	\$22,623	\$22,623
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$452,057	\$447,948	\$783,395	\$1,039,218
<b>Total Indirect Annual Costs</b>		<b>\$699,064</b>	<b>\$692,915</b>	<b>\$1,194,865</b>	<b>\$1,577,669</b>
<b>TOTAL ANNUAL COST</b>		<b>\$736,769</b>	<b>\$730,620</b>	<b>\$1,232,570</b>	<b>\$1,615,374</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 3 - Electrostatic Precipitators, dated September 1999 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> Electricity cost form U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.

<sup>3</sup> Water cost from Maui County (<https://www.mauicounty.gov/216/Water-Charges>) lowest general rate.

<sup>4</sup> For ESP Plate Area (Section 3.2.1):

p = 1 - (Control Efficiency %)

5.080 ft<sup>2</sup>/kacfm = 1 (s/m)

w<sub>e</sub> = effective migration velocity (m/s), assume w<sub>e</sub> = 31.4 cm/s for Bituminous coal fly ash for a design efficiency of 95% from Table 3.3 (no listings for 90% efficiency or fuel oil)

Q = system flow rate (kacfm)

<sup>5</sup> From Chemical Engineering Plant Cost Index (CEPCI)

Appendix Table A-4. Wet ESP Capital and O&M Cost Estimate

Parameters/Costs	Equation	K1	K2	K3	K4
Average High Exhaust Flow Rate (m <sup>3</sup> /s) <sup>1</sup>		12.4	12.3	21.6	28.6
Average High Exhaust Flow Rate (ACFM) <sup>1</sup>		26,360	26,121	45,681	60,599
Annual Operating Time (hrs, θ)		8,760	8,760	8,760	8,760
ESP efficiency (from white paper)		90%	90%	90%	90%
ESP Plate Area (ft <sup>2</sup> ) <sup>4</sup>	ESCA = -ln(p)/w <sub>e</sub> × 5.080 × Q	982	973	1,702	2,257
Purchased Equipment Cost (Table 3.14 for 90% Control Efficiency and 15,000 ACFM bins)	\$25.5/acfm	\$672,189	\$666,078	\$1,164,874	\$1,545,272
Basic Equipment Costs - Table 3.12	0.45 × Equipment Cost	\$302,485	\$299,735	\$524,193	\$695,372
<b>Direct Costs - Table 3.16</b>					
<b>Purchased equipment costs</b>					
ESP + auxiliary equipment (A)	As estimated, A	\$974,674	\$965,814	\$1,689,067	\$2,240,644
Instrumentation	0.10 A	\$97,467	\$96,581	\$168,907	\$224,064
Sales taxes	0.03 A	\$29,240	\$28,974	\$50,672	\$67,219
Freight	0.05 A	\$48,734	\$48,291	\$84,453	\$112,032
<b>Purchased Equipment cost, PEC</b>	<b>B = 1.18 A</b>	<b>\$1,150,116</b>	<b>\$1,139,660</b>	<b>\$1,993,099</b>	<b>\$2,643,960</b>
<b>Direct Installation Costs</b>					
Foundation & supports	0.04 B	\$46,005	\$45,586	\$79,724	\$105,758
Handling & erection	0.50 B	\$575,058	\$569,830	\$996,549	\$1,321,980
Electrical	0.08 B	\$92,009	\$91,173	\$159,448	\$211,517
Piping	0.01 B	\$11,501	\$11,397	\$19,931	\$26,440
Insulation for ductwork	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
Painting	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
<b>Direct Installation Costs, DIC</b>	<b>0.67 B</b>	<b>\$770,578</b>	<b>\$763,572</b>	<b>\$1,335,376</b>	<b>\$1,771,453</b>
<b>Total Direct Costs, TDC</b>	<b>PEC + DIC</b>	<b>\$1,920,694</b>	<b>\$1,903,233</b>	<b>\$3,328,475</b>	<b>\$4,415,413</b>
<b>Indirect Costs (installation) Table 3.16</b>					
Engineering	0.20B	\$230,023	\$227,932	\$398,620	\$528,792
Construction & field expenses	0.20B	\$230,023	\$227,932	\$398,620	\$528,792
Contractor fees	0.10B	\$115,012	\$113,966	\$199,310	\$264,396
Start-up	0.01B	\$11,501	\$11,397	\$19,931	\$26,440
Performance test	0.01B	\$11,501	\$11,397	\$19,931	\$26,440
Model study	0.02B	\$23,002	\$22,793	\$39,862	\$52,879
Contingencies	0.03B	\$34,503	\$34,190	\$59,793	\$79,319
<b>Total Indirect Costs, IC</b>	<b>0.57B</b>	<b>\$655,566</b>	<b>\$649,606</b>	<b>\$1,136,066</b>	<b>\$1,507,057</b>
Cost Index <sup>2</sup>					
a. 2019	607.5				
b. 1999	390.6				
Capital recovery factor (CRF)	CRF = [ 1 x (1+i) <sup>a</sup> ] / [ (1+i) <sup>a</sup> - 1 ], where I = interest rate, a = equipment life	0.07	0.07	0.07	0.07
	#NAME?				
<b>Total Capital Investment (2019 Dollars)</b>	<b>(TDC + IC) * (Retrofit factor of 1.4) * (CI<sub>2019</sub>/CI<sub>1999</sub>) (Retrofit factor based on average provided for ESP on Page 3-41).</b>	<b>\$5,609,598</b>	<b>\$5,558,601</b>	<b>\$9,721,178</b>	<b>\$12,895,700</b>
<b>Annual Costs</b>					
<b>Direct Annual Costs - Section 3.4.1</b>					
<b>Operating Labor</b>					
Operator	2hr/shift*2shifts/day*365 days/yr * \$20/hr	\$29,200	\$29,200	\$29,200	\$29,200
Supervisor	15% of operator	\$4,380	\$4,380	\$4,380	\$4,380
<b>Maintenance</b>					
Labor	For ESP plate area < 50,000 ft <sup>2</sup> = \$4125	\$4,125	\$4,125	\$4,125	\$4,125
<b>Utilities</b>					
	Utilities currently not estimated due to variability				
<b>Total Direct Annual Cost</b>		<b>\$37,705</b>	<b>\$37,705</b>	<b>\$37,705</b>	<b>\$37,705</b>
<b>Annual Indirect Costs, IC</b>					
Administrative charges	2% of Total Capital Investment	\$112,192	\$111,172	\$194,424	\$257,914
Property tax	1% of Total Capital Investment	\$56,096	\$55,586	\$97,212	\$128,957
Insurance	1% of Total Capital Investment	\$56,096	\$55,586	\$97,212	\$128,957
Overhead	60% of total labor and material costs	\$22,623	\$22,623	\$22,623	\$22,623
Annualized Capital Cost	Capital Recovery Factor * Total Capital Investment	\$385,822	\$382,314	\$668,612	\$886,952
<b>Total Indirect Annual Costs</b>		<b>\$632,829</b>	<b>\$627,281</b>	<b>\$1,080,082</b>	<b>\$1,425,403</b>
<b>TOTAL ANNUAL COST</b>		<b>\$670,534</b>	<b>\$664,986</b>	<b>\$1,117,787</b>	<b>\$1,463,108</b>

Source: All cost were estimated using EPA Air Pollution Control Cost Manual (APCCM), 6<sup>th</sup> Edition, Section 6, Chapter 3 - Electrostatic Precipitators, dated September 1999 (EPA/452/B-02-001).

<sup>1</sup> Exhaust parameters from Cover Source Permit Application.

<sup>2</sup> Electricity cost from U.S. Energy Information Administration. Electric Power Monthly with Data for September 2019. Table 5.6.a for Hawaii Industrial Sector.

<sup>3</sup> Water cost from Maui County (<https://www.mauicounty.gov/216/Water-Charges>) lowest general rate.

<sup>4</sup> For ESP Plate Area (Section 3.2.1):

$$p = 1 - (\text{Control Efficiency } \%)$$

$$5.080 \text{ ft}^2/\text{kacfm} = 1 \text{ (s/m)}$$

$$w_e = \text{effective migration velocity (m/s), assume } w_e = 31.4 \text{ cm/s for Bituminous coal fly ash for a design efficiency of 95\% from Table 3.3 (no listings for 90\% efficiency or fuel oil)}$$

$$Q = \text{system flow rate (kacfm)}$$

<sup>5</sup> From Chemical Engineering Plant Cost Index (CEPCI)