



DISABILITY AND COMMUNICATION ACCESS BOARD

1010 Richards Street, Room 118 • Honolulu, Hawaii 96813
Ph. (808) 586-8121 (V) • Fax (808) 586-8129 • (808) 586-8162 (TTY)

INTERPRETIVE OPINION

Pursuant to §103-50, Hawaii Revised Statutes (HRS), all public buildings, facilities and sites constructed by, or on behalf of the State or any county, shall conform to the 2004 Americans with Disabilities Act Accessibility Guidelines (2004 ADAAG) and amendments. In accordance to HRS §103-50 and Chapter 11-216, Hawaii Administrative Rules, the Disability and Communication Access Board has authority to issue interpretive opinions to HRS §103-50 design standards.

Docket: **DCAB 2011-03: What is considered ‘outdoor rinsing showers’ and are they required to be accessible? If they are required to be accessible, what are the scoping and technical requirements for accessible outdoor rinsing showers?**

(Amend): In Interpretive Opinion 2011-03 with regard to the scoping provisions, what is the scope of coverage? In Interpretive Opinion 2011-03 with regard to the technical provisions, should HODAAG technical provisions be applied to outdoor rinsing showers that are not covered by HODAAG?

Summary: There are a number of State and county facilities with outdoor rinsing showers where walls or enclosed spaces are not provided and where vandalism is a concern. These showers are not intended as “shower compartments”. It is not always practical or reasonable to require the construction of shower stalls where outdoor rinsing showers are provided. Yet if outdoor rinsing showers are provided, an accessible rinsing shower must also be provided for the use of persons with disabilities.

As of January 2, 2017, the Hawaii Outdoor Developed Areas Accessibility Guidelines (HODAAG) has been in effect and provides the scoping and technical requirements for outdoor rinsing showers within outdoor developed areas. However, there may be State and county facilities where outdoor rinsing showers are provided that may not fall within the scope of coverage by the HODAAG. Although the Interpretive Opinion provides scoping and technical requirements for outdoor rinsing showers, it is being amended to clarify the scope of coverage to facilities that do not fall within the scope of coverage by the HODAAG, and revising the fixed showerhead height.

The 2004 ADAAG does not address rinsing showers located in outdoor areas. The U.S. Access Board published the **Final Accessibility Guidelines for Outdoor Developed Areas**, which included technical provisions for outdoor rinsing showers. The Final Rule does not include grab bars for outdoor rinsing showers. DCAB feels that grab bars should be required at outdoor rinsing showers since someone with a disability relies on grab bars for support and assistance when standing or using the shower and the shower controls. While someone may not be “bathing” or disrobing at an outdoor rinsing shower, their operation of the controls and need for support and assistance due to their disability would be the same as someone using a “bathing shower”. Without grab bars it could be very difficult, if not impossible, for some individuals to use a rinsing shower.

ADAAG Section 213 Toilet and Bathing Facilities

Outdoor rinsing showers are showers that permit people to wash off sand, water, dirt, debris, etc. They are not designed for bathing, as they are generally located within view of the general public and do not offer privacy and people are usually not permitted to disrobe.

Where provided, outdoor rinsing showers not covered by the Hawaii Outdoor Developed Areas Accessibility Guidelines (HODAAG) shall comply with the following:

At least 20% but not less than one outdoor rinsing shower shall be provided in each area, in new construction and alterations, and shall comply with the following:

Outdoor Rinsing Showers. Outdoor rinsing showers shall provide at least two-fixed showerheads. One fixed showerhead shall be 48 inches above the ground surface, and one fixed showerhead shall be 72 inches minimum above the ground surface.

EXCEPTION. A hand-held shower spray unit complying with 608.6 shall be permitted instead of the fixed showerhead 48 inches maximum above the ground surface.

Clear Ground Space. A clear ground space shall comply with provisions for size and location, firm and stable surface, and slope.

EXCEPTIONS: Where individual outdoor constructed features are altered and the ground surface is not altered, the clear ground space shall not be required to comply with surface and slope requirements.

Size and Location. 60 inches by 60 inches centered on the showerheads. Locate the clear ground space so that the shower pedestal or showerhead is at the rear end of the space. One full unobstructed side of the clear ground space shall adjoin or overlap an accessible route or another clear ground space.

Surface. The surface of the clear ground space shall be firm, stable and slip-resistant.

Slope. The slope of the clear ground space surface shall not be steeper than 1:48 in any direction.

EXCEPTION. When the surface is other than asphalt, concrete, or boards, slopes not steeper than 1:33 shall be permitted where necessary for drainage.

Openings. Openings in clear ground space surface shall comply with 302.3.

Operable Parts. Operable parts shall comply with 309.3 and 309.4.

Grab Bars. Grab bars shall be provided and shall comply with ADAAG Section 609. In addition, at least one grab bar shall comply with one of the following provisions:

- a) **Vertical Grab Bar.** Where the showerhead is mounted on a post, a vertical grab bar shall be provided under the showerhead and shall start 33 inches (840 mm) maximum above the floor and extend to within at least 3 inches (75 mm) of the showerhead. Where vertical grab bars are provided, the grab bar shall be permitted to be offset a maximum of 6 inches from the vertical alignment of the fixed showerhead. Note, see Hawaii

Outdoor Developed Areas Accessibility Guidelines (HODAAG) Figure H1011.7 for mounting heights and vertical grab bar options.

EXCEPTION: Where a hand-held shower spray is provided, an 18 inch (455 mm) minimum vertical grab bar offset not more than 6 inches (150 mm) maximum from the fixed position of the hand-held shower spray shall be permitted.

- b) **Circular Grab Bar.** Where the showerhead is mounted on a post, a grab bar that surrounds the usable part of the post shall be provided. The grab bar shall be provided 33 inches (840 mm) minimum to 36 inches (915 mm) maximum above the floor.
- c) **Horizontal Grab Bar.** A horizontal grab bar extending 18 inches (455 mm) minimum in both directions from the centerline of the showerhead shall be provided under the showerhead. The grab bar shall be provided 33 inches (840 mm) minimum to 36 inches (915 mm) maximum above the floor.

[Rul: 01/03/2011] (Auth and Imp: HRS §103-50)

[Rev: 05/11/2017]

If you have any questions or comments regarding this ruling, please call us at 586-8121.
DISABILITY AND COMMUNICATION ACCESS BOARD