

Office of Health Care Assurance

State Licensing Section

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION

Facility's Name: Cora's	CHAPTER 100.1
Address: 1711 Ema Place, Honolulu, Hawaii 96819	Inspection Date: January 10, 2019 Annual

THIS PAGE MUST BE SUBMITTED WITH YOUR PLAN OF CORRECTION. IF IT IS NOT, YOUR PLAN OF CORRECTION WILL BE RETURNED TO YOU, UNREVIEWED.

YOUR PLAN OF CORRECTION MUST BE SUBMITTED WITHIN TEN (10) WORKING DAYS. IF IT IS NOT RECEIVED WITHIN TEN (10) DAYS, YOUR STATEMENT OF DEFICIENCIES WILL BE POSTED ONLINE, WITHOUT YOUR RESPONSE.

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-10 <u>Admission policies.</u> (g) An inventory of all personal items brought into the Type I ARCH by the resident shall be maintained.</p> <p><u>FINDINGS</u> Resident #1 – No documented evidence of inventory of personal items on admission</p>	<p>PART 1</p> <p><u>DID YOU CORRECT THE DEFICIENCY?</u></p> <p>USE THIS SPACE TO TELL US HOW YOU CORRECTED THE DEFICIENCY</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-10 <u>Admission policies.</u> (g) An inventory of all personal items brought into the Type I ARCH by the resident shall be maintained.</p> <p><u>FINDINGS</u> Resident #1 – No documented evidence of inventory of personal items on admission</p>	<p>PART 2</p> <p><u>FUTURE PLAN</u></p> <p>USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (g)(3)(D) Fire prevention protection.</p> <p>Type I ARCHs shall be in compliance with, but not limited to, the following provisions:</p> <p>A drill shall be held to provide training for residents and personnel at various times of the day or night at least four times a year and at least three months from the previous drill, and the record shall contain the date, hour, personnel participating and description of drill, and the time taken to safely evacuate residents from the building. A copy of the fire drill procedure and results shall be submitted to the fire inspector or department upon request;</p> <p><u>FINDINGS</u> Fire drills not held at various times of the day or night</p>	<p>PART 1</p> <p>Correcting the deficiency after-the-fact is not practical/appropriate. For this deficiency, only a future plan is required.</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (g)(3)(D) Fire prevention protection.</p> <p>Type I ARCHs shall be in compliance with, but not limited to, the following provisions:</p> <p>A drill shall be held to provide training for residents and personnel at various times of the day or night at least four times a year and at least three months from the previous drill, and the record shall contain the date, hour, personnel participating and description of drill, and the time taken to safely evacuate residents from the building. A copy of the fire drill procedure and results shall be submitted to the fire inspector or department upon request;</p> <p><u>FINDINGS</u> Fire drills not held at various times of the day or night</p>	<p>PART 2</p> <p><u>FUTURE PLAN</u></p> <p>USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p>	

Licensee's/Administrator's Signature: _____

Print Name: _____

Date: _____