

Office of Health Care Assurance

State Licensing Section

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION

Facility's Name: JML	CHAPTER 100.1
Address: 92-560 Pilipono Street, Kapolei, Hawaii 96707	Inspection Date: September 26, 2018 Annual

THIS PAGE MUST BE SUBMITTED WITH YOUR PLAN OF CORRECTION. IF IT IS NOT, YOUR PLAN OF CORRECTION WILL BE RETURNED TO YOU, UNREVIEWED.

YOUR PLAN OF CORRECTION MUST BE SUBMITTED WITHIN TEN (10) WORKING DAYS. IF IT IS NOT RECEIVED WITHIN TEN (10) WORKING DAYS, YOUR STATEMENT OF DEFICIENCIES WILL BE POSTED ONLINE, WITHOUT YOUR RESPONSE.

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-14 <u>Food sanitation.</u> (f) Toxic chemicals and cleaning agents, such as insecticides, fertilizers, bleaches and all other poisons, shall be properly labeled and securely stored apart from any food supplies.</p> <p>FINDINGS Resident bathroom, unsecured chemical ("Glade" spray) on a towel bar and resident accessible.</p>	<p style="text-align: center;">PART 1</p> <p style="text-align: center;"><u>DID YOU CORRECT THE DEFICIENCY?</u></p> <p style="text-align: center;">USE THIS SPACE TO TELL US HOW YOU CORRECTED THE DEFICIENCY</p> <p>Unsecured chemical (Glade spray) was removed out of residents' access and was securely stored</p>	<p>9/26/18</p>

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-14 <u>Food sanitation.</u> (f) Toxic chemicals and cleaning agents, such as insecticides, fertilizers, bleaches and all other poisons, shall be properly labeled and securely stored apart from any food supplies.</p> <p><u>FINDINGS</u> Resident bathroom, unsecured chemical ("Glade" spray) on a towel bar and resident accessible.</p>	<p style="text-align: center;">PART 2</p> <p style="text-align: center;"><u>FUTURE PLAN</u></p> <p style="text-align: center;">USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p> <p>In the future, all toxic chemicals are securely stored at all times; Educate all caregivers and household members to remove all toxic chemicals and cleaning agents out of residents' access, and to put them all in secured place. Make it a daily routine to check all toxic chemicals and cleaning agents in secured place.</p>	<p>9/26/18</p>

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-17 <u>Records and reports.</u> (e) In the event of an emergency, an oral summary of the resident's condition shall be provided to the receiving facility, followed by a written transfer summary.</p> <p><u>FINDINGS</u> Resident #1, emergency sheet available for emergency transport is outdated. TB clearance, physicians and medication orders do not reflect those listed in record.</p>	<p style="text-align: center;">PART 1</p> <p style="text-align: center;"><u>DID YOU CORRECT THE DEFICIENCY?</u></p> <p style="text-align: center;">USE THIS SPACE TO TELL US HOW YOU CORRECTED THE DEFICIENCY</p> <p style="text-align: center;">Emergency sheet form for emergency transport was updated with all the correct and current information of the resident.</p>	<p style="text-align: center;">9/26/18</p>

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-17 <u>Records and reports.</u> (e) In the event of an emergency, an oral summary of the resident's condition shall be provided to the receiving facility, followed by a written transfer summary.</p> <p><u>FINDINGS</u> Resident #1, emergency sheet available for emergency transport is outdated. TB clearance, physicians and medication orders do not reflect those listed in record.</p>	<p style="text-align: center;">PART 2</p> <p style="text-align: center;"><u>FUTURE PLAN</u></p> <p style="text-align: center;">USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p> <p>Primary caregiver updates emergency forms everytime there's any change in anything in regards to the care of a resident. Make a log for chart check to be done every beginning of the month to make sure everything is updated</p>	<p style="text-align: right;">12/17/18</p>

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (o)(1)(D) Bedrooms:</p> <p>General conditions:</p> <p>Bedrooms shall not be used for recreation, cooking, dining, storage, bathrooms, laundries, foyers, corridors, lanais, and libraries;</p> <p><u>FINDINGS</u> Bedroom #2, wardrobe cabinet used to store linens for the entire care home is located inside a licensed bed room.</p>	<p style="text-align: center;">PART 1</p> <p style="text-align: center;"><u>DID YOU CORRECT THE DEFICIENCY?</u></p> <p style="text-align: center;">USE THIS SPACE TO TELL US HOW YOU CORRECTED THE DEFICIENCY</p> <p>Wardrobe cabinet for linens storage was taken out from the licensed residents' bedroom and was relocated in an area outside all the licensed residents' bedrooms.</p>	<p>9/26/18</p>

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (o)(1)(D) Bedrooms:</p> <p>General conditions:</p> <p>Bedrooms shall not be used for recreation, cooking, dining, storage, bathrooms, laundries, foyers, corridors, lanais, and libraries;</p> <p><u>FINDINGS</u> Bedroom #2, wardrobe cabinet used to store linens for the entire care home is located inside a licensed bed room.</p>	<p style="text-align: center;">PART 2</p> <p style="text-align: center;"><u>FUTURE PLAN</u></p> <p style="text-align: center;">USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p> <p>In the future all licensed residents' bedrooms are not to be used to store any care home supplies. Remind/educate all caregivers not to store any care home supply/supplies in any licensed residents' bedroom.</p>	<p style="text-align: center;">9/26/18</p>

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-86 <u>Fire safety.</u> (a)(3) A Type I expanded ARCH shall be in compliance with existing fire safety standards for a Type I ARCH, as provided in section 11-100.1-23(b), and the following:</p> <p>Fire drills shall be conducted and documented at least monthly under varied conditions and times of day;</p> <p><u>FINDINGS</u> Fire drill record available for only ten (10) of the prior twelve months instead of the required monthly fire drill.</p>	<p style="text-align: center;">PART 1</p> <p style="text-align: center;">Correcting the deficiency after-the-fact is not practical/appropriate. For this deficiency, only a future plan is required.</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-86 <u>Fire safety.</u> (a)(3) A Type I expanded ARCH shall be in compliance with existing fire safety standards for a Type I ARCH, as provided in section 11-100.1-23(b), and the following:</p> <p>Fire drills shall be conducted and documented at least monthly under varied conditions and times of day;</p> <p><u>FINDINGS</u> Fire drill record available for only ten (10) of the prior twelve months instead of the required monthly fire drill.</p>	<p style="text-align: center;">PART 2</p> <p style="text-align: center;"><u>FUTURE PLAN</u></p> <p style="text-align: center;">USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p> <p>In the future, make a 12 months calendar with a marked designated monthly fire drill day. Educate/remind all caregivers about the monthly fire drill day calendar.</p>	<p style="text-align: right;">9/26/18</p>

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
☒	<p>§11-100.1-86 <u>Fire safety.</u> (a)(4) A Type I expanded ARCH shall be in compliance with existing fire safety standards for a Type I ARCH, as provided in section 11-100.1-23(b), and the following:</p> <p>Hard wired smoke detectors shall be approved by a nationally recognized testing laboratory and all shall be tested at least monthly to assure working order;</p> <p><u>FINDINGS</u> Smoke detector batteries test available for ten (10) of twelve months instead of the required monthly smoke detector test.</p>	<p style="text-align: center;">PART 1</p> <p style="text-align: center;">Correcting the deficiency after-the-fact is not practical/appropriate. For this deficiency, only a future plan is required.</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-86 <u>Fire safety.</u> (a)(4) A Type I expanded ARCH shall be in compliance with existing fire safety standards for a Type I ARCH, as provided in section 11-100.1-23(b), and the following:</p> <p>Hard wired smoke detectors shall be approved by a nationally recognized testing laboratory and all shall be tested at least monthly to assure working order;</p> <p><u>FINDINGS</u> Smoke detector batteries test available for ten (10) of twelve months instead of the required monthly smoke detector test.</p>	<p style="text-align: center;">PART 2</p> <p style="text-align: center;"><u>FUTURE PLAN</u></p> <p style="text-align: center;">USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p> <p>In the future, make a 12 month calendar with a marked designated monthly smoke detector batteries test day; to be done at the same time/day with monthly fire drill day. Remind all caregivers to be mindful of the monthly smoke detector batteries test day.</p>	<p style="text-align: right;">9/26/18</p>

Licensee's/Administrator's Signature: *Merlyne G. Lim*

Print Name: MERLYNE G. LIM

Date: December 17, 2018

Licensee's/Administrator's Signature: *Merlyne G. Lim*

Print Name: MERLYNE G. LIM

Date: 10/08/2018