

Hawaii Dept. of Health, Office of Health Care Assurance

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 125048	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 02/28/2025
--	---	---	---

NAME OF PROVIDER OR SUPPLIER ANN PEARL NURSING FACILITY	STREET ADDRESS, CITY, STATE, ZIP CODE 45-181 WAIKALUA ROAD KANEHOE, HI 96744
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
4 000	<p>11-94.2-0 Initial Comments</p> <p>The Department of Health, OHCA has accepted the federal Medicare recertification of this facility for state relicensing purposes and has exempted this facility from a full relicensing inspection as authorized by chapter 11-94.2-6(e) Hawaii Administrative Rules (HAR). Refer to the federal Medicare recertification survey report to see citations and plans of correction. The facility was not found to meet the unique requirements for HAR, 11-93.2-6(e), construction requirements.</p> <p>The facility's adult day health services program is no longer operational effective July 2024.</p>	4 000		
41260	<p>11-94.2-65 (e) Construction requirements</p> <p>(e) The facility shall have resident bedrooms that ensure the health and safety of residents:</p> <p>(1) Each room shall be at or above grade 65 level;</p> <p>(2) Each resident bedroom shall have window coverings to provide an adequate means of ensuring privacy;</p> <p>(3) Resident bedrooms shall have not more than four beds;</p> <p>(4) Single resident bedrooms shall measure at least one hundred square feet of usable space, excluding closets, bathrooms, alcoves, and entryways;</p> <p>(5) Multi-resident bedrooms shall provide a minimum of eighty square feet per bed of usable space, excluding closets, bathrooms, alcoves, and entryways;</p>	41260		

Office of Health Care Assurance LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
Electronically Signed		

Hawaii Dept. of Health, Office of Health Care Assurance

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 125048	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 02/28/2025
--	---	---	---

NAME OF PROVIDER OR SUPPLIER ANN PEARL NURSING FACILITY	STREET ADDRESS, CITY, STATE, ZIP CODE 45-181 WAIKALUA ROAD KANEOHE, HI 96744
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
41260	<p>Continued From page 1</p> <p>(6) Bedside screens or curtains shall be provided in multi-bed bedrooms to ensure privacy for each resident;</p> <p>(7) Beds shall be placed at least three feet apart; and</p> <p>(8) Each resident shall be provided with:</p> <p>(A) A separate bed of proper size and height for the convenience of the resident and that permits an individual in a wheelchair to get in and out of bed unassisted;</p> <p>(B) A comfortable mattress with impermeable mattress cover, and a pillow with an impermeable cover;</p> <p>(C) Sufficient clean bed linen and blankets to meet the resident's needs;</p> <p>(D) Appropriate furniture, cabinets, and closets, accessible to and meeting individual resident's needs. Locked containers shall be available upon resident's request; and</p> <p>(E) An effective signal call system at the resident's bedside.</p> <p>This Statute is not met as evidenced by: Based on requested entrance documentation and interview, the facility failed to ensure a single resident bedroom measured at least one hundred square feet of usable space and ensure a multi-resident room provides a minimum space of eighty square feet per bed of usable space, excluding closets, bathrooms alcoves and entry ways for two of six rooms on a unit.</p> <p>Findings include:</p>	41260		

Hawaii Dept. of Health, Office of Health Care Assurance

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 125048	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 02/28/2025
NAME OF PROVIDER OR SUPPLIER ANN PEARL NURSING FACILITY		STREET ADDRESS, CITY, STATE, ZIP CODE 45-181 WAIKALUA ROAD KANEHOE, HI 96744		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
41260	Continued From page 2 Room HH1 in the memory unit accommodates one resident. HH1 does not measure at least one hundred square feet of usable space for a resident that would occupy this room. Room HH2 in the memory unit houses multiple residents and does not meet the requirements of eighty square feet per bed of usable space for each resident that would occupy this room. On 02/25/25 at 07:49 AM, interview with Administrator was done. Administrator confirmed no construction changes have been made to the two bedrooms. The facility currently has been issued a waiver for booths rooms.	41260		