

Office of Health Care Assurance

State Licensing Section

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION

Facility's Name: Lisa and Letty Care Home, LLC	CHAPTER 100.1
Address: 95-528 Wailoa Loop, Mililani, Hawaii, 96789	Inspection Date: October 1, 2025 Annual

THIS PAGE MUST BE SUBMITTED WITH YOUR PLAN OF CORRECTION. IF IT IS NOT, YOUR PLAN OF CORRECTION WILL BE RETURNED TO YOU, UNREVIEWED.

YOUR PLAN OF CORRECTION MUST BE SUBMITTED WITHIN TEN (10) WORKING DAYS. IF IT IS NOT RECEIVED WITHIN TEN (10) DAYS, YOUR STATEMENT OF DEFICIENCIES WILL BE POSTED ONLINE, WITHOUT YOUR RESPONSE.

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (p)(5) Miscellaneous:</p> <p>Signaling devices approved by the department shall be provided for resident's use at the bedside, in bathrooms, toilet rooms, and other areas where residents may be left alone. In Type I ARCHs where the primary care giver and residents do not reside on the same level or when other signaling mechanisms are deemed inadequate, there shall be an electronic signaling system.</p> <p><u>FINDINGS</u> Signaling device in bathroom not operational, corrected during inspection.</p>	<p style="text-align: center;">PART 1</p> <p style="text-align: center;">Correcting the deficiency after-the-fact is not practical/appropriate. For this deficiency, only a future plan is required.</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (p)(5) Miscellaneous:</p> <p>Signaling devices approved by the department shall be provided for resident's use at the bedside, in bathrooms, toilet rooms, and other areas where residents may be left alone. In Type I ARCHs where the primary care giver and residents do not reside on the same level or when other signaling mechanisms are deemed inadequate, there shall be an electronic signaling system.</p> <p>FINDINGS Signaling device in bathroom not operational, corrected during inspection.</p>	<p style="text-align: center;">PART 2</p> <p style="text-align: center;"><u>FUTURE PLAN</u></p> <p style="text-align: center;">USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p> <p><i>care home has generated weekly checklist to insure all call bells are working and operational.</i></p>	<p style="text-align: center;"><i>12/19/25</i></p>

Licensee's/Administrator's Signature: for: Leticia Dagala / MJA

Print Name: Leonisa Sandusky

Date: 12/19/16