

Office of Health Care Assurance

State Licensing Section

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION

Facility's Name: Aiea Heights Senior Living	CHAPTER 100.1
Address: 99-1657 Aiea Heights Drive, Aiea, Hawaii 96701	Inspection Date: May 5, 2026 Annual

THIS PAGE MUST BE SUBMITTED WITH YOUR PLAN OF CORRECTION. IF IT IS NOT, YOUR PLAN OF CORRECTION WILL BE RETURNED TO YOU, UNREVIEWED.

YOUR PLAN OF CORRECTION MUST BE SUBMITTED WITHIN TEN (10) WORKING DAYS PER HAR 11-100.1-3(e)(2). IF IT IS NOT RECEIVED WITHIN TEN (10) WORKING DAYS, YOUR STATEMENT OF DEFICIENCIES WILL BE POSTED ONLINE, WITHOUT YOUR RESPONSE.

FAILURE TO CORRECT CITED DEFICIENCIES AS PER THE PLAN OF CORRECTION COULD RESULT IN REFUSAL TO RENEW YOUR LICENSE PER HAR 11-100.1-3(e)(3).

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (g)(3)(D) Fire prevention protection.</p> <p>Type I ARCHs shall be in compliance with, but not limited to, the following provisions:</p> <p>A drill shall be held to provide training for residents and personnel at various times of the day or night at least four times a year and at least three months from the previous drill, and the record shall contain the date, hour, personnel participating and description of drill, and the time taken to safely evacuate residents from the building. A copy of the fire drill procedure and results shall be submitted to the fire inspector or department upon request;</p> <p><u>FINDINGS</u> Duration of monthly fire drills unavailable for 10/2025, 11/2025, and 2/2026</p>	<p style="text-align: center;">PART 1</p> <p style="text-align: center;">Correcting the deficiency after-the-fact is not practical/appropriate. For this deficiency, only a future plan is required.</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (g)(3)(D) Fire prevention protection.</p> <p>Type I ARCHs shall be in compliance with, but not limited to, the following provisions:</p> <p>A drill shall be held to provide training for residents and personnel at various times of the day or night at least four times a year and at least three months from the previous drill, and the record shall contain the date, hour, personnel participating and description of drill, and the time taken to safely evacuate residents from the building. A copy of the fire drill procedure and results shall be submitted to the fire inspector or department upon request;</p> <p><u>FINDINGS</u> Duration of monthly fire drills unavailable for 10/2025, 11/2025, and 2/2026</p>	<p>PART 2</p> <p><u>FUTURE PLAN</u></p> <p>USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (r) Facilities shall be maintained in accordance with provisions of state and local zoning, building, fire safety and health codes.</p> <p><u>FINDINGS</u> Documented evidence of monthly smoke alarm testing unavailable for the following months: 9/2025, 10/2025, 11/2025, 1/2026, 2/2026, 3/2026, and 4/2026</p>	<p style="text-align: center;">PART 1</p> <p style="text-align: center;">Correcting the deficiency after-the-fact is not practical/appropriate. For this deficiency, only a future plan is required.</p>	

	RULES (CRITERIA)	PLAN OF CORRECTION	Completion Date
<input checked="" type="checkbox"/>	<p>§11-100.1-23 <u>Physical environment.</u> (r) Facilities shall be maintained in accordance with provisions of state and local zoning, building, fire safety and health codes.</p> <p><u>FINDINGS</u> Documented evidence of monthly smoke alarm testing unavailable for the following months: 9/2025, 10/2025, 11/2025, 1/2026, 2/2026, 3/2026, and 4/2026</p>	<p>PART 2</p> <p><u>FUTURE PLAN</u></p> <p>USE THIS SPACE TO EXPLAIN YOUR FUTURE PLAN: WHAT WILL YOU DO TO ENSURE THAT IT DOESN'T HAPPEN AGAIN?</p>	

Licensee's/Administrator's Signature: _____

Print Name: _____

Date: _____