



PERIODIC OPERATION AND MAINTENANCE WALKTHROUGH INSPECTIONS

Instructions: This is a recommended form to be completed in compliance with Hawaii Administrative Rules (HAR), Chapter 11-280.1-36 for Single - Tank System.

Part 1: The periodic operation and maintenance walkthrough inspections for Spill Prevention Equipment and Release Detection Equipment are conducted every 31 days. HAR 11-280.1-36(a)(1)

A. Spill Prevention Equipment – HAR 11-280.1-36(a)(1)(A)	YES	NO	N/A	Remarks
<ul style="list-style-type: none"> ○ Visually check for damage ○ Remove liquid or debris ○ Check for and remove obstructions in the fill pipe ○ For double-walled (DW) spill prevention equipment with interstitial monitoring, check for a leak in the interstitial area 				
B. Release Detection Equipment – HAR 11-280.1-36(a)(1)(B)	YES	NO	N/A	Remarks
<ul style="list-style-type: none"> ○ Check to make sure the release detection equipment is operating with no alarms or other unusual operating conditions present ○ Records of release detection testing are reviewed and current 				

Note any deficiencies observed, as well as any corrective actions taken:

Part 2: The periodic operation and maintenance walkthrough inspections for Containment Sumps used for interstitial monitoring of piping and handheld release detection equipment are conducted every 365 days. HAR 11-280.1-36(a)(2)

A. Containment Sumps - HAR 11-280.1-36(a)(2)	YES	NO	N/A	Remarks
<ul style="list-style-type: none"> ○ Visually check for damage, leaks to the containment area, or releases to the environment ○ Remove liquid (in contained sumps) or debris ○ For DW sumps with interstitial monitoring, check for a leak in the interstitial area 				
B. Hand held release detection equipment – HAR 11-280.1-36(a)(2)(B)	YES	NO	N/A	Remarks
<ul style="list-style-type: none"> ○ Check devices such as tank gauge sticks or groundwater bailers for operability and serviceability ○ List the dates of annual (365 days) inspections: _____, _____, and _____ 				

Note any deficiencies observed, as well as any corrective actions taken:

Date: _____
 Name of person conducting inspection: _____
 Signature of person conducting inspection: _____