



DEPARTMENT OF THE NAVY
COMMANDER
NAVY REGION HAWAII
850 TICONDEROGA ST STE 110
JBPBH, HAWAII 96860-5101

RECEIVED JUL 10 2015

Scanner

5090
Ser N45/538
July 10, 2015

CERTIFIED NO: 7014 1200 0000 9858 7329

Mr. Richard Takaba
Hawaii State Department of Health
Environmental Management Division
Solid and Hazardous Waste Branch
Underground Storage Tank Section
919 Ala Moana Boulevard, Room 212
Honolulu, HI 96814

Dear Mr. Takaba:

SUBJECT: RED HILL TANK COMPLEX
JUNE 2015 OIL/WATER INTERFACE MEASUREMENTS
DOH FACILITY ID NO. 9-102271
DOH RELEASE ID NO. 990051, 010011, 020028, AND 140010

In response to the January 2014 release from Red Hill Tank 5, oil/water interface measurements were taken at groundwater monitoring wells RHMW01, RHMW02, RHMW03, and RHMW05 on June 25, 2015. No free product was observed in the wells. A summary of the oil/water interface measurements from January 2014 through June 2015 is being submitted as Enclosure 1.

If there are any questions regarding this matter, or if more information is needed, please contact Ms. Raelynn Kishaba at (808) 471-1171, extension 233.

Sincerely,

AARON Y. POENTIS
Director

Regional Environmental Department
By direction of the
Commander

Enclosure: 1. Red Hill Oil/Water Interface Measurements,
January 2014 through June 2015

Copy to: Ms. Joanna Seto, DOH Safe Drinking Water Branch
LCDR Andrew Lovgren, NAVSUP FLC Pearl Harbor
Mr. Rockne Krill, DLA Energy Pacific

Date	RHMW01 Elevation = 102.27 ft ¹				RHMW02 Elevation = 104.76 ft ¹				RHMW03 Elevation = 121.06 ft ¹				RHMW05 Elevation = 101.55 ft ¹			
	DTW (TOC)	SWL	LNAPL	0	DTW (TOC)	SWL	LNAPL	0	DTW (TOC)	SWL	LNAPL	0	DTW (TOC)	SWL	LNAPL	0
15-Jan-14	83.94	18.33	0	0	86.62	18.14	0	0	NT	NT	NT	0	NT	NT	NT	0
16-Jan-14	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	83.09	18.46	0	0
22-Jan-14	83.53	18.74	0	0	86.20	18.56	0	0	NT	NT	NT	0	82.87	18.68	0	0
23-Jan-14	83.58	18.69	0	0	86.24	18.52	0	0	NT	NT	NT	0	82.94	18.61	0	0
24-Jan-14	83.57	18.70	0	0	86.23	18.53	0	0	NT	NT	NT	0	82.93	18.62	0	0
27-Jan-14	83.55	18.72	0	0	86.23	18.53	0	0	NT	NT	NT	0	82.93	18.62	0	0
28-Jan-14	83.56	18.71	0	0	86.25	18.51	0	0	102.52	18.54	0	0	82.94	18.61	0	0
29-Jan-14	83.56	18.71	0	0	86.22	18.54	0	0	NT	NT	NT	0	82.94	18.61	0	0
30-Jan-14	83.53	18.74	0	0	86.21	18.55	0	0	NT	NT	NT	0	82.93	18.62	0	0
31-Jan-14	83.53	18.74	0	0	86.19	18.57	0	0	NT	NT	NT	0	82.88	18.67	0	0
3-Feb-14	83.54	18.73	0	0	86.20	18.56	0	0	NT	NT	NT	0	82.91	18.64	0	0
4-Feb-14	83.54	18.73	0	0	86.20	18.56	0	0	NT	NT	NT	0	82.89	18.66	0	0
10-Feb-14	84.49	17.78	0	0	86.16	18.60	0	0	102.47	18.59	0	0	82.83	18.72	0	0
24-Feb-14	83.54	18.73	0	0	86.24	18.52	0	0	102.47	18.59	0	0	82.97	18.58	0	0
4-Mar-14*	NT	NT	0	0	NT	NT	0	0	NT	NT	NT	0	NT	NT	NT	0
13-Mar-14*	NT	NT	0	0	NT	NT	0	0	NT	NT	NT	0	NT	NT	NT	0
28-Mar-14	83.76	18.51	0	0	86.42	18.34	0	0	102.65	18.41	0	0	83.18	18.37	0	0
7-Apr-14*	83.42	18.85	0	0	86.43	18.33	0	0	NT	NT	NT	0	83.21	18.34	0	0
21-Apr-14	83.93	18.34	0	0	86.58	18.18	0	0	102.80	18.26	0	0	83.27	18.28	0	0
8-May-14*	84.03	18.24	0	0	86.68	18.08	0	0	NT	NT	NT	0	83.46	18.09	0	0
22-May-14*	83.81	18.46	0	0	86.47	18.29	0	0	NT	NT	NT	0	83.15	18.40	0	0
27-May-14	83.91	18.36	0	0	86.60	18.16	0	0	102.85	18.21	0	0	83.31	18.24	0	0
10-Jun-14*	83.93	18.34	0	0	86.55	18.21	0	0	NT	NT	NT	0	83.34	18.21	0	0
23-Jun-14	84.06	18.21	0	0	86.72	18.04	0	0	103.99	17.07	0	0	83.54	18.01	0	0
21-Jul-14	84.13	18.14	0	0	86.80	17.96	0	0	102.98	18.08	0	0	83.49	18.06	0	0
27-Aug-14	84.01	18.26	0	0	86.65	18.11	0	0	102.87	18.19	0	0	83.04	18.51	0	0
25-Sep-14	84.64	17.63	0	0	87.27	17.49	0	0	103.51	17.55	0	0	84.10	17.45	0	0
28-Oct-14	83.79	18.48	0	0	86.51	18.25	0	0	102.78	18.28	0	0	83.21	18.34	0	0
20-Nov-14	83.87	18.40	0	0	86.56	18.20	0	0	102.78	18.28	0	0	83.35	18.20	0	0
23-Dec-14	83.67	18.60	0	0	86.37	18.39	0	0	102.64	18.42	0	0	83.05	18.50	0	0
28-Jan-15	83.63	18.64	0	0	86.35	18.41	0	0	102.63	18.43	0	0	83.03	18.52	0	0
27-Feb-15	83.68	18.59	0	0	86.28	18.48	0	0	102.52	18.54	0	0	83.06	18.49	0	0
26-Mar-15	83.83	18.44	0	0	86.04	18.72	0	0	102.79	18.27	0	0	83.24	18.31	0	0
21-Apr-15	84.33	17.94	0	0	86.97	17.79	0	0	103.18	17.88	0	0	83.72	17.83	0	0
28-May-15	84.29	17.98	0	0	86.97	17.79	0	0	103.24	17.82	0	0	83.95	17.60	0	0
25-Jun-15	84.58	17.69	0	0	87.28	17.48	0	0	103.57	17.49	0	0	83.75	17.80	0	0

Notes:

1 - Elevations were updated based on the Groundwater Flow Direction/Gradient and Tier 3 Risk Assessment Re-evaluation Letter Report, Red Hill Bulk Fuel Storage Facility, Pearl Harbor, Hawaii, Contract No. N47408-04-D-8514, Task Order 54, dated April 15, 2010. Measurements recorded by ESI, unless otherwise noted.

* - Measurements recorded by NAVFAC HI.

All units in feet (ft).

DTW (TOC) - depth to water from top of well casing

LNAPL - light non-aqueous phase liquid

NP - measurement not provided

NT - measurement not taken

SWL - static water level