

# DEPARTMENT OF THE NAVY

COMMANDER  
NAVY REGION HAWAII  
850 TICONDEROGA ST STE 110  
PEARL HARBOR, HAWAII 96860-5101

5090  
Ser N45/  
December 03, 2021

Ms. Roxanne Kwan  
Underground Storage Tank Section  
Solid and Hazardous Waste Branch  
Hawaii State Department of Health  
2827 Waimano Home Road #100  
Pearl City, Hawaii 96782

Dear Ms. Kwan:

SUBJECT: CONFIRMED RELEASE NOTIFICATION FORM, FIRE SUPPRESSION  
DRAIN LINE, DOH FACILITY ID NO. 9-102271, HEER INCIDENT CASE NO.  
20211120-2330

As reported on November 20, 2021 to DOH Hazard Evaluation and Emergency Response (HEER) Office, there was a release of approximately 14,000 gallons of a mix of water and fuel from a fire suppression drain line in the tunnel downhill of the Red Hill Bulk Fuel Storage Facility.

Per Hawaii Administrative Rules (HAR) 11-280.1-52, the Navy is submitting a Confirmed Release Notification Form as Enclosure 1.

If there are any questions regarding this matter, or if more information is needed, please contact me at (808) 471-3858.

Sincerely,

ENG.SHERRI.R.1229438936  
.1229438936

Digitally signed by  
ENG.SHERRI.R.1229438936  
Date: 2021.12.05 21:23:01  
-10'00'

SHERRI R. ENG  
Director  
Regional Environmental Department  
By direction of the  
Commander

Enclosure: 1. Confirmed Release Notification Form for Fire Suppression Drain Line

Copy to: Mr. John Floyd, NAVSUP FLC Pearl Harbor  
Mr. John Reed, DLA Energy Pacific

