



DEPARTMENT OF THE NAVY
COMMANDER
NAVY REGION HAWAII
850 TICONDEROGA ST STE 110
JBPBH, HAWAII 96860-5101

JUN 24 2021

5000-45A
N45
June 21, 2021

CERTIFIED NO: 9489 0090 0027 6232 9868 66

Ms. Roxanne Kwan
Hawaii State Department of Health
Solid and Hazardous Waste Branch
Underground Storage Tank Section
2827 Waimano Home Road #100
Pearl City, Hawaii 96782

Dear Ms. Kwan:

SUBJECT: CONFIRMED RELEASE NOTIFICATION FORM, PIPELINE AT TANKS 18 AND 20, RED HILL BULK FUEL STORAGE FACILITY, DOH FACILITY ID NO. 9-102271, DOH UST RELEASE ID NO. 210012, HEER INCIDENT CASE NO. 20210507-0852

As reported originally on May 7, 2021 to Ms. Lene Ichinotsubo, Mr. Richard Takaba and Mr. Hugh Myers of the Hawaii Department of Health (DOH) Solid and Hazardous Waste Branch, and to Ms. Liz Galvez of the DOH Hazard Evaluation and Emergency Response (HEER) Office, there was an incident related to the tunnel piping leading to Tanks 18 and 20 on May 6, 2021. Initial estimate was less than 1,000 gallons of fuel was released from a separated coupling and was subsequently captured in the containment trench and waste sump within the tunnel. The incident is currently under investigation by an independent investigator.

In response to DOH letter U0636RK of June 9, 2021, the Navy is submitting a Confirmed Release Notification Form as Enclosure 1. The Navy will follow the timelines identified in the June 9, 2021 letter, beginning today.

If there are any questions regarding this matter, or if more information is needed, please contact me at (808) 471-3858.

Sincerely,

SHERRI R. ENG
Director
Regional Environmental Department
By direction of the
Commander

Enclosure: 1. Confirmed Release Notification Form for Red Hill Bulk Fuel Storage Facility
Tanks 18 and 20

Copy to: Mr. John Floyd, NAVSUP FLC Pearl Harbor
Mr. Ralph Wells, DLA Energy Pacific

CONFIRMED RELEASE NOTIFICATION FORM

STATE USE ONLY

Facility ID:	Release ID:	Date Received:
--------------	-------------	----------------

GENERAL INFORMATION AND INSTRUCTIONS

This form should be completed immediately and only after reporting a confirmed release by telephone within 24-hours to the Hawai'i DOH UST Section. Completion of this notice will serve to fulfill part of the notification requirements of HAR 11- 280.1-61. Please type or print in ink all items except "Signature" in Section III. This form must be completed for **each UST release occurrence**. Completed form must be mailed to: Department of Health, Solid and Hazardous Branch, 2827 Waimano Home Road #100, Pearl City, Hawaii 96782

I. REPORTING PARTY AND FACILITY INFORMATION

24-Hour Reporting Party Name, Title, Affiliation: _____ Phone Number: _____

Raelynn Kishaba, Environmental Engineer, Commander, Navy Region Hawaii (808)471-4848

Facility Name & Address:

Red Hill Bulk Fuel Storage Facility, Aiea, HI 96701

Facility Contact Person, Affiliation, & Address:

Sherri Eng, Commander, Navy Region Hawaii, 850 Ticonderoga Street, Suite 110, JBPHH, HI 96860-5101

Landowner Name, Affiliation & Address: Commander, Navy Region Hawaii 850 Ticonderoga Street, Suite 110 JBPHH, HI 96860-5101 E-mail address: james.g.meyer@navy.mil Phone Number (808) 471-3926	Lessor Name, Affiliation & Address: E-mail address: Phone Number ()	Lessee Name, Affiliation & Address: E-mail address: Phone Number ()
---	--	--

II. RELEASE INFORMATION (Circle all that apply in Items A-I)

A. Source of the Release: Piping Tank(s) Overfill Problems Dispenser Submersive Turbine Pump Delivery Problems

If "Tank(s)" list tank sizes:

B. Cause of the Release: Spill Overfill Physical / Mechanical Damage Corrosion Installation Problem

Other (Specify): Under Investigation

C. Method of Discovery & Confirmation: Closure Monthly Release Detection Tightness Test Site Check

Other (Specify): Identified immediately by watch-stander

D. Estimated Quantity of Substance Released: <1,000 Gallons Unknown

E. Type of Substance Released: Unleaded Gas Leaded Gas Diesel Used or Waste Oil Hazardous Substance

Other (Specify): JP-5 Jet Fuel

F. Immediate Hazards: Explosion Fire Vapor Exposure Recoverable Free Product Drinking Water Threat

Other (Specify):

G. Release Impact: Surface Water Ground Water Soil Air
 *Soil vapor monitoring vaults compromised during wash-down .

H. Migration Pathways: None Utility Conduits Subsurface Drains Sewer Lines Unknown

Other (Specify): *Soil vapor monitoring vaults compromised during wash-down .

I. Actions Taken: Evacuated Nearby Area Removed UST Contents Recovered Free Product Excavated Soils Ground Water Recovery

Other (Specify): Secured source, ventilated area, wash-down tunnels, and transferred recovered product from sump to waste tank


III. UST OWNER OR OPERATOR CERTIFICATION (Read and sign after completing all sections to the extent possible)

I certify under penalty of law that I have examined and am familiar with the information submitted in this notice, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, I believe that the submitted information is true and accurate.

Name, Title, & Company:

Sherri R Eng, Director, Regional Environmental Department
 Commander, Navy Region Hawaii

Signature: _____ Date: _____



21 Jun 2021